

May 11, 2023

Posted via Ariba (2 pages) + 1 attachment

**ADDENDUM NO. 2
REQUEST FOR TENDERS NO. DOC3950532421**

EXTENDED CLOSING DATE: May 31, 2023 12:00 NOON (Local Toronto Time)

**FOR: QUIET ROOM, GIFT SHOP, LOBBY RENOVATIONS AT
LAKESHORE LODGE LONG TERM CARE HOME**

Please refer to the above Request for Tender (RFT) document in your possession and be advised of the following:

I. Revisions

1. Architectural Drawings

- **DELETE** A2.01 Proposed Floor Plan Re-issued for Tender-R01 23-04-18, A7.01 Interior Elevations Re-issued for Tender-R01 23-04-18, and A9.03 Plan Details Re-issued for Tender-R01 23-04-18
- **ADD** A2.01 Proposed Floor Plan Issued for Addendum-002 23-05-11, A7.01 Interior Elevations Issued for Addendum-002 23-05-11, and A9.03 Plan Details Re-issued for Issued for Addendum-002 23-05-11.

Description

Architectural Addendum 2 (*includes but not limited to the following, refer to drawings for details*)

1. Drawing A2.01, A7.01 & A9.03

- Reduce roller shutter width
- Add additional partition wall
- Adjust location of HMD

II. Additional Information

No additional information has been issued as part of this tender.

III. Questions and Answers

Q1. Could you please extend the closing for a week?

A1. Tender has been extended one week to May 31, 2023

Q2. Are we moving pictures frames from walls?

A2. No – picture frames and plaques will be removed and reinstated by Lakeshore Lodge. The contractor shall make allowance to coordinate this work with the home.

Q3. Are you requiring negative air pressure during work?

A3. Yes - negative air pressure as per IPAC procedures is required during any works that may create dust, contractor shall monitor and provide logs to ensure negative air pressure has been maintained.

IV. Attachments

- File name: *Architectural Addendum 2_230511.pdf* – Three (3*) pages total – 11” x 17”.

Should you have any questions regarding this addendum please contact:

Alexandra.Mutinelli-Djukic@toronto.ca

Please attach this addendum to your RFT document and be governed accordingly. Bidders must acknowledge receipt of all addenda in the space provided in Part 4-Submission Items, as per Section 1.7, Addenda in Part 1-RFT Process. All other aspects of the RFT remain the same.

Thank you,

Reena Chadha
Supervisor, CSS, CMO, CSO & CCO
Purchasing & Materials Management Division