



Addendum No:	4
Date Issued	May 30, 2023
Project Title and Number	RFP ID#2735479312 - Oak Valley General Contractor to Fit-out Uxbridge Foundation Office
Closing Time	May 31, 2023, 2:00 PM (EST)
Number of Pages in Addendum	1
Number Attachments	0

By way of this Addendum, the following changes, revisions, additions, deletions and clarification form an integral part of the bid documents. Proponents are to read the Addendum in its entirety.

Section A – Clarifications/Updates

- **Addendum 2 - May 23 and Addendum 2 - May 24 were mistakenly numbered the same although they are two different addendums. I will leave as is, not to confuse the matter anymore. This new addendum will be Addendum 4.**
- **There will be no changes to the BAS scope at this time, please price based on the documents provided.**

Section B – Questions/Answers

Q1: Please confirm the model of the water chiller and inline filter?

A1: There is no chiller on this project. Hot water dispenser with faucet is specified. specification for the dispenser is on drawing M0.1. Filter to be 10 Stage Plus inline filter by Absolute Aqua or New Wave Enviro or equal.

Q2: Do we need to price out the data/communication wiring Rough in only, or finishing as well.

A2: Contractor / bidder needs to price data / communication scope as described on drawing E0.1 “Notes Re Voice / Data System” and as shown on the floor plans.

Sincerely,
Bid Administrator

End of Addendum