



Project No. & Name:	1100110- 273857- Remediate Lead Paint in Mech Rooms	Addendum No.: 01
		No. of Pages:01
		Date: November 20, 2023
		Doc. No.: P2704-1346537626-51(1.0)

The following change(s) in the Tender Documents are effective immediately.  
This Addendum forms part of the Contract Documents.

ITEM	DESCRIPTION	ACTION
1.1	Would the GC be expected to paint over the conduits? <a href="#">Answer: Yes, GC is expected to paint over the conduits.</a>	
1.2	Is the GC required to do paint touch-ups where the areas are spot flaking or are they required to paint the entire wall? <a href="#">Answer: In places, where the paint is spot flaking, touch-ups are sufficient. In case the area cannot be covered with touch-ups, the entire wall has to be painted.</a>	
1.3	Will there be any cash allowance for unforeseen conditions? <a href="#">Answer: No cash allowance for unforeseen conditions.</a>	

Colliers Project Leaders Inc.

Date: November 20, 2023

Distribution:

All Bidders

File: P2704-1346537626-51(1.0)