

2023-T-117 - City of Niagara Falls GO/VIA Station – Interior Alterations and Upgrades

Date Issued: Tuesday, April 9th, 2024

Addendum No. 9

No. of Addenda pages: 1

Attachments: Not applicable.

Questions and Answers

Question 1:

Is the exterior glazing to be 1 inch overall - 6mm tempered with lowe / 1/2 inch air space / 6mm laminated?

Answer 1:

The makeup of the Insulated glazing Units is as follows: Double pane, 2X6mm +interpane space, total thickness of 25mm.

Inner pane : 6mm impact rated tempered safety glass,

Outer pane : 6 mm impact rated safety glass, Low "E" coating on surface 2.

Refer to Appendix E - NF Station Tender Specifications, section 08 80 00 2.2 & 2.3.

Question 2:

Is the interior glazing to be - 6mm tempered OR 6mm laminated Or 3mm tempered/.30 interlayer / 3mm tempered (laminated)?

Answer 2:

Refer to Answer 1.

End of Addenda