



Smith + Andersen

1100 – 100 Sheppard Ave. East, Toronto ON, M2N 6N5

416 487 8151 f 416 487 9104 smithandandersen.com

ADDENDUM

PROJECT NAME: Seneca College – K3170

COMPANY: Seneca Polytechnic

ATTENTION: Tina Preston

PROJECT NO.: 01105.034.AV.001

DATE: 2024-04-30

ADDENDUM NO.: ADD-02

ISSUED BY: Nelson Liao

The following amendments are hereby made as part of the Contract Documents. The following revisions and/or additions shall be made to contract documents and the cost shall be included in the Tender Price.

1.0 CLARIFICATION

1.1 Question: Capstone room – what are the requirements of 48” display? Can AV spec’ing 49” commercial display instead?

1.1.1 Response: Refer to Note N-2 on drawing AV103A and Specification section 27 41 00.00 subsection 1.3.5.

1.2 Question: Drawing AV 301 - Detail 1 - Shows a finished ceiling with conduit terminating above. Is this correct?

1.2.1 Response: Ceiling type shall be open ceiling. AV drawing and specifications to be revised.

2.0 SPECIFICATION

2.1 Refer to Specification Section 27 41 00.00

2.1.1 Revised section 2.2 - SURFACE-MOUNT PROJECTION SCREEN 133” 16:9

- .1 Projector Screen shall have an image area diagonal of 133” at 16:9 aspect ratio.
- .2 Projector Screen shall be a motorized wall-mounted, tab-tensioned front projection screen.
- .3 Projection screen shall be black-backed.
- .4 Allow for an additional 24” of black-drop during pricing and confirm required black drop during shop drawing reviews prior to ordering product.
- .5 Projection screen surface shall have a minimum gain of 1.1 and half angle of 85-degrees with ambient light rejection features.
- .6 Provide low voltage switch. Install switch in equipment rack for backup operation.

- .7 Typical device shall be Da-lite Advantage Contour Tensioned series or approved equivalent.

3.0 DRAWINGS

3.1 Refer to Drawing AV301 - AV RISER DIAGRAMS (included herein)

- 3.1.1 Revised AV riser diagram Detail 1.

END OF AUDIO VISUAL ADDENDUM

01105.034.AV.001.add02 - Seneca Polytechnic K3170.docx



SCALE	PROJECT NUMBER
DATE 4/30/2024	
DRAWN BY NL	DRAWING AV301
CHECKED BY PG	