

## Addendum #3

Issued May 1, 2024

The following information changes the RFT documents issued on April 17, 2024.

### GENERAL INFORMATION

Item 1: See 'Addendum #03' dated May 1, 2024 issued by the Consultant (1 page)

---

**End of Addendum #3**



## ADDENDUM #03

RE: REQUEST FOR TENDER #2024-137-P01947  
Hess Street Elementary School – Renovation Project

---

May 01, 2024

Please review the following addendum. This document shall be considered a component of TENDER #2024-137-P01947. All other terms and conditions remain the same.

### Clarification/Change:

- 1) **Question:** Can we get confirmation on who will be supplying the motors for the basketball nets, electrical contractor or the equipment supplier?

**Answer:** Equipment supplier.

- 2) **Question:** Can we get the manufactures name and model number for the existing fire alarm system control panel?

**Answer:** Simplex 4100 ES.

- 3) **Question:** Who is responsible for removing and reinstalling the air handling sensor and the automatic flush sensor in the gym?

**Answer:** Electrical Contractor – refer to DWG E1.00.

- 4) **Question:** Who is responsible for removing and reinstalling the scoreboards, school bell and wireless access points in the gym?

**Answer:** Electrical Contractor – refer to DWG E1.00.

--END--