



# Addendum #2

**Issued May 3, 2024** 

The following information changes the RFT documents issued on April 17, 2024.

#### **GENERAL INFORMATION**

Item 1: See 'Addendum No. 1' dated May 2, 2024 issued by the Consultant (1 page)

## **QUESTIONS AND RESPONSES**

- Q1 Regarding the window shades in room 128 and 129, please confirm the height of the shades, is it the full height of vision window or as noted on the Curtain Wall Elevation C129 it kind of looks like it might be where the doted lines are for the width and height.
- R1 Refer to General Information, Item 1.

End of Addendum #2

**BE YOU. BE EXCELLENT.** 



# Addendum No. 1

JASON FUNG ARCHITECT INC. 675 King St W Unit 211 Toronto ON, M5V 1M9 www.jasonfung.ca 647 948 9176

Project: 2024-159-P01929 - Westview Elementary School Window Replacement

Owner: Hamilton Wentworth District School Board

JFA Project Number: 2333

Date: May 2, 2024

The following information supplements and/or supersedes the bid documents issued on February 3, 2022

This Addendum forms part of the contract documents and is to be read, interpreted, and coordinated with all other parts. The cost of all contained herein is to be included in the contract sum. The following revisions supersede the information contained in the original drawings and specifications issued for the above-named project to the extent referenced and shall become part thereof. Acknowledge receipt of this Addendum by inserting its number and date on the Tender Form. Failure to do so may subject the bidder to disqualification.

### **Questions and Answers:**

1.1 Question: Regarding the window shades in room 128 and 129, please confirm the h

eight of the shades, is it the full height of vision window or as noted on the Curtain Wall Elevation C129 it kind of looks like it might be where

the doted lines are for the width and height.

Answer: The Intention is for the roller shades in rooms 128 and 129 to be mounted on

the mullion above the vision glass as per detail 7-A7.00 and have enough shade length to completely cover the vision glass in those rooms. Disregard

hidden lines showing shades in detail 3-A8.03.

End of Addendum No. 1

Jason Fung, OAA, MArch, MRAIC