

Addendum 5

Request for Quotation

MA24- 5035 Interior Door Replacement at Homelands Senior Public School

TO: ALL POTENTIAL BIDDERS

This Addendum 5 has been issued for the above mentioned RFQ for the following:

- Please note that the closing date has been extended to May 13, 2024, at 3 p.m. local time.
- Please see attached Addendum No. 5 from Consultant with further clarifications regarding questions from bidders.

All other terms and conditions shall remain the same.

Regards,
John Marinescu, Commodity Specialist
Peel District School Board
Tel. (905) 890.1010 x 2123
Fax. (905) 890-0660
E-mail: john.marinescu@peelsb.com



**ADDENDUM No. 5
To BID DOCUMENTS FOR
HOMELANDS SENIOR PUBLIC SCHOOL
2420 HOMELANDS DRIVE, MISSISSAUGA, ON
INTERIOR DOOR REPLACEMENT
OHE PROJECT No. 28769
MAY 6, 2024**

This Addendum consists of one (1) page only. This Addendum is to make the following clarification and changes to the Bid Documents:

Respondents shall acknowledge receipt of the Addendum by signing below and including the signed copy in the bid submission.

1.1 CLARIFICATIONS

Please note the following clarifications/modifications/additions below to replace the existing bid documents specifications Section 01 00 00 Subsection 2.5.2.1 for Interior Doors:

“Supply and install new hollow metal doors and frames as indicated on Drawings, Door Schedule, and as per Section 08 11 00- Hollow Metal Doors and Frames of the Specification. The installation is to include all hardware and thresholds at all doors. Door and side-lites to be single glazed glass. Frame location and frame depth to match existing frames unless indicated otherwise, with proportions to be as outlined in the drawings. Install additional structural reinforcing components above the ceiling to support new two interior door frames at the hallway. See interior door schedule for doors requiring ceiling reinforcement. Provide shop drawings for the structural reinforcing components, stamped by a professional engineer licensed to practice in the province of Ontario for review.”

To be replace with the below specifications:

“Supply and install new hollow metal doors and frames as indicated on Drawings, Door Schedule, and as per Section 08 11 00- Hollow Metal Doors and Frames of the Specification. The installation is to include all hardware and thresholds at all doors. Door and side-lites to be single glazed glass. Frame location and frame depth to match existing frames unless indicated otherwise, with proportions to be as outlined in the drawings.”

END OF ADDENDUM NO.5