



**Addendum # 3**  
**Bid Opportunity: T-24-28 - ST PETER'S C.S.S**  
**ACCESSIBILITY UPGRADES & ROOFTOP AIR**  
**HANDLING UNIT REPLACEMENT (P00692)**  
**NEW Closing Date: Thursday, May 16, 2024 2:00**  
**PM**

---

This Addendum shall take precedence over all requirements of the previously issued specifications and plans in the Call for Bid document(s) with which it may prove to be at variance with, unless otherwise clarified by the Board.

The following document(s) and verbiage shall form part and parcel of the Call for Bid document(s):

**Question 1:**

Demo Note No.7 on Drawing A102, please clarify if you require surface installed tactile indicators or new cast-in-place concrete with tactile indicators. The areas set to receive a new concrete sidewalk are assumed to be cast-in-place tactile.

**Answer 1:**

All tactile indicators are to be cast-in-place in the sidewalks, in new concrete.

**End of document.**