

Questions and Responses		
Question #	Question	Response
57	I can seem to find the overhead door size on the door schedule for level 3 ambulance bay location. I see the door width of 3355mm but cannot find the door height, even through the section drawing it shows nothing. Can you get me the opening size w x h???	Garage door opening size is 3550wx3600h mm
58	1.In the spec Section 27 10 00 Page 7, Racking states to have RFMote but then proceeds to state using Middle Atlantic or APC please clarify 2.On Drawing E603 in the Structured Cabling Riser diagram, Note 7 refers to providing a crossconnect from punch down to voice panel, but doesn't indicate it in the diagram. Please clarify. 3.Also On drawing E603 Note 9 states to provide a 12 strand CAT5E can we clarify that they mean a 25- Pair CAT5E and if so CMP or CMR?	1- APC, RF MOTE or Middle Atlantic are all acceptable 2- WE don't show that much detail on these schematics – they would become illegible. Provide the cross connects. 3- This can be 12 pair or 25 if necessary Cat 5E. CMP or CMR is fine – this is not a return air plenum