

Question #	Question	Response
60	<p>With regards to roofing installation item 2.3.1.1 page 6, section 075216 indicated torched membrane is not permitted however didn't mentioned any other application for membrane.</p> <p>Wondering whether we can use torch application only at seams and laps for base and cap sheet membrane to make the system watertight and loose laid all other components inclusive of tapered insulation below, filter fabric, insulation, drainage board above and hold in place with stone ballas ?</p>	Torching is not allowed
61	<p>In addendum # 4 reference is made to the inclusion of CAD7 in our tender submission. Please note that this document became obsolete in 2020. Please clarify what you need.</p>	CAD 7 is referenced as a guide for calculation only
62	<p>Regarding signage on this project – there is a specification section and documents for “Wayfinder Signage.” Please clarify what signage is included in the cash allowance of \$ 5,000 for “Small Signage.”</p>	<p>Cash allowance is for, small sign ex.sign for nusre call in the washroom. Signs locations and size to be coordinated with GGH</p>
63	<p>The geotechnical report does not appear to make any reference to rock which has to be removed, but there is a specification Section 31 23 17 Rock Removal. Please provide a cash allowance for what we must include in our tender price for rock removal</p>	<p>The contractor will be responsible for meeting the requirements, and accommodating the existing conditions, stipulated in the tender information provided, including the geotechnical report. The material must be reviewed holistically. An approach in a specification does not correspond to an obligation to execute an unidentified scope of work.</p>
64	<p>please confirm,</p> <p>1- Both CP1 and CP2 are the same tile shape, and size. Only difference is colour and texture</p> <p>2- CP1 should be all 1 colour and 1 texture. Please have a look at the attached (page2) and let me know what texture you are thinking of. If you are also able to select a colour that would be helpful.</p> <p>3- CP2 to be single fire Glaze - Glossy Red colour. No texture.</p>	<p>1- Yes, CP1 and CP2 same size and shape</p> <p>2- Yes, the base of design is KeraTwin neutral-grey 2 H (6252)</p> <p>3- Yes, the base of design is KeraTwin contrasting red H (192)</p>