

TRANSMITTAL

BENNETT DESIGN ASSOCAITED INC.



Attention: **AMANDA HUGESSEN**

Transmittal # **#1**

Project : **6925 CENTURY AVE**
MISSISSAUGA

Date: **5/Jun/24**
Project # **SP0004334**

Subject: **Fire Protection Drawing & Hydraulic Calculations requiring review & acceptance**

Qty.	Drawing #	Fire Protection Drawing Title	Date	Revision #1		
1	SP-1	Site Plan, Details, Ex. Riser Diagram Unit 502 - sprinkler system layout	5/Jun/24	#1	PDF	<input checked="" type="checkbox"/>

Qty.	Calc. #	Hydraulic Calculation Description	Date	Revision #1		
1	#1	DA #1 SP-1 Unit 502	5/Jun/24	#1	PDF	<input checked="" type="checkbox"/>

Regards,

Akash Sheth
Project Coordinator
ONYX Sprinkler Installation
Phone: 647 334 2643
asheth@onyx-sprinkler.com

SCOPE OF WORK:
 MODIFY EXISTING SPRINKLER SYSTEM @ UNIT 502 - 6925 CENTURY AVENUE, IN MISSISSAUGA, ONTARIO, BASED ON NEW TENANT LAYOUT SPRINKLER SYSTEM TO MEET NFPA 13 (2013ED), CBC 2012.

SPRINKLER SYSTEM DESIGN CRITERIA:
 NFPA 13 2013 EDITION,
 ONTARIO BUILDING CODE 2012 (AS AMENDED),
 LIGHT HAZARD (GROUP I) 0.10 USGPM OVER 900 SQ. FT. (ACTUAL 948 SQ. FT.) (DESIGN AREA REDUCED BY 40% BASED ON NFPA 13 (2013): 11.2.3.2.3.1, AND 10'-0" CEILINGS) PLUS 100 USGPM HOSE ALLOWANCE.

GENERAL NOTES:
 1) ALL PIPE LOCATIONS ARE TO BE FIELD MEASURED PRIOR TO FABRICATION.
 2) PIPE LENGTHS ARE SHOWN CENTRE TO CENTRE.
 3) REUSE EXISTING BRANCH LINES WHERE POSSIBLE - TAKE BACK EXISTING ARM OVERS WHERE NEW PIPE IS REQUIRED.
 4) NEW 1" PIPING TO BE SCH. 40 BLACK STEEL PIPE WITH THREADED ENDS AND CAST IRON SCREWED FITTINGS.
 5) NEW PIPING 1 1/2" AND LARGER TO BE SCH. 10 BLACK STEEL PIPE WITH GROOVED ENDS AND GROOVED FITTINGS.
 6) SCHEDULE 7 PIPE NOT PERMITTED.
 7) ALL 1" ARM OVERS EXCEEDING 2'-0" IN LENGTH REQUIRE HANGERS WITH UNSUPPORTED PIPE LENGTHS BETWEEN HANGER AND END HEAD NOT TO EXCEED 3'-0" HORIZONTALLY.
 8) PROVIDE INTERMEDIATE AND HIGH TEMPERATURE SPRINKLERS WHERE REQUIRED BY CODE.
 9) AS PER NFPA 13 (2013) 25.2.1.5 WHERE ADDITION OR MODIFICATION IS MADE TO AN EXISTING SYSTEM AFFECTING MORE THAN 20 SPRINKLERS, THE NEW PORTION SHALL BE ISOLATED AND TESTED AT NOT LESS THAN 200 PSI (13.8 BAR) FOR 2 HOURS.
 10) AS PER NFPA 13 (2013) 25.2.1.6 MODIFICATIONS THAT CANNOT BE ISOLATED, SUCH AS RELOCATED DROPS, SHALL NOT REQUIRE TESTING IN EXCESS OF SYSTEM WORKING PRESSURE.
 11) HATCHED AREA NOT IN CONTRACT.

WATER FLOW TEST INFORMATION:
 THE WATER SUPPLY INFORMATION USED TO PERFORM THE HYDRAULIC CALCULATIONS IS BASED ON THE WATER FLOW TEST PERFORMED BY THE EXISTING FIRE PUMP TEST REPORT.

FIRE PUMP DATA:
 60 PSI @ 600.5 GPM







TABLE B.6.1.1 POSITIONING OF SPRINKLERS TO AVOID OBSTRUCTIONS TO DISCHARGE (STANDARD SPRINKLERS) (UNLESS OTHERWISE SPECIFIED, REFER TO SECTION 910)	MAXIMUM ALLOWABLE CLEARANCE FROM SPRINKLER TO OBSTRUCTION (IN) (SI)
LESS THAN 18"	0
18" TO LESS THAN 24"	2
24" TO LESS THAN 30"	4
30" TO LESS THAN 36"	6
36" TO LESS THAN 42"	8
42" TO LESS THAN 48"	10
48" TO LESS THAN 54"	12
54" TO LESS THAN 60"	14
60" TO LESS THAN 66"	16
66" TO LESS THAN 72"	18
72" TO LESS THAN 78"	20
78" TO LESS THAN 84"	22
84" TO LESS THAN 90"	24
90" TO LESS THAN 96"	26
96" TO LESS THAN 102"	28
102" TO LESS THAN 108"	30

FIGURE B.6.1.2 (a) POSITIONING OF STANDARD PENDENT OR UPRIGHT SPRINKLERS TO AVOID OBSTRUCTION TO DISCHARGE (IN) (SI)



SITE PLAN
 SCALE: N.T.S.

REVISIONS		
1.0	ISSUED FOR PERMIT	05/09/2024

IMPORTANT		
OWNERS MUST MAINTAIN SUFFICIENT HEAT (HEATING DEVICES) THROUGHOUT THE WINTER HEREIN "HOT" SYSTEM AND INSTALLED TO PREVENT FREEZING OF WATER UNLESS AN ANTI-FREEZE OR A "HOT" SYSTEM IS PROVIDED.		
1-10	INDICATE THE GRAVIMETER ELEVATION IN FT. FROM THE 2.0' OF THE PIPE	INDICATE THE GRAVIMETER POINT
1-11	INDICATE THE GRAVIMETER ELEVATION IN FT. FROM THE 2.0' OF THE PIPE	INDICATE THE GRAVIMETER POINT
1-12	INDICATE THE GRAVIMETER ELEVATION IN FT. FROM THE 2.0' OF THE PIPE	INDICATE THE GRAVIMETER POINT


DRAWING LEGEND			
SPRINKLER OCCUPANCY	SIZE	TYPE	MARK
NEW OR SC SEMI-RECESSED PENDENT	1 1/2"	DRIP	DRIP
NEW OR SC SEMI-RECESSED PENDENT	1 1/2"	DRIP	DRIP
EXISTING SPRINKLER TO REMAIN	1 1/2"	DRIP	DRIP
EXISTING SPRINKLER TO REMAIN	1 1/2"	DRIP	DRIP
EXISTING SPRINKLER TO REMAIN	1 1/2"	DRIP	DRIP
EXISTING SPRINKLER TO REMAIN	1 1/2"	DRIP	DRIP
EXISTING SPRINKLER TO REMAIN	1 1/2"	DRIP	DRIP
EXISTING SPRINKLER TO REMAIN	1 1/2"	DRIP	DRIP

APPLICABLE CODES & STANDARDS	
NFPA 13	NFPA 30
NFPA 14	IBC

TYPE OF SYSTEM	
WT	HEATER
SW	DRIP WATER
DRIP WATER-FLOW	DRIP WATER
DRIP WATER	DRIP WATER

LEGEND:

- SIZE UP OR DOWN
- DOWN OR DOWN
- CAPPED PIPE
- NEW PIPING
- EXISTING PIPING




HYDRAULIC CALCULATION DATA

DESIGN AREA NUMBER:	1
DESIGN AREA LOCATION:	UNIT 502
HAZARD OCCUPANCY:	LIGHT HAZARD
DESIGN DENSITY:	0.1
COVERAGE PER HEAD:	225 SQ. FT.
NUMBER OF SPRINKLERS IN DESIGN AREA:	8
SYSTEM FLOW:	292.1 USGPM
SYSTEM PRESSURE:	36.9 PSI
HOSE ALLOWANCE (INCLUDED):	100
SAFETY MARGIN:	29.1 PSI

*LIGHT HAZARD 0.10 USGPM OVER 948 SQ. FT. (DESIGN AREA REDUCED BY 40% BASED ON NFPA 13 (2013): 11.2.3.2.3.1, AND 10'-0" CEILINGS). PLUS 100 USGPM HOSE ALLOWANCE.

UNIT 502 - NEW SPRINKLER SYSTEM LAYOUT
 SCALE: 1/8"=1'-0"



EXISTING RISER DIAGRAM
 SCALE: N.T.S.

NORTH

ONYX-FIRE
 PROTECTION SERVICES INC.

Address: 400 McPherson Blvd West, MISSISSAUGA, ON, L5R 0H1
 Phone: 416-674-9633
 Fax: 416-674-9623
 Email: info@onyx-fire.com

STAMP

M.M. BASSLEY
 PROFESSIONAL ENGINEER
 CIVIL ENGINEERING
 ONTARIO

PROJECT: **6925 CENTURY AVE**

UNIT 502 - 6925 CENTURY AVE, MISSISSAUGA, ON
 DWG TITLE: **SPRINKLER SYSTEM LAYOUT**

DATE	PROJECT NO.
2024 JUNE	SP0004334

SCALE	CHC BY:	R.R.
AS SHOWN		

DWN BY	DWG. NO.	C.B.
	SP 1	

ISSUED FOR REVISION NO.	1.0	of
		1

ONYX-FIRE

PROTECTION SERVICES INC.

Onyx-Fire Protection Services
400 Matheson Blvd. West
Mississauga, ON
L5R 0H1
416-674-5633



Job Name : SP0004334 - UNIT 502, 6925 CENTURY AVE - CALC #1
Drawing : UNIT 502
Location : UNIT 502 - 6925 CNETURY AVE, MISSISSAUGA, ON
Remote Area : D.A. #1
Contract : SP0004334
Data File : SP0004334 - 6925 CENTURY AVE - UNIT 502 - CALC #1.WXF

Hydraulic Design Information Sheet

Name - Remote Area #1 Date - 2024 JUNE
 Location - UNIT 502 - 6925 CNETURY AVE, MISSISSAUGA, ON
 Building - UNIT 502 System No. - D.A. #1
 Contractor - Onyx-Sprinkler Insatllation Inc. Contract No. - SP0004334
 Calculated By - JC Drawing No. - SP-1
 Construction: () Combustible (X) Non-Combustible Ceiling Height - 92.68 Ft
 Occupancy - LIGHT HAZARD

S (X) NFPA 13 (X) Lt. Haz. Ord.Haz.Gp. () 1 () 2 () 3 () Ex.Haz.
 Y () NFPA 231 () NFPA 231C () Figure Curve
 S Other
 T Specific Ruling NFPA13-13,11.2.3.2.3.1 Made By Date

M	Area of Sprinkler Operation	- 995 SQ.FT	System Type	Sprinkler/Nozzle
	Density	- 0.1	(X) Wet	Make
D	Area Per Sprinkler	- 225 SQ.FT	() Dry	Model
E	Elevation at Highest Outlet	- 78'7"	() Deluge	Size 1/2"
S	Hose Allowance - Inside	- 50	() Preaction	K-Factor 5.6
I	Rack Sprinkler Allowance	-	() Other	Temp.Rat.155°F
G	Hose Allowance - Outside	- 50		

N Note

Calculation Flow Required - 292.1 Press Required - 36.9 S.F= 29.1
 Summary C-Factor Used: 120 Overhead 140 Underground

W	Water Flow Test:	Pump Data:	Tank or Reservoir:
A	Date of Test -		Cap. -
T	Time of Test -	Rated Cap.- 600.5 Gpm	Elev.- 0
E	Static Press -	@ Press - 60 Psi	
R	Residual Press -	Elev. - 0	Well
S	Flow -		Proof Flow
U	Elevation -		

P Location - EXISTING FIRE PUMP

L Source of Information - Onyx-Sprinkler Installation Inc.

C	Commodity	Class	Location
O	Storage Ht.	Area	Aisle W.
M	Storage Method:	%	Palletized % Rack
	() Single Row	() Conven. Pallet	() Auto. Storage () Encap.
S	() Double Row	() Slave Pallet	() Solid Shelf () Non
T	() Mult. Row		() Open Shelf

R K Flue Spacing Clearance:Storage to Ceiling
 A Longitudinal Transverse

E Horizontal Barriers Provided:


Water Supply Curve

Onyx-Fire Protection Services
 SP0004334 - UNIT 502, 6925 CENTURY AVE - CALC #1

Page 2
 Date 2024 JUNE

Pump Data:
 P1 - Pump Churn Pressure : 65.99
 P2 - Pump Rated Pressure : 60
 P2 - Pump Rated Flow : 0
 P3 - Pump Pressure @ Max Flow : 38.999
 P3 - Pump Max Flow : 0

Demand:
 D1 - Elevation : -1.912
 D2 - System Flow : 192.105
 D2 - System Pressure : 36.889
 Hose (Demand) : 100
 D3 - System Demand : 292.105
 Safety Margin : 29.102



Fittings Used Summary

Onyx-Fire Protection Services
 SP0004334 - UNIT 502, 6925 CENTURY AVE - CALC #1

Page 3
 Date 2024 JUNE

Fitting Legend Abbrev. Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
B NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
E NFPA 13 90° Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
S NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65	71	81	91	101	121
T NFPA 13 90° Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121

Units Summary

- Diameter Units Inches
- Length Units Feet
- Flow Units US Gallons per Minute
- Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Flow Summary - NFPA

Onyx-Fire Protection Services
 SP0004334 - UNIT 502, 6925 CENTURY AVE - CALC #1

Page 4
 Date 2024 JUNE

SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
PUMP	See Information on Pump Curve			65.991	292.1	36.889

NODE ANALYSIS

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
S1	78.576	5.6	16.14	22.5	0.1 225
L1	82.99		25.4		
S2	78.576	5.6	16.4	22.68	0.1 225
L2	82.99		25.82		
M201	82.99		27.12		
S3	78.576	5.6	17.09	23.15	0.1 225
L3	82.99		26.94		
S4	78.576	5.6	17.09	23.15	0.1 225
L4	82.99		26.95		
S5	78.576	5.6	16.16	22.51	0.1 225
L5	82.99		25.42		
S6	78.576	5.6	16.47	22.73	0.1 225
L6	82.99		25.94		
M202	82.99		27.25		
S7	78.576	5.6	24.72	27.84	0.1 225
L7	82.99		26.53		
S8	78.576	5.6	24.19	27.54	0.1 225
L8	82.99		25.94		
M203	82.99		28.18		
M204	82.99		28.89		
M205	82.99		29.81		
M206	82.99		30.56		
M207	82.99		31.2		
M208	82.99		31.32		
M209	82.99		31.38		
M210	82.99		31.39		
M101	82.99		31.53		
M102	82.99		31.57		
M103	82.99		31.65		
M104	82.99		31.85		
M105	82.99		32.46		
M106	82.99		33.29		
M110	82.99		33.76		
M109	82.99		33.78		
M108	82.99		33.82		
M107	82.99		33.93		
M1	82.99		35.56		
TOR	-2.0		73.45	100.0	
PUMP	82.99		36.89		

Final Calculations : Hazen-Williams

Onyx-Fire Protection Services
 SP0004334 - UNIT 502, 6925 CENTURY AVE - CALC #1

Page 5
 Date 2024 JUNE

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
*EQUIVALENT K'S												
*LN 1												
S1 to L1	78.576 82.990	5.60	22.50 22.5	1 1.049			62.000 62.000	120 0.1801	16.143 -1.912 11.166			Vel = 8.35
L1 to L2	82.990 82.990		0.0 22.5	1.25 1.442			12.292 12.292	120 0.0343	25.397 0.0 0.422			Vel = 4.42
L2			0.0 22.50						25.819			K Factor = 4.43
S2 to L2	78.576 82.990	5.60	22.68 22.68	1 1.049			62.000 62.000	120 0.1827	16.401 -1.912 11.330			Vel = 8.42
L2 to M201	82.990 82.990		22.50 45.18	1.25 1.442	T	7.432	3.000 7.432 10.432	120 0.1248	25.819 0.0 1.302			Vel = 8.88
M201 to L3	82.990 82.990		-64.41 -19.23	1.25 1.442			7.000 7.000	120 -0.0257	27.121 0.0 -0.180			Vel = 3.78
L3			0.0 -19.23						26.941			K Factor = -3.70
S3 to L3	78.576 82.990	5.60	23.15 23.15	1 1.049			62.000 62.000	120 0.1898	17.086 -1.912 11.767			Vel = 8.59
L3 to L4	82.990 82.99		-19.24 3.91	1.25 1.442			9.917 9.917	120 0.0013	26.941 0.0 0.013			Vel = 0.77
L4			0.0 3.91						26.954			K Factor = 0.75
S4 to L4	78.576 82.99	5.60	23.15 23.15	1 1.049			62.000 62.000	120 0.1899	17.094 -1.912 11.772			Vel = 8.59
L4 to M101	82.99 82.99		3.92 27.07	1.25 1.442	2E T	7.432 7.432	79.750 14.864 94.614	120 0.0484	26.954 0.0 4.576			Vel = 5.32
M101			0.0 27.07						31.530			K Factor = 4.82
*LN 2												
S5 to L5	78.576 82.99	5.60	22.51 22.51	1 1.049			62.000 62.000	120 0.1802	16.159 -1.912 11.175			Vel = 8.36
L5 to L6	82.99 82.990		0.0 22.51	1.25 1.442			15.000 15.000	120 0.0344	25.422 0.0 0.516			Vel = 4.42
L6			0.0 22.51						25.938			K Factor = 4.42
S6 to L6	78.576 82.990	5.60	22.73 22.73	1 1.049			62.000 62.000	120 0.1835	16.474 -1.912 11.376			Vel = 8.44

Final Calculations : Hazen-Williams

Onyx-Fire Protection Services
 SP0004334 - UNIT 502, 6925 CENTURY AVE - CALC #1

Page 6
 Date 2024 JUNE

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
L6 to M202	82.990 82.990		22.51 45.24	1.25 1.442	T	7.432	3.083 7.432 10.515	120 0.1252	25.938 0.0 1.316			Vel = 8.89
M202 to L7	82.990 82.99		-86.25 -41.01	1.25 1.442			6.917 6.917	120 -0.1044	27.254 0.0 -0.722			Vel = 8.06
L7			0.0 -41.01						26.532			K Factor = -7.96
S7 to L7	78.576 82.99	5.60	27.84 27.84	1.25 1.442			62.000 62.000	120 0.0601	24.717 -1.912 3.727			Vel = 5.47
L7 to L8	82.99 82.99		-41.01 -13.17	1 1.049			9.917 9.917	120 -0.0601	26.532 0.0 -0.596			Vel = 4.89
L8			0.0 -13.17						25.936			K Factor = -2.59
S8 to L8	78.576 82.99	5.60	27.54 27.54	1.25 1.442			62.000 62.000	120 0.0589	24.194 -1.912 3.654			Vel = 5.41
L8 to M102	82.99 82.99		-13.17 14.37	1 1.049	T	5.0	74.750 5.000 79.750	120 0.0706	25.936 0.0 5.633			Vel = 5.33
M102			0.0 14.37						31.569			K Factor = 2.56
*TRANSFER LINES												
M203 to M103	82.99 82.99		21.91 21.91	1.25 1.442	2T	14.864	91.460 14.864 106.324	120 0.0327	28.176 0.0 3.478			Vel = 4.30
M103			0.0 21.91						31.654			K Factor = 3.89
M204 to M104	82.99 82.99		20.08 20.08	1.25 1.442	2T	14.864	91.460 14.864 106.324	120 0.0278	28.886 0.0 2.959			Vel = 3.94
M104			0.0 20.08						31.845			K Factor = 3.56
M205 to M105	82.99 82.990		18.92 18.92	1.25 1.442	2T	14.864	91.460 14.864 106.324	120 0.0249	29.812 0.0 2.652			Vel = 3.72
M105			0.0 18.92						32.464			K Factor = 3.32
M206 to M106	82.99 82.990		17.45 17.45	1.25 1.442	4E 2T	14.864	97.550 29.728 127.278	120 0.0215	30.559 0.0 2.733			Vel = 3.43
M106			0.0 17.45						33.292			K Factor = 3.02
M207 to M107	82.99 82.990		19.22 19.22	1.25 1.442	2T	14.864	91.460 14.864 106.324	120 0.0257	31.205 0.0 2.729			Vel = 3.78

Final Calculations : Hazen-Williams

Onyx-Fire Protection Services
 SP0004334 - UNIT 502, 6925 CENTURY AVE - CALC #1

Page 7
 Date 2024 JUNE

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
M107			0.0 19.22						33.934		K Factor = 3.30	
M208 to M108	82.99 82.99		18.36	1.25	2T	14.864	91.460 14.864 106.324	120	31.316 0.0 2.507		Vel = 3.61	
M108			0.0 18.36						33.823		K Factor = 3.16	
M209 to M109	82.99 82.990		16.89	1.25	2E 2T	7.432 14.864	96.668 22.296 118.964	120	31.378 0.0 2.404		Vel = 3.32	
M109			0.0 16.89						33.782		K Factor = 2.91	
M210 to M110	82.990 82.99		17.83	1.25	2T	14.864	91.460 14.864 106.324	120	31.389 0.0 2.375		Vel = 3.50	
M110			0.0 17.83						33.764		K Factor = 3.07	
* MAIN 2												
M201 to M202	82.990 82.990		64.41	2.5			10.417	120	27.121 0.0 0.133		Vel = 3.79	
M202 to M203	82.990 82.99		86.25	2.5			15.000	120	27.254 0.0 0.922		Vel = 8.86	
M203 to M204	82.99 82.99		150.66	2.635			15.000	0.0615	0.922		Vel = 8.86	
M203 to M204	82.99 82.99		-21.91	2.5			15.458	120	28.176 0.0 0.710		Vel = 7.57	
M204 to M205	82.99 82.99		128.75	2.635			15.458	0.0459	0.710		Vel = 7.57	
M204 to M205	82.99 82.99		-20.07	2.5			27.542	120	28.886 0.0 0.926		Vel = 6.39	
M205 to M206	82.99 82.99		108.68	2.635			27.542	0.0336	0.926		Vel = 6.39	
M205 to M206	82.99 82.99		-18.93	2.5			31.668	120	29.812 0.0 0.747		Vel = 5.28	
M206 to M207	82.99 82.99		89.75	2.635			31.668	0.0236	0.747		Vel = 5.28	
M206 to M207	82.99 82.99		-17.45	2.5			40.875	120	30.559 0.0 0.646		Vel = 4.25	
M207 to M208	82.99 82.99		72.3	2.635			40.875	0.0158	0.646		Vel = 4.25	
M207 to M208	82.99 82.99		-19.22	2.5			12.500	120	31.205 0.0 0.111		Vel = 3.12	
M208 to M209	82.99 82.99		53.08	2.635			12.500	0.0089	0.111		Vel = 3.12	
M208 to M209	82.99 82.99		-18.36	2.5			15.042	120	31.316 0.0 0.062		Vel = 2.04	
M209 to M210	82.99 82.990		34.72	2.635			15.042	0.0041	0.062		Vel = 2.04	
M209 to M210	82.99 82.990		-16.89	2.5			9.750	120	31.378 0.0 0.011		Vel = 1.05	
M210			0.0 17.83				9.750	0.0011	0.011		Vel = 1.05	
M210			0.0 17.83						31.389		K Factor = 3.18	

Final Calculations : Hazen-Williams

Onyx-Fire Protection Services
 SP0004334 - UNIT 502, 6925 CENTURY AVE - CALC #1

Page 8
 Date 2024 JUNE

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
*MAIN 1 - L												
M101 to M102	82.99 82.99		27.07 27.07	2.5 2.635			15.417 15.417	120 0.0025	31.530 0.0 0.039			Vel = 1.59
M102 to M103	82.99 82.99		14.37 41.44	2.5 2.635			15.000 15.000	120 0.0057	31.569 0.0 0.085			Vel = 2.44
M103 to M104	82.99 82.99		21.91 63.35	2.5 2.635			15.458 15.458	120 0.0124	31.654 0.0 0.191			Vel = 3.73
M104 to M105	82.99 82.990		20.08 83.43	2.5 2.635			30.042 30.042	120 0.0206	31.845 0.0 0.619			Vel = 4.91
M105 to M106	82.990 82.990		18.92 102.35	2.5 2.635			27.542 27.542	120 0.0301	32.464 0.0 0.828			Vel = 6.02
M106 to M1	82.990 82.990		17.46 119.81	2.5 2.635	T	16.474	39.958 16.474 56.432	120 0.0402	33.292 0.0 2.271			Vel = 7.05
M1			0.0 119.81						35.563			K Factor = 20.09
*MAIN 1 - L												
M110 to M109	82.99 82.990		17.83 17.83	2.5 2.635			15.000 15.000	120 0.0012	33.764 0.0 0.018			Vel = 1.05
M109 to M108	82.990 82.99		16.89 34.72	2.5 2.635			10.000 10.000	120 0.0041	33.782 0.0 0.041			Vel = 2.04
M108 to M107	82.99 82.990		18.36 53.08	2.5 2.635			12.500 12.500	120 0.0089	33.823 0.0 0.111			Vel = 3.12
M107 to M1	82.990 82.990		19.22 72.3	2.5 2.635	B 2T 2E	9.61 32.948 16.474	44.000 59.032 103.032	120 0.0158	33.934 0.0 1.629			Vel = 4.25
M1 to TOR	82.990 -2		119.80 192.1	4 4.26	2E	26.334	90.000 26.334 116.334	120 0.0093	35.563 36.809 1.081			Vel = 4.32
TOR to PUMP	-2 82.990	H100	100.00 292.1	6 6.357	B S E	12.573 40.235 17.603	15.000 70.411 85.411	120 0.0029	73.453 -36.809 0.245			Vel = 2.95
PUMP			0.0 292.10						36.889			K Factor = 48.09