

CITY OF PICKERING
INTERIOR ALTERATIONS TO EXISTING FIRE HALL
553 KINGSTON ROAD, PICKERING, Ontario
“RE-ISSUED FOR TENDER”

Project 17216

DATE June 10, 2024



BARRY BRYAN ASSOCIATES
Architects, Engineers, Project Managers

250 Water Street
Suite 201
Whitby, Ontario
Canada
L1N 0G5

Telephone: 905 666-5252
Toronto: 905 427-4495
Fax: 905 666-5256
Email: bba@bba-archeng.com
Web Site: www.bba-archeng.com

DIVISION 00 PROCUREMENT AND CONTRACTING REQUIREMENTS

00 01 11 Table of Contents 2

DIVISION 01 – GENERAL REQUIREMENTS

01 11 00 Summary of Work 3
01 26 15 Requests for Information 2
01 31 00 Project Management and Coordination 2
01 32 00 Construction Progress Documentation 3
01 33 00 Submittal Procedures 4
01 40 00 Quality Requirements 3
01 41 00 Regulatory Requirements 3
01 51 00 Temporary Utilities 3
01 52 00 Construction Facilities 3
01 56 00 Temporary Barriers and Enclosures 2
01 61 00 Common Product Requirements 4
01 70 03 Safety Requirements 4
01 71 00 Examination and Preparation 3
01 73 00 Execution Requirements 4
01 74 11 Cleaning 2
01 74 19 Construction Waste Management and Disposal 4
01 77 00 Closeout Procedures 2
01 78 00 Closeout Submittals 7

DIVISION 02 – EXISTING CONDITIONS

02 41 19.13 Selective Building Demolition 10

DIVISION 03 – CONCRETE

03 10 00 Concrete Forming and Accessories 5
03 20 00 Concrete Reinforcing 5
03 30 00 Cast-in-Place Concrete 11

DIVISION 04 – MASONRY

04 05 19 Masonry Anchorage and Reinforcing 5
04 22 00 Concrete Unit Masonry 7

DIVISION 06 – WOOD, PLASTICS, AND COMPOSITES

06 10 00 Rough Carpentry 3
06 20 00 Finish Carpentry 6
06 40 00 Architectural Woodwork 6

DIVISION 07 – THERMAL AND MOISTURE PROTECTION

07 21 13 Building Insulation 4
07 27 13 Modified Bituminous Sheet Air Barriers 4
07 51 00 Built-Up Bituminous Roofing 11
07 62 00 Sheet Metal Flashing and Trim 4
07 84 00 Firestopping 6
07 92 00 Joint Sealants 6

DIVISION 08 – OPENINGS

08 11 00 Metal Doors and Frames 6
08 71 10 Door Hardware 6
Finishing Hardware Schedule 6

DIVISION 09 – FINISHES

09 21 16 Gypsum Board 5

09 22 16	Non-Structural Metal Framing	5
09 30 13	Ceramic Tiling	7
09 51 13	Acoustic Panel Ceilings	3
09 53 00	Acoustical Suspension	3
09 65 19	Resilient Tile Flooring	5
09 68 13	Carpet Tile	5
09 91 23	Interior Painting	10

DIVISION 10 – SPECIALTIES

10 21 13	Compartments and Cubicles	5
10 28 10	Toilet and Bath Accessories	4

DIVISION 12 – FURNISHINGS

12 24 13	Roller Shades	5
----------	---------------	---

DIVISION 26 – ELECTRICAL

26 05 00	General Conditions	8
26 05 01	Common Work Results – Electrical	4
26 05 20	Wire and Box Connectors (0-1000V)	1
26 05 21	Wires and Cables	3
26 05 27	Grounding	2
26 05 29	Hangers and Supports for Electrical Systems	2
26 05 31	Splitter, Junction, Pull Boxes and Fittings	2
26 05 32	Outlet Boxes, Conduit Boxes and Fittings	2
26 05 34	Conduits, Conduit Fastenings and Conduit Fittings	3
26 27 26	Wiring Devices	2
26 28 13.01	Fuses – Low Voltage	2
26 28 23	Disconnect Switches – Fused and Non-Fused	1
26 51 00	Interior Lighting	9
26 60 01	Electrical Identification	3
26 60 02	Testing and Commissioning of Electrical Systems	5
	Panel Schedules	2

End of Section

PART 1 GENERAL

1.1 Section Includes

- .1 Work covered by contract documents
- .2 Owner
- .3 Location of the site
- .4 Scheduling requirements
- .5 Site access
- .6 Work sequence
- .7 Contractor use of premises
- .8 Engineer design
- .9 Hazardous material discovery
- .10 Building smoking environment
- .11 Special conditions
- .12 Site security
- .13 "By Others"
- .14 Protection of Drawings

1.2 Work Covered by Contract Documents

- .1 Work of this Contract comprises the construction of the **INTERIOR ALTERATIONS TO EXISTING FIREHALL**, 530 Kingston Road, Pickering, Ontario for the City of Pickering, and as indicated on the drawings and specifications.

1.3 Location of Site

- .1 The Work of this Contract is located at **530 Kingston Road, Pickering, Ontario** .

1.4 Site Access

- .1 Access to the site to be arranged by the Owner.
- .2 Provide and maintain access roads, sidewalk crossings, ramps and construction runways as may be required for access to Work
- .3 Provide secure construction fencing as specified and where indicated.

1.5 Work Sequence

- .1 Construct Work continuously.

1.6 Contractors Use of Premises

- .1 Contractor has unrestricted use of site until Substantial Performance.

1.7 Engineer Design

- .1 Where specifications require work to be designed by an engineer, engage an engineer licensed in the Province of Ontario to design such work. Refer to Section 01 78 00.

1.8 Hazardous Material Discovery

- .1 Refer to Designated Substances Survey of Pickering Fire Station #2 Located at 553 Kingston Road Pickering, Ontario prepared by Chem Solv and dated January 9, 2018 for known hazardous materials and designated substances.
- .2 Should any other material not identified in the above referenced report material and resembling asbestos or other hazardous substances be encountered in course of demolition work, immediately stop work and notify the Consultant. Refer to Section 01 41 00.

1.9 Verification

- .1 All dimensions shall be verified on site, and all necessary modifications and adjustments shall be made as necessary to suit.

1.10 Building Smoking Environment

- .1 Smoking and vaping are prohibited in all workplaces within the Owner's buildings and on the Owner's property.

1.11 Special Conditions

- .1 The following general and special conditions apply:
 - .1 All existing surfaces and finishes are to be repaired wherever damaged during the course of the Work.
 - .2 Wherever existing floor and wall finishes are to be removed, include full removal down to the existing concrete substrate of all tile, base, mortars, grouts, waterproofing membranes and adhesives. Patch and repair existing substrate to the quality required by the new finish material manufacturer for the installation of their products.
 - .3 All openings in existing fire rated assemblies or fire separations which are created by the removal of existing services, plumbing, conduit, ductwork, fittings fixtures or accessories are to be firestopped to maintain the integrity of the existing construction.
 - .4 All exposed interior surfaces except prefinished surfaces shall be painted whether referred to in the specifications and drawings or not.

1.12 Site Security

- .1 Daily Inspection: Provide inspection of the building and site daily while the work is in progress and take whatever measures are necessary to secure the building from theft, vandalism and unauthorized entry.

1.13 "By Others"

- .1 The term "by others" where it is used in the contract documents means that work shown or described in the contract documents and labeled with this designation is not included in the specific sub-trade's scope of work but will be required to be done within the General Contractor's contract.

1.14 Use of Drawings

- .1 Drawings are not to be scaled.
- .2 Copies of architectural and structural "issued for construction" drawings in digital format will be made available for the contractors use under the following conditions.

- .1 Copyright remains with BBA.
- .2 The drawings will only be used for shop drawings for this project and not be put to any other use.
- .3 BBA assumes no liability for errors or omissions in the drawings. The Contractor assumes all risk and expenses associated with the use of drawings in the production of his work.
- .4 References to BBA and other Consultants must be deleted from the title block.
- .5 The Contractor signs a release available from BBA that addresses the above items in more detail.

- .3 Arrangements for use of sub-consultant drawings must be made with the appropriate sub-consultant.

1.15 Protection of Drawings

- .1 Copyright of electronic document belongs to the Consultant. Electronic documents may not be forwarded to others, transmitted, downloaded or reproduced in any format, whether print or electronic, without the express, written permission of the copyright owner.
- .2 Drawings, specifications and other contract related documents which are posted on Contractor controlled websites for access by sub-trades and suppliers, shall be posted only on password protected and secure websites approved by the Consultant to limit access to those with an expressed interest in the Project.
- .3 Provide Consultant and Owner with access to such websites as noted above.

PART 2 PRODUCTS

3.1 Not Used

- .1 Not used

PART 3 EXECUTION

3.2 Not Used

- .1 Not used

End of Section

PART 1 GENERAL

1.1 Section Includes

- .1 Requests for Information
- .2 Submittal procedures
- .3 Screening of RFI's
- .4 Response to RFI's
- .5 Response Timing

1.2 Request for Information (RFI)

- .1 A request for information (RFI) is a formal process used during the Work to obtain an interpretation of the Contract Documents or to obtain additional information.
- .2 An RFI shall not constitute notice of claim for a delay.

1.3 Submittal Procedures

- .1 Make submittals in accordance with Section 01 33 00 – Submittal Procedures.
- .2 Number RFI's consecutively in one sequence in order submitted, in numbering system as established by the Contractor.
- .3 Submit one distinct subject per RFI form. Do not combine unrelated items on one form.
- .4 RFI form:
 - .1 Submit a draft "Request for Information" form to be approved by the Owner and Consultant.
 - .2 Submit RFI's to the Consultant on approved "Request for Information" form. The Consultant shall not respond to an RFI except as submitted on this form.
 - .3 Where RFI form does not have sufficient space to provide complete thereon, attach additional sheets as required.
 - .4 Submit with RFI form all necessary supporting documentation.
- .5 RFI log:
 - .1 Maintain log of RFI's sent to and responses received from the Consultant, complete with corresponding dates.
 - .2 Submit updated log of RFI's at each construction meeting and with each application for payment submission.
- .6 Submit RFI's sufficiently in advance of affected parts of the Work so as not to cause delay in the performance of the Work. Costs resulting from failure to do so will not be paid by the Owner.
- .7 Only the Contractor shall submit RFI's to the Consultant.
- .8 RFI's submitted by Subcontractors or Suppliers directly to the Consultant will not be accepted.

1.4 Screening of RFI's

- .1 Contractor shall satisfy itself that an RFI is warranted by undertaking a thorough review of the Contract Documents to determine that the claim, dispute, or other matters in question relating to the performance of the Work or the Interpretation of the Contract Documents cannot be resolved by direct reference to the Contract Documents. Contractor shall describe in detail this review on

the RFI form as part of the RFI submission. RFI submittals that lack such detailed review description, or where the detail provided is, in the opinion of the Consultant, insufficient, shall not be reviewed by the Consultant and shall be rejected.

1.5 Response to RFI's

- .1 Consultant shall review RFI's from the Contractor submitted in accordance with this section with the following understandings:
 - .1 Consultant's response shall not be considered as a Change Order or Change Directive, nor does it authorize changes in the Contract Price or Contract Time or changes in the Work.
 - .2 Only the Consultant shall respond to RFI's. Responses to RFI's received from entities other than the Consultant shall not be considered.

1.6 Response Timing

- .1 Allow 5 Working Days for review of each RFI by the Consultant.
- .2 Consultant's review of RFI commences on date of receipt of RFI submission by the Consultant from Contractor and extends to date RFI returned by Consultant.
- .3 When the RFI submission is received by Consultant before noon, review period commences that day. When RFI submittal is received by Consultant after noon, review period begins on the next Working Day.
- .4 If, at any time, the Contractor submits a large enough number of RFI's or the Consultant considers the RFI to be of such complexity that the Consultant cannot process these RFI's within 5 Working Days, the Consultant will confer with the Contractor within 3 Working Days of receipt of such RFI's, and the Consultant and the Contractor will jointly prepare an estimate of the time necessary for processing same as well as an order of priority among the RFI's submitted. The Contractor shall accommodate such necessary time at no increase in the Contract Time and at no additional cost to the Owner.

PART 2 PRODUCTS

2.1 Not Used

- .1 Not used

PART 3 EXECUTION

3.1 Not Used

- .1 Not used

End of Section

PART 1 GENERAL

1.1 Section Includes

- .1 Preconstruction Conference
- .2 Project Meetings
- .3 On Site Documents
- .4 Closeout Procedures
- .5 Cost Breakdown

1.2 Preconstruction Conference

- .1 The Consultant will call for and administer Preconstruction Conference at time and place to be announced.
- .2 Contractor, all major Subcontractors, and major suppliers shall attend the Preconstruction Conference.
- .3 Agenda will include, but not be limited to, the following items.
 - .1 Lines of communication and contact information
 - .2 Schedules
 - .3 Personnel and vehicle permit procedures
 - .4 Use of premises
 - .5 Location of any Contractor on-site facilities
 - .6 Security
 - .7 Housekeeping
 - .8 Submittal and RFI procedures
 - .9 Inspection and testing procedures, on-Site and off-Site
 - .10 Control and reference point survey procedures
 - .11 Health and Safety
 - .12 Contractor's Schedule of Values
 - .13 Contractor's Schedule of Submittals
- .4 The Consultant will distribute copies of minutes to attendees. Attendees shall have seven days to submit comments or additions to minutes. Minutes will constitute final documentation of results of Preconstruction Conference.

1.3 Project Meetings

- .1 The Contractor will arrange project meetings and assume responsibility for setting times and recording and distributing minutes.
- .2 Meetings will be held minimum bi-weekly.

1.4 On-Site Documents

- .1 Maintain at job site, one copy each of the following:
 - .1 Contract drawings.
 - .2 Specifications.
 - .3 Addenda.
 - .4 Reviewed shop drawings.
 - .5 Requests for Information (RFI's)
 - .6 Change orders.
 - .7 Other modifications to Contract.

- .8 Field test reports.
- .9 Copy of approved Work schedule.
- .10 Manufacturers' installation and application instructions.
- .11 Health and Safety Plan and Other Safety Related Documents.
- .12 Other documents as specified.

1.5 Cost Breakdown

- .1 Submit a detailed cost breakdown to Consultant at least ten working days prior to the submission of the first progress claim. After approval by Consultant the cost breakdown will be used as basis for progress payment.

PART 2 PRODUCTS

2.1 Not Used

- .1 Not used

PART 3 EXECUTION

3.1 Not Used

- .1 Not used

End of Section

PART 1 GENERAL

1.1 Section Includes

- .1 Submittals
- .2 Schedules
- .3 Format
- .4 Submission
- .5 Critical Path Scheduling
- .6 Submittals Schedule

1.2 Submittals

- .1 Make submittals in accordance with Section 01 33 00 – Submittal Procedures.

1.3 Schedules Required

- .1 Submit schedules as follows:
 - .1 Construction Progress Schedule.
 - .2 Submittal Schedule for Shop Drawings and Product Data.
 - .3 Submittal Schedule for Samples.
 - .4 Product Delivery Schedule.
 - .5 Cash Allowance Schedule for purchasing Products.
 - .6 Shutdown or closure activity.

1.4 Format

- .1 Prepare schedule in form of a horizontal bar chart using Microsoft Project 2016 or later.
- .2 Provide a separate bar for each major item of work, trade or operation.
- .3 Split horizontally for projected and actual performance.
- .4 Provide horizontal time scale identifying first work day of each week.
- .5 Format for listings: chronological order of start of each item of work.
- .6 Identification of listings: By Systems description.

1.5 Submission

- .1 Submit initial format of schedules within 10 working days after award of Contract.
- .2 Submit schedules in electronic format, by email as PDF files.
- .3 Consultant will review schedule and return review copy within 10 days after receipt.
- .4 Resubmit finalized schedule within 7 days after return of review copy.
- .5 During progress of Work revise and resubmit schedule as directed by Consultant.
- .6 Submit revised progress schedule with each application for payment.

- .7 Distribute copies of revised schedule to:
 - .1 Job site office.
 - .2 Subcontractors.
 - .3 Other concerned parties.
 - .4 Instruct recipients to report to Contractor within 10 days, any problems anticipated by timetable shown in schedule.
- .8 Table current and up to date schedule at each regular site meeting.

1.6 Critical Path Scheduling

- .1 Include complete sequence of construction activities.
- .2 Schedules shall represent a practical plan to complete the work within the Contract period, and shall convey the plan to execute the work. Schedules as developed shall show the sequence and interdependencies of activities required for complete performance of the work.
- .3 The submittal of schedules shall be understood to be the Contractor's representation that the schedule meets the requirements of the Contract Documents and that the work will be executed in the sequence and duration indicated in the schedule.
- .4 Failure to include any element of work required for performance of the Contract or failure to properly sequence the work shall not excuse the Contractor from completing all work within the Contract Time.
- .5 All schedules shall be developed utilizing industry standard 'best practices' including, but not limited to:
 - .1 No open-ended activities.
 - .2 No use of constraints other than those defined in the Contract Documents without the prior approval of the Consultant.
 - .3 No negative leads or lags.
 - .4 No excessive leads or lags without prior justification and approval from the Consultant.
 - .5 For individual schedule construction activities, do not exceed 14 days in duration without prior approval of the Consultant. Subdivide activities exceeding 14 days in duration to an appropriate level.
 - .6 Sufficiently describe schedule activities to include what is to be accomplished in each work area. Express activity durations in whole days. Clearly define work that is to be performed by subcontract.
 - .7 Create the schedule in conformance with the work-hours and constraints set forth in these Contract Documents.
- .6 Include dates for commencement and completion of each major element of construction.
- .7 Show projected percentage of completion of each item as of first day of month.
- .8 Indicate progress of each activity to date of submission schedule.
- .9 Show changes occurring since previous submission of schedule:
 - .1 Major changes in scope.
 - .2 Activities modified since previous submission.
 - .3 Revised projections of progress and completion.
 - .4 Other identifiable changes.

- .10 Provide a narrative report to define:
 - .1 Problem areas, anticipated delays, and impact on schedule.
 - .2 Corrective action recommended and its effect.
 - .3 Effect of changes on schedules of other prime contractors.

1.7 Submittals Schedule

- .1 Include schedule for submitting shop drawings, product data, and samples. Indicate manufacture and delivery lead times into the shop drawing submittal schedule.
- .2 Indicate dates for submitting, review time, resubmission time, and last date for meeting fabrication schedule.

PART 2 PRODUCTS

2.1 Not Used

- .1 Not used

PART 3 EXECUTION

3.1 Not Used

- .1 Not used

End of Section

PART 1 GENERAL

1.1 Section Includes

- .1 Administrative
- .2 Requests for Information (RFI's)
- .3 Shop Drawings and Product Data
- .4 Interference Drawings
- .5 Progress Photographs
- .6 Samples
- .7 Mock-Ups
- .8 Certificates and Transcripts

1.2 Administrative

- .1 Submit to Consultant submittals listed for review. Submit promptly and in orderly sequence to not cause delay in Work. Failure to submit in ample time is not considered sufficient reason for extension of Contract Time and no claim for extension by reason of such default will be allowed.
- .2 Work affected by submittal shall not proceed until review is complete.
- .3 Present shop drawings, product data, samples and mock-ups in metric units.
- .4 Where items or information is not produced in metric units converted values are acceptable.
- .5 Review submittals prior to submission to Consultant. This review represents that necessary requirements have been determined and verified, or will be, and that each submittal has been checked and coordinated with requirements of Work and Contract Documents. Submittals not stamped, signed, dated and identified as to specific project will be returned without being examined and considered rejected.
- .6 Notify Consultant in writing at time of submission, identifying deviations from requirements of Contract Documents stating reasons for deviations.
- .7 Verify field measurements and affected adjacent work are coordinated.
- .8 Contractor's responsibility for errors and omissions in submission is not relieved by Consultant's review.
- .9 Contractor's responsibility for deviations in submission from requirements of Contract Documents is not relieved by Consultant's review.
- .10 Keep one reviewed copy of each submission on site.

1.3 Requests for Information (RFI's)

- .1 Refer to Section 01 26 15 – Requests for Information

1.4 Shop Drawings and Product Data

- .1 The term "shop drawings" means drawings, diagrams, illustrations, schedules, performance charts, brochures, product data and other data which the Contractor provides to illustrate details of a portion of Work.

- .2 Coordinate each submission with requirements of work and Contract Documents. Individual submissions will not be reviewed until all related information is available.
- .3 Submit shop drawings bearing stamp and signature of qualified professional Engineer registered or licensed in the Province of Ontario where required by the individual specification sections. Each submittal and each resubmittal must bear the stamp of the Engineer
- .4 Indicate materials, methods of construction and attachment or anchorage, erection diagrams, connections, explanatory notes and other information necessary for completion of Work. Where articles or equipment attach or connect to other articles or equipment, indicate that such items have been coordinated, regardless of Section under which adjacent items will be supplied and installed. Indicate cross references to design drawings and specifications.
- .5 Prior to submission to Consultant, review all submitted drawings. By this review, Contractor represents to have determined and verified field measurements, site conditions, materials, catalogue number and similar data and to have checked and coordinated each drawing with the requirements of Work and of Contract Documents. Contractor's review of each drawing shall be indicated by stamp, date and signature of a responsible person.
- .6 At time of submission, notify Consultant in writing of any deviations in drawings from the requirements of the Contract Documents.
- .7 Allow ten (10) days for Consultant's review of each submission.
- .8 Adjustments made on shop drawings by Consultant are not intended to change Contract Price. If adjustments affect value of Work, state such in writing to Consultant prior to proceeding with Work.
- .9 Make any changes in submitted drawings which Consultant may require, consistent with Contract Documents and resubmit unless otherwise directed by Consultant. When resubmitting, notify Consultant in writing of any revisions other than those requested by Consultant.
- .10 Accompany submissions with transmittal letter containing:
 - .1 Date.
 - .2 Project title and number.
 - .3 Contractor's name and address.
 - .4 Identification and quantity of each shop drawing, product data and sample.
 - .5 Other pertinent data.
- .11 Submissions shall include:
 - .1 Date and revision dates.
 - .2 Project title and number.
 - .3 Name and address of:
 - .1 Subcontractor.
 - .2 Supplier.
 - .3 Manufacturer.
 - .4 Contractor's stamp, signed by Contractor's authorized representative certifying approval of submissions, verification of field measurements and compliance with Contract Documents.
 - .5 Details of appropriate portions of Work as applicable:
 - .1 Fabrication.
 - .2 Layout, showing dimensions, including identified field dimensions, and clearances.
 - .3 Setting or erection details.
 - .4 Capacities.
 - .5 Performance characteristics.

- .6 Standards.
- .7 Operating weight.
- .8 Wiring diagrams.
- .9 Single line and schematic diagrams.
- .10 Relationship to adjacent work.

- .12 After Consultant's review, distribute copies.

- .13 Submit 3 prints plus one electronic copy in PDF format of shop drawings for each requirement requested in specification Sections and as Consultant may reasonably request.

- .14 Submit electronic copy in PDF format of product data sheets or brochures for requirements requested in Specification Sections and as requested by Consultant where shop drawings will not be prepared due to standardized manufacture of product.

- .15 Delete information not applicable to project.

- .16 Supplement standard information to provide details applicable to project.

- .17 If upon review by Consultant, no errors or omissions are discovered or if only minor corrections are made, copies will be returned, and fabrication and installation of Work may proceed. If shop drawings are rejected, noted copy will be returned and resubmission of corrected shop drawings, through same procedure indicated above, must be performed before fabrication and installation of Work may proceed.

- .18 The review of shop drawings by the Consultant is for sole purpose of ascertaining conformance with general concept.
 - .1 This review shall not mean that the Consultant approves detail design inherent in shop drawings, responsibility for which shall remain with Contractor submitting same, and such review shall not relieve Contractor of responsibility for errors or omissions in shop drawings or of responsibility for meeting requirements of construction and Contract Documents.
 - .2 Without restricting generality of foregoing, Contractor is responsible for dimensions to be confirmed and correlated at job site, for information that pertains solely to fabrication processes or to techniques of construction and installation and for co-ordination of Work of sub-trades.

- 1.5 Interference Drawings
 - .1 Prepare interference drawings to coordinate the installation of the work of all sections, within available space. Conflicts between trades which could be determined beforehand, by the careful coordination and preparation of interference drawings, shall be corrected at no expense to the Owner.
 - .2 Prepare interference drawings of all buried services as necessary to avoid conflicts with new or existing structures, foundations or services.
 - .3 Submit interference and equipment placing drawings as specified in Section 01 71 00, when requested by the Consultant.

- 1.6 Progress Photographs
 - .1 Progress photograph to be electronically formatted and labelled as to location and view.

1.7 Samples

- .1 Submit for review samples as requested in respective specification Sections. Label samples with origin, manufacturer, product information, applicable specification section, and intended use.
- .2 Notify Consultant in writing, at time of submission of deviations in samples from requirements of Contract Documents.
- .3 Where colour, pattern or texture is criterion, submit full range of manufacturer's samples.
- .4 Adjustments made on samples by Consultant are not intended to change Contract Price. If adjustments affect value of Work, state such in writing to Consultant prior to proceeding with Work.
- .5 Make changes in samples which Consultant may require, consistent with Contract Documents.
- .6 Reviewed and accepted samples will become standard of workmanship and material against which installed Work will be verified.

1.8 Mock-Ups

- .1 Erect mock-ups in accordance with 01 45 00 - Quality Control.

1.9 Certificates and Transcripts

- .1 Immediately after award of Contract, Submit Workplace Safety and Insurance Board Experience Report.

PART 2 PRODUCTS

2.1 Not Used

- .1 Not used

PART 3 EXECUTION

3.1 Not Used

- .1 Not used

End of Section

PART 1 GENERAL

1.1 Section Includes

- .1 Requirements for quality of work.
- .2 Requirements for material inspection and testing.
- .3 Requirements for determination of defective materials and work.

1.2 References

- .1 CSA Group (CSA)
 - .1 CSA-A23.1-14/ CSA-A23.2-14 Concrete Materials and Methods of Concrete Construction/ Methods of Test Methods and Standard Practice for Concrete.
 - .2 CSA S16.1 Limit States Design of Steel Structures.
 - .3 CSA S304.1-04 (R2010) - Design of Masonry Structures
 - .4 CSA W47.1 Certification of Companies for Fusion Welding of Steel Structures.
 - .5 CSA W59 Welded Steel Construction (Metal Arc Welding).
- .2 CISC Code of Standard Practice for Structural Steel.
- .3 OPSS Ontario Provincial Standard Specifications.

1.3 Regulatory Requirements

- .1 Products and services provided to complete the Work shall meet or exceed requirements of specified standards, municipal by-laws, building codes and referenced documents.

1.4 Independent Inspection and Testing

- .1 Independent Inspection and Testing Consultants will be engaged on behalf of the Owner, for the purpose of inspecting and/or testing individual portions of the Work. The initial cost of such services will be included in the Contract Price, as allocated under Section 01 21 00, Allowances.

1.5 Responsibilities

- .1 Inspection and Testing Consultants
 - .1 Inspection and Testing Consultants shall;
 - .1 Provide inspection and testing specified,
 - .2 Inform the Contractor and Consultant immediately upon observance of materials, systems, or procedures not in compliance with the specifications, and
 - .3 Submit complete reports to the Contractor and the Consultant in a timely manner.
- .2 Contractor
 - .1 Contractor shall:
 - .1 Ensure the quality control requirements of the Contract are implemented.
 - .2 Provide access to the Work for Inspection/Testing Consultants, and
 - .3 Inform the Inspection/Testing Consultants in advance of day and time required for inspection and tests.
- .3 Consultant
 - .1 The Consultant will make final decisions on changes to the scope of work of inspection and testing that may affect the Contract Price.
 - .2 When informed of any material procedure or test result that does not meet or exceed the specifications, the Consultant will respond in an expedient manner to resolve the issue.

1.6 Access to Work

- .1 Allow inspection & testing company's access to the Work, as well as off-site manufacturing and fabrication plants.

1.7 Work Subject to Inspection and Testing

- .1 Refer to individual specification sections for requirements for inspection and testing.
- .2 Provide additional inspection and testing beyond that listed in the specifications where directed by the Consultant.

1.8 Reports

- .1 Submit inspection and test reports to the Consultant.
- .2 Provide copies to Subcontractor of work being inspected or tested, manufacturer or fabricator of material being inspected or tested.
- .3 Submit one copy of inspection and test reports to the Building Official having jurisdiction, where required by that official.
- .4 The cost of tests beyond those called for in the Contract Documents or beyond those required by the law of the Place of Work shall be appraised by the Consultant and may be authorized as recoverable.

PART 2 PRODUCTS

2.1 Not Used

- .1 Not used

PART 3 EXECUTION

3.1 Inspection and Testing – General

- .1 Furnish test results and mix designs as may be requested.
- .2 The cost of tests and mix designs beyond those called for in the Contract Documents or beyond those required by the law of the Place of Work shall be appraised by the Consultant and may be authorized as recoverable.

3.2 Inspection and Testing – Procedures

- .1 Notify the appropriate agency and Consultant in advance of the requirement for tests, in order that attendance arrangements can be made.
- .2 Submit samples and/or materials required for testing, as specifically requested in specifications. Submit with reasonable promptness and in an orderly sequence so as not to cause delay in the Work.
- .3 Provide labour and facilities to obtain and handle samples and materials on site. Provide sufficient space to store, cure and inspect test samples.

3.3 Quality of Work

- .1 Quality of the Work shall be first class, executed by workers experienced and skilled in the respective duties for which they are employed. Immediately notify the Consultant if required work is such as to make it impractical to produce required results.
- .2 Do not employ any unfit person or anyone unskilled in their required duties. The Consultant reserves the right to require the dismissal from the site, of workers deemed incompetent, careless, insubordinate or otherwise objectionable.

3.4 Defective Materials and Work

- .1 Where evidence exists that defective work has occurred, or that work has been carried out incorporating defective products, the Consultant may have independent tests, inspections, or surveys performed in order to determine if work is defective.
- .2 Tests, inspections, or surveys carried out under these circumstances will be made at the Contractor's expense in the event of defective work, or at the Owner's expense where work is in conformance. Where tests incorporate a number of samples, payment will be assessed, by the Consultant, based on the ratio of conforming to non-conforming results. This does not include re-testing of soil compaction during placement, where evidence exists of non-conformance with the Contract documents, but rather only if re-testing is called for after completion of compaction.

End of Section

PART 1 GENERAL

1.1 Section Includes

- .1 References.
- .2 Owner's Regulations.
- .3 Standards and Definitions.
- .4 Designated Substances.
- .5 Hazardous Materials.
- .6 Spills Reporting.
- .7 Protection of Water Quality.
- .8 Potable Water Systems.
- .9 Access for Inspection and Testing.
- .10 Other Regulatory Requirements.

1.2 References

- .1 Perform Work in accordance with Ontario Building Code (OBC), National Fire Code of Canada (NFC), the Canadian Electrical Code CSA C22.1-18, including all Supplements and other codes of provincial or local application provided that in case of conflict or discrepancy, more stringent requirements apply.
- .2 Where a material is designated in the Contract Documents for a certain application, unless otherwise specified, that material shall conform to standards designated in the Code. Similarly, unless otherwise specified, installation methods and standards of workmanship shall also conform to standards invoked by the aforementioned Code.
- .3 Meet or exceed requirements of:
 - .1 Contract documents.
 - .2 Specified standards, codes and referenced documents.
 - .3 Manufacturer's instructions.
- .4 Where requirements of Contract Documents exceed Code requirements provide such additional requirements.
- .5 Where the Building Code or the Contract Documents do not provide all information necessary for complete installation of an item, then the manufacturer's instructions for first quality workmanship shall be strictly complied with.

1.3 Owner's Regulations

- .1 Conform to requirements, regulations and procedures of the Owner.

1.4 Standards and Definitions

- .1 Where a reference is made to specification standards produced by various organizations, conform to latest edition of standards, as amended and revised to date of Contract.
- .2 Have a copy of each specified standard which relates to your work available on the site to be produced immediately on Consultant's request.

1.5 Designated Substances

- .1 Known designated substances are identified in the Designated Substance Report.

- .2 Stop work immediately when material resembling asbestos, mould or any other designated substance which is not identified in the Designated Substance Report is encountered during the course of the work. Notify Owner and Consultant immediately.
- .3 The Owner will arrange for independent testing of suspected designated substances and removal of such substances encountered on the site during the course of the work which are not identified in the Designated Substance Report.

1.6 Hazardous Materials

- .1 Definition: "Hazardous Material" is material, in any form, which by its nature, may be flammable, explosive, irritating, corrosive, poisonous, or may react violently with other materials, if used, handled or stored improperly. Included are substances prohibited, restricted, designated or otherwise controlled by law.
- .2 Provide SDS for all materials brought to the Place of Work.
- .3 Hazardous Materials will not be introduced for experimental or any other use prior to being evaluated for hazards.
- .4 Make known to the Consultant those hazardous materials or designated substances intended to be used in the workplace and receive permission to use before introducing to the Owner's property.
- .5 Many common construction materials such as asbestos pipe and various insulations are designated substances and shall not be used under any circumstances. Such materials are banned from the Owner's facilities.

1.7 Spills Reporting

- .1 Spills or discharges of pollutants or contaminants under the control of the Contractor, and spills or discharges of pollutants or contaminants that are a result of the Contractor's operations that cause or are likely to cause adverse effects shall forthwith be reported to the Consultant. Such spills or discharges and their adverse effects shall be as defined in the Environmental Protection Act R.S.O. 1999.
- .2 All spills or discharges of liquid, other than accumulated rain water, from luminaries, internally illuminated signs, lamps, and liquid type transformers under the control of the Contractor, and all spills or discharges from this equipment that are a result of the Contractor's operations shall, unless otherwise indicated in the Contract, be assumed to contain PCB's and shall forthwith be reported to the Consultant.
- .3 This reporting will not relieve the Contractor of his legislated responsibilities regarding such spills or discharges.

1.8 Protection of Water Quality

- .1 No waste or surplus organic material including topsoil is to be stored or disposed of within 30 metres of any watercourses. Run-off from excavation piles will not be permitted to drain directly into watercourses. Where this measure is not sufficient or feasible to control sediment entering the watercourses, sedimentation traps or geo-textile coverage will be required.
- .2 If de-watering is required, the water shall be pumped into a sedimentation pond or diffused onto vegetated areas a minimum of 30 metres from any watercourses and not pumped directly into the

watercourses.

- .3 Provide all de-watering and sedimentation control required to properly complete the work of this contract.
- .4 Supply, install and maintain silt/sediment control fencing along the edge of the site to intercept construction runoff silt, to the satisfaction of the Owner.

1.9 Potable Water Systems

- .1 Potable water systems in completed buildings must meet criteria and guidelines established by Provincial and Municipal authorities, prior to occupancy by the Owner.
- .2 Upon completion, submit testing certificates verifying water quality and water systems meets all applicable Provincial and Legislated Standards

1.10 Access for Inspection and Testing

- .1 Cooperate fully with and provide assistance to, all outside authorities including Building Inspectors, utilities, testing agencies and consultants, with the inspection of the Work.

1.11 Other Regulatory Requirements

- .1 Conform to the requirements of the Ontario Ministry of Transportation, Regional and Local authorities regarding transportation of materials.
- .2 Pay any required roadway damage deposits required by the local municipality.
- .3 Conform to the requirements of the Ontario Ministry of the Environment.
- .4 Conform to the requirements of the Ontario Ministry of Labour.
- .5 Conform to all applicable local by-laws, regulations and ordinances.

PART 2 PRODUCTS

2.1 Not Used

- .1 Not used

PART 3 EXECUTION

3.1 Not Used

- .1 Not used

End of Section

PART 1 GENERAL

1.1 Section Includes

- .1 Temporary utilities

1.2 Installation and Removal

- .1 Provide temporary utilities and controls in order to execute work expeditiously.
- .2 Remove from site all such work after use.

1.3 Dewatering

- .1 Provide temporary drainage and pumping facilities to keep excavations and site free from standing water.

1.4 Water Supply

- .1 Existing sources of water can be made available to the Contractor at no charge, subject to operational requirements. Arrange for connection and pay all costs for installation, maintenance and removal. Conversions or alterations to existing sources of water to meet construction requirements are the responsibility of the Contractor.
- .2 The points of delivery and limits on amount available will be determined on site by the Owner whose written permission must be obtained before any connection is made.

1.5 Temporary Heating and Ventilation

- .1 Provide temporary heating required during construction period, including attendance, maintenance and fuel.
- .2 Construction heaters used inside building must be vented to outside or be flameless type. Solid fuel salamanders are not permitted, unless prior approval is given by the Consultant.
- .3 Provide temporary heat and ventilation in enclosed areas as required to:
 - .1 Facilitate progress of Work.
 - .2 Protect Work and products against dampness and cold.
 - .3 Prevent moisture condensation on surfaces.
 - .4 Provide ambient temperatures and humidity levels for storage, installation and curing of materials.
 - .5 Provide adequate ventilation to meet health regulations for safe working environment.
- .4 Maintain temperatures of minimum 10° C in areas where construction is in progress.
- .5 Ventilating:
 - .1 Prevent accumulations of dust, fumes, mists, vapours or gases in areas occupied during construction.
 - .2 Provide local exhaust ventilation to prevent harmful accumulation of hazardous substances into atmosphere of occupied areas.
 - .3 Dispose of exhaust materials in manner that will not result in harmful exposure to persons.
 - .4 Ventilate storage spaces containing hazardous or volatile materials.
 - .5 Ventilate temporary sanitary facilities.
 - .6 Continue operation of ventilation and exhaust system for time after cessation of work process

to assure removal of harmful contaminants.

- .6 Permanent heating system of building may not be used when available, unless there are savings to the contract price and Consultant's written permission is obtained stating conditions of use, provisions relating to guarantees on equipment and operation and maintenance of system. Be responsible for damage to heating system if use is permitted.
- .7 On completion of Work for which permanent heating system is used, replace filters.
- .8 Ensure Date of Substantial Performance and Warranties for heating system do not commence until entire system is in as near original condition as possible and is certified by Consultant.
- .9 Pay costs for maintaining temporary heat, when using permanent heating system. Owner will pay utility charges when temporary heat source is existing building equipment.
- .10 Maintain strict supervision of operation of temporary heating and ventilating equipment to:
 - .1 Conform to applicable codes and standards.
 - .2 Enforce safe practices.
 - .3 Prevent abuse of services.
 - .4 Prevent damage to finishes.
 - .5 Vent direct fired combustion units to outside.
- .11 Be responsible for damage to Work due to failure in providing adequate heat and protection during construction.

1.6 Temporary Power and Light

- .1 Existing sources of electric power can be made available to the Contractor. Conversions or alterations to existing sources of electric power to meet construction requirements are the responsibility of the Contractor.
- .2 The points of delivery and limits on amount available will be determined on site by the Owner whose written permission must be obtained before any connection is made.
- .3 Electrical power and lighting systems installed under this Contract may be used for construction requirements only with prior approval of Consultant provided that guarantees are not affected.
- .4 Provide and maintain temporary lighting throughout project. Lighting levels shall be sufficient to complete work including inspections. Provide minimum lighting levels of 400 lux at work areas. Lighting levels at floors and stairs not within work areas shall be not less than 160 lux at all times during construction activity.
- .5 All equipment used shall be CSA approved.
- .6 Wiring and method of installation shall conform to local power requirements and shall be reviewed by a licensed inspector prior to use.

1.7 Temporary Communication Facilities

- .1 Provide and pay for temporary telephone, fax, data hook up, lines and equipment necessary for own use.

PART 2 PRODUCTS

2.1 Not Used

.1 Not used

PART 3 EXECUTION

3.1 Not Used

.1 Not used

End of Section

PART 1 GENERAL

1.1 Section Includes

- .1 Construction aids.
- .2 Site storage.
- .3 Parking
- .4 Offices
- .5 Equipment and Material Storage.
- .6 Sanitary facilities.
- .7 Signage.
- .8 Shoring

1.2 References

- .1 CSA Group (CSA)
 - .1 CAN/CSA Z321-96 (R2006) Signs and Symbols for the Workplace

1.3 Installation and Removal

- .1 Provide construction facilities in order to execute work expeditiously.
- .2 Remove from site all such work after use.

1.4 Hoisting

- .1 Provide, operate and maintain hoists and cranes required for moving of workers, materials and equipment.
- .2 Hoists and cranes shall be operated by qualified operator.

1.5 Site Storage/Loading

- .1 Do not unreasonably encumber premises with products.
- .2 Do not load or permit to load any part of Work with a weight or force that will endanger the Work.

1.6 Construction Parking

- .1 Parking will be permitted on site at areas designated by the Owner provided it does not disrupt performance of Work or ongoing Owners operations.
- .2 Provide and maintain adequate access to project site.
- .3 If authorized to use existing roads for access to project site, maintain such roads for duration of Contract and make good damage resulting from Contractors' use of roads.

1.7 Offices

- .1 General Contractor and Subcontractors may provide their own offices as necessary and subject to site constraints. Direct location of these offices.

1.8 Equipment, Tool and Material Storage

- .1 Provide and maintain, in a clean and orderly condition, lockable weatherproof sheds for storage of tools, equipment and materials.
- .2 Locate materials not required to be stored in weatherproof sheds on site in a manner to cause least interference with work activities.

1.9 Sanitary Facilities

- .1 Provide sanitary facilities for work force in accordance with governing regulations and ordinances.
- .2 Post notices and take such precautions as required by local health authorities. Keep area and premises in sanitary condition.

1.10 Construction Signage

- .1 Direct requests for approval to erect a Contractor signboard to Consultant.
- .2 Signs and notices for safety and instruction shall be in English. Graphic symbols shall conform to CAN/CSA Z321.
- .3 Post "Construction Zone" signage outside barrier and entrance to all work areas.
- .4 Maintain approved signs and notices in good condition for duration of project and dispose of off-site on completion of project.
- .5 Install signage to direct site traffic and deliveries to the Construction work areas.

1.11 Shoring

- .1 Examine the site to determine the conditions under which work will be performed.
- .2 Contractor shall formulate his own conclusions as to the extent of the existing conditions and shoring required.
- .3 The method of shoring shall be according to the Contractor's and his Engineer's directions.
- .4 All existing loads must be shored prior to commencement of demolition and removal of load bearing elements.
- .5 All shoring and frame braces must be supplied with a safe load rating which must not be exceeded. Install in accordance with manufacturer's recommended procedures and safety guidelines. Ensure that the safe load conditions of the shoring are not exceeded by dead, live or construction loads.
- .6 All shoring shall be subject to the Consultant's review and approval prior to commencing demolition work.
- .7 Completely remove all shoring after new structure is installed and all concrete is set.
- .8 Submit shoring drawings and a proposed installation procedure stamped by a professional engineer registered in the Province of Ontario. Procedures shall follow the information provided on

- these drawings. The shoring design engineer shall be retained and paid for by the Contractor. The shoring engineer shall review all existing conditions on site prior to completing shoring design.
- .9 Removal of existing materials without proper engineered shoring is a safety hazard and will not be permitted.
 - .10 Make good all damage to the existing structure and adjoining structures and bear full responsibility for failure to provide adequate shoring.
 - .11 The failure or refusal of the Consultant to suggest the use of shoring, shall not in any way or to any extent relieve the Contractor of any responsibility concerning the condition of the work or of any of their obligations under the Contract, nor impose any liability on the Owner or their agents; nor shall any delay, whether caused by any action or want of action on the part of the Contractor, or by any act of the Owner, or their agents, or employees, relieve the Contractor from necessity of properly and adequately protecting the existing structure from collapse or damage, nor from and of his obligations under the Contract relating to injury to persons or property, nor entitle him to any claims for extra compensation or an extension in schedule.

PART 2 PRODUCTS

2.1 Not Used

- .1 Not used

PART 3 EXECUTION

3.1 Not Used

- .1 Not used

End of Section

PART 1 GENERAL

1.1 Section Includes

- .1 Barriers.
- .2 Environmental Controls.
- .3 Traffic Controls.
- .4 Fire Routes.

1.2 Installation and Removal

- .1 Provide temporary controls in order to execute Work expeditiously.
- .2 Remove from site all such work after use.

1.3 Hoarding

- .1 Erect temporary site enclosure using new solid plywood hoarding, minimum 1.8 metres high. Provide gates as necessary. Maintain hoarding in good repair.

1.4 Guard Rails and Barricades

- .1 Provide secure, rigid guard rails and barricades around deep excavations, open shafts, open stair wells, open edges of floors and roofs.
- .2 Provide as required by governing authorities.

1.5 Traffic Barriers

- .1 Where indicated, provide precast concrete barriers conforming to ASTM C825 - 06(2011) Standard Specification for Precast Concrete Barriers.
- .2 Provide sufficient barriers as necessary to protect the public and Owner from construction traffic.
- .3 Remove barriers on completion.

1.6 Weather Enclosures

- .1 Provide weather tight closures to unfinished door and window openings, tops of shafts and other openings in floors and roofs.
- .2 Close off floor areas where walls are not finished; seal off other openings; enclose building interior work for temporary heat.
- .3 Design enclosures to withstand wind pressure and snow loading.

1.7 Dust Tight Screens

- .1 Provide dust tight screens or partitions to localize dust generating activities, and for protection of workers, finished areas of Work and public.
- .2 Maintain and relocate protection until such work is complete.

1.8 Protection of Building Finishes

- .1 Provide protection for finished and partially finished building finishes and equipment during performance of Work.
- .2 Provide necessary screens, covers, and hoardings.
- .3 Confirm with Consultant locations and installation schedule 3 days prior to installation.
- .4 Be responsible for damage incurred due to lack of or improper protection.

1.9 Protection of Surrounding Work

- .1 Provide protection for finished and partially finished Work from damage.
- .2 Provide necessary cover and protection.
- .3 Be responsible for damage incurred due to lack of or improper or inappropriate protection.

1.10 Public Traffic Flow

- .1 Provide and maintain competent signal flag operators, traffic signals, barricades and flares, lights, or lanterns as required to perform Work and protect the public.

1.11 Fire Routes

- .1 Maintain access to property including overhead clearances for use by emergency response vehicles.

PART 2 PRODUCTS

2.1 Not Used

- .1 Not used

PART 3 EXECUTION

3.1 Not Used

- .1 Not used

End of Section

PART 1 GENERAL

1.1 Section Includes

- .1 Product quality, availability, storage, handling, protection, and transportation.
- .2 Manufacturer's instructions.
- .3 Quality of Work, coordination and fastenings.
- .4 Existing Utilities

1.2 Quality

- .1 Products, materials, equipment and articles incorporated in Work shall be new, not damaged or defective, and of best quality (compatible with specifications) for purpose intended. If requested, furnish evidence as to type, source and quality of products provided.
- .2 Defective products, whenever identified prior to completion of Work, will be rejected, regardless of previous inspections. Inspection does not relieve responsibility but is precaution against oversight or error. Remove and replace defective products at own expense and be responsible for delays and expenses caused by rejection.
- .3 Should any dispute arise as to quality or fitness of products, decision rests strictly with Consultant based upon requirements of Contract Documents.
- .4 Unless otherwise indicated in specifications, maintain uniformity of manufacture for any particular or like item throughout building.
- .5 Permanent labels, trademarks and nameplates on products are not acceptable in prominent locations, except where required for operating instructions, or when located in mechanical or electrical rooms.

1.3 Availability

- .1 Review product delivery requirements and anticipate foreseeable supply delays for any items. If delays in supply of products are foreseeable, notify Consultant of such, in order that substitutions or other remedial action may be authorized in ample time to prevent delay in performance of Work.
- .2 In event of failure to notify Consultant at commencement of Work and should it subsequently appear that Work may be delayed for such reason, Consultant reserves right to substitute more readily available products of similar character, at no increase in Contract Price or Contract Time.

1.4 Storage, Handling and Protection

- .1 Handle and store products in manner to prevent damage, adulteration, deterioration and soiling and in accordance with manufacturer's instructions when applicable.
- .2 Store packaged or bundled products in original and undamaged condition with manufacturer's seal and labels intact. Do not remove from packaging or bundling until required in Work.
- .3 Store products subject to damage from weather in weatherproof enclosures.
- .4 Store cementitious products clear of earth or concrete floors, and away from walls.
- .5 Keep sand, when used for grout or mortar materials, clean and dry. Store sand on wooden platforms and cover with waterproof tarpaulins during inclement weather.

- .6 Store sheet materials and lumber on flat, solid supports and keep clear of ground. Slope to shed moisture.
- .7 Store and mix paints in heated and ventilated room. Remove oily rags and other combustible debris from site daily. Take every precaution necessary to prevent spontaneous combustion.
- .8 Remove and replace damaged products at own expense and to satisfaction of Consultant.
- .9 Touch up damaged factory finished surfaces to Consultant's satisfaction. Use touch up materials to match original. Do not paint over name plates.

1.5 Transportation

- .1 Pay costs of transportation of products required in performance of Work.
- .2 Transportation cost of products supplied by Owner will be paid for by Owner. Contractor shall be responsible for the unloading, handling and storage of such products.

1.6 Manufacturer's Instructions

- .1 Unless otherwise indicated in specifications, install or erect products in accordance with manufacturer's instructions. Do not rely on labels or enclosures provided with products. Obtain written instructions directly from manufacturers.
- .2 Notify Consultant in writing, of conflicts between specifications and manufacturer's instructions, so that Consultant may establish course of action.
- .3 Improper installation or erection of products, due to failure in complying with these requirements, authorizes Consultant to require removal and re installation at no increase in Contract Price or Contract Time.

1.7 Quality of Work

- .1 Ensure Quality of Work is of highest standard, executed by workers experienced and skilled in respective duties for which they are employed.
- .2 Immediately notify Consultant if required Work is such as to make it impractical to produce required results.
- .3 Do not employ anyone unskilled in their required duties. Consultant reserves right to require dismissal from site, workers deemed incompetent or careless.
- .4 Decisions as to standard or fitness of Quality of Work in cases of dispute rest solely with Consultant, whose decision is final.

1.8 Coordination

- .1 Ensure cooperation of workers in laying out Work. Maintain efficient and continuous supervision.
- .2 Be responsible for coordination and placement of openings, sleeves and accessories.

1.9 Concealment

- .1 In finished areas, conceal pipes, ducts and wiring in floors, walls and ceilings, except where

indicated otherwise.

- .2 Before installation, inform Consultant if there is interference. Install as directed by Consultant.

1.10 Remedial Work

- .1 Perform remedial work required to repair or replace parts or portions of Work identified as defective or unacceptable. Coordinate adjacent affected Work as required.
- .2 Perform remedial work by specialists familiar with materials affected. Perform in a manner to neither damage nor put at risk any portion of Work.

1.11 Location of Fixtures

- .1 Consider location of fixtures, outlets, and mechanical and electrical items indicated as approximate.
- .2 Inform Consultant of conflicting installation. Install as directed.

1.12 Fastenings

- .1 Provide metal fastenings and accessories in same texture, colour and finish as adjacent materials, unless indicated otherwise.
- .2 Prevent electrolytic action between dissimilar metals and materials.
- .3 Use non corrosive hot dip galvanized steel fasteners and anchors for securing exterior work, unless stainless steel or other material is specifically requested in affected specification Section.
- .4 Space anchors within individual load limit or shear capacity and ensure they provide positive permanent anchorage. Wood, or any other organic material plugs are not acceptable.
- .5 Keep exposed fastenings to a minimum, space evenly and install neatly.
- .6 Fastenings which cause spalling or cracking of material to which anchorage is made are not acceptable.

1.13 Fastenings – Equipment

- .1 Use fastenings of standard commercial sizes and patterns with material and finish suitable for service.
- .2 Use heavy hexagon heads, semi-finished unless otherwise specified. Use No. 304 stainless steel for exterior areas.
- .3 Bolts may not project more than one diameter beyond nuts.
- .4 Use plain type washers on equipment, sheet metal and soft gasket lock type washers where vibrations occur. Use resilient washers with stainless steel.

1.14 Protection of Work in Progress

- .1 Adequately protect Work completed or in progress. Work damaged or defaced due to failure in providing such protection is to be removed and replaced, or repaired, as directed by Consultant, at

no increase in Contract Price or Contract Time.

- .2 Prevent overloading of any part of building. Do not cut, drill or sleeve any load bearing structural member, unless specifically indicated without written approval of Consultant.

1.15 Existing Utilities

- .1 When breaking into or connecting to existing services or utilities, execute Work at times directed by local governing authorities, with minimum of disturbance to Work, and/or building occupants and pedestrian and vehicular traffic.
- .2 Protect, relocate or maintain existing active services. When services are encountered, cap off in manner approved by authority having jurisdiction. Stake and record location of capped service.

1.16 Hazardous Materials

- .1 Report any found or suspected hazardous materials to the Owner.

PART 2 PRODUCTS

2.1 Not Used

- .1 Not used

PART 3 EXECUTION

3.1 Not Used

- .1 Not used

End of Section

PART 1 GENERAL

1.1 Section Includes

- .1 Safety Requirements
- .2 Fire Protection
- .3 Accident Reporting
- .4 Records on Site

1.2 References

- .1 Fire Commissioners of Canada, FC 301, Standard for Construction Operations.
- .2 Canada Labour Code, Part 2, Canada Occupational Safety and Health Regulations.
- .3 Ontario Building Code.
- .4 Occupational Health and Safety Act.
- .5 R.R.O. 1990, Reg. 860: Workplace Hazardous Materials Information System (WHMIS)
- .6 National Fire Protection Agency (NFPA)
 - .1 NFPA 241 Standard for Safeguarding Construction, Alteration, and Demolition Operations

1.3 Submittals

- .1 Make submittals in accordance with Section 01 33 00 – Submittal Procedures.
- .2 Submit to Owner and Consultant copies of the following documents, including updates issued:
 - .1 Notice of Project filed with Provincial Ministry of Labour or equivalent for Place of Work
 - .2 Site-specific Health and Safety Plan prior to commencement of work on the work site. Plan shall include but not be limited to the following:
 - .1 Name and contact info of Contractor's Health and Safety Representative for Work Site; including twenty-four (24) hour emergency contact phone numbers.
 - .2 Phone numbers of local fire, police, and ambulance outside of 911 services.
 - .3 Location of nearest medical facility and level of injury that each can service.
 - .3 Submit to the Owner, Consultant and Municipal Fire Department, for review, a "Fire Safety Plan" conforming to Section 2.14 of the National Fire Code of Canada. Maintain a copy of the "Fire Safety Plan" on site.
 - .4 Copies of certification for all employees on site of applicable safety training including, but not limited to:
 - .1 WHMIS.
 - .2 Fall arrest and protection.
 - .3 Suspended Access Equipment.
 - .4 Erection of Scaffolding.
 - .5 License for powder actuated devices.
 - .5 On-site Contingency and Emergency Response Plan addressing:
 - .1 Standard procedures to be implemented during emergency situations.
 - .2 Preventative planning and protocols to address possible emergency situations.
- .3 Guidelines for handling, storing, and disposing of hazardous materials that maybe encountered on site, including measures to prevent damage or injury in case of an accidental spill.
- .4 Incident and accident reports, promptly if and upon occurrence
 - .1 Reports or directions issued by authorities having jurisdiction, immediately upon issuance from that authority.
 - .2 Accident or Incident Reports, within 24 hours of occurrence.

- .5 Submit other data, information and documentation upon request by the Consultant as stipulated elsewhere in this section.

1.4 Compliance Requirements

- .1 Comply with the latest edition of the Ontario Occupational Health and Safety Act, and the Regulations made pursuant to the Act.

1.5 Constructor

- .1 Notify all regulatory bodies required for construction activities, (i.e., Notice of Project, employer notification, etc.). Notifications shall include, but not be limited to, the notification requirements laid out in OHS Act Sec 51-53 and the requirements of Ontario Regulation 213/91 for Construction Projects, Sections 5, 6 and 7. For the purpose of this contract the Contractor shall be the "Constructor".
- .2 The "Constructor" will be solely responsible for the safety of all persons on the Site.

1.6 Safety Requirements

- .1 Observe and enforce all construction safety measures and comply with the latest edition and amending regulations of the following documents and in the event of any differences among those provisions, the most stringent shall apply:
 - .1 Occupational Health and Safety Act and Regulations for Construction Projects, August 1997, Ontario Regulation 213/91 including amendments.
 - .2 Hazardous Products Act and Canada Labour Code.
 - .3 The Workplace Safety and Insurance Board, O-Reg 454.
 - .4 Ontario Building Code Act, Ontario Regulation 332/12 including amendments.
 - .5 National Building Code of Canada, Part 8: Safety Measures on Construction and Demolition Sites.
 - .6 National Fire Code of Canada.
 - .7 NFPA 241 Standard for Safeguarding Construction, Alteration, and Demolition Operations, 2013 Edition
 - .8 Environmental Protection Act.
 - .9 The Power Commission Act.
 - .10 The Boiler and Pressure Vessels Act.
 - .11 The Elevators and Lifts Act.
 - .12 The Operating Engineer's Act.
 - .13 Municipal statutes.
- .2 Obey all Federal, Provincial and Municipal Laws, Acts, Statutes, Regulations, Ordinances and By-laws which could in any way, pertain to the work outlined in the Contract, or to any employees of the Contractor. Satisfy all statutory requirements imposed by the Occupational Health and Safety Act and Regulations made thereunder, on a Contractor, and Constructor and/or Employer with respect to or arising out of the performance of the Contractors obligations under this Contract.
- .3 Working at Heights: The supervisor of the project, will be responsible to ensure that his employees and subcontractors/suppliers have current Working at Heights and Fall Protection certification.
- .4 The supervisor of the project will be responsible for his employees and subcontractors/suppliers maintaining standard safety practices, as well as the specific safety rules listed below, while working on the Owner's property.
- .5 The Owner reserves the right to order individuals to leave the site if the individual is in violation of

- any safety requirement or any Act. Any expense incurred will be the responsibility of the Contractor.
- .6 Notify the Owner should any hazardous condition become apparent.
- .7 Enforce the use of CSA approved hard hats, reflective vests and safety boots for all persons entering or working at the construction site. Refuse admission to those refusing to conform to this requirement.
- .8 Provide safeguard and protection against accident, injury or damage to any person on the site, adjacent work areas and adjacent property.

1.7 Confined Space

- .1 Confined Space: Where applicable, provide the Consultant and all Regulatory Authorities with a copy of the Contractors' Confined Space Entry Procedure. In the event that defined procedures are not available, abide by the applicable requirements of the Occupational Health and Safety Act and all regulations made thereunder.
- .2 Persons intended to work in confined spaces, as defined by the Owner, must have formal training in performing work in confined spaces.
- .3 Provide proof of valid certificates of such training for all workers prior to entry of such workers into confined spaces.
- .4 Provide all necessary safety equipment for entry into confined spaces.
- .5 Where workers are required to enter a confined space, as defined by the OHSA, O. Reg. 632/05 Section 221.2, ensure that workers of the Contractor and all Subcontractors follow the requirements of the above legislation, including but not limited to:
 - .1 Having a method for recognizing each confined space to which the program applies
 - .2 Having a method for assessing the hazards to which workers may be exposed
 - .3 Having a method for the development of confined space entry plans (which include on-site rescue procedures)
 - .4 Having a method for training workers
 - .5 Having an entry-permit system.
 - .6 Supply the necessary tools and equipment to perform the confined space entry. These items include, but are not limited to, required documentation, gas detectors, breathing equipment, fall protection and rescue equipment.

1.8 Safety Meetings

- .1 Site toolbox safety meetings will be held weekly for all Contractor employees and all sub trade contractors.
- .2 Where a Joint Health and Safety Committee is required on a project, workers and supervisors, selected, as members of the committee must attend.

1.9 Workplace Hazardous Materials Information System (WHMIS)

- .1 Be familiar with WHMIS regulations and be responsible for compliance.
- .2 Provide to the Consultant a list of Designated Substances that will be brought to the site prior to commencing work. Safety Data Sheets (SDS) and the hazardous material inventory for each substance listed must be kept on the Project.

- .3 Be responsible for all other requirements of regulations as applicable to Employers.
- .4 All controlled products to be properly labelled and stored.
- .5 Immediately inform Owner and Consultant if any unforeseen or peculiar safety-related factor, hazard, or condition becomes evident during performance of Work.

1.10 Fire Protection

- .1 Provide and maintain safeguard and protection against fire in accordance with current fire codes and regulations.
- .2 Provide temporary fire protection throughout the course of construction. Particular attention shall be paid to the elimination of fire hazards.
- .3 Comply with the requirements of FCC No. 301 Standards for Construction Operations issued by the Fire Commissioner of Canada and the National Building Code.
- .4 Provide and maintain portable fire extinguishers during construction, in accordance with Part 6 of the National Fire Code of Canada 2015 and NFPA 241.
- .5 Maintain unobstructed access for firefighting at all areas in accordance with the National Building Code of Canada.

1.11 First Aid

- .1 Provide such equipment and medical facility as required by WSI Act to supply first aid services to anyone who may be injured at the place of Work. Report all accidents or injuries to the proper authorities and to the Owner and Consultant.

1.12 Accident Reporting

- .1 Investigate and report incidents and accidents as required by Occupational Safety and Health Act, and the Regulations made pursuant to the Act.

1.13 Records on Site

- .1 Maintain on site a copy of the safety documentation as specified in this section and any other safety related reports and documents issued to or received from the authorities having jurisdiction.
- .2 Upon request, make copies available to the Consultant.

PART 2 PRODUCTS

2.1 Not Used

- .1 Not used

PART 3 EXECUTION

3.1 Not Used

.1 Not used

End of Section

PART 1 GENERAL

1.1 Section Includes

- .1 Survey services to establish and confirm inverts for Work.
- .2 Recording of subsurface conditions found.

1.2 Submittals

- .1 Make submittals in accordance with Section 01 33 00 – Submittal Procedures.
- .2 Submit name and address of Surveyor to Consultant.
- .3 On request of Consultant, submit documentation to verify accuracy of field engineering work.
- .4 Submit certificate signed by surveyor certifying and noting those elevations and locations of completed Work that conform and do not conform to Contract Documents.

1.3 Examination of Work and Site

- .1 Examine the site and existing building to be fully informed of their particulars as related to the Work.
- .2 Verify dimensions of completed Work in place before fabrication of Work to be incorporated with it. Ensure that all necessary job dimensions are taken for the proper execution of the work. Assume complete responsibility for the accuracy and completeness of such dimensions.
- .3 No claims for extra payment will be paid for extra work made necessary or for difficulties encountered due to conditions of the site which were visible or reasonably inferable from an examination of the site at the time prior to tender closing date and furthermore, failure of the Contractor to visit and examine the site shall be deemed a waiver of all claims for extra payment due to any condition of the site existing prior to tender closing date.
- .4 As-found damage: Record by photography and submit evidence to Owner's representative before commencing work, any found damaged surfaces or materials adjacent to new work, and not included under scope of this new work. Remedial work to any damage, not so recorded, shall be the responsibility of the Contractor.

1.4 Existing Services

- .1 Before commencing work, establish location and extent of service lines in area of Work and notify Consultant of findings. The Contractor is responsible for coordination of all utility locates.
- .2 Remove abandoned service lines within 2 m of structures. Cap or otherwise seal lines at cut off points as directed by Consultant.
- .3 Where Work involves breaking into or connecting to existing services, carry out work at times directed by authorities having jurisdiction, with minimum of disturbance to building occupants, pedestrian and vehicular traffic.
- .4 Where unknown services are encountered, immediately advise Consultant and confirm findings in writing.
- .5 Install temporary drain plugs to prevent construction debris from blocking pipes downstream of the work.

- .6 All existing concrete floor slabs shall be scanned prior to any cutting or breaking of concrete. Employ a qualified concrete scanning company or inspection and testing agency to scan and map floor slabs for reinforcing, plastic and metal conduit, piping, grounding cables, embedments and the like. Map all slabs and provide copies to the Owner and Consultant.

1.5 Location of Services, Equipment and Fixtures

- .1 Location of services, equipment, fixtures and outlets indicated on drawings or specified are to be considered as approximate.
- .2 Locate equipment, fixtures and distribution systems to provide minimum interference and maximum usable space and in accordance with manufacturer's recommendations for safety, access and maintenance. Include existing equipment which affects or will be affected by the work.
- .3 Inform Consultant of impending installation and obtain approval for actual location.
- .4 Location of site services where required, is approximate and is based on information provided by the Owner. Undertake all locates to determine exact locations of existing services and lay out new services to avoid any conflicts with new building elements, including site improvements, building foundations and other new or existing services.
- .5 Submit field drawings and interference drawings to indicate relative position of various services and equipment. Refer to requirements for interference drawings specified elsewhere.
- .6 Prepare interference and equipment placing drawings to ensure that all components will be properly accommodated within the spaces provided.
- .7 Prepare drawings to indicate coordination and methods of installation of a system with other systems where their relationship is critical. Ensure that all details of equipment apparatus and connections are coordinated.
- .8 Ensure that clearances required by jurisdictional authorities and clearances for proper maintenance and access are indicated and maintained.
- .9 Submit interference drawings to Owner and Consultant in accordance with Section 01 33 00.

1.6 Records

- .1 Maintain a complete, accurate log of control and survey work as it progresses.
- .2 Record locations of maintained, re-routed and abandoned service lines.

1.7 Subsurface Conditions

- .1 Promptly notify Consultant in writing if subsurface conditions at Place of Work differ materially from those indicated in Contract Documents, or a reasonable assumption of probable conditions based thereon.
- .2 After prompt investigation, should Consultant determine that conditions do differ materially, instructions will be issued for changes in Work.

PART 2 PRODUCTS

2.1 Not Used

.1 Not used

PART 3 EXECUTION

3.1 Not Used

.1 Not used

End of Section

PART 1 GENERAL

1.1 Section Includes

- .1 Requirements and limitations for cutting and patching the Work.

1.2 Submittals

- .1 Make submittals in accordance with Section 01 33 00 – Submittal Procedures.
- .2 Submit written request and obtain Consultant’s approval in advance of cutting or alteration which affects:
 - .1 Structural integrity of any element of Project.
 - .2 Integrity of weather exposed or moisture resistant elements.
 - .3 Efficiency, maintenance, or safety of any operational element.
 - .4 Visual qualities of sight exposed elements

1.3 Materials

- .1 As specified and required for original installation.
- .2 Change in Materials: Submit request for substitution in accordance with Section 01 25 00 - Substitution Procedures.
- .3 Requests for change in materials shall include documentation indicating conformance to project requirements and intent.

1.4 Definitions

- .1 Cutting: Removal of in-place construction necessary to permit installation or performance of other work.
- .2 Patching: Fitting and repair work required to restore construction to original conditions after installation of other work.

PART 2 PRODUCTS

2.1 Materials

- .1 General: Comply with requirements specified in other Sections.
- .2 In-Place Materials: Use materials for patching identical to in-place materials. For exposed surfaces, use materials that visually match in-place adjacent surfaces to the fullest extent possible.
- .3 If identical materials are unavailable or cannot be used, use materials that, when installed, will provide a match acceptable to Consultant for the visual and functional performance of in-place materials.

PART 3 EXECUTION

3.1 Preparation

- .1 Inspect existing conditions, including elements subject to damage or movement during cutting and patching.

- .2 After uncovering, inspect conditions affecting performance of Work.
- .3 Beginning of cutting or patching means acceptance of existing conditions.
- .4 Provide supports to assure structural integrity of surroundings; provide devices and methods to protect other portions of project from damage.
- .5 Provide protection from elements for areas which may be exposed by uncovering work; maintain excavations free of water.

3.2 General

- .1 Carry out all cutting and patching required for the work of the Contract.
- .2 Repair all wall and floor surfaces where items have been removed.
- .3 Make good all finishes as required.
- .4 Repaint damaged wall surfaces.
- .5 Fit several parts together, to integrate with other Work.
- .6 Uncover Work to install ill-timed Work.
- .7 Remove and replace defective and non-conforming Work.
- .8 Provide cutting and patching of all openings in non-structural elements of Work as necessary to complete installation of mechanical and electrical Work. Include complete removal and replacement of such elements as necessary to provide construction access.
- .9 Execute Work by methods to avoid damage to other Work, and which will provide proper surfaces to receive patching and finishing.
- .10 Employ original installer to perform cutting and patching for weather-exposed and moisture-resistant elements, and sight-exposed surfaces.
- .11 Cut rigid materials using masonry saw or core drill. Pneumatic or impact tools are not allowed on masonry work without prior approval.
- .12 Restore work with new products in accordance with requirements of Contract Documents.
- .13 Fit work airtight to pipes, sleeves, ducts, conduit, and other penetrations through surfaces.
- .14 At penetration of fire rated wall, ceiling, or floor construction, completely seal voids with "ULC approved firestopping material, full thickness of the construction element. Include any openings in existing building elements created by removal of existing services or equipment.
- .15 Refinish surfaces to match adjacent finishes: Refinish continuous surfaces to nearest intersection. Refinish assemblies by refinishing entire unit.

3.3 Cutting and Patching

- .1 General: Employ skilled workers to perform cutting and patching. Proceed with cutting and patching at the earliest feasible time, and complete without delay.

- .2 Cut in-place construction to provide for installation of other components or performance of other construction, and subsequently patch as required to restore surfaces to their original condition.
- .3 Existing Warranties: Remove, replace, patch, and repair materials and surfaces cut or damaged during installation or cutting and patching operations, by methods and with materials so as not to void existing warranties.
- .4 Temporary Support: Provide temporary support of work to be cut.
- .5 Protection: Protect in-place construction during cutting and patching to prevent damage. Provide protection from adverse weather conditions for portions of Project that might be exposed during cutting and patching operations.
- .6 Adjacent Occupied Areas: Where interference with use of adjoining areas or interruption of free passage to adjoining areas is unavoidable, coordinate cutting and patching according to requirements in Section 01 10 00 - Summary of Work.
- .7 Existing Utility Services and Mechanical/Electrical Systems: Where existing services/systems are required to be removed, relocated, or abandoned, bypass such services/systems before cutting to minimize interruption to occupied areas.
- .8 Cutting: Cut in-place construction by sawing, drilling, breaking, chipping, grinding, and similar operations, including excavation, using methods least likely to damage elements retained or adjoining construction. If possible, review proposed procedures with original Installer; comply with original Installer's written recommendations.
 - .1 In general, use hand or small power tools designed for sawing and grinding, not hammering and chopping. Cut holes and slots neatly to minimum size required, and with minimum disturbance of adjacent surfaces. Temporarily cover openings when not in use.
 - .2 Finished Surfaces: Cut or drill from the exposed or finished side into concealed surfaces.
 - .3 Concrete and Masonry: Cut using a cutting machine, such as an abrasive saw or a diamond-core drill.
 - .4 Excavating and Backfilling: Comply with requirements in applicable Sections where required by cutting and patching operations.
 - .5 Mechanical and Electrical Services: Cut off pipe or conduit in walls or partitions to be removed. Cap, valve, or plug and seal remaining portion of pipe or conduit to prevent entrance of moisture or other foreign matter after cutting.
 - .6 Proceed with patching after construction operations requiring cutting are complete.
- .9 Patching: Patch construction by filling, repairing, refinishing, closing up, and similar operations following performance of other work. Patch with durable seams that are as invisible as practicable. Provide materials and comply with installation requirements specified in other Sections, where applicable.
 - .1 Inspection: Where feasible, test and inspect patched areas after completion to demonstrate physical integrity of installation.
 - .2 Exposed Finishes: Restore exposed finishes of patched areas and extend finish restoration into retained adjoining construction in a manner that will minimize evidence of patching and refinishing.
 - .1 Clean piping, conduit, and similar features before applying paint or other finishing materials.
 - .2 Restore damaged pipe covering to its original condition.
 - .3 Floors and Walls: Where walls or partitions that are removed extend one finished area into another, patch and repair floor and wall surfaces in the new space. Provide an even surface of uniform finish, colour, texture, and appearance. Remove in-place floor and wall coverings and replace with new materials, if necessary, to achieve uniform colour and appearance.

- .1 Where patching occurs in a painted surface, prepare substrate and apply primer and intermediate paint coats appropriate for substrate over the patch, and apply final paint coat over entire unbroken surface containing the patch. Provide additional coats until patch blends with adjacent surfaces.
 - .4 Ceilings: Patch, repair, or rehang in-place ceilings as necessary to provide an even-plane surface of uniform appearance.
 - .5 Exterior Building Enclosure: Patch components in a manner that restores enclosure to a weathertight condition and ensures thermal and moisture integrity of building enclosure.
- .10 Clean areas and spaces where cutting and patching are performed. Remove paint, mortar, oils, putty, and similar materials from adjacent finished surfaces.

3.4 Fire Barrier Seals

- .1 Ensure fire separations are maintained as indicated on the drawings. patch and firestop all penetrations accordingly.

End of Section

PART 1 GENERAL

1.1 Section Includes

- .1 Progressive Cleaning
- .2 Final Cleaning

1.2 Project Cleanliness

- .1 Maintain Work in tidy condition, free from accumulation of waste products and debris.
- .2 Remove waste materials from site at daily regularly scheduled times or dispose of as directed by the Owner. Do not burn waste materials on site.
- .3 Clear snow and ice from access to building, bank/pile snow in designated areas only.
- .4 Make arrangements with and obtain permits from authorities having jurisdiction for disposal of waste and debris.
- .5 Provide on-site containers for collection of waste materials and debris.
- .6 Provide and use clearly marked separate bins for recycling.
- .7 Clean interior areas prior to start of finishing work and maintain areas free of dust and other contaminants during finishing operations.
- .8 Store volatile waste in covered metal containers and remove from premises at end of each working day.
- .9 Provide adequate ventilation during use of volatile or noxious substances. Use of building ventilation systems is not permitted for this purpose.
- .10 Schedule cleaning operations so that resulting dust, debris and other contaminants will not fall on wet, newly painted surfaces nor contaminate building systems.

PART 2 PRODUCTS

2.1 Products

- .1 All cleaning materials and products shall be low VOC type. Submit list of cleaning products including SDS for approval prior to commencement of cleaning operations.
- .2 Use only cleaning materials recommended by manufacturer of surface to be cleaned and recommended by cleaning material manufacturer.

PART 3 EXECUTION

3.1 Final Cleaning

- .1 When Work is Substantially Performed remove surplus products, tools, construction machinery and equipment not required for performance of remaining Work.
- .2 Remove waste products and debris other than that caused by others and leave Work clean and suitable for occupancy.

- .3 Prior to final review remove surplus products, tools, construction machinery and equipment.
- .4 Clean and polish glass, mirrors, hardware, wall tile, stainless steel, chrome, porcelain enamel, baked enamel, plastic laminate, and mechanical and electrical fixtures. Replace broken, scratched or disfigured glass.
- .5 Remove stains, spots, marks and dirt from decorative work, electrical and mechanical fixtures, furniture fitments, walls, floors and ceilings.
- .6 Clean lighting reflectors, lenses, and other lighting surfaces. Clean and/or replace lamps, light fixtures, grilles and lenses.
- .7 Vacuum clean and dust building interiors, behind grilles, louvres and screens.
- .8 Thoroughly vacuum clean interior of electrical equipment.
- .9 Wax, seal, shampoo or prepare floor finishes, as recommended by manufacturer.
- .10 Clean and seal concrete floor surfaces with non-skid matte sealer.
- .11 Inspect finishes, fitments and equipment and ensure specified workmanship and operation.
- .12 Clean equipment and fixtures to a sanitary condition; clean or replace filters of mechanical equipment.
- .13 Remove dirt and other disfiguration from exterior surfaces.
- .14 Clean and sweep roofs. Clear all drains, gutters and downspouts.
- .15 Remove debris and surplus materials from crawl areas and other accessible concealed spaces.
- .16 Remove snow and ice from access to building.
- .17 Under direction of Consultant, aim adjustable luminaires.

End of Section

PART 1 GENERAL

1.1 Section Includes

- .1 References.
- .2 Submittals.
- .3 Definitions.
- .4 Waste Management Goals for the Project.
- .5 Documents.
- .6 Waste Management Plan.
- .7 Waste Audit.
- .8 Waste Reduction Work Plan.
- .9 Materials Source Separation Program.
- .10 Disposal of Wastes.
- .11 Scheduling.
- .12 Storage, Handling and Protection.
- .13 Application.
- .14 Diversion of Materials.

1.2 References

- .1 O. Reg. 102/94, Waste Audits and Waste Reduction Work Plans.
- .2 O. Reg. 278/05, Occupational Health and Safety Act

1.3 Submittals

- .1 Make submittals in accordance with Section 01 33 00 – Submittal Procedures.
- .2 Submit a completed Waste Management Plan (WMP) including Waste Reduction Workplan (WRW) and Materials Source Separation Program description prior to project start-up.

1.4 Definitions

- .1 Waste Management Plan (WMP): Contractor's approved overall strategy for waste management including waste audit, waste reduction workplan and materials source separation program.
- .2 Waste Audit (WA): Relates to projected waste generation. Involves measuring and estimating quantity and composition of waste, reasons for waste generation, and operational factors which contribute to waste.
- .3 Waste Reduction Work Plan (WRW): Written report which addresses opportunities for reduction, reuse, or recycling of materials. WRW is based on information acquired from WA.
- .4 Materials Source Separation Program (MSSP): Consists of a series of ongoing activities to separate reusable and recyclable waste material into material categories from other types of waste at point of generation.
- .5 Waste Management Coordinator (WMC): Designate individual who is in attendance on-site, full-time. Designate, or have designated, individuals from each Subcontractor to be responsible for waste management related to their trade and for coordinating activities with WMC.
- .6 Separate Condition: Refers to waste sorted into individual types.

1.5 Waste Management Goals for the Project

- .1 The Owner has established that this Project shall generate the least amount of waste possible and that processes shall be employed that ensure the generation of as little waste as possible including prevention of damage due to mishandling, improper storage, contamination, inadequate protection or other factors as well as minimizing over packaging and poor quantity estimating.
- .2 Of the waste that is generated, the waste materials designated in this specification shall be salvaged for reuse and or recycling. Waste disposal in landfills or incinerators shall be minimized.

1.6 Documents

- .1 Maintain at job site, one copy of following documents:
 - .1 Waste Audit
 - .2 Waste Reduction Workplan
 - .3 Material Source Separation Plan

1.7 Waste Management Plan

- .1 Waste Management Plan: Within 10 calendar days after receipt of Notice of Award of Contract, or prior to any waste removal, whichever occurs sooner, submit a Waste Management Plan. The Plan shall contain the following:
 - .1 Analysis of the proposed job site waste to be generated, including the types of recyclable and waste materials generated (by volume or weight). In the case of demolition, a list of each item proposed to be salvaged during the course of the project should also be prepared
 - .2 Alternatives to Land Filling: Contractor shall designate responsibility for preparing a list of each material proposed to be salvaged, reused, or recycled during the course of the Project.
- .2 Post WMP or summary where workers at site are able to review its content.

1.8 Waste Audit

- .1 Prepare Waste Audit prior to project start-up.
- .2 Record, on Waste Audit , extent to which materials or products used consist of recycled or reused materials or products

1.9 Waste Reduction Work Plan

- .1 Prepare WRW prior to project start-up.
- .2 Reduce construction and demolition waste in compliance with O. Reg. 102/94.
- .3 Reduction will involve action to minimize quantity of waste at source. Reuse products which would become waste where practical. Recycling will involve collection and source separation at the site, of materials for use as feedstock in manufacturing of new products.
- .4 Conform to local Municipal and Regional Landfill Solid waste management requirements. Consider reduction, reuse and recycling of waste generated during construction such as dimensional lumber, clean drywall, concrete, brick, scrap metal and corrugated cardboard.

1.10 Materials Source Separation Program

- .1 The Waste Management Plan shall include a Source Separation Program for recyclable waste, and shall be in accordance with the established policies currently in place at the local Municipality, and the requirements of O. Reg. 102/94.
- .2 Prepare MSSP and have ready for use prior to project start-up.
- .3 Implement MSSP for waste generated on project in compliance with approved methods and as approved by Consultant.
- .4 Provide on-site facilities for collection, handling, and storage of anticipated quantities of reusable and/or recyclable materials.
- .5 Provide containers to deposit reusable and/or recyclable materials.
- .6 Locate containers to facilitate deposit of materials without hindering daily operations.
- .7 Locate separated materials in areas which minimize material damage.
- .8 Collect, handle, store on-site, and transport off-site, salvaged materials in separate condition.

1.11 Disposal of Wastes

- .1 Make arrangements with and obtain permits from authorities having jurisdiction for disposal of waste and debris.
- .2 Provide appropriate on-site containers for collection of waste materials and debris. Containers for volatile wastes shall be closed containers and shall be removed from site daily.
- .3 Provide and use clearly marked separate bins for recycling.
- .4 Remove waste materials from site at regularly scheduled times or dispose of as directed by Consultant. Do not burn waste materials on site.
- .5 Remove waste material and debris from site and deposit in waste container at end of each working day.
- .6 Do not permit waste to accumulate onsite.
- .7 Burying of rubbish and waste materials is prohibited.
- .8 Disposal of waste into waterways, storm, or sanitary sewers is prohibited.

1.12 Scheduling

- .1 Coordinate work with other activities at site to ensure timely and orderly progress of the Work.

1.13 Storage, Handling and Protection

- .1 Store, materials to be reused, recycled and salvaged in locations as directed by Owner.

- .2 Materials from building demolition to be salvaged or re-used are to be removed and salvaged.
- .3 Unless specified otherwise, materials for removal become Contractor's property.

PART 2 PRODUCTS

2.1 Not Used

- .1 Not used

PART 3 EXECUTION

3.1 Application

- .1 Do work in compliance with Waste Management Plan.
- .2 Handle waste materials not reused, salvaged, or recycled in accordance with appropriate regulations and codes.
- .3 Source separate materials to be reused/recycled into specified sort areas.

3.2 Designated Substances

- .1 All designated substances abatement, removal and disposal shall be completed in accordance with O. Reg 278/05 and all other applicable legislation.

3.3 Diversion of Materials

- .1 Separate materials from general waste stream and stockpile in separate piles or containers, to approval of Owner, and consistent with applicable fire regulations. Mark containers or stockpile areas. Provide instruction on disposal practices.
- .2 On-site sale of materials is not permitted.

End of Section

PART 1 GENERAL

1.1 Section Includes

- .1 Administrative procedures preceding preliminary and final inspections of Work.

1.2 References

- .1 Canadian Construction Documents Committee CCDC 2-2008, Stipulated Price Contract including Supplementary Conditions.
- .2 OAA/OGCA Document 100 - Recommended procedures regarding Substantial Performance of Construction Contracts and Completion Takeover of Projects.
- .3 The Construction Act.

1.3 Inspection and Declaration

- .1 Contractor's Inspection: The Contractor shall conduct an inspection of Work, identify deficiencies and defects, and repair as required to conform to Contract Documents. Submit duplicate copies of the deficiency list to the Owner and Consultant.
 - .1 Notify Consultant in writing of satisfactory completion of Contractor's Inspection and that corrections have been made.
 - .2 Request Consultant's review.
- .2 Consultant's Review: Consultant and Contractor will perform review of Work to identify obvious defects or deficiencies. Contractor shall correct Work accordingly.
- .3 Completion: submit written certificate that following have been performed:
 - .1 Work has been completed and inspected for compliance with Contract Documents.
 - .2 Defects have been corrected and deficiencies have been completed.
 - .3 Equipment and systems have been tested, adjusted and balanced and are fully operational.
 - .4 Certificates required by Boiler Inspection Branch, Fire Commissioner, Utility companies, TSSA and other regulatory agencies have been submitted.
 - .5 Operation of systems have been demonstrated to Owner's personnel.
 - .6 Work is complete and ready for Final Review by the Consultant.
- .4 Final Inspection: when items noted above are completed, request final review of Work by Consultant, and Contractor. If Work is deemed incomplete by the Consultant, complete outstanding items and request re-review.
- .5 Declaration of Substantial Performance: when Consultant consider deficiencies and defects have been corrected and it appears requirements of Contract have been substantially performed, make application for certificate of Substantial Performance. Refer to CCDC 2, General Conditions Article GC 5.4 - Substantial Performance of Work and the Construction Act for specifics to application.
- .6 Commencement of Lien and Warranty Periods: date of Owner's acceptance of submitted declaration of Substantial Performance shall be date for commencement for warranty period and commencement of lien period unless required otherwise by lien statute of Place of Work.
- .7 Final Payment: When Consultant considers final deficiencies and defects have been corrected and it appears requirements of Contract have been totally performed, make application for final payment. Refer to CCDC 2, General Conditions Article GC 5.7 for specifics to application.

- .8 Payment of Holdback: After issuance of certificate of Substantial Performance of Work, submit an application for payment of holdback amount in accordance with CCDC 2, General Conditions Article 5.5

PART 2 PRODUCTS

2.1 Not Used

- .1 Not used

PART 3 EXECUTION

3.1 Not Used

- .1 Not used

End of Section

PART 1 GENERAL

1.1 Section Includes

- .1 As built, samples, and specifications.
- .2 Equipment and systems.
- .3 Product data, materials and finishes, and related information.
- .4 Operation and maintenance data.
- .5 Spare parts, special tools and maintenance materials.
- .6 Warranties and bonds.
- .7 Final site survey.

1.2 Submittals

- .1 Make submittals in accordance with Section 01 33 00 – Submittal Procedures.

1.3 Submission

- .1 Prepare instructions and data using personnel experienced in maintenance and operation of described products.
- .2 At least 2 weeks prior to commencement of scheduled commissioning activities, submit 2 copies of the draft Operating and Maintenance Manuals, for Consultants review and use during the commissioning activities. After the completion of the commissioning activities, the Consultant will return to the Contractor 1 draft copy, with review comments, for revision. Submit 1 copy of the revised Operating and Maintenance for approval prior to the production of final copies. Prior to the Issuance of the Final Certificate of Completion, and within 10 working days after Substantial Performance, submit 2 copies of the final Operating and Maintenance Manuals.
- .3 Building will not be deemed ready for use unless the draft copies of the Operating and Maintenance Manuals and the "As-built" Record Documents have been submitted and reviewed by the Consultant.
- .4 Building will not be deemed ready for use unless the completed and submitted Operating and Maintenance Manuals and "As-built" Record Documents have been accepted by the Consultant.
- .5 Ensure spare parts, maintenance materials and special tools provided are new, undamaged or defective, and of same quality and manufacture as products provided in Work.
- .6 If requested, furnish evidence as to type, source and quality of products provided.
- .7 Defective products will be rejected, regardless of previous inspections. Replace products at own expense.

1.4 Format

- .1 Organize data in the form as instructional manual.
- .2 Binders: vinyl, hard covered, 3 'D' ring, loose leaf 219 x 279 mm with spine and face pockets.
- .3 When multiple binders are used correlate data into related consistent groupings. Identify contents of each binder on spine.

- .4 Cover: identify each binder with type or printed title 'Project Record Documents'; list title of project and identify subject matter of contents.
 - .5 Arrange content by Section numbers and sequence of Table of Contents.
 - .6 Provide tabbed fly leaf for each separate product and system, with typed description of product and major component parts of equipment.
 - .7 Text: manufacturer's printed data, or typewritten data.
 - .8 Drawings: provide with reinforced punched binder tab. Bind in with text; fold larger drawings to size of text pages.
 - .9 Provide 1:1 scaled CAD files in .dwg format. Provide duplicate copies on memory stick
- 1.5 Contents Each Volume
- .1 Table of Contents: provide title of project;
 - .1 Date of submission; names.
 - .2 Addresses, and telephone numbers of Consultant and Contractor with name of responsible parties.
 - .3 Schedule of products and systems, indexed to content of volume.
 - .2 For each product or system:
 - .1 List names, addresses and telephone numbers of subcontractors and suppliers, including local source of supplies and replacement parts.
 - .3 Product Data: mark each sheet to identify specific products and component parts, and data applicable to installation; delete inapplicable information.
 - .4 Drawings: supplement product data to illustrate relations of component parts of equipment and systems, to show control and flow diagrams.
 - .5 Typewritten Text: as required to supplement product data. Provide logical sequence of instructions for each procedure, incorporating manufacturer's instructions specified in Section 01 45 00 - Quality Control.
- 1.6 Occupant Manual
- .1 Submit Occupant Manual to Consultant's requirements.
 - .2 Occupant Manual to include:
 - .1 General building information.
 - .2 Building management.
 - .3 Building operations.
 - .4 Safety.
 - .5 Security.
 - .6 Environmental considerations.
 - .7 Communications.
 - .8 Contact List.
 - .9 Other/Miscellaneous.

1.7 As Builts and Samples

- .1 In addition to requirements in General Conditions, maintain at the site for Consultant one record copy of:
 - .1 Contract Drawings.
 - .2 Specifications.
 - .3 Addenda.
 - .4 Change Orders and other modifications to Contract.
 - .5 Reviewed shop drawings, product data, and samples.
 - .6 Field test records.
 - .7 Inspection certificates.
 - .8 Manufacturer's certificates.
- .2 Store record documents and samples in field office apart from documents used for construction. Provide files, racks, and secure storage.
- .3 Label record documents and file in accordance with Section number listings in List of Contents of this Project Manual. Label each document "PROJECT RECORD" in neat, large, printed letters.
- .4 Maintain record documents in clean, dry and legible condition. Do not use record documents for construction purposes.
- .5 Keep record documents and samples available for inspection by Consultant.

1.8 Recording Actual Site Conditions

- .1 Record information on set of drawings, provided by Consultant.
- .2 Record information concurrently with construction progress. Do not conceal Work until required information is recorded.
- .3 Contract Drawings and shop drawings: mark each item to record actual construction, including:
 - .1 Measured depths of elements of foundation in relation to finish first floor datum.
 - .2 Measured horizontal and vertical locations of underground utilities and appurtenances, referenced to permanent surface improvements.
 - .3 Measured locations of internal utilities and appurtenances, referenced to visible and accessible features of construction.
 - .4 Field changes of dimension and detail.
 - .5 Changes made by change orders.
 - .6 Details not on original Contract Drawings.
 - .7 References to related shop drawings and modifications.
- .4 Submit following drawings:
 - .1 Record changes in red. Mark on one set of prints and at completion of project prior to final inspection, produce electronic "as-built" records on disk using latest version of AutoCad. Annotate "AS-BUILT RECORD" in each drawing title block.
 - .2 All changes shall be shown on a separate drawing layer named "as-built".
 - .3 At least 2 weeks prior to commencement of scheduled commissioning activities, submit one copy of the draft "As-built" Project Record Documents for Consultants review and use during

the commissioning activities. After the completion of the commissioning activities, the Consultant will return to the Contractor the draft copy, with review comments, for revision. Prior to the Issuance of the Final Certificate of Completion, and within 10 working days after Substantial Performance, submit 2 copies of the final "As-built" Project Record Documents and disk of "as-built" record drawings.

- .5 Specifications: legibly mark each item to record actual construction, including:
 - .1 Manufacturer, trade name, and catalogue number of each product actually installed, particularly optional items and substitute items.
 - .2 Changes made by Addenda and change orders.
- .6 Other Documents: maintain manufacturer's certifications, inspection certifications, field test records, required by individual specifications sections

1.9 Final Survey

- .1 Submit final site survey certificate in accordance with Section 01 71 00 - Examination and Preparation, certifying that elevations and locations of completed Work are in conformance, or non-conformance with Contract Documents.

1.10 Equipment and Systems

- .1 Each Item of Equipment and Each System: include description of unit or system, and component parts. Give function, normal operation characteristics, and limiting conditions. Include performance curves, with Engineering data and tests, and complete nomenclature and commercial number of replaceable parts.
- .2 Panel board circuit directories: provide electrical service characteristics, controls, and communications.
- .3 Include installed colour coded wiring diagrams.
- .4 Operating Procedures: include start-up, break-in, and routine normal operating instructions and sequences. Include regulation, control, stopping, shut-down, and emergency instructions. Include summer, winter, and any special operating instructions.
- .5 Maintenance Requirements: include routine procedures and guide for trouble-shooting; disassembly, repair, and reassembly instructions; and alignment, adjusting, balancing, and checking instructions.
- .6 Provide servicing and lubrication schedule, and list of lubricants required.
- .7 Include manufacturer's printed operation and maintenance instructions.
- .8 Include sequence of operation by controls manufacturer.
- .9 Provide original manufacturer's parts list, illustrations, assembly drawings, and diagrams required for maintenance.
- .10 Provide installed control diagrams by controls manufacturer.
- .11 Provide Contractor's co-ordination drawings, with installed colour coded piping diagrams.

- .12 Provide charts of valve tag numbers, with location and function of each valve, keyed to flow and control diagrams.
- .13 Provide list of original manufacturer's spare parts, current prices, and recommended quantities to be maintained in storage.
- .14 Include test and balancing reports as specified in Section 01 45 00 - Quality Control
- .15 Additional requirements: as specified in individual specification sections.

1.11 Materials and Finishes

- .1 Building Products, Applied Materials, and Finishes: include product data, with catalogue number, size, composition, and colour and texture designations.
- .2 Instructions for cleaning agents and methods, precautions against detrimental agents and methods, and recommended schedule for cleaning and maintenance.
- .3 Moisture-Protection and Weather-Exposed Products: include manufacturer's recommendations for cleaning agents and methods, precautions against detrimental agents and methods, and recommended schedule for cleaning and maintenance.
- .4 Additional Requirements: as specified in individual specifications sections.

1.12 Spare Parts

- .1 Provide spare parts, in quantities specified in individual specification sections.
- .2 Provide items of same manufacture and quality as items in Work.
- .3 Spare parts as identified in individual sections are to be delivered to the Owner prior to the Contractor's application for Substantial Performance.
- .4 Receive and catalogue items. Submit inventory listing to Consultant. Include approved listings in Maintenance Manual.
- .5 Obtain receipt for delivered products and submit prior to final payment.

1.13 Maintenance Materials

- .1 Provide maintenance and extra materials, in quantities specified in individual specification sections.
- .2 Provide items of same manufacture and quality as items in Work.
- .3 Maintenance materials are to be delivered to the Owner prior to the Contractor's application for Substantial Performance.
- .4 Receive and catalogue items. Submit inventory listing to Consultant. Include approved listings in Maintenance Manual.
- .5 Obtain receipt for delivered products and submit prior to final payment.

1.14 Special Tools

- .1 Provide special tools, in quantities specified in individual specification section.
- .2 Provide items with tags identifying their associated function and equipment.
- .3 Special tools are to be delivered to the Owner prior to the application for Substantial Performance.
- .4 Receive and catalogue items. Submit inventory listing to Consultant. Include approved listings in Maintenance Manual.

1.15 Storage, Handling and Protection

- .1 Store spare parts, maintenance materials, and special tools in manner to prevent damage or deterioration.
- .2 Store in original and undamaged condition with manufacturer's seal and labels intact.
- .3 Store components subject to damage from weather in weatherproof enclosures.
- .4 Store paints and freezable materials in a heated and ventilated room.
- .5 Remove and replace damaged products at own expense and to satisfaction of Consultant.

1.16 Warranties and Guarantees

- .1 Separate each warranty or guarantee with index tab sheets keyed to Table of Contents listing.
- .2 List subcontractor, supplier, and manufacturer, with name, address, and telephone number of responsible principal.
- .3 Obtain warranties and guarantees, executed in duplicate by subcontractors, suppliers, and manufacturers, within ten days after completion of the applicable item of work.
- .4 Except for items put into use with Owner's permission, leave date of beginning of time of warranty until the Date of Substantial Performance is determined.
- .5 Verify that documents are in proper form, contain full information, and are notarized.
- .6 Co-execute submittals when required.
- .7 Retain warranties and guarantees until time specified for submittal.

1.17 Independent Specialty Engineers Sign-Off

- .1 Prior to Substantial Performance, provide copies of signed and stamped engineers review and sign-off letters stating that the work has been built in accordance with their drawings and designs. Conditional or vague letters of sign-off will not be accepted. All specialty design engineers for all sub-contractors and suppliers will be required to review the work in progress at appropriate intervals to ensure compliance with their designs and drawings and shall provide final sign-off letters. Provide copies of all field reports issued by specialty engineers. Carry all costs associated with full compliance with this requirement.

PART 2 PRODUCTS

2.1 Not Used

.1 Not used

PART 3 EXECUTION

3.1 Not Used

.1 Not used

End of Section

PART 1 GENERAL

1.1 General

- .1 Conform to the requirements of Division 1.

1.2 Related Sections

- .1 Section 01 35 43 Environmental Procedures
- .2 Section 01 56 00 Temporary Barriers and Enclosures
- .3 Section 01 74 11 Cleaning
- .4 Section 01 74 19 Construction Waste Management and Disposal

1.3 References

- .1 The National Building Code of Canada, Part 8-Safety Measures on Construction and Demolition Sites.
- .2 Ontario Regulation 102/94, Waste Audits and Waste Reduction Work Plans.
- .3 Ontario Regulation 103/94, Environmental Protection Act.
- .4 Ontario Regulation 213/07 -The Fire Code.
- .5 Ontario Regulation 232/98 - Landfilling Sites.
- .6 Ontario Regulation 278/05 -Designated Substance - Asbestos on Construction Projects and in Buildings and Repair Operations.
- .7 Ontario Regulation 347- Environmental Protection Act, General — Waste Management.
- .8 Ontario Regulation 332/12 - The Building Code.
- .9 The Workplace Health and Safety Act, and Regulations for Construction Projects.
- .10 The Contractors Health and Safety Policy.
- .11 Laws, rules and regulations of other authorities having jurisdiction.

1.4 Submittals

- .1 Make submittals in accordance with Section 01 33 00 – Submittal Procedures.
- .2 Submit detailed written schedule, methodology and proposed procedures for demolition, including a Safe Work Plan to Consultant and Owner for review prior to commencement of demolition.
- .3 Where required by authorities having jurisdiction, submit for approval drawings, diagrams or details clearly showing sequence of disassembly work or supporting structures and underpinning.
- .4 Drawings for structural elements of the demolition process including shoring, underpinning and installation of new lintels or beams in existing load bearing walls, shall bear signature and stamp of qualified professional engineer registered in the Province of Ontario.
- .5 Submit a construction waste management plan including demolition and removal procedures under provisions of Section 01 74 19.
- .6 Submit proposed dust-control measures.
- .7 Submit proposed noise-control measures.
- .8 Submit schedule of demolition activities indicating the following:
 - .1 Detailed sequence of demolition and removal work, including start and end dates for each activity.

- .2 Dates for shutoff, capping, and continuation of utility services.
- .3 If hazardous materials are encountered and disposed of, landfill records indicating receipt and acceptance of hazardous wastes by a landfill facility licensed to accept hazardous wastes.

- .9 At Project Closeout: Submit record drawings in accordance with Section 01 78 00. Identify and accurately locate capped utilities and other subsurface structural, electrical, or mechanical conditions

1.5 Permits

- .1 Obtain and pay for all permits and comply with all laws, rules, ordinances, and regulations relating to Demolition of Building and preservation of Public Health and Safety.
- .2 The Consultant will complete General Review during demolition in accordance with the Ontario Building Code. All other engineering required for shoring design and for other structural elements of the demolition work will be completed by the Contractor's own engineer and paid for by the Contractor.

1.6 Waste Management Plan

- .1 All work of this section shall be completed in accordance with the contractors approved Waste Management Plan specified in Section 01 74 19.

1.7 Definitions

- .1 Chemical Waste: Includes petroleum products, bituminous materials, salts, acids, alkalis, herbicides, pesticides, organic chemicals and inorganic wastes.
- .2 Demolition Waste: Building materials and solid waste resulting from construction, remodeling, repair, cleanup, or demolition operations that are not hazardous. This term includes, but is not limited to, asphalt concrete, Portland cement concrete, brick, lumber, gypsum wallboard, cardboard and other associated packaging, roofing material, ceramic tile, carpeting, plastic pipe, and steel. The materials may include rock, soil, tree stumps, and other vegetative matter resulting from land clearing and landscaping for construction or land development projects.
- .3 Environmental Pollution and Damage: The presence of chemical, physical, or biological elements or agents which adversely affect human health or welfare; unfavorably alter ecological balances of importance to human or animal life; affect other species of importance to humanity; or degrade the utility of the environment for aesthetic, cultural or historical purposes.
- .4 Inert Fill: A permitted facility that accepts inert waste such as asphalt and concrete exclusively for the purpose of disposal.
- .5 Inert Solids/Inert Waste: Non-liquid solid waste including, but not limited to, soil and concrete that does not contain hazardous substances or soluble pollutants at concentrations in excess of water-quality standards established by a regional water board and does not contain significant quantities of decomposable solid waste.
- .6 Landfill: A landfill that accepts non-hazardous materials such as household, commercial, and industrial waste, resulting from construction, remodeling, repair, and demolition operations. A

landfill must have a solid waste facilities permit from the Ministry of the Environment and be in conformance to O.Reg 232/98.

- .7 Recycling: The process of sorting, cleansing, treating and reconstituting materials for the purpose of using the altered form in the manufacture of a new product. Recycling does not include burning, incinerating or thermally destroying solid waste.
- .8 Remove: Remove and legally dispose of items, except those identified for use in recycling, re-use, and salvage programs.
- .9 Reuse: The use, in the same or similar form as it was produced, of a material which might otherwise be discarded.
- .10 Solid Waste: All putrescible and non-putrescible solid, semisolid, and liquid wastes, including garbage, trash, refuse, paper, demolition and construction wastes, abandoned vehicles and parts thereof, discarded home and industrial appliances, dewatered, treated, or chemically fixed sewage sludge which is not hazardous waste, manure, vegetable or animal solid and semisolid wastes, and other discarded solid and semisolid wastes. "Solid waste" does not include hazardous waste, radioactive waste, or medical waste as defined or regulated by law.

1.8 Quality Assurance

- .1 Demolition Firm Qualifications: Demolition contractor shall be an experienced firm that has successfully completed demolition Work similar to that indicated for this Project.
- .2 Regulatory Requirements: Comply with governing regulations before starting demolition. Comply with hauling and disposal regulations of authorities having jurisdiction. Obtain and pay for all permits required.
- .3 Pre-demolition Conference: Conduct a conference at Project site.
 - .1 Review the environmental goals of this Project and make a proactive effort to increase awareness of these goals among all labor forces on site.
 - .2 Review schedule and scheduling procedures.
 - .3 Review health and safety procedures.
 - .4 Review of Project conditions including review of record photographs.

1.9 Project Site Conditions

- .1 Construct safety barriers, barricades, fencing and hoarding to separate public from work areas as described in Section 01 56 00.
- .2 The Owner assumes no responsibility for the actual condition of the structures to be demolished.
- .3 Conditions existing at the time of inspection for bidding purposes will be maintained by the Owner insofar as practicable. Variations within the structures may occur by the Owner's salvage operations prior to start of demolition.

1.10 Designated Substances

- .1 Refer to Non-Intrusive Designated Substances Survey, by CHEM SOLV, dated January 8, 2018.
- .2 Should any other material not identified in the above referenced reports resembling asbestos or other hazardous substances be encountered in course of demolition work, immediately stop work

and notify the Owner's Representative. Refer to Section 01 41 00.

PART 2 PRODUCTS

2.1 Materials

- .1 Conform to requirements of Division 1, in particular, articles on Design and Safety Requirements for Temporary Work. Provide all materials necessary for temporary shoring. On completion, remove temporary materials from site.
- .2 All building materials removed from the building shall become the property of the Contractor unless specified otherwise and shall be reused in new construction or removed from the Site.
- .3 All concrete, masonry, asphalt and similar materials shall be crushed prior to disposal.

2.2 Salvage

- .1 All items of salvageable value must be salvaged.
- .2 Provide a schedule of items to be salvaged and clearly indicate which items are to be retained by Owner. Clearly identify and tag each salvageable item.
- .3 Transport salvaged items from the site as they are removed.
- .4 Items of salvageable value to the Contractor may be removed from the structure as the work progresses, if such items are not claimed by the Owner.

2.3 Reuse

- .1 Salvage and reuse materials as indicated on the drawings.

2.4 Recycle

- .1 All materials from demolition and land clearing which can be recycled through local municipal programs and which is not scheduled for salvage shall be sorted and separated in accordance with Regional, Provincial and Municipal standards and regulations.
- .2 Provide recycling receptacles for the duration of construction activities at the building site.

PART 3 EXECUTION

3.1 Examination

- .1 Survey existing conditions and correlate with requirements indicated to determine extent of demolition, salvage and recycling required.
- .2 Verify that utilities have been disconnected and capped.
- .3 Survey condition of the building to determine whether removing any element might result in a structural deficiency or unplanned collapse of any portion of the structure or adjacent structures during demolition.

- .4 Retain a licensed and qualified civil or structural engineer to provide analysis, including calculations, necessary to ensure the safe execution of the demolition work.
- .5 Perform surveys and tests as the Work progresses to detect hazards resulting from demolition activities.
- .6 Preliminary Survey:
 - .1 The Demolition Plans indicate the general extent of existing conditions based upon drawings provided by the Owner and existing site conditions. Review all areas of work to determine full extent of areas to be demolished, altered or renovated and become familiar with actual conditions and extent of work required.
 - .2 Before commencing demolition operations, examine Site and provide engineering survey to determine type of construction, condition of structure, and Site conditions. Assess strength and stability of damaged or deteriorated structures.
 - .3 Assess potential effect of removal of any part or parts on the remainder of structure before such part(s) are removed.
 - .4 Assess effects of demolition at adjacent structures and consider need for underpinning, shoring and/or bracing.
 - .5 Investigate for following conditions:
 - .1 load bearing walls and floors
 - .2 structure suspended from another
 - .3 effects of soils, water, lateral pressures on retaining or foundations walls
 - .4 presence of tanks and other piping systems
 - .5 presence of designated substances and hazardous materials.
- .7 After determining demolition methods, determine area of possible vibration. Carefully inspect beyond those adjacent areas. List potential damage areas and photograph each for record purposes before starting work.

3.2 Utilities

- .1 Contact authorities or utility companies for assistance in locating and marking services passing under, through, overhead or adjacent to structure to be demolished. Such services include:
 - .1 Electrical power lines
 - .2 Gas mains
 - .3 Communication cables
 - .4 Fibre optic cables
 - .5 Water lines.
 - .6 Drainage piping (storm and sanitary).
- .2 Before disconnecting, removing, plugging or abandoning any existing utilities serving the building:
 - .1 Notify the Owner, applicable utility companies, and local authorities having jurisdiction.
 - .2 Cut off and cap utilities at the mains on the property or in the street as required by the Owner and responsible utility company. Maintain fire protection to the existing buildings at all times.
 - .3 Remove, cut off and plug, or cap all utilities within the existing building areas to be demolished, except those designated to remain

3.3 Protection

- .1 Erect and maintain temporary protection, such as walks, fences, railings, canopies, and covered passageways, where required by authorities having jurisdiction. Maintain such areas free of snow, ice, water and debris. Lighting levels shall be equal to that prior to erection.

- .2 Provide safe access and egress from working areas using entrances, hallways, stairways or ladder runs, protected to safeguard personnel using them from falling debris.
- .3 Do not interfere with use and activities of adjacent buildings and site. Maintain free and safe passage to and from buildings.
- .4 Where demolition operations prevent normal access to adjacent properties, provide and maintain suitable alternative access.
- .5 Provide flagmen where necessary or appropriate, to provide effective and safe access to site to vehicular traffic and protection to Owner's personnel. Refer to Division 1 for safety requirements.
- .6 Protect existing site improvements, and appurtenances that are designated to remain in place.
- .7 Ensure that all necessary controls are in place at the beginning of each work period which will prevent the spread of contaminated material beyond the work area limits. Stop work immediately if there exists any possibility of the spread of contaminated materials.
- .8 Keep dust from entering existing facilities and areas of building not affected by the Work. Comply with Ministry of Health requirements regarding debris control.
- .9 Ensure scaffolds, ladders, equipment and other such equipment are not accessible to public. Protect with adequate fencing or remove and dismantle at end of each day or when no longer required.
- .10 Take precautions to guard against movement, settlement or collapse of adjacent structures, services or driveways. Be liable for such movement, settlement or collapse caused by failure to take necessary precautions. Repair promptly such damage when ordered.
- .11 If Owner considers additional bracing and shoring necessary to safeguard and prevent such movement or settlement, install bracing or shoring upon Owner's orders.
- .12 Particular attention shall be paid to prevention of fire and elimination of fire hazards which would endanger new work or existing premises.
- .13 Protect existing adjacent work against damages which might occur from falling debris or other causes due to work of this Section.
- .14 At all times protect the structure from overloading.
- .15 Provide protection around floor and/or roof openings.
- .16 Protect from weather, parts of adjoining structures not previously exposed.
- .17 Protect interiors of building parts not to be demolished from exterior elements at all times.
- .18 At end of each day's work, leave work in safe condition so that no part is in danger of toppling or falling.

3.4 Preparation

- .1 Provide all shoring and bracing required for the execution of the work.

- .2 Ensure all sedimentation controls as required are in place prior to commencement of demolition activities.
- .3 Before commencing demolition, verify that existing water, gas, electrical and other services in areas being demolished are cut off, capped diverted or removed as required. Post warning signs on electrical lines and equipment which must remain energized to serve adjacent areas during period of demolition.
- .4 Conduct demolition operations and remove materials from demolition to ensure minimum interference with roads, streets, walks, and other adjacent occupied and utilized facilities.
- .5 Do not close or obstruct streets, walks, or other adjacent occupied or utilized facilities without permission from authorities having jurisdiction. Provide alternate routes around closed or obstructed traffic ways if required by governing regulations.

3.5 Temporary Ventilation

- .1 Provide all required temporary ventilation for demolition work.

3.6 Environmental Controls

- .1 Comply with provincial and municipal regulations pertaining to water, air, solid waste, recycling, chemical waste, sanitary waste, sediment and noise pollution.
- .2 Protection of Natural Resources:
 - .1 Preserve the natural resources.
 - .2 Confine demolition activities to areas defined by public roads, easements, and work area limits indicated on the drawings.
 - .3 Water Resources: Comply with applicable regulations concerning the direct or indirect discharge of pollutants to underground and natural surface waters. Provide sedimentation control where necessary.
 - .4 Store and service construction equipment at areas designated for collection of oil wastes.
 - .5 Oily Substances: Prevent oily or other hazardous substances from entering the ground, drainage areas, or local bodies of water in such quantities as to affect normal use, aesthetics, or produce a measurable ecological impact on the area.
- .3 Dust Control, Air Pollution, and Odour Control: Prevent creation of dust, air pollution and odors.
 - .1 Use temporary enclosures and other appropriate methods to limit dust and dirt rising and scattering in air to lowest practical level.
 - .2 Store volatile liquids, including fuels and solvents, in closed containers.
 - .3 Properly maintain equipment to reduce gaseous pollutant emissions.
- .4 Noise Control: Perform demolition operations to minimize noise.
 - .1 Provide equipment, sound deadening devices, and take noise abatement measures that are necessary to comply with municipal regulations.
- .5 Salvage, Re-Use, and Recycling Procedures:
 - .1 Identify re-use, salvage, and recycling facilities.
 - .2 Develop and implement procedures to re-use, salvage, and recycle demolition materials.
 - .3 Identify materials that are feasible for salvage, determine requirements for site storage, and transportation of materials to a salvage facility.

- .4 Source-separate clean and uncontaminated demolition materials including, but not limited to the following types:
 - .1 Concrete, Concrete Block, Concrete Masonry Units (CMU), Brick.
 - .2 Metal (ferrous and non-ferrous).
 - .3 Wood.
 - .4 Glass.
 - .5 Plastics and Insulation.
 - .6 Gypsum Board.
 - .7 Porcelain Plumbing Fixtures.
 - .8 Fluorescent Light Tubes.
 - .9 Paper: Bond, Newsprint, Cardboard, Paper, Packaging Materials.
 - .10 Other materials as appropriate.

3.7 Performance

- .1 Ensure demolition work is supervised by competent foreman at all times.
- .2 Demolition shall proceed safely in systematic manner. Work on each floor level shall be complete before commencing work on supporting structure and safety of its supports are impaired. Parts of building which would otherwise collapse prematurely shall be securely shored. Walls and piers shall not be undermined.
- .3 Until acceptance, maintain and preserve active utilities traversing premises.
- .4 Provide enclosed chutes for disposal of debris from heights more than 1 storey in accordance with CAN S350-M.
- .5 Maintain safety of site by shoring below-grade-structures and excavations resulting from demolition against collapse.

3.8 Demolition

- .1 Review demolition procedures to ensure no personnel or equipment are located or working without additional safe working platforms or working surface adequate to support the operations.
- .2 Any damage caused to the adjacent buildings or properties by the neglect of the Contractor or any of his forces shall be made good at the expense of the Contractor including all costs and charges which may be claimed by the Owner for damages suffered.
- .3 Demolish in a manner to minimize dusting. Keep dusty materials wetted at all times.
- .4 Prevent movement, settlement or damage of adjacent structures, services, adjacent grades, and existing building to remain. Make good damage caused by demolition.
- .5 Demolition: Use methods required to complete Work within limitations of governing regulations and as follows:
 - .1 Locate demolition equipment throughout the building and remove debris and materials so as not to impose excessive loads on supporting walls, floors, or framing.
 - .2 Demolish concrete and masonry in sizes that will be suitable for acceptance at recycling or disposal facilities.

- .3 Remove structural framing members and lower to ground by method suitable to avoid free fall and to prevent ground impact or dust generation.
- .4 Break up and remove concrete slabs on grade in small sizes, suitable for acceptance at recycling or disposal facilities, unless otherwise shown to remain.
- .5 Remove all disconnected, abandoned utilities.
- .6 Remove all finishes, fixtures, fitments and services as indicated
- .7 Damages: Promptly repair damages to adjacent facilities caused by demolition operations.
- .8 Prevent access to excavations by means of fences or hoardings.

3.9 Selective Demolition

- .1 Carefully dismantle and remove all items in as shown and as necessary to complete the work.
- .2 Salvage items scheduled for reuse or to be handed over to the Owner.
- .3 Particular attention shall be paid to prevention of fire and elimination of fire hazards which would endanger the existing buildings.
- .4 Erect and maintain dustproof and weatherproof partitions as required to prevent spread of dust, fumes and smoke to other parts of building. Maintain fire exits. On completion, remove partitions and make good surfaces to match adjacent surfaces of building.
- .5 Where existing flooring is to be removed from floor slabs to remain, including ceramic tile flooring, carefully remove flooring, grout, adhesives, waterproofing membranes and the like down to the base slab. Patch and repair slab where damaged with concrete or acceptable leveling compound in accordance with new flooring manufacturer's instructions and ASTM F710-17. Refer to original building drawings and remove and replace existing concrete floor toppings as necessary and where required.
- .6 Return areas to condition existing prior to the start of the work unless indicated otherwise.
- .7 At exterior and interior bearing walls to be removed, include breaking out and removal of existing concrete foundations to a minimum of 200 mm below new finished floor level.

3.10 Handling of Demolished Materials

- .1 Conform to the approved Waste Management Plan.
- .2 Do not allow demolished materials to accumulate or be stored on-site for more than 5 days.
- .3 Do not burn, bury or otherwise dispose of rubbish and waste materials on project site.
- .4 Pallet and shrink-wrap materials scheduled for re-use and stockpile where directed on site.
- .5 Disposal: Transport demolished materials off Owner's property and legally reuse, salvage, recycle, or dispose of materials. Legally transport and dispose of materials that cannot be delivered to a source separated or mixed recycling facility to a transfer station or disposal facility that can legally accept the materials for the purpose of disposal.
- .6 Deliver to facilities that can legally accept new construction, excavation and demolition materials for purpose of re-use, recycling, composting, or disposal.

3.11 Cleaning

- .1 Proceed in accordance with Section 01 74 11 – Cleaning.
- .2 Clean adjacent streets and driveways of dust, dirt and materials caused by demolition operations.
- .3 Reinstate areas and existing works outside areas of demolition to conditions that existed prior to commencement of work.
- .4 Upon completion of demolition work, remove debris, trim surfaces and leave work site clean.
- .5 Video storm and sanitary sewers and jet clean where debris may have accumulated

End of Section

PART 1 GENERAL

1.1 General

- .1 Conform to the requirements of Division 1.

1.2 Related Sections

- .1 Section 03 20 00 Concrete Reinforcing
- .2 Section 03 30 00 Cast-in-Place Concrete

1.3 References

- .1 ASTM International (ASTM)
 - .1 ASTM D1751-04(2013)e1 Standard Specification for Preformed Expansion Joint Filler for Concrete Paving and Structural Construction (Nonextruding and Resilient Bituminous Types)
 - .2 ASTM D1752-04a(2013) Standard Specification for Preformed Sponge Rubber Cork and Recycled PVC Expansion Joint Fillers for Concrete Paving and Structural Construction
- .2 American Concrete Institute (ACI)
 - .1 ACI 117-10, Standard Specifications for Tolerances for Concrete Construction and Materials.
 - .2 ACI 347R-14 Guide to Formwork for Concrete
 - .3 SP-4 Formwork for Concrete
- .3 CSA International (CSA)
 - .1 CSA A23.1-14, Concrete Materials and Methods of Concrete Construction.
 - .2 CSA A23.2-14 Test Methods and Standard Practices for Concrete
 - .3 CAN/CSA S269.3-M92 (R2013) Concrete Formwork.
 - .4 CSA O86-14 Engineering Design in Wood

1.4 Submittals

- .1 Make submittals in accordance with Section 01 33 00 – Submittal Procedures.
- .2 Shop Drawings:
 - .1 Submit shop drawings showing type, extent and locations of items to be built into concrete.
 - .2 Sleeving Drawings: Submit drawings showing sleeves required through floors, roof and other structural members.
 - .3 Submit drawings showing size and spacing of conduits and piping, if requested by Consultant.
 - .4 Coordinate with other Divisions prior to submittal.
 - .5 Prior to submission to Consultant, review all submitted drawings. By this review, Contractor represents to have determined and verified field measurements, site conditions, materials, catalogue number and similar data and to have checked and coordinated each drawing with the requirements of Work and of Contract Documents. Contractor's review of each drawing shall be indicated by stamp, date and signature of a responsible person.
 - .6 At time of submission, notify Consultant in writing of any deviations in drawings from the requirements of the Contract Documents.
 - .7 Consultant will review and return submitted drawings in accordance with an agreed schedule. Consultant's review will be for conformity to design concept and for general arrangement, and shall not relieve Contractor of responsibility for errors or omissions in submitted drawings or of responsibility for meeting requirements of Contract Documents.
 - .8 Make any changes in submitted drawings which Consultant may require, consistent with Contract Documents and resubmit unless otherwise directed by Consultant. When resubmitting, notify Consultant in writing of any revisions other than those requested by Consultant.

- .9 Do not commence placing sleeves, conduits, or piping before drawings have been reviewed and Consultant's comments incorporated on drawings issued to site.
- .10 Assume responsibility for accuracy of Work. Review of submitted shop drawings does not relieve Contractor from compliance with requirements of Contract Documents.

- .3 Submit shop drawings as follows:
 - .1 4 copies for review before any Work commences.
 - .2 1 additional copy for distribution as directed by Consultant.
 - .3 1 copy to Inspection and Testing Company.

- .4 Required by Regulatory Agencies: Submit shop drawings bearing signature and seal of Professional Engineer responsible for formwork design, as may be required by regulatory Agencies. Proceed with construction of formwork only with their approval.

- 1.5 Requirements of Regulatory Agencies
 - .1 Conform to local and provincial regulations, including construction safety regulations.

- 1.6 Quality Assurance
 - .1 Obtain a copy of CSA A23.1-14/A23.2-14 and maintain on site
 - .2 Design of Formwork: Assume full responsibility for complete structural design and construction of formwork in accordance with CAN/CSA S269.3-M92 (R2013) and CAN/CSA O86-14, as applicable.
 - .1 The design and engineering of the formwork, as well as its' construction, shall be the responsibility of the Contractor.
 - .3 Formwork shall be designed for the loads and lateral pressures outlined in the ACI publication "SP-4 Formwork for Concrete" and wind pressures and allowable stresses as set down in the National Building Code and in accordance with CSA CAN3-A23.1&2. Formwork shall be of sufficient strength and rigidity to support all concrete and construction loads, taking into account proposed rate and method of pouring concrete so that the resultant finished concrete shall conform to the shapes, lines and dimensions of the members shown on the drawings.

- 1.7 Shipping, Handling and Storage
 - .1 Refer to Section 01 61 00 – Common Product Requirements.
 - .2 Protect formwork to prevent functional damage and damage to faces affecting appearance of concrete surfaces exposed to view.

- 1.8 Waste Management and Disposal
 - .1 Refer to Section 01 74 19 – Construction Waste Management and Disposal.

- PART 2 PRODUCTS
 - 2.1 Materials
 - .1 All materials shall be new, in accordance with referenced standards.

- .2 Plywood: Douglas Fir, conforming to CSA O121-08. Sound undamaged sheets finished one side, fabricated especially for use as concrete form panels, with sealed edges. Minimum 17mm thickness.
- .3 Lumber: Conforming to CSA O141-05 (R2009), with grade stamp clearly visible.
- .4 Chamfers: Cut from 19mm x 19mm wood, smooth with no open defects.
- .5 Form Ties: snap ties, with spreader washer and 25mm break back.
- .6 Void Form: Honeycomb cellular core structure manufactured from kraft fibre. Top and sides protected with wax coated corrugated board, and bottom unprotected.
- .7 Round Column Fibre Forms: Sonotube "W" Coated, by Sonoco Limited.
- .8 Joint Tape: non-staining, water impermeable, self-release.
- .9 Nails, Spikes and Staples: Galvanized, conforming to CSA B111-1974 (R2003).
- .10 Form Release Agent: Colourless mineral oil which will not stain concrete.
- .11 For concrete surfaces exposed to view, provide panels smooth and free of defects which would be reproduced as concrete blemishes.

PART 3 EXECUTION

3.1 Examination

- .1 Before starting this work, examine work done by others which affects this work.
- .2 Notify the Consultant of any conditions which would prevent proper completion of this work.
- .3 Commencement of work implies acceptance of existing conditions.

3.2 Erection

- .1 Verify lines, levels and centres before proceeding with formwork. Ensure dimensions agree with drawings.
- .2 Align joints and make watertight, to prevent leakage of cement paste and disfiguration of concrete.
- .3 Construct formwork to produce concrete with dimensions, lines and levels within tolerances specified in ACI 347R-14.
- .4 Provide formed openings where required for pipes, conduits, sleeves and other work to be embedded in and passing through concrete members.
- .5 Install chamfers at all external corners exposed to view.
- .6 Provide waterstops in accordance with manufacturer's instructions at construction joints in walls which retain earth, and wherever else indicated or detailed. Waterstops shall be continuous.
- .7 Bed mud sills on sand, gravel or crushed stone placed on unfrozen, dry, solid and stable subgrade.

- .8 Adequately brace and shore formwork to sustain loads (both concrete and working loads) applied during construction.
- .9 Be responsible for safety of the structure both before and after the removal of forms, until the concrete has reached its specified 28 day strength.
- .10 Voidform: Install voidform and place 7.5 mm thick plywood over voidform, to provide firm surface for supporting reinforcement.
- .11 Round Fibre Forms:
 - .1 At concealed locations, provide uncoated fibre form.
 - .2 Provide round fibre form where indicated for piers, equipment bases, light pole bases, fence foundation and wherever indicated or required.

3.3 Built-In Work

- .1 Form openings and build in anchors, inserts, sub-frames, key-ways, sleeves, miscellaneous metal items, reglets and similar items furnished under Work of other Sections, which are indicated on Drawings and on shop drawings of other trades, and as required for proper completion of Work.
- .2 Do not embed wood in concrete.
- .3 Anchor Bolts: Tie anchor bolts securely in position to prevent movement during concrete placing. Use template to locate bolts. Verify that bolts have specified projection above concrete.
- .4 Openings or Sleeves Not Shown on Structural Drawings:
 - .1 Obtain Consultant's written approval before forming openings of sleeves through columns and beams, or through slabs within 1800 mm of their supports.
 - .2 Obtain Consultant's written approval before forming openings or sleeves larger than 200 mm square in any location.
- .5 Embedded Pipe or Conduit Not Shown or Detailed on Structural Drawings:
 - .1 Obtain Consultant's written approval before placing conduit or pipe which would be embedded in finished structure.
- .6 Confirm that built-in items that penetrate surface waterproofing are installed to meet requirements of waterproofing trade.

3.4 Construction Joints

- .1 Form construction and expansion joints with bulkheads to ensure straight lines. Immediately before subsequent pour at construction joint, remove bulkhead and tighten forms so that concrete surfaces will be on same plane with no overlapping of concrete.
- .2 Review with Consultant proposed location and details of construction joints in walls, columns, beams and slabs.
 - .1 Construction joints shall present appearance of normal form panel joint.
 - .2 Install continuous shear key in construction joints in walls and framed floors which are 152mm or more thick.
 - .3 Provide vertical construction joints in walls at not more than 20 metres centre to centre.
 - .4 Provide waterstops in accordance with manufacturer's instructions at construction joints in walls which retain earth. Waterstops shall be continuous.

3.5 Treatment of Formwork Surfaces

- .1 Form Release Agent:
 - .1 Coat formwork with form release agent before reinforcement, anchors, accessories, and other built in items are installed.
 - .2 Do not coat plywood forms pre-treated with release agent.
 - .3 On surfaces to receive finish materials, adhesives, sealers, paint or other coatings or materials, use a compatible release agent.

3.6 Stripping of Formwork

- .1 Strip formwork on vertical surfaces when concrete has hardened sufficiently that no damage will result from stripping operations.
- .2 Do not remove plywood formwork by jerking loose or by metal pinch bars. Use wood wedges and gradually force panels loose. Leave plywood forms in place as long as possible to permit maximum shrinkage away from concrete.
- .3 Take particular care not to damage external corners when stripping formwork.
- .4 When forms are stripped during curing period, cure and protect exposed concrete in accordance with Section 03 30 00 - Cast-in-Place Concrete.

3.7 Defective Work

- .1 Movement and displacement of formwork during construction, variations in excess of specified tolerances, marked and disfigured surfaces, and failure of materials or workmanship to meet requirements of this specification, and which cannot be repaired by approved methods, will be considered defective work.
- .2 Replace defective work, as directed by Consultant.
- .3 Pay for additional inspection and testing, redesign, corrective measures, and related expenses, if work has proven to be deficient.
- .4 Reconstruct defective formwork and replace concrete and reinforcement placed in defective formwork at no additional cost.

3.8 Cleaning

- .1 Proceed in accordance with Section 01 74 11 – Cleaning.

End of Section

PART 1 GENERAL

1.1 General

- .1 Conform to the requirements of Division 1.

1.2 Related Sections

- .1 Section 03 10 00 Concrete Forming and Accessories
- .2 Section 03 30 00 Cast-in-Place Concrete
- .3 Section 04 05 19 Masonry Anchorage and Reinforcing
- .4 Section 04 22 00 Concrete Unit Masonry

1.3 References

- .1 ASTM International (ASTM)
 - .1 ASTM A143/A143M-07(2014) Standard Practice for Safeguarding Against Embrittlement of Hot-Dip Galvanized Structural Steel Products and Procedure for Detecting Embrittlement
 - .2 ASTM A1064/A1064M-17 Standard Specification for Carbon-Steel Wire and Welded Wire Reinforcement, Plain and Deformed, for Concrete
 - .3 ASTM A775/A775M-17 Standard Specification for Epoxy-Coated Steel Reinforcing Bars
- .2 American Concrete Institute (ACI)
 - .1 ACI SP-66 (04) ACI Detailing Manual.
- .3 CSA International (CSA)
 - .1 CSA A23.1-14, Concrete Materials and Methods of Concrete Construction.
 - .2 CSA A23.2-14 Test Methods and Standard Practices for Concrete
 - .3 CSA A23.3-14, Design of Concrete Structures.
 - .4 CSA G30.18-09 (R2014), Carbon Steel Bars for Concrete Reinforcement.
 - .5 CSA G40.20-13/G40.21-13 General Requirements for Rolled or Welded Structural Quality Steel/Structural Quality Steel.
 - .6 CSA W186-M1990 (R2012) Welding of Reinforcing Bars in Reinforced Concrete Construction
- .4 Reinforcing Steel Institute of Canada (RSIC)
 - .1 RSIC Reinforcing Steel Manual of Standard Practice.

1.4 Submittals

- .1 Make submittals in accordance with Section 01 33 00 – Submittal Procedures.
- .2 Shop Drawings:
 - .1 Submit shop drawings, including placing drawings and bar lists.
 - .2 Prepare placing drawings and bar lists in accordance with the American Concrete Institute (ACI) Detailing Manual, and the Reinforcing Steel Institute of Canada (RSIC) Reinforcing Steel Manual of Standard Practice, the typical details included with Contract Documents.
 - .3 Prepare placing drawings to minimum scale of 1:50.
 - .4 Submit placing drawings and bar lists sufficiently detailed and dimensioned to permit correct placement of reinforcement and accessories without reference to architectural or structural Drawings.
 - .5 Show reinforcement, including dowels, in elevation on placing drawings for wall reinforcement.
 - .6 Show concrete cover to reinforcement.
 - .7 Show location of construction joints.
 - .8 Prior to submission to Consultant, review all shop drawings. By this review, Contractor represents to have determined and verified field measurements, site conditions, materials, catalogue number and similar data and to have checked and coordinated each shop drawing

- with the requirements of Work and Contract Documents.
- .9 Review of each shop drawing shall be indicated by stamp, date, and signature of a responsible person.
 - .10 At time of submission, notify Consultant in writing of any deviations in shop drawings from requirements of Contract Documents.
 - .11 Consultant will review and return shop drawings in accordance with the agreed schedule. Consultant's review will be for conformity to design concept and for general arrangement, and shall not relieve Contractor of responsibility for errors or omissions in shop drawings or of responsibility for meeting requirements of Contract Documents.
 - .12 Make any changes in shop drawings which Consultant may require consistent with Contract Documents and resubmit unless otherwise directed by Consultant. When resubmitting, notify Consultant in writing of any revisions other than those requested by Consultant.
 - .13 Do not commence fabrication of reinforcement before drawings have been reviewed and Consultant's comments incorporated on drawings issued to fabricating shop.
- .3 Inspection Reports: Inspection and Testing Company shall submit reports of inspections and tests.
- .1 Distribute inspection reports as follows:
 - .1 2 copies to Consultant.
 - .2 1 copy to Consulting Structural Engineer
 - .3 1 copy to Contractor.
- .4 Quality Assurance Submittals:
- .1 Mill Test Report: upon request, provide Consultant with certified copy of mill test report of reinforcing steel, showing physical and chemical analysis, minimum 4 weeks prior to beginning reinforcing work.
 - .2 Upon request submit in writing to Consultant proposed source of reinforcement material to be supplied.
- 1.5 Quality Assurance
- .1 Obtain a copy of CSA A23.1 and maintain on site.
 - .2 Qualifications:
 - .1 Welding: Undertake welding of reinforcement only by a fabricator or Subcontractor approved by Canadian Welding Bureau to requirements of CSA W186.
 - .3 Source Quality Control:
 - .1 Source Quality Control may be performed by an Inspection and Testing Company appointed by Consultant.
 - .4 Review provided by Inspection and Testing Company does not relieve Contractor of his sole responsibility for quality control over Work. Performance or non-performance of Inspection and Testing Company shall not limit, reduce, or relieve Contractor of his responsibilities in complying with the requirements of the Specification.
 - .5 Identify and correlate reinforcing steel from Canadian mills with test reports for compliance with requirements specified.
 - .6 Test unidentified reinforcing steel at expense of Contractor. Perform testing for each 1 tonne or part thereof supplied for incorporation in Work.

1.6 Shipping, Handling and Storage

- .1 Refer to Section 01 61 00 – Common Product Requirements.
- .2 Deliver, handle and store materials in accordance with manufacturer's printed instructions.

1.7 Waste Management and Disposal

- .1 Refer to Section 01 74 19 – Construction Waste Management and Disposal.

PART 2 PRODUCTS

2.1 Materials

- .1 In accordance with reference standards.
- .2 Substitute different size bars only if permitted in writing by Consultant.
- .3 Bar Reinforcing Steel:
 - .1 Bars which are to be welded by arc-welding process: to CSA G30.18, Grade 400W.
 - .2 Other bars: to CSA G30.18, Grade 400R.
- .4 Plain round bars: to CSA G40.20-04/G40.21.
- .5 Epoxy Coated Bar Reinforcing Steel: to ASTM A775/A775M.
- .6 Welded Wire Fabric: to ASTM A1064/A1064M-15 and in flat sheets, not rolls.
- .7 Cold-drawn annealed steel wire ties: to ASTM A497/A497M.
- .8 Chairs, bolsters, bar supports, spacers: to CSA A23.1.
- .9 Mechanical splices: subject to approval of Consultant.

2.2 Fabrication

- .1 Fabricate reinforcing steel only in permanent fabricating shop.
- .2 Fabricate reinforcing steel in accordance with shop drawings.
- .3 Tag reinforcing bars to indicate placement as designated on shop drawings.
- .4 Splices:
 - .1 Provide splices only where specifically indicated on Drawings.
 - .2 Stagger alternate mechanical splices 750 mm apart.
 - .3 Stagger alternate end bearing splices 750 mm apart.
 - .4 Install on threaded splices, plastic internal coupler thread protector and plastic bar end thread protector.

PART 3 EXECUTION

3.1 Examination

- .1 Before starting this work, examine work done by others which affects this work.
- .2 Examine formwork to verify that it has been completed, and adequately braced in place.
- .3 Notify the Consultant of any conditions which would prejudice proper completion of this work.
- .4 Commencement of work implies acceptance of existing conditions.

3.2 Installation

- .1 Place reinforcing steel in accordance with reviewed placing drawings, typical details, and CSA A23.3.
- .2 Adequately support reinforcing and secure against displacement within tolerances permitted.
- .3 Place reinforcing steel to provide minimum spacing and proper concrete cover as noted on drawings.
- .4 Do not cut reinforcement to incorporate other Work.
- .5 Relocate or rebend bars only on written instructions of Consultant.
- .6 Tie, do not weld, reinforcement in place.

3.3 Adjusting and Cleaning

- .1 Adjust and secure reinforcement in correct position immediately before concrete is placed.
- .2 Remove contaminants which lessen bond between concrete and reinforcement.

3.4 Field Quality Control

- .1 Provide competent supervisor, with at least three years of experience in reinforcement placement, to direct placement of reinforcement.
- .2 Inspect placement of reinforcement for conformance with Drawings and Specifications, before each concrete placement, and correct as necessary.
- .3 Be aware that Consultant's periodic review of selected areas of reinforcement are for verification of conformity to design concept and general arrangement only and shall not relieve Contractor of responsibility for quality control, errors, or omissions, or conformance with requirements of Contract Documents.

3.5 Defective Work

- .1 Incorrectly fabricated, misplaced or omitted reinforcement, will be considered defective Work.
- .2 Replace or adjust defective reinforcement before concrete is placed as directed by Consultant.
- .3 Replace or strengthen concrete work which is deficient as a result of incorrectly fabricated,

misplaced, or omitted reinforcement, which was not corrected before concrete was placed.

- .4 Pay for additional inspection and testing, redesign, corrective measures, and related expenses, if Work has proven to be deficient.

3.6 Cleaning

- .1 Proceed in accordance with Section 01 74 11 – Cleaning.

End of Section

PART 1 GENERAL

1.1 General

- .1 Conform to the requirements of Division 1.

1.2 Related Sections

- .1 Section 03 10 00 Concrete Forming and Accessories
- .2 Section 03 20 00 Concrete Reinforcing
- .3 Section 04 05 19 Masonry Anchorage and Reinforcing
- .4 Section 04 22 00 Concrete Unit Masonry
- .5 Section 07 92 00 Joint Sealants

1.3 References

- .1 ASTM International (ASTM)
 - .1 ASTM C150/C150M-15 Standard Specification for Portland Cement
 - .2 ASTM C260/C260M-10a Standard Specification for Air Entraining Admixtures for Concrete
 - .3 ASTM C309-11 Standard Specification for Liquid Membrane Forming Compounds for Curing Concrete
 - .4 ASTM C330/C330M-14 Standard Specification for Lightweight Aggregates for Structural Concrete
 - .5 ASTM C494/C494M-15a Standard Specification for Chemical Admixtures for Concrete
 - .6 ASTM C881/C881M-14 Standard Specification for Epoxy-Resin-Base Bonding Systems for Concrete
 - .7 ASTM C1017/C1017M-13e1 Standard Specification for Chemical Admixtures for Use in Producing Flowing Concrete
 - .8 ASTM C1107/C1107M-14a Standard Specification for Packaged Dry, Hydraulic-Cement Grout (Nonshrink)
 - .9 ASTM D412-06a(2013) Standard Test Methods for Vulcanized Rubber and Thermoplastic Elastomers—Tension
 - .10 ASTM D624-00(2012) Standard Test Method for Tear Strength of Conventional Vulcanized Rubber and Thermoplastic Elastomers.
 - .11 ASTM D1751-04(2013)e1 Standard Specification for Preformed Expansion Joint Filler for Concrete Paving and Structural Construction (Nonextruding and Resilient Bituminous Types)
 - .12 ASTM D1752-04a(2013) Standard Specification for Preformed Sponge Rubber Cork and Recycled PVC Expansion Joint Fillers for Concrete Paving and Structural Construction
 - .13 ASTM D2240-05(2010) Standard Test Method for Rubber Property—Durometer Hardness
- .2 American Concrete Institute (ACI)
 - .1 ACI 117-10, Standard Specifications for Tolerances for Concrete Construction and Materials.
 - .2 ACI 232.1R-12, Use of Raw or Processed Natural Pozzolans in Concrete
- .3 Canadian Standards Association (CSA International)
 - .1 CSA A3000-13 Cementitious Materials Compendium (Consists of A3001, A3002, A3003, A3004 and A3005), Includes Update No. 1 (2014), Update No. 2 (2014), Update No. 3 (2014)
 - .2 CSA A23.1-14 Concrete Materials and Methods of Concrete Construction
 - .3 CSA A23.2-14 Test Methods and Standard Practices for Concrete.
 - .4 CSA A283-06 (R2011), Qualification Code for Concrete Testing Laboratories.
- .4 Ontario Provincial Standard Specifications (OPSS)
 - .1 OPSS 1010, Material Specification for Aggregates - Granular A, B, M and Select Subgrade Material.
 - .2 OPSS 1212, Material Specification for Hot-Poured Rubberized Asphalt Joint Sealing Compound.

1.4 Submittals

- .1 Make submittals in accordance with Section 01 33 00 – Submittal Procedures.
- .2 Samples: Submit for inspection, material samples of specified mix designs.
- .3 Concrete Mix Designs:
 - .1 Submit concrete mix designs for review; when optimum bulk density of aggregates is specified, provide supporting evidence of compliance with requirements.
 - .2 Review of mix design does not relieve Contractor from responsibility for compliance with Contract Documents.
 - .3 Provide certification that mix proportions selected will produce concrete of specified quality and yield and that strength will comply with CSA A23.1-14, Clause 7. Mix design shall be adjusted to prevent alkali aggregate reactivity problems.
 - .4 Provide certification that plant, equipment, and all materials to be used in concrete comply with the requirements of CSA A23.1-14.
 - .5 Submit mix design for each type of concrete. Specify intended use for each mix design.
 - .6 Submit written requests for use of admixtures not specified, for site mixing of concrete, and for use of bonding agents.
 - .7 Submit in writing, proposed method of in-situ strength testing.
 - .8 Review of submittals by the Consultant is for the sole purpose of ascertaining conformance with the general design concept. This review does not mean approval of detail design inherent in submittals, the responsibility for which remains with the Contractor submitting same. Contractor is responsible for conditions to be confirmed and correlated at the job site, for information that pertains solely to the fabrication, or to techniques of construction and installation, and for co-ordination of work of all trades.
- .4 Inspection Reports: Inspection and Testing Company shall:
 - .1 Submit written reports of inspection and tests.
 - .2 Distribute reports as follows:
 - .1 2 copies to Consultant;
 - .2 1 copy to Consulting Structural Engineer;
 - .3 1 copy to Contractor.
 - .3 On concrete cylinder test reports, include:
 - .1 Specific location of concrete represented by sample
 - .2 Design strength.
 - .3 Unit weight of sample
 - .4 Class of exposure
 - .5 Aggregate size and mixtures incorporated
 - .6 Date, hour and temperature at time sample taken
 - .7 Percentage air content
 - .8 Test strength of cylinder
 - .9 Type of failure if test fails to meet specification.

1.5 Quality Assurance

- .1 Obtain a copy of CSA A23.1-14/A23.2 and maintain on site.
- .2 Pre-Construction Conference:
 - .1 At least 35 days prior to the start of concrete construction schedule, conduct a meeting to review proposed mix designs and to discuss detailed requirements of the proposed concrete operations. Review requirements for submittals, coordination, and availability of materials.

- Establish work progress and sequencing schedules and procedures for material testing, inspection and certifications.
- .3 Source Quality Control:
 - .1 Both source quality control, and field quality control specified in Article 1.5.4, may be performed by an Inspection and Testing Company appointed by Consultant.
 - .2 Review provided by Inspection and Testing Company does not relieve the Contractor of his sole responsibility for quality control over Work. Performance or non- performance of Inspection and Testing Company shall not limit, reduce, or relieve Contractor of his responsibilities in complying with the requirements of the Specification.
 - .3 Inspection and Testing Company shall be certified under CSA A283, Qualification Code for Concrete Testing Laboratories, for Category 1 Certification.
 - .4 Payment for specified Work performed by Inspection and Testing Company will be made from Cash Allowance.
 - .5 Payment for additional tests (including testing of structure and its performance and load testing) required by changes of materials or mix design requested by Contractor, and failure of completed Work to meet specified requirements, shall be made at Contractor's expense.
 - .6 Perform Work of source quality control in accordance with CSA A23.2 and to include:
 - .1 Verification that ready-mix supplier is qualified to supply concrete in accordance with Specification.
 - .2 Review of proposed concrete mix designs.
 - .3 Sampling, inspection, and testing of materials as may be required.
 - .4 Field Quality Control:
 - .1 Inspection and Testing Company, when appointed as specified for Source Quality Control, shall perform sampling, inspection and testing of concrete work at site.
 - .2 Perform sampling, inspection and testing in accordance with CSA A23.2, and to include:
 - .1 Making of standard slump tests.
 - .2 Obtaining of three standard specimens for strength tests from each 100 m of concrete, or fraction thereof, of each mix design of concrete placed in any one day. In addition, for slabs-on-grade, obtain beam specimens for determination of modulus of rupture.
 - .3 Verification that test specimens are stored within an enclosure, maintained at specified temperatures.
 - .4 Making compression tests of each set of three specimens, one at 7 days and two at 28 days; modulus of rupture tests at 90 days.
 - .5 Verification of air content of air-entrained concrete.
 - .1 For Class of exposure F-1, and C-2, test at frequency in accordance with CSA A23.1.
 - .2 Make first test before placing any concrete.
 - .3 After stable air content has been established, frequency of tests will be determined by Consultant.
 - .4 For other Classes of exposure, test at time of obtaining strength test specimens.
 - .3 Inspection for Tolerances:
 - .1 Confirm that concrete work meets specified tolerance requirements.
 - .2 Use the elevation survey records of elevations of finished concrete surfaces specified in Section 03 10 00 and this section as basis for judging compliance.
 - .3 Use approved aluminum straightedge to judge compliance with specified slab tolerances, except use dipstick equipment where F-number tolerance is specified.
 - .4 Slabs-on-Grade:
 - .1 Observe application of curing compound to sample slab, recording rate of application.
 - .2 Monitor on a random basis acceptable to the Consultant, that slab is being saw cut before slab temperature starts to fall.

- .3 Qualifications: Floor finishing shall be undertaken only by contractors with at least 10 years of experience.
- .4 Sample of Finish Flooring:
 - .1 Finish an area of floor slab where directed by Consultant to provide sample of finish for approval.
 - .2 Protect new sample area until finish is approved.
 - .3 If liquid membrane curing compound is to be used on Project, determine and apply correct quantity required to meet rate of coverage recommended by manufacturer for measured test area.
 - .4 Approved sample will provide standard by which subsequent finishing will be judged and will be incorporated into Work.

1.6 Tolerances

- .1 In accordance with ACI 117-10 and CSA A23.1-14.
- .2 Difference between elevation of high point and low point in specified area not to exceed:
 - .1 In any bay up to 100 m²: 12 mm.
 - .2 In any bay up to 400 m²: 25 mm.
- .3 Straightedge method: Finish floor slabs to meet following tolerances when measured at 72 +/- 12 hours after completion of floor finishing, before shores are removed from formed slabs, by placing a freestanding unlevelled straight edge anywhere on slab and allowing it to rest on two high points. Gap between straightedge placed on two high points and slab not to exceed:
 - .1 3 metre straightedge: 8 mm (Class A).
 - .2 2 metre straightedge: 4 mm.

1.7 Shipping, Handling and Storage

- .1 Refer to Section 01 61 00 – Common Product Requirements.

1.8 Job Conditions

- .1 Protect floor slabs, and concrete surfaces exposed to view or on which finishes are to be applied, from grease, oil, and other soil which will affect the appearance of the concrete or impair the bond of finish material.
- .2 Environmental Conditions: In addition to Cold Weather and Hot Weather Requirements of CSA A23.1-14, the following shall apply to Work of this Section:
 - .1 Provide protection or heat, or both, so that temperature of concrete at surfaces is maintained at not less than 21°C for three days after placing, not less than 10°C for the next two days and above freezing for the next two days.
 - .2 Do not permit alternate freezing and thawing for fourteen days after placing.
 - .3 Vent exhaust gases from combustion type heaters to atmosphere outside protection enclosures.
 - .4 Provide protection to maintain concrete continuously moist during curing period.
 - .5 For field cured cylinders representing strength development of in-situ concrete, provide same specified hot and cold weather protection for storage of each concrete compression specimen as for concrete from which it was taken, until it is sent to testing laboratory.
 - .6 Do not place concrete during rain. Should rain commence during placing, cover freshly placed concrete.
 - .7 Do not place bonded toppings on rough slabs that are less than 15° C.

- .8 Do not grout at ambient air temperatures or concrete surface temperatures less than 5° C, or when temperature is forecast to fall to less than 5°C within 24 hours of grouting.
- .9 Do not apply sealants at ambient air temperatures or concrete surface temperatures less than 5° C.

1.9 Project Records

- .1 Maintain record of all concrete pour related to time, date, delivery slip serial number and location of each concrete pour and identify related test cylinders. Keep records on site until project is completed.
- .2 Delivery Records: File duplicate copies of concrete delivery slips on which shall be recorded: supplier, serial number of slip, date, truck number, contractor, Project, Class of exposure, cementing materials content, air content, volume in load, and time of first mixing of aggregate, cementing materials and water.
- .3 Record Drawings:
 - .1 Record on a set of Drawings:
 - .1 founding elevations of all footings
 - .2 variations of foundation Work from that indicated on Drawings.
 - .2 Make record drawings available for Consultant's inspection at all times.

1.10 Waste Management and Disposal

- .1 Refer to Section 01 74 19 – Construction Waste Management and Disposal.

PART 2 PRODUCTS

2.1 Materials

- .1 To meet specified requirements of referenced Standards.
- .2 Cement:
 - .1 Portland Cement: to ASTM C150/C150M.
 - .2 Cementitious Hydraulic Slag: to ACI 232.1R
- .3 Fine Aggregate: For slabs-on-grade, fineness modulus of fine aggregate to be between 2.7 and 3.1.
- .4 Coarse Aggregates:
 - .1 20 mm to 5 mm (No. 4 sieve) except as specified below.
 - .2 For slabs-on-grade 125 mm and thicker: 40 mm to 5 mm (No. 4 sieve); combine at least two of the single sizes specified in Table 5 Group II of CSA A23.1, one of which is to be 40 mm, to obtain maximum bulk density (unit weight) and optimum grading, in accordance with an approved procedure.
 - .3 For slabs-on-grade: Abrasion loss not to exceed 35%. Petrographic number of aggregate not to exceed 125 when tested in accordance with ASTM C295/C295M-12 Standard Guide for Petrographic Examination of Aggregates for Concrete.
 - .4 For toppings 50 mm thick and less and for slabs over open web steel joists: 12 mm to 5 mm (No. 4 sieve).
- .5 .Admixtures:

- .1 Conform to Reference Standards for chemical and air-entraining admixtures.
- .2 Provide only admixtures that are free of chlorides.
- .3 When requested, provide evidence acceptable to Consultant that superplasticizer does not increase shrinkage of concrete.

- .6 Premoulded Expansion Joint Filler:
 - .1 Asphalt impregnated fibreboard conforming to ASTM D1751, sizes indicated on drawings.

- .7 Curing-Sealing Compound: Membrane curing-sealing compound formulated from chlorinated rubber resins, or acrylic emulsion, solvent free for use in occupied buildings, to ASTM C309, type 1.
 - .1 Basis-of-Design Product: Subject to compliance with requirements, provide Euclid Chemical Company; Floor Coat. or a comparable product by one of the following:
 - .1 BASF Corporation - Construction Systems.
 - .2 Sika Corporation
 - .3 W.R. Meadows
 - .2 For areas which will be exposed to sunlight:
 - .1 Diamond Clear by Euclid.

- .8 Bonding Agent: To ASTM C881/C881M-10, 100% reactive, 2 component, low viscosity, high modulus bonding adhesive.

- .9 Saw Cut Filler: Semi-rigid flexible epoxy joint filler shall be a two-component, pourable, moisture insensitive formulation and possess the following characteristics:
 - .1 Compliance to ACI 302.1R for joint fillers used in control and construction joints.
 - .2 Solids, % by weight, ASTM D1259-06(2012): 100%.
 - .3 Tensile adhesion to concrete 24° C, ASTM D5329-09: 290 psi.
 - .4 Shore D Hardness (7 days), ASTM D2240 - 05(2010): 60.
 - .5 Shore A Hardness (7 days), ASTM D2240 - 05(2010): 95.
 - .6 Tensile Strength, ASTM D638-10.
 - .1 24° C, (3 days): 660 psi.
 - .2 24° C, (7 days): 770 psi.
 - .7 Elongation, ASTM D638-10.
 - .1 24° C, (3 days): 72%.
 - .2 24° C, (7 days): 53%
 - .8 Water Absorption 24° C (24 hrs.), ASTM D570-98(2010)e1: 0.56% by weight.

- .10 Sealant: Refer to Section 07 92 00 – Joint Sealants

- .11 Mechanical Anchors: 'Kwik' Bolts, 'Cinch' Anchors or Parabolts.

2.2 Concrete Mixes

- .1 Ready Mix, with 28 day compressive strength as indicated on Drawings.
- .2 Design concrete mix in conformance with CSA A23.1-14, Tables 1, 2, 5 (Alternative 1) and 17, and as follows. Provide concrete meeting water/cementing materials ratio and air content of Table 14 in accordance with Class of exposure specified in following sub-paragraphs, and minimum strength specified on Drawings. Note that concrete designed in accordance with water/cementing materials ratio of Table 14 may yield strength exceeding minimum strength specified on Drawings.
 - .1 Class of exposure C-2 with 25 percent Portland cement replaced with cementitious hydraulic slag: for pavements, sidewalks, curbs and gutters.
 - .2 Class of exposure F-2 with 25 percent Portland cement replaced with cementitious hydraulic slag: for grade beams.

- .3 Slabs-on-Grade:
 - .1 Use type 20 Portland cement, or replace 35 percent type Portland cement with cementitious hydraulic slag.
 - .2 When mean daily temperature exceeds 25°C at time of placement, replace 25 percent of type 20 cement, or 50 percent of type 10 cement, with cementitious hydraulic slag.
 - .3 Use water/cementing materials ratio 0.45 maximum.
 - .4 Use aggregates specified in paragraphs 2.1.3.
 - .5 Cementing materials content 325 kg/m.
 - .6 Modulus of rupture 3.5 MPa average, 3.0 MPa minimum.
 - .7 Slump at delivery, before addition of superplasticizer, 50 mm; add superplasticizer, not water, to bring slump to level acceptable to floor finisher for placement.
- .4 Interior Concrete, other than specified above, and not exposed to freezing and thawing or the application of deicing chemicals: select water/cementing materials ratio and cementing materials content on basis of strength, workability, and finishing requirements.
- .3 Submit evidence, and material samples, if requested, acceptable to the Inspection and Testing Company, to verify that the proposed concrete mix design will produce specified quality of concrete.
- .4 List all proposed admixtures in mix design submission. Do not change or add admixtures to approved design mixes without Consultants approval.
- .5 Concrete Weight: Air dry unit weight: minimum 2,300 kg/m; adjusted proportionally for maximum air content listed in CSA A23.1-14, Clause 15, Table 10.

2.3 Admixtures

- .1 Chemical Admixture: Incorporate water-reducing admixture, type WN, in all concrete.
- .2 Air Entraining Agent: Incorporate air-entraining agent in addition to chemical admixture in concrete of relevant Class of exposure, in accordance with CSA A23.1-14, Clause 15, Table 10.
- .3 Chloride: Do not use calcium chloride or admixtures containing chloride in concrete.

2.4 Premixed Grout

- .1 Non-Shrink Metallic: Non-catalyzed metallic grout to ASTM C1107/C1107M, Compressive strength at 28 days: 48 MPa.
- .2 Non-Shrink, Non Stain, Non-Metallic: to ASTM C1107/C1107M. Compressive strength at 28 days: 59 MPa.
- .3 Flowable Grout: High-tolerance Non-shrink, Non-metallic shrinkage compensating grout to ASTM ASTM C1107/C1107M. Compressive strength at 28 days: 59 MPa.

PART 3 EXECUTION

3.1 Examination

- .1 Before starting this work, examine work done by others which effects this work.
- .2 Notify Consultant of any condition which would prejudice proper completion of this work.

- .3 Commencement of work implies acceptance of existing conditions.
- .4 Confirm that surfaces on which concrete is to be placed are free of frost and water before placing.
- .5 Confirm that reinforcement, dowels, control joints, inserts and all other built in work are in place and secured.

3.2 Treatment of Formed Surfaces

- .1 Conform to the requirements of CSA A23.1, and as additionally specified herein.
- .2 Treat concrete surfaces which will be exposed or painted in the completed building to provide a "Smooth Rubbed Finish" in accordance with CSA A23.1, uniform in colour and texture.
- .3 Plugs at Recessed Ties:
 - .1 Clean tie holes to remove all foreign matter.
 - .2 Coat plugs by dipping in adhesive and insert in hole.
 - .3 Remove excess adhesive immediately with thinner which will not stain concrete, as recommended by manufacturer.
- .4 Obtain Consultant's approval of finished exposed concrete and grind or otherwise correct to the satisfaction of the Consultant.

3.3 Placing Concrete

- .1 Place concrete in accordance with requirements CSA A23.1.
- .2 Notify Consultant and inspection and testing firm at least 24 hours prior to commencement of concrete placing operation and 24 hours before wall forms are closed in.
- .3 Do not place concrete in water or open frozen surfaces.
- .4 Remove contaminants which lessen concrete bond to reinforcement before concrete is placed.
- .5 Maintain accurate records of cast in place concrete items. Record date, location of pour, quantity, air temperature and test samples taken.
- .6 Ensure that reinforcement, inserts, embedded items, formed expansion joints and the like, are not disturbed during concrete placement.
- .7 Provide construction joint as indicated on the drawings. Ensure dowels are adequately anchored and placed at right angles to the joint before placing concrete.
- .8 Place floor slabs to depth indicated on the drawings with 25 MPa minimum concrete unless otherwise noted on drawings but consistent with minimum cement content specified for exposed floors in this specification.
- .9 Sloping Surfaces and Slabs: commence concrete placement at bottom of sloping surfaces.
- .10 Obtain Geotechnical Engineer's confirmation that thickness, elevation and compaction of sub-grade meets specifications before placing concrete.

3.4 Finishing Concrete

- .1 Perform finishing operations on plastic concrete surfaces in accordance with CSA A23.1-14, and as specified herein.
- .2 Refer to the drawings for floor finishes and coverings.
- .3 Screed the top of rough floor slabs to an even level or sloping surface at the proper elevation to receive the finish or topping specified on the drawings and in finish schedule.
- .4 Provide a smooth steel trowel finish on all areas scheduled to receive a covering, or painted finish.
- .5 Exposed Floor Surfaces: Provide hard, smooth, dense, steel trowelled surface, free from blemishes, and of uniform appearance.
- .6 Non-slip Surfaces: Provide swirl trowel or broom finish of texture acceptable to Consultant.
- .7 Curb Edging: Finish external corners of curbs rounded and smooth.

3.5 Curing

- .1 Cure concrete in accordance with CSA A23.1-14, and as specified herein.
- .2 Curing Compound Method:
 - .1 Use curing and sealing compound specified except:
 - .1 On surfaces to receive epoxy or similar paint finish.
 - .2 On surfaces to which architectural finishes will be adhered, the adhesives for which are incompatible with the curing compound.
 - .3 Select acrylic water compound except that if ambient conditions extend drying time unduly and if area is well ventilated and unoccupied by other workers, solvent based compound may be used.
 - .4 Apply curing compound in accordance with manufacturer's instructions, increasing application rate as necessary to cover surface completely.
 - .5 Curing Blanket or Wet Burlap Method: For e finished concrete surfaces that will be exposed to freezing and thawing or deicing chemicals:
 - .1 Cover with curing blanket or wet burlap overlaid with 0.102 mm thick polyethylene and maintain in place for the additional curing for durability period in accordance with CSA A23.1-14 but in no case for less than 7 days.
 - .2 Wet blanket or burlap regularly to maintain in moist condition. Do not allow to dry out.
 - .6 Cure finished concrete surface with an approved curing and sealing compound which will leave the surface with a uniform appearance and with a minimum of discolouration after drying. Ensure that the curing compound will be compatible with the architectural finishes or adhesives for finishes to be applied later. Apply the compound in strict accordance with the manufacturer's instructions.
 - .7 Protect surface which will be exposed to direct sunlight during the curing period, with a light coloured, laminated waterproof paper immediately after the curing and sealing compound has hardened sufficiently for the paper to be placed without damage to the sealed surface. Lap the paper a minimum of 100 mm and seal the laps. Leave the paper in place for at least seven days.

3.6 Grouting

- .1 Mix prepackaged grout with water in accordance with manufacturer's printed instructions.
- .2 Dampen concrete surfaces immediately before installing grout.
- .3 Use non-shrink and shrinkage-compensating grouts only when grout will be contained against expansion and self-disintegration.
- .4 Slope grout beyond edge of plate at 45 degrees.
- .5 Provide same environmental protection and curing as specified for concrete.

3.7 Joint Sealant

- .1 Apply sealant to thoroughly dry surfaces only, at ambient air temperatures above 5°C.
- .2 Provide sealant on top of joint filler with a polyethylene bond breaker between joint filler and joint sealant applied in accordance with manufacturer's direction.
- .3 Confirm that preformed joint filler and backer rod are compatible with sealant.
- .4 Caulk joints in accordance with the following:
 - .1 Do not commence joint preparation until concrete is at least 28 days old.
 - .2 Thoroughly clean sides of joints with mason's router, or power saw, equipped with double blade where necessary to suit joint width.
 - .3 Blow clean with compressed air with oil trap on line, or vacuum clean.
 - .4 Install backer rod of diameter 25 percent greater than joint width, and type recommended by sealant manufacturer to be compatible with sealant. Locate backer rod to provide for sealant depth of one-half joint width, but not less than 12 mm.
 - .5 Prime joint if required, as recommended by sealant manufacturer.

3.8 Defective Work

- .1 Variations in excess of specified tolerances and marked and disfigured surfaces that cannot be repaired by approved methods will be considered defective work.
- .2 Replace or modify concrete that is out of place or does not conform to lines, detail or grade as directed by the Consultant.
- .3 Replace or repair defectively placed or finished concrete as directed by the Consultant.
- .4 Testing and Replacement of Deficient Concrete in Place:
 - .1 Pay for additional testing and related expenses if concrete has proven to be deficient.
 - .2 Replace or strengthen deficient concrete work as directed by the Consultant, and pay for all testing and related expenses for replaced work until approved by the Consultant.

3.9 Cleaning

- .1 Proceed in accordance with Section 01 74 11 – Cleaning.
- .2 Clear away from the building site excess and waste materials and debris resulting from Work of this Section.

End of Section

PART 1 GENERAL

1.1 General

- .1 Conform to the requirements of Division 1.

1.2 Related Sections

- .1 Section 04 22 00 Concrete Unit Masonry

1.3 References

- .1 Canadian Standards Association (CSA)
 - .1 CAN/CSA-A371-04 (R2014) Masonry Construction for Buildings.
 - .2 CSA-S304.1-04 Masonry Design for Buildings (Limit States Design)
 - .3 CSA G30.3-M1983 (R1998) Cold-Drawn Steel Wire for Concrete Reinforcement.
 - .4 CSA G30.18-09 (R2014) Carbon Steel Bars for Concrete Reinforcement
 - .5 CSA W186-M1990 (R2016) Welding of Reinforcing Bars in Reinforced Concrete Construction
 - .6 CSA A23.1-14/A23.2-14 Concrete Materials and Methods of Concrete Construction / Test Methods and Standard Practices for Concrete
- .2 American Concrete Institute (ACI)
 - .1 Detailing Manual
- .3 Reinforcing Steel Institute of Canada (RSIC)
 - .1 Reinforcing Steel Manual of Standard Practice

1.4 Submittals

- .1 Make submittals in accordance with Section 01 33 00 – Submittal Procedures.
- .2 Submit the following samples:
 - .1 Two of each type of masonry reinforcing and connector specified.
- .3 Product Data: Submit manufacturer's printed product literature, specifications and data sheets.
- .4 Shop Drawings:
 - .1 Submit shop drawings for all masonry reinforcing. Include placing drawings, bar lists and details. Indicate clearly reinforcing bar sizes, spacing, bending details, lap details, dowels to adjacent construction location and quantities of reinforcement and connectors.
 - .2 Prepare placing drawings and bar lists in accordance with the American Concrete Institute (ACI) Detailing Manual, and the Reinforcing Steel Institute of Canada (RSIC) Reinforcing Steel Manual of Standard Practice, the typical details included with Contract Documents.
 - .3 Prepare placing drawings to minimum scale of 1:50.
 - .4 Submit placing drawings and bar lists sufficiently detailed and dimensioned to permit correct placement of reinforcement and accessories without reference to architectural or structural Drawings.
 - .5 Show reinforcement, including dowels, in elevation on placing drawings for wall reinforcement.
 - .6 Show cover to reinforcement
 - .7 Show location of construction joints.
 - .8 Prior to submission to Consultant, review all shop drawings. By this review, Contractor represents to have determined and verified field measurements, site conditions, materials, catalogue number and similar data and to have checked and coordinated each shop drawing with the requirements of Work and Contract Documents. Contractor's review of each shop

- drawing with the requirements of Work and Contract Documents. Contractor's review of each shop drawing shall be indicated by stamp, date, and signature of a responsible person.
- .9 At time of submission, notify Consultant in writing of any deviations in shop drawings from requirements of Contract Documents.
 - .10 Consultant will review and return shop drawings in accordance with an agreed schedule. Consultant's review will be for conformity to design concept and for general arrangement, and shall not relieve Contractor of responsibility for errors or omissions in shop drawings or of responsibility for meeting requirements of Contract Documents.
 - .11 Make any changes in shop drawings which Consultant may require consistent with Contract Documents and resubmit unless otherwise directed by Consultant. When resubmitting, Contractor shall notify Consultant in writing of any revisions other than those requested by Consultant.
 - .12 Do not commence fabrication of reinforcement before drawings have been reviewed and Consultant's comments incorporated on drawings issued to fabricating shop.

1.5 Design Criteria

- .1 Non-conventional Masonry Connectors
 - .1 Deflection: maximum 2.0 mm, including free play when acted upon by 0.45 kN lateral load, in all possible positions of adjustment.
 - .2 Positive restraint at position of maximum adjustment.
- .2 Multi-component Ties - Free Play: Maximum 1.2 mm, when assembled in any possible configuration.

1.6 Shipping, Handling and Storage

- .1 Refer to Section 01 61 00 – Common Product Requirements.
- .2 Deliver, handle and store materials in accordance with manufacturer's printed instructions.

1.7 Waste Management and Disposal

- .1 Refer to Section 01 74 19 – Construction Waste Management and Disposal.

PART 2 PRODUCTS

2.1 Materials

- .1 All metal components: hot dipped zinc galvanized to CSA-S304 unless otherwise indicated.
- .2 Bar Reinforcement: To CSA-A371 and CSA G30.18, grade 400R, deformed billet steel bars.
- .3 Wire Reinforcement: To CSA-A371 and CSA G30.3.
 - .1 Interior walls: hot dipped galvanized to CSA-S304
 - .1 4.76 mm wire diameter hot dipped galvanized to CSA-S304 for interior bearing walls.
 - .2 3.66 mm wire diameter bright wire finish, standard duty for interior non-bearing walls and partitions
 - .3 Truss Type: Blok-Trus BL-30 by Blok-Lok Ltd. for non-vertically reinforced walls
 - .4 Ladder Type: Blok-Trus BL-10 by Blok-Lok Ltd. for vertically reinforced walls

- .4 Equivalent products as manufactured by the following manufacturer's may be used subject to submission and acceptance by the Consultant of technical data:
 - .1 Dayton Superior Dur-O-Wall
 - .2 Hohmann and Barnard Inc.

2.2 Fabrication

- .1 Fabricate reinforcing in accordance with CSA-A23.1 and Reinforcing Steel Manual of Standard Practice by the Reinforcing Steel Institute of Ontario.
- .2 Obtain Consultant's approval for locations of reinforcement splices other than shown on placing drawings.
- .3 Upon approval of Consultant, weld reinforcement in accordance with CSA W186.
- .4 Ship reinforcement clearly identified in accordance with drawings.

PART 3 EXECUTION

3.1 Installation

- .1 Install masonry anchors in accordance with CSA-A370, CSA-A371, CSA-A23.1 and CSA3-S304 unless indicated otherwise.

3.2 Reinforcement

- .1 Unless otherwise noted, all masonry walls shall be reinforced with joint reinforcement.
- .2 Reinforcement shall be installed in the first and second bed joints, 200 mm apart immediately above lintels and below sill at openings, and in bed joints at 400 mm vertical intervals elsewhere. Reinforcement in the second bed joint above or below openings shall extend two feet beyond the jambs. All other reinforcement shall be continuous except that it shall not pass through vertical masonry control joints. Side rods shall be lapped at least 150 mm at splices.
- .3 Use prefabricated corner and tee sections for continuous reinforcement at corners and intersecting walls.
- .4 Vertical reinforcement shall have a minimum clearance of 13 mm from the masonry and not less than one bar diameter between bars.
- .5 All block cores containing vertical reinforcing and/or anchor bolts shall be solidly filled with non-shrink grout.
- .6 Place reinforcement and ties in grout spaces prior to grouting.
- .7 Cleanouts: Provide cleanouts in the bottom course of masonry for each grout pour when the grout pour height exceeds 1.5 m.
- .8 Construct cleanouts so that the space to be grouted can be cleaned and inspected. In solid grouted masonry, space cleanouts horizontally a maximum of 800 mm on center.

.9 Construct cleanouts with an opening of sufficient size to permit removal of debris. The minimum opening dimension shall be 76 mm.

.10 After cleaning, close cleanouts with closures braced to resist grout pressure.

3.3 Bonding and Tying

.1 Install masonry connectors in accordance with CSA-A370, CSA-A371, CSA-A23.1 and CSA3-S304 unless indicated otherwise.

.2 Bond walls of two or more wythes using seismic connectors and ladder type reinforcement in accordance with NBC CSA-S304, CSA-A371 and as indicated.

.3 Tie masonry veneer to backing in accordance with NBC, CSA-S304, CSA-A371 and as indicated herein.

3.4 Reinforced Lintels and Bond Beams

.1 Reinforce masonry lintels and bond beams as indicated.

.2 Place and grout reinforcement in accordance with CSA-S304.

3.5 Metal Anchors

.1 Do metal anchors as indicated.

3.6 Lateral Support and Anchorage

.1 Do lateral support and anchorage in accordance with CSA-S304 and as indicated.

3.7 Control Joints

.1 Terminate reinforcement 25 mm short of each side of control joints unless otherwise indicated.

.2 Control joints shall be stepped to avoid cutting lintel beams. Under no circumstance shall the control joints be placed to compromise the bearing for the lintel.

3.1 Field Bending

.1 Do not field bend reinforcement and connectors except where indicated or authorized by Consultant.

.2 When field bending is authorized, bend without heat, applying a slow and steady pressure.

.3 Replace bars and connectors which develop cracks or splits.

3.2 Field Touch Up

.1 Touch up damaged and cut ends of galvanized reinforcement steel and connectors with compatible finish to provide continuous coating.

3.3 Cleaning

- .1 Proceed in accordance with Section 01 74 11 – Cleaning.

End of Section

PART 1 GENERAL

1.1 General

- .1 Conform to the requirements of Division 1.

1.2 Related Sections

- | | | |
|-----|------------------|-----------------------------------|
| .1 | Section 03 10 00 | Concrete Forming and Accessories |
| .2 | Section 03 20 00 | Concrete Reinforcing |
| .3 | Section 03 30 00 | Cast-in-Place Concrete |
| .4 | Section 04 05 19 | Masonry Anchorage and Reinforcing |
| .5 | Section 06 10 00 | Rough Carpentry |
| .6 | Section 07 84 00 | Firestopping |
| .7 | Section 07 92 00 | Joint Sealants |
| .8 | Section 08 11 00 | Metal Doors and Frames |
| .9 | Section 09 21 16 | Gypsum Board |
| .10 | Section 09 91 23 | Interior Painting |

1.3 References

- .1 Canadian Concrete Masonry Producers Association (CCMPA) Quality Assurance Program.
- .2 ASTM International, (ASTM)
 - .1 ASTM C90-15 Standard Specification for Loadbearing Concrete Masonry Units
 - .2 ASTM C129-14a Standard Specification for Nonloadbearing Concrete Masonry Units
 - .3 ASTM C150/C150M-15 Standard Specification for Portland Cement
 - .4 ASTM C207-06 (2011) Standard Specification for Hydrated Lime for Masonry Purposes.
 - .5 ASTM D2240-05(2010) Standard Test Method for Rubber Property—Durometer Hardness.
 - .6 ASTM D5249-10 Standard Specification for Backer Material for Use with Cold and Hot Applied Joint Sealants in Portland Cement Concrete and Asphalt Joints.
- .3 Canadian Standards Association
 - .1 CSA A23.1-09, Concrete Materials and Methods of Concrete Construction.
 - .2 CAN/CSA A165 Series-04 (R2009), CSA Standards on Concrete Masonry Units.
 - .3 CAN/CSA A179-04 (R2009), Mortar and Grout for Unit Masonry,
 - .4 CAN3-A370-04 (2009) Connectors for Masonry.
 - .5 CAN/CSA A371-04 (R2009), Masonry Construction for Buildings.
 - .6 CSA S304.1-04 (R2010), Masonry Design for Buildings.

1.4 Submittals

- .1 Make submittals in accordance with Section 01 33 00 – Submittal Procedures.
- .2 Data: Submit manufacturer's printed product literature, specifications and data sheets
- .3 Submit shop drawings for all masonry reinforcing. Include placing drawings, bar lists and details. Indicate clearly reinforcing bar sizes, spacing, bending details, lap details, dowels to adjacent construction location and quantities of reinforcement and connectors.
- .4 Submit engineered temporary bracing design drawings for temporary support of masonry walls. Drawings shall be prepared by, and bear the seal of a Professional Engineer, licensed in the Province of Ontario.
- .5 Certificates: submit product certificates signed by manufacturer certifying materials comply with

specified performance characteristics and criteria and physical requirements.

1.1 Quality Assurance

- .1 The masonry sub-contractor shall have a minimum of five years of continuous documented Canadian experience in work of the type and quality shown and specified. Proof of experience shall be submitted when requested by the Consultant and shall be subject to the approval of the Consultant.

1.2 Shipping, Handling and Storage

- .1 Refer to Section 01 61 00 – Common Product Requirements.
- .2 Deliver, handle and store materials in accordance with manufacturer's printed instructions.
- .3 Materials shall be kept clean and dry.
- .4 Deliver cement, lime and mortar ingredients with manufacturer's seal and labels intact.
- .5 Cementitious material and aggregates shall be stored in accordance with the requirements of CAN A23.1-09.
- .6 Exposed units which become stained or chipped, surface marked or scratched, and materials which are affected by inadequate protection shall be replaced, at no additional expense to the Consultant.
- .7 Masonry units shall be delivered to site in protective film and shall be stored without contact with ground or ground water.

1.3 Cold Weather Requirements

- .1 Provide heat enclosures and heat as required.
- .2 Work to be undertaken shall be carried out according to CAN3-A371, Clause 5.15.2.
- .3 Maintain temperature of mortar between 5°C and 50°C until batch is used.

1.4 Hot Weather Requirements

- .1 Protect freshly laid masonry from drying too rapidly by means of waterproof, non-staining coverings.

1.5 Protection

- .1 Keep masonry dry using secure waterproof, non-staining coverings that extend over walls and down sides sufficient to protect walls from wind driven snow, rain and dirt, until masonry work is completed and protected by flashings or other permanent construction.
- .2 Protect masonry and other work from marking and other damage. Protect completed work from mortar droppings. Use non-staining coverings.

1.6 Waste Management and Disposal

- .1 Refer to Section 01 74 19 – Construction Waste Management and Disposal.

PART 2 PRODUCTS

2.1 Materials

- .1 Masonry Units: Concrete Block: Modular, conforming to CCMPA requirements and CAN/CSA A165.1.
- .1 H/20/A/M concrete masonry units to be used at all load bearing masonry walls.
 - .2 H/15/A/M concrete, masonry units, at all other locations unless noted otherwise.
 - .3 SS/15/A/M semi-solid concrete masonry units to be used at all 2 hour rated fire walls.
 - .4 Refer to drawings for Fire Resistance Ratings. Type of concrete and block to conform to Table 5.0, Fire Resistance Rating of Concrete Block in Hours, of the Canadian Concrete Masonry Producers Association Handbook.
 - .5 Special shapes: provide special shapes indicated or required including bullnose and corner blocks, base blocks, fillers, and the like as may be required. Provide purpose made shapes for lintels and bond beams.
 - .6 Exposed block shall all be made by one manufacturer and shall be uniform in colour, shade and texture.
- .2 Masonry Reinforcement and Connectors:
- .1 Bar Reinforcement, wire reinforcement, connectors and ties: as specified in Section 04 05 19 - Masonry Anchorage and Reinforcing.
- .3 Control Joint Filler: to ASTM D5249-10, Type 1, Round, flexible, continuous-length, nonabsorbent, nongassing, nonstaining, and nonshrinking. Extruded from a cross-linked polyethylene. Flexible foam, heat-Resistant Backer Rod. 9.5 mm thick by width of wall.
- .4 Pre-manufactured Masonry Control Joint: Pre-manufactured polyvinylchloride control joints may be used in lieu of the specified built-up type of joint.
- .5 Mortar and Grout: Conforming to CAN/CSA A179-04 (R2009).
- .1 Use same brand of material and source of aggregate for entire project.
 - .2 Aggregate: CAN/CSA A179-04 (R2009), fine grain aggregates.
 - .3 Cement: normal Portland to ASTM C150/C150M-12, Type 10.
 - .4 Water shall be clean, potable and free of deleterious amounts of acid, alkalies, or organic materials.
 - .5 Hydrated Lime: Type 'S' to ASTM C207-06 (2011).
 - .6 Type 'S' mortar shall be used for all concrete block masonry work.
 - .7 Proprietary Mortar Mixes: conform to mix requirements specified
 - .8 Mortar colour for concrete unit masonry work shall be grey.
 - .9 Admixtures of any kind are not allowed.
- .6 Grout: to CAN/CSA A179-04 (R2009), Table 3:
- .1 Premixed, non-shrink non-metallic grout.
- .7 Other Materials: all other materials not specifically described but required for a complete and proper installation of masonry, shall be as selected by the Contractor subject to approval by the Consultant

2.2 Mixes

- .1 Mixing: Prepare and mix mortar materials under strict supervision, and in small batches only for immediate use.
- .2 Mix proprietary mortars in strict accordance with manufacturer's instructions to produce the specified mortar types in accordance with CAN/CSA A179-04 (R2009). Do not use re-tempered mortars.
- .3 Take representative samples for testing consistency of strength and colour according to CAN/CSA A179-04 (R2009).

2.3 Damp Course and Flashings

- .1 Peel and stick modified SBS bitumen membrane reinforced with proprietary glass screen, minimum thickness of 1.0 mm.
- .2 Lap Sealant: recommended by flashing manufacturer.

2.4 Accessories

- .1 Mechanical Fasteners: As recommended by manufacturer of material to be fastened, and in accordance with the reference standards, corrosion resistant.

PART 3 EXECUTION

3.1 Existing Conditions

- .1 Examine work of other trades for defects or discrepancies and report same in writing to Consultant.
- .2 Installation of any part of this work shall constitute acceptance of such surfaces as being satisfactory.

3.2 General

- .1 Do masonry work in accordance with CAN/CSA A371-04 (R2009) except where specified otherwise.
- .2 A competent masonry foreman shall supervise and direct the work and only skilled masons shall execute the work of this Section.
- .3 Coordinate work of this Section with others such as, field welding of anchors to steel work, insulation application, and the like. Prepare all items for built-in as the work proceeds, either supplied and installed by other trades or installed under this Section.
- .4 Unless otherwise indicated on the drawings, all interior masonry partitions shall extend from floor level to the underside of floor or roof structures above.

3.3 Workmanship

- .1 Build masonry plumb, level, and true to line, with vertical joints in alignment.

- .2 Lay out coursing and bond to achieve correct coursing heights, and continuity of bond above and below openings, with minimum of cutting.
- .3 Lay block with webs to align plumb over each other with thick ends of webs up. The top course of all partitions which do not pass through a ceiling or up to the underside of a roof deck shall have the open cells filled solid.
- .4 Cut exposed block with power driven abrasive cutting disc or diamond cutting wheel for flush mounted electrical outlets, grilles, pipes, conduits, leaving 3 mm maximum clearance.
- .5 Fill all vertical and bed joints, including plain end faces, through the entire wall thickness solidly with mortar.
- .6 Do not break bond of exposed walls where partitions intersect and if bond would show through on exposed face of walls. Bond these partitions to walls they intersect with prefabricated intersection masonry reinforcement in each course.
- .7 Bond intersecting block walls in alternate courses.
- .8 Terminate non load bearing walls within 20 mm of structure above unless indicated otherwise.
- .9 Where walls are pierced by structural members, ducts, pipes, fill voids with mortar to within 20 mm of such members.
- .10 Buttering corners of units, throwing mortar droppings into joints, deep or excessive furrowing of bed joints, is not permitted. Do not shift or tap units after mortar has taken initial set. Where adjustment must be made after mortar has started to set, remove mortar and replace with fresh supply.
- .11 Do not wet concrete masonry before or during laying in wall.
- .12 Bed and vertical joints shall be evenly and solidly filled with mortar.
- .13 Provide reinforced bond beams where indicated on structural drawings.
- .14 Provide vertical reinforcement as indicated on structural drawings.

3.4 Exposed Masonry

- .1 Do not use chipped, cracked or stained, and otherwise damaged units or unsatisfactory material in exposed and load bearing masonry walls.
- .2 Lay all joints 10 mm thick (uniform). All joints shall be full of mortar except where specifically designated to be left open.
- .3 All joints shall be slightly concave. Use sufficient force to press mortar tight against masonry units on both sides of joints. Remove excess material or burrs left after jointing by means of a trowel or rubbing with burlap bag.
- .4 Provide bullnose block at all exposed masonry corners.

3.5 Tolerances

- .1 Tolerances in notes to Clause 5.3 of CAN/CSA A371-04 (R2009) apply.

3.6 Reinforcement

- .1 Refer to Section 04 05 19 - Masonry Anchorage and Reinforcing.

3.7 Connectors

- .1 Refer to Section 04 05 19 - Masonry Anchorage and Reinforcing.

3.8 Concrete Masonry Lintels

- .1 Refer to Section 04 05 19 - Masonry Anchorage and Reinforcing.
- .2 Lintels in non-load-bearing walls shall be constructed with special bond or lintel block units unless shown otherwise on plans. Lintels shall bear 200 mm minimum and bearing shall be isolated with two layers of heavy asphalt coated paper.
- .3 Reinforcing steel in lintels shall be 2 x 20 M bars minimum specified under Section 04 05 19 - Masonry Anchorage and Reinforcing, or as noted on drawings.
- .4 Concrete fill for lintels shall be 25 MPa or as noted on the drawings. Concrete shall be as specified in Section 03 30 00.

3.9 Loose Steel Lintels

- .1 Install loose steel lintels. Centre over opening width.

3.10 Control Joints

- .1 Provide continuous joints as indicated and at spacing not to exceed 6000 mm c/c unless noted otherwise on drawings.
- .2 Break vertical mortar bond with extruded neoprene gasket or building paper.
- .3 Prime control joint to prevent drying out of caulking material.

3.11 Support of Loads

- .1 Use 25 MPa concrete unless specified otherwise on the Drawings, where concrete fill is used in lieu of solid units.
- .2 Use grout to CAN/CSA A179-04 (R2009) where grout is used in lieu of solid units.
- .3 Install building paper below voids to be filled with grout. Keep paper 25 mm back from face of units.

3.12 Lateral Support and Anchorage

- .1 Do lateral support and anchorage of masonry in accordance with CSA S304.1-04 (R2010) and as indicated.

3.13 Grouting

- .1 Grout masonry in accordance with CSA S304.1-04 (R2010) and as indicated.

3.14 Temporary Wall Bracing

- .1 Design and provide all required temporary engineered wall bracing.
- .2 Brace masonry walls to resist wind pressure and other lateral loads during construction period.
- .3 Provide temporary bracing of masonry work during and after erection until mortar has cured and permanent lateral support is in place

3.15 Built-ins

- .1 Build in items required to be built into masonry and provided by other Sections, including bearing plates, door frames, anchor bolts, sleeves and inserts. Build in items to present a neat, rigid, true and plumb installation. Leave wall openings required for ducts, grilles, pipes and other items.
- .2 Prevent displacement of built-in items during construction. Check plumb, location and alignment frequently, as work progresses.
- .3 Brace door jambs to maintain plumb. Fill voids between masonry and metal frames with masonry mortar or insulation, as indicated on drawings or as required to provide a neat finished appearance.
- .4 Set wall plates on masonry in non-shrink grout in accordance with manufacturer's instructions.
- .5 Do all cutting, fitting, drilling, patching and making good for other trades in masonry work.

3.16 Protection

- .1 Protect masonry units from damage resulting from subsequent construction operations.
- .2 Use protection materials and methods which will not stain or damage masonry units.
- .3 Remove protection materials upon Substantial Performance, or when risk of damage is no longer present.

3.17 Cleaning

- .1 Proceed in accordance with Section 01 74 11 – Cleaning.
- .2 Allow mortar droppings on unglazed concrete masonry to partially dry then remove by means of trowel, followed by rubbing lightly with small piece of block and finally by brushing.
- .3 Remove mortar from concrete floor slabs and leave entire area vacuum clean.

End of Section

PART 1 GENERAL

1.1 General

- .1 Conform to the requirements of Division 1.

1.2 Related Sections

- .1 Section 03 10 00 Concrete Forming and Accessories
- .2 Section 03 30 00 Cast-In-Place Concrete
- .3 Section 04 22 00 Concrete Unit Masonry
- .4 Section 06 20 00 Finish Carpentry
- .5 Section 07 21 13 Building Insulation
- .6 Section 08 11 00 Metal Doors and Frames

1.3 References

- .1 ASTM International (ASTM)
 - .1 ASTM F1667 - 17 Standard Specification for Driven Fasteners: Nails, Spikes, and Staples
- .2 Canadian Standards Association (CSA)
 - .1 CSA C22.1-18 Canadian Electrical Code
 - .2 CAN/CSA-O80 SERIES-15 - Wood Preservation
 - .3 CSA 086-14 Engineering Design in Wood
 - .4 CSA 0121-17 Douglas Fir Plywood.
 - .5 CSA O141-05 (R2014) - Softwood Lumber
 - .6 CSA 0151-17 Canadian Softwood Plywood
 - .7 CAN/CSA-O437 Series-93 (R2011) Standards on OSB and Waferboard
 - .8 CAN/CSA G164-M92 (R2003) Hot Dip Galvanizing of Irregularly Shaped Articles
- .3 Canadian General Standards Board (CGSB)
 - .1 CAN/CGSB 71.26-M88 Adhesive for Field Glueing Plywood to Lumber Framing for Floor Systems.
- .4 Underwriters Laboratories Canada (ULC)
 - .1 CAN/ULC-S102 Standard Method of Test for Surface Burning Characteristics of Building Materials and Assemblies.
- .5 National Lumber Grading Authority (NGLA)
 - .1 Standard Grading Rules for Canadian Lumber, Latest Edition.

1.4 Submittals

- .1 Make submittals in accordance with Section 01 33 00 – Submittal Procedures.
- .2 When required by authorities having jurisdiction, submit sequential erection drawings indicating all necessary false work, temporary construction bracing and hoisting.

1.5 Quality Assurance

- .1 Sawn lumber shall be identified by the grade stamp of an association or independent grading agency certified by the Canadian Lumber Standards Accreditation Board.
- .2 Pressure treated and fire retardant treated materials shall conform to CAN/CSA-080 SERIES.

1.1 Shipping, Handling and Storage

- .1 Materials shall not be delivered before they are required for proper conduct of the work.
- .2 Protect materials, under cover, both in transit and on the site.
- .3 Store materials to prevent deterioration or the loss or impairment of their structural and other essential properties. Do not store materials in areas subject to high humidity and areas where masonry and concrete work are not completely dried out.
- .4 Protect work from damage during storage, handling, installation and until the building is turned over to the Owner. Make good damage and loss without additional expense to the Owner.
- .5 Store sheathing materials level and flat, in a dry location. Protect panel edges from moisture at all times.

PART 2 PRODUCTS

2.1 Materials

- .1 General: Use materials specified herein.
- .2 Timber Material shall be 'Grade Stamped'.
- .3 Construction Lumber: To CAN/CSA 0141 Softwood Lumber graded to NLGA Standard Grading Rules for Canadian Lumber, published by the National Lumber Grades Authority. All lumber shall bear grade stamps. Moisture content of softwood lumber not to exceed 19% at time of installation.
 - .1 Framing lumber, plates, furring, blocking, No. 1 SPF.
 - .2 Nailing strips, furring and strapping: No. 4 S-P-F.
 - .3 Fitment framing: No. 1 S-P-F.
- .4 Canadian Softwood Plywood: to CSA 0151-M, standard construction, good one or both sides as required, thickness as shown or specified.
 - .1 Douglas Fir Plywood: To CSA 0121-M, standard construction, good one side, thickness as shown on the drawings.
 - .2 Plywood used for exposed interior work shall have select grade veneer, one or both faces where exposed, with fire retardant finish. Fire retardant shall be in accordance with CAN/CSA-080.1, and all treated materials shall bear a ULC approval stamp.
 - .3 Poplar Plywood: to CSA 0153, standard construction.
 - .4 Mat formed structural panel board (oriented strand board): to CAN3-0437.0, square edge, 12.7 mm thickness.
- .5 Nails, Spikes and Staples: To ASTM F1667.
- .6 Bolts: 12.5 mm diameter, galvanized, complete with nuts and washers.
- .7 Proprietary Fasteners: toggle bolts, expansion shields and lag bolts, screws and lead or inorganic fibre plugs, recommended for purpose by manufacturer.
- .8 Nailing Discs: flat caps, minimum 25 mm diameter, minimum 26 gauge thick, sheet metal, formed to prevent dishing.
- .9 Wood Preservative to CAN/CSA-080 SERIES.

- .10 Adhesive: Contractors gun grade cartridge loaded wood adhesive, general purpose, to CSA 0112 Series and CAN/CGSB-71.26.
- .11 Building Paper: to CAN2-51.32-M, 15# asphalt impregnated paper.
- .12 Fibreglass Insulation: to CSA A101, loose batt type, minimum density of 1.5 pcf.
- .13 Galvanizing: to CAN/CSA-G164. Use galvanized fasteners, and hardware for exterior work, preservative treated lumber, and materials in contact with concrete or masonry.

PART 3 EXECUTION

3.1 Installation

- .1 Workmanship:
 - .1 Comply with the requirements of the Ontario Building Code, Part 9.
 - .2 Execute work using skilled mechanics according to best practice, as specified here.
 - .3 Lay out work carefully and to accommodate work of other trades. Accurately cut and fit; erect in proper position true to dimensions; align, level, square, plumb, adequately brace, and secure permanently in place. Join work only over solid backing.
- .2 Rough Hardware:
 - .1 Work shall include rough hardware such as nails, bolts, nuts, washers, screws, clips, hangers, connectors, strap iron, and operating hardware for temporary enclosures.
- .3 Provide treated wood nailers, blocking, cants, grounds, furring and similar members where shown and where required for screeding or attachment of other work and surface applied items. Attach to substrate as required to support applied loading.
- .4 Blocking: Provide solid wood backing to support equipment and fixtures as required.

End of Section

PART 1 GENERAL

1.1 General

- .1 Conform to the requirements of Division 1.

1.2 Related Sections

- .1 Section 06 10 00 Rough Carpentry
- .2 Section 06 40 00 Architectural Woodwork
- .3 Section 07 92 00 Joint Sealants
- .4 Section 08 11 00 Metal Doors and Frames
- .5 Section 08 71 10 Door Hardware
- .6 Section 09 21 16 Gypsum Board
- .7 Section 09 91 23 Interior Painting
- .8 Section 10 28 10 Toilet and Bath Accessories.

1.3 References

- .1 ASTM International, (ASTM)
 - .1 ASTM E1333-14 Standard Test Method for Determining Formaldehyde Concentrations in Air and Emissions Rates from Wood Products Using a Large Chamber.
 - .2 ASTM F1667 - 17 Standard Specification for Driven Fasteners: Nails, Spikes, and Staples
- .2 American National Standards Institute (ANSI)
 - .1 ANSI A208.1-2009 Particleboard.
 - .2 ANSI A208.2-2016 Medium Density Fibreboard (MDF) for Interior Applications.
 - .3 ANSI/HPVA HP-1-2016, Standard for Hardwood and Decorative Plywood.
- .3 Architectural Woodwork Manufacturers Association of Canada (AWMAC) and Architectural Woodwork Institute (AWI)
 - .1 Architectural Woodwork Quality Standards Illustrated.
- .4 Canadian Plywood Association (CanPly)
 - .1 The Plywood Handbook 2005.
- .5 Canadian Standards Association (CSA International)
 - .1 CSA B111-1974 (R2003) Wire Nails, Spikes and Staples.
 - .2 CAN/CSA-G164-M92 (R2003), Hot Dip Galvanizing of Irregularly Shaped Articles.
 - .3 CSA 0121-17 Douglas Fir Plywood.
 - .4 CSA O141-05 (R2014) - Softwood Lumber
 - .5 CSA 0151-17 Canadian Softwood Plywood
 - .6 CSA O153-13 (R2017) Poplar Plywood.
 - .7 CSA Z760-94 (R2001) Life Cycle Assessment
- .6 Forest Stewardship Council (FSC)
 - .1 FSC-STD-01-001-V4-0 FSC Principle and Criteria for Forest Stewardship.
 - .2 FSC-STD-20-002-2004, Structure and Content of Forest Stewardship Standards V2-1
 - .3 FSC Accredited Certified Bodies.
- .7 National Hardwood Lumber Association (NHLA)
 - .1 Rules for the Measurement and Inspection of Hardwood and Cypress 1998.
- .8 National Lumber Grades Authority (NLGA)
 - .1 Standard Grading Rules for Canadian Lumber 2005.
- .9 South Coast Air Quality Management District (SCAQMD), California State (SCAQMD)
 - .1 SCAQMD Rule 1168-03, Adhesives and Sealants Applications

1.4 Submittals

- .1 Make submittals in accordance with Section 01 33 00 – Submittal Procedures.
- .2 Submit shop drawings.
 - .1 Indicate details of construction, profiles, jointing, fastening and other related details.
 - .2 Indicate materials, thicknesses, finishes and hardware.
- .3 Submit duplicate 300 mm long samples of each type of solid wood or 300 x 300 mm square type of plywood to receive stain or natural finish.
- .4 Submit samples of plastic laminate materials.

1.5 Quality Assurance

- .1 Lumber by grade stamp of an agency certified by Canadian Lumber Standards Accreditation Board.
- .2 Plywood, particleboard, OSB and wood based composite panels in accordance with CSA and ANSI standards.
- .3 Wood materials certified by Forestry Stewardship Council.

1.6 Shipping, Handling and Storage

- .1 Refer to Section 01 61 00 – Common Product Requirements.
- .2 Protect materials against dampness during and after delivery.
- .3 Store materials in ventilated areas, protected from extreme changes of temperature or humidity.

1.7 Waste Management and Disposal

- .1 Refer to Section 01 74 19 – Construction Waste Management and Disposal.

PART 2 PRODUCTS

2.1 Lumber Materials

- .1 Softwood lumber: unless specified otherwise, S4S, moisture content 19% or less in accordance with following standards:
 - .1 CAN/CSA- O141-91(R1999).
 - .2 NLGA Standard Grading Rules for Canadian Lumber.
 - .3 AWMAC custom premium grade, moisture content as specified.
 - .4 Machine stress-rated lumber is acceptable.
- .2 Hardwood Lumber: To NHLA requirements, moisture content of 6% maximum, maple species, AWMA Custom Grade.
 - .1 Bench Slats: Select Grade Maple.

2.2 Panel Materials

- .1 Douglas fir plywood (DFP): to CSA O121-M89 (R2003), standard construction.
 - .1 Forestry Stewardship Council (FSC) certified.

- .2 Urea-formaldehyde free.
- .2 Canadian softwood plywood (CSP): to CSA O151-04, standard construction.
 - .1 Forestry Stewardship Council (FSC) certified.
 - .2 Urea-formaldehyde free.
- .3 Hardwood Veneered Plywood: To CSA 0115, of thickness indicated, Type II Select Grade Maple, where transparent finish is required and Solid Grade where paint finish is required. Good two sides for work with two sides exposed to view; good one side for work with one side exposed to view. Use particle board core with Type I bond.
- .4 Particleboard: to ANSI A208.1-99.
 - .1 Forestry Stewardship Council (FSC) certified.
 - .2 Urea-formaldehyde free.
- .5 Medium density fibreboard (MDF): to ANSI A208.2-02, density 640-800 kg/m³.
 - .1 Forestry Stewardship Council (FSC) certified.
 - .2 Urea-formaldehyde free.

2.3 Plastic Laminate

- .1 Plastic laminate facing sheet: ANSI/NEMA LD 3-2005 High-Pressure Decorative Laminates (HPDL) PF-S and GP-S;
 - .1 Backing sheet: BK Grade by manufacturer of facing sheet.
 - .2 Core: CAN3-0188.1M, Grade R.
 - .3 Laminating adhesive: CAN3-0112 Series M.
 - .4 Core sealer: clear water resistant synthetic resin sealer.
 - .5 Colours, pattern, gloss and texture will be selected by Consultant from full range of products by one of the following:
 - .1 Formica,
 - .2 Arborite,
 - .3 Pionite,
 - .4 Nevamar
 - .5 Wilsonart.
 - .6 Up to three (3) colours and patterns will be selected by the Consultant.

2.4 Accessories

- .1 Rough Hardware: Bolts, lag screws, anchors, nails and expansion shields required to secure this portion of work. Rough hardware hot dip galvanized conforming to latest edition of CAN/CSA-G164. All fasteners used in damp or wet areas to be suitable for use in corrosive environment. Use hot dipped galvanized or other material approved by the Consultant.
- .2 Nails and staples: to ASTM F1667 galvanized.
- .3 Wood screws: to CSA B 35.4 plain type and size to suit application.
- .4 Stainless Steel hardware: Type 316 Stainless steel for exposed or wet locations, tamper proof.
- .5 Splines: wood or metal to suit application.
- .6 Adhesive: recommended by manufacturer, waterproof type, maximum VOC limit 30 g/L SCAQMD Rule 1168 - Adhesives and Sealants Applications.

PART 3 EXECUTION

3.1 Construction

- .1 Fastening:
 - .1 Position items of finished carpentry work accurately, level, plumb, true and fasten or anchor securely.
 - .2 Design and select fasteners to suit size and nature of components being joined. Use proprietary devices as recommended by manufacturer.
 - .3 Set finishing nails to receive filler. Where screws are used to secure members, countersink screw in round smooth cut hole and plug with wood plug to match material being secured.
 - .4 Replace items of finish carpentry with damage to wood surfaces including hammer and other bruises.
- .2 Interior and exterior frames:
 - .1 Set frames with plumb sides, level heads and sills, and secure.

3.2 Fabrication

- .1 General:
 - .1 Field measure all dimensions.
 - .2 Fabricate all finish carpentry items to AWMAC premium grade, and in accordance with the reviewed shop drawings.
 - .3 Set nails and screws, apply stained plain wood filler to indentations, sand smooth and leave ready to receive finish.
 - .4 Provide 10 mm thick solid matching wood strip on plywood and particle board edges 13 mm or thicker, exposed in final assembly.
 - .5 Ease edges of solid lumber components to 1.6 mm radius.
- .2 Plastic Laminate Components
 - .1 Fabricate plastic laminate window stools as detailed. Stools shall be minimum 19 mm thick plastic laminate plywood, with edge banding on all exposed faces. Fabricate in one piece, without joints, wherever as possible. Where necessary, joints shall be centred on window mullions and tightly butted together with concealed splines.
 - .2 Fabricate vanities and change room shelving units as detailed.
 - .3 Unless otherwise specified herein, comply with requirements of CAN3-A172-M Appendix 'A'.
 - .4 Assembly: Bond plastic laminate to core with adhesive, under pressure.
 - .5 Core: unless otherwise indicated: 19 mm thick.
 - .6 Balanced construction: plastic laminate covered components shall be of balanced construction, with plastic laminate on both faces of core. Seal core edges not covered with plastic laminate.
 - .7 Use largest practicable plastic laminate sheet size.
 - .8 Provide joints symmetrically; provide joints as corners and at changes in superficial areas; provide concealed draw bolt anchors and joints. All butt joints shall have a blind spine.
 - .9 Openings and cutouts:
 - .1 Radius internal corners at least 3 mm and chamfer edges.
 - .2 Where core edge is to remain exposed, cover with plastic laminate edging.
 - .3 Where core edge is to be concealed, seal with sealer.

3.3 Installation

- .1 Do finish carpentry to Quality Standards of the Architectural Woodwork Manufacturers Association of Canada (AWMAC), except where specified otherwise.
- .2 All fastenings shall be concealed.

- .3 Provide heavy duty grounds as necessary for secure installation of finish carpentry work.
- .4 All wood surfaces shall be sanded smooth, ready to receive finish.
- .5 Scribe and cut as required, fit to abutting walls and surfaces, fit properly into recesses and to accommodate piping, columns, fixtures, outlets or other projecting, intersecting or penetrating objects.
- .6 Form joints to conceal shrinkage.
- .7 Set and secure materials and components in place, rigid plumb and square.
- .8 Design and select fasteners to suit size and nature of components being joined. Use proprietary devices as recommended by manufacturer.
- .9 Set finishing nails to receive filler. Where screws are used to secure members, countersink screws in round, cleanly cut hole and plug with wood plug to match material being secured.
- .10 Replace items of finish carpentry with damage to wood surfaces including hammer and other bruises.
- .11 Install plastic laminate components using concealed fastening devices.
- .12 Install window stools with wood levelling shims, after installation of windows and interior finishing is complete. Screw levelling shims to metal stud framing with self-tapping sheet metal screws. Bond stools to shims with waterproof adhesive. Tightly butt all joints and bond together with adhesive and concealed splines. Cut to fit tight to all penetrations.
- .13 Apply mildew resistant clear silicone sealant to perimeter of all vanity tops and window stools as specified in Section 07 92 00.

3.4 Door Installation

- .1 Install doors in accordance with instructions in Section 08 11 00 and Section 08 14 16 and manufacturer's printed instructions.

3.5 Finish Hardware Installation

- .1 Finish hardware will be supplied for installation under this Section.
- .2 Prepare doors and frames in accordance with manufacturer's instructions and templates. Install finish hardware complete in all respects, hang doors and make adjustments necessary.
- .3 Doors shall swing freely. Where thresholds are to be used, door bottom shall be finished to suit thresholds as required.
- .4 Where indicated on door schedules or drawings, under-cut doors.

3.6 Miscellaneous

- .1 Install Toilet and Bath Accessories as specified in Section 10 28 10, including accessories supplied by Owner.

3.7 Cleaning

.1 Proceed in accordance with Section 01 74 11 – Cleaning.

End of Section

PART 1 GENERAL

1.1 General

- .1 Conform to the requirements of Division 1.

1.2 Related Sections

- .1 Section 05 50 00 Metal Fabrications
- .2 Section 06 10 00 Rough Carpentry
- .3 Section 06 20 00 Finish Carpentry
- .4 Section 07 92 00 Joint Sealants
- .5 Section 09 21 16 Gypsum Board

1.3 References

- .1 ASTM International (ASTM)
 - .1 ASTM F1667 - 17 Standard Specification for Driven Fasteners: Nails, Spikes, and Staples
- .2 Architectural Woodwork Manufacturer's Association of Canada (AWMAC)
 - .1 Architectural Woodwork Standards Manual.
- .3 American National Standards Institute (ANSI)
 - .1 ANSI A208.1, Mat-Formed Wood Particleboard
 - .2 ANSI/NEMA LD 3-2005 High-Pressure Decorative Laminates (HPDL)
 - .3 ANSI/HPVA HP-1-09 American National Standard for Hardwood and Decorative Plywood
- .4 Canadian Standards Association (CSA)
 - .1 CSA O121-08 (R2013) Douglas Fir Plywood
 - .2 CSA O151-17 Canadian Softwood Plywood
 - .3 CSA O153-13 Poplar Plywood

1.4 Submittals

- .1 Make submittals in accordance with Section 01 33 00 – Submittal Procedures.
- .2 Submit detailed shop drawings for cabinetwork showing proposed assembly, connections, anchorage, materials, dimensions, thickness, and finishes.
- .3 Submit duplicate, 300 mm long samples of each type of solid wood and 300 x 300 mm samples of each type of plywood used in exposed work and scheduled to receive stained or natural finish, complete with specified finish, prior to fabrication of cabinetwork.
- .4 Submit full range of manufacturer's standard plastic laminates for selection by the Consultant.
- .5 Submit sample of each type of cabinet hardware component used.

1.5 Quality Assurance

- .1 Unless otherwise specified, carry out finish carpentry work in accordance with the requirements of "Millwork Standards" (latest issue) of Architectural Woodwork Manufacturers' Association of Canada (AWMAC), Custom Grade.

1.6 Definition

- .1 "Exposed" when referred to in this Section, shall mean all parts which can be viewed and shall

include interiors of cabinets, backs of doors, shelving and gables.

1.7 Shipping, Handling and Storage

- .1 Refer to Section 01 61 00 – Common Product Requirements.
- .2 Deliver, handle and store materials in accordance with manufacturer's printed instructions.
- .3 Protect against damage, including damage by excessive changes in moisture content, during delivery and storage. Maintain minimum storage temperature of 16^o C, and relative humidity of 25% to 55%.
- .4 Cover plastic laminate faces at shop with heavy Kraft paper.
- .5 Do not deliver finish carpentry components to site before all wet trades are completed, the building is closed in and humidity conditions on site are acceptable. Do not deliver during rain or damp weather
- .6 Store materials on site in such a way as to prevent deterioration or loss or impairment of essential properties. Prevent excessive moisture gain of materials.

1.8 Protection

- .1 Provide coverings as necessary to protect finish carpentry components from damage of any kind during storage and after installation.

1.9 Waste Management and Disposal

- .1 Refer to Section 01 74 19 – Construction Waste Management and Disposal.

1.10 Warranty

- .1 Warrant the work of this Section against defects of workmanship and material, for a period of two years from the date of Substantial Performance and agree to make good promptly any defects which occur or become apparent within the warranty period.

PART 2 PRODUCTS

2.1 Materials

- .1 Solid Wood:
 - .1 Unless otherwise indicated, provide AWMAC Premium Grade.
 - .2 All wood materials shall be new, straight and clean, free of sap, knots, pitch, and other defects, except as permitted by applicable grading rules.
 - .3 All wood shall be kiln dried to a maximum moisture content of 7%.
 - .4 Softwood: to CSA 0141, dressed all sides used in concealed locations.
- .2 Plywood:
 - .1 Soft Plywood: to CSA 0151-M Standard Grade, solid two sides. Use in concealed locations only, except as indicated.
- .3 Particleboard: to CAN 3-O188.1-M, minimum density of 720kg/m³ Grade "R".

- .4 Plastic laminate facing sheet: ANSI/NEMA LD 3-2005 High-Pressure Decorative Laminates (HPDL) PF-S and GP-S;
 - .1 Backing sheet: BK Grade by manufacturer of facing sheet.
 - .2 Core: CAN3-0188.1M, Grade R.
 - .3 Laminating adhesive: CAN3-0112 Series M.
 - .4 Core sealer: clear water resistant synthetic resin sealer.
 - .5 Colours, pattern, gloss and texture will be selected by Consultant from full range of products by one of the following:
 - .1 Formica,
 - .2 Arborite,
 - .3 Pionite,
 - .4 Nevamar
 - .5 Wilsonart.
 - .6 Up to three (3) colours and patterns will be selected by the Consultant.
- .5 Melamine Overlaid Panels:
 - .1 Melamine overlay, heat and pressure laminated with phenolic resin to 12.7 mm thick particle board.
 - .2 Overlay bonded to both faces where exposed two sides, and when panel material require surface on one side only, reverse side to be overlaid with a plain balancing sheet.
 - .3 Furniture finish: solid colour as selected by the Consultant.
 - .4 Edge Finishing: matching melamine and polyester overlay edge strip with self-adhesive.
- .6 Fasteners and Adhesive:
 - .1 Nails and staples: ASTM F1667, galvanized, spiral head nails.
 - .2 Screws: To CSA B35.4 zinc, cadmium or chrome plated steel.
 - .3 Splines: wood or metal, to suit application.
 - .4 Adhesive: To CSA 0112-M, type as appropriate for the intended application waterproof. Complying with ANSI/WDMA I.S-1 series. Contact bond not acceptable.
 - .5 Avoid the use of adhesives, preservatives, synthesizing agents and finish coatings that contain formaldehyde and high V.O.C. content.
- .7 Cabinet Hardware: Products listed are a standard of acceptance. Products by other manufacturers, of equal quality and similar appearance may also be accepted subject to review and approval by Consultant.
 - .1 Shelf Standards: Knape & Vogt KV80, Anochrome finish.
 - .2 Brackets: Knape & Vogt KV180, Anochrome finish.
 - .3 Hinges: Blum concealed hinges, 125° clip and 125° opening with self-closing spring. Full or half overlay. Nickel plated steel.
 - .4 Cabinet Pulls: Richelieu D-Pull No: 30134-170, 96 mm c.c. brushed stainless steel.
 - .5 Catches: Type optional with manufacturer.
 - .6 Drawer Slides: Knape & Vogt 8450FM Soft-Close Full-Extension Drawer Slide
 - .7 Door and Drawer Bumpers: "Quietex" bumpers.
 - .8 All exposed hardware to have Platinum (Mica) finish by Teknion or equivalent unless noted otherwise.
- .8 Stainless Steel: Type 316 with AISI No. 4 finish, 15 gauge.

2.1 Fabrication

- .1 Exposed joints and edges:
 - .1 Uniformly space exposed joints unless otherwise indicated.

- .2 No edge grain shall be visible; mitre external corners, house internal fasteners. Glue mitred corners.
 - .3 All exposed edges of plywood and particle board shall have solid wood edging, pressure glued. AWMAC No. 3 edge.
 - .4 Ease edges of solid lumber components to 1.6 mm radius.
- .2 Mechanical Fasteners:
- .1 Inconspicuously locate mechanical fasteners. Wherever possible, conceal fastenings.
 - .2 Countersink nail heads.
 - .3 Where exposed to view, countersink screw and bolt heads and fill holes with matching wood plugs.
 - .4 Cutting and fitting: make cut-outs in work of this Section as required to accommodate work of other Sections.
 - .5 Make provisions in cabinetwork to accept built-in appliances, provided by others.
- .3 Plastic Laminate Components:
- .1 Assembly: Bond plastic laminate to core with adhesive, under pressure.
 - .2 Core: unless otherwise indicated: 19 mm thick.
 - .3 Balanced construction: plastic laminate covered components shall be of balanced construction, with plastic laminate on both faces of core. Seal core edges not covered with plastic laminate.
 - .4 Use largest practicable plastic laminate sheet size.
 - .5 Provide joints symmetrically; provide joints as corners and at changes in superficial areas; provide concealed draw bolt anchors and joints. All butt joints shall have a blind spine.
 - .6 Construct countertops post formed or self-edged as detailed on drawings.
 - .7 Apply self-edged minimum 1.0 mm thick plastic laminate to exposed ends of countertops.
 - .8 Construct splash backs minimum 100 mm high or higher where indicated. Do not return post formed splash back at ends except where specifically called for.
 - .9 Openings and cut-outs:
 - .1 Radius internal corners at least 3 mm and chamfer edges.
 - .2 Where core edge is to remain exposed, cover with plastic laminate edging.
 - .3 Where core edge is to be concealed, seal with sealer.
 - .10 Stainless Steel Countertops: Fabricate stainless steel counters and vanities with stainless steel sheeting bonded under pressure to exterior grade high density overlaid DFP plywood, 19 mm thick. Provide all returns and radii to present a clean neat finish. Provide splashbacks, 100 mm high at adjacent walls. Weld all seams and grind smooth.

2.2 Cabinetwork

- .1 Except where otherwise detailed, use flush overlaid construction. Tenon, dado, dowel, or rabbit interior construction with all parts well glued. Shoulder mitre all exposed corners. Open ends or skeleton frames against walls are not permitted. Unless otherwise permitted by Consultant, use unitized construction system for all components.
- .2 Construct cabinetwork components of plastic laminate faced particle board as indicated and in accordance with AWMAC Custom grade.
- .3 Rout gables for pilaster strips where adjustable shelving is required.
- .4 Construct shelving as indicated with edge moulding to match. Shelving to cabinetwork to be adjustable unless otherwise noted.
- .5 Construct doors fronts of 19 mm plastic laminate faced plywood.

- .6 Construct doors 19 mm thick with sides tongued into front and back housed into sides.
- .7 Install cabinet hardware in accord with hardware manufacturer's directions. Unless otherwise indicated, provide each door with pull and with minimum two hinges. Provide locks where indicated.
- .8 Apply moisture repellent sealer to concealed backs of cabinetwork.
- .9 Coordinate installation of wiring for electrical work with Electrical.

2.3 Stainless Steel Countertops

- .1 Stainless Steel Countertops: Fabricate stainless steel counters with stainless steel sheeting bonded under pressure to exterior grade high density overlaid DFP plywood, 19 mm thick. Provide all returns and radii to present a clean neat finish. Provide splashbacks, 100 mm high at adjacent walls. Continuously weld all seams and grind smooth.

2.4 Finishes

- .1 All exposed exterior surfaces: plastic laminate as indicated. Colours selected by the Consultant.
- .2 All exposed interior surfaces: melamine unless indicated otherwise.
- .3 Stainless Steel: Type 316 stainless steel, brushed finish.
- .4 Cabinet and case backs unexposed to view shall be back primed with one coat of moisture repellent sealer.
- .5 Apply finishes in accordance with the AWMAC Manual and Section 09 91 23.

PART 3 EXECUTION

3.1 Installation

- .1 Verify adequacy of backing and support framing. Advise Contractor of areas and surfaces requiring further modifications for plumb, level, even or square fitting.
- .2 Verify HVAC controls and systems are operating properly.
- .3 Install work in accordance with AWMAC Installation Manual, Premium grade.
- .4 Install cabinetwork components plumb, true and level and securely fasten in place.
- .5 Accurately scribe and closely fit components to irregularities of adjacent surfaces.
- .6 Accurately fit joints in true plane, locate joints over bearing or supporting surfaces.
- .7 Provide mechanical fastening devices such as nails, screws and bolts required for fastening wood components. Unless permitted, provide concealed fastening of components.
- .8 Where permitted, nail with small headed finishing nails. Countersink nail heads with nail setter.

- .9 Install plastic laminate components using concealed fastening devices.
- .10 Where components are fastened with screws or bolts, countersink screw and bolt heads and provide wood plugs matching surrounding wood.
- .11 Where cabinetwork abuts other building elements, provide wood trim matching cabinetwork except where otherwise detailed.
- .12 Where access is required to valves and other mechanical and electrical components, located behind cabinetwork, provide removable plywood access panels of size required and secure with four brass screws.
- .13 Apply mildew resistant silicone sealant to perimeter of all countertops as specified in Section 07 92 00.

3.2 Adjustment

- .1 Upon completion of installation, inspect work of this Section and touch-up, where required, minor or damaged surface finish to restore it to original condition.
- .2 Touch up exposed job made nail and screw holes, raw finishes resulting from job fitting, scratches and mars.
- .3 Check operation of all moveable parts and, if necessary, adjust to ensure proper and smooth function.
- .4 Replace damaged components which, in the opinion of the Consultant, cannot be satisfactorily repaired.

3.3 Cleaning

- .1 Proceed in accordance with Section 01 74 11 – Cleaning.
- .2 Clean all surfaces.

End of Section

PART 1 GENERAL

1.1 General

- .1 Conform to the requirements of Division 1.

1.2 Related Sections

- .1 Section 06 10 00 Rough Carpentry
- .2 Section 07 27 13 Modified Bituminous Sheet Air Barriers
- .3 Section 07 92 00 Joint Sealants

1.3 References

- .1 ASTM International (ASTM)
 - .1 ASTM C518-17 Standard Test Method for Steady-State Thermal Transmission Properties by Means of the Heat Flow Meter Apparatus
 - .2 ASTM C578-17a Standard Specification for Rigid, Cellular Polystyrene Thermal Insulation
 - .3 ASTM C612-14 Standard Specification for Mineral Fiber Block and Board Thermal Insulation
 - .4 ASTM C665-17 Standard Specification for Mineral-Fiber Blanket Thermal Insulation for Light Frame Construction and Manufactured Housing
 - .5 ASTM D1621-16 Standard Test Method for Compressive Properties of Rigid Cellular Plastics
 - .6 ASTM D1623-17 Standard Test Method for Tensile and Tensile Adhesion Properties of Rigid Cellular Plastics
 - .7 ASTM E1677-11 Standard Specification for Air Barrier (AB) Material or System for Low-Rise Framed Building Walls
 - .8 ASTM E84-17a Standard Test Method for Surface Burning Characteristics of Building Materials
- .2 Underwriters Laboratories Canada (ULC)
 - .1 CAN/ULC S701, Thermal Insulation, Polystyrene, Boards and Pipe Covering
 - .2 CAN/ULC-S702-09, Thermal Insulation Mineral Fibre for Buildings
 - .3 CAN/ULC S704 Thermal Insulation Polyurethane and Polyisocyanurate, Boards, Faced.
- .3 Canadian General Services Board (CGSB)
 - .1 CGSB 71-GP-24M Adhesive, Flexible, for Bonding to Cellular Polystyrene Insulation.
 - .2 CAN 2-51.32 Sheathing, Membrane, Breather Type.
- .4 Canadian Standards Association (CSA)
 - .1 CSA B111-1974 (R2003) Wire Nails, Spikes and Staples

1.4 Submittals

- .1 Make submittals in accordance with Section 01 33 00 – Submittal Procedures.
- .2 Submit insulation manufacturer's product literature including specified physical properties for each type of insulation specified.
- .3 Submit installation instructions.
- .4 Submit certification that product complies with specification requirements and is suitable for the use indicated.

1.5 Quality Assurance

- .1 Insulation shall not be produced with, or contain, any of the regulated CFC compounds listed in the Montreal Protocol of the United Nations Environmental Program.

1.6 Shipping, Handling and Storage

- .1 Refer to Section 01 61 00 – Common Product Requirements.
- .2 Deliver, handle and store materials in accordance with manufacturer's printed instructions.
- .3 Deliver material to the site in the original unbroken packages bearing the name of manufacturer.
- .4 Store materials in an approved manner at the site preceding application and protect from damage at all times.
- .5 Remove damaged or deteriorated materials from site.

1.7 Waste Management and Disposal

- .1 Refer to Section 01 74 19 – Construction Waste Management and Disposal.

1.8 Warranty

- .1 Provide written warranty that the actual thermal resistance of the extruded polystyrene foam insulation will not vary by more than 10% from its published thermal resistance.
- .2 Warranty period is 15 years after date of Substantial Performance.

PART 2 PRODUCTS

2.1 Board Insulation

- .1 Rigid Insulation above grade: Extruded polystyrene insulation to CAN/ULC S701 Type 3. Insulation shall have a minimum compressive strength of 170 KPa, RSI value of not less than 0.99/25 mm and a moisture absorption rate of not more than 0.7% by volume. Insulation boards shall be 100 mm thick or as detailed, 600 x 2400 mm with butt edges.
 - .1 Styrofoam Panelmate Ultra Insulation as manufactured by Dow Chemical Canada.
 - .2 Owens Corning Foamular 400
- .2 Adhesives: As recommended by material manufacturer, compatible with insulation and substrate membrane, waterproof, conforming to CGSB 71-GP-24M.
 - .1 Air-Bloc 21 by Monsey Bakor
 - .2 Shur Stik 99 by The GH Company
 - .3 PL Premium by LePage
- .3 Primer for concrete and masonry surfaces recommended by the adhesive manufacturer for the materials to be adhered.

2.2 Accessories

- .1 Sealing Tape: minimum 65 mm width, polypropylene sheathing tape with acrylic adhesive.
- .2 Rough Hardware: Nails and staples as required for installation of insulation and membrane materials, galvanized to CSA B111 and B34.
- .3 Mechanical Fastening: galvanized screw type fasteners with 25 mm galvanized plate washers. Screws shall be 13 mm longer than the combined thickness of the insulation and sheathing.
- .4 Vapour Retarder: As specified in Section 07 26 00.

PART 3 EXECUTION

3.1 Installation – General

- .1 Install insulation of types indicated, or, where not indicated, as appropriate, to provide a continuously un-interrupted building envelope in accordance with the requirements of the reference standards.
- .2 Install insulation after building substrate materials are dry.
- .3 Install insulation to maintain continuity of thermal protection to building elements and spaces.
- .4 Fit insulation tightly around all structural angles, penetrations and other protrusions.
- .5 Cut and trim insulation neatly to fit spaces. Butt joints tightly; offset vertical joints. Use only
- .6 Insulation board materials free from chipped or broken edges.
- .7 Sizes of materials shall be consistent with the module of the system.
- .8 Do not enclose or conceal insulation until it has been inspected by the Consultant.

3.2 Perimeter Insulation

- .1 Do not proceed with installation until concrete surfaces are dry and cured, and water proofing membranes have been inspected and approved.
- .2 Install perimeter insulation vertically just prior to backfilling.
- .3 Prime porous concrete surfaces.
- .4 Apply adhesive in gobs or pads to the back of the insulation board in accordance with manufacturer's instructions. Joints shall be left dry with joints brought into tight contact. Apply insulation to the wall with a slight sliding motion to ensure good contact.
- .5 Protect insulation from damage until time for backfilling.

- .6 Following backfilling and prior to placement of underslab vapour barriers, install horizontal insulation. Install rigid insulation at perimeter of all exterior walls and for extent as indicated. Tightly butt joints.

3.3 Drainage Board Insulation

- .1 Verify that all masonry joints are struck flush and that other conditions are satisfactory for proper installation.
- .2 Remove concrete fins and mortar projections that interfere with placement of insulation boards.
- .3 Vertical Insulation:
 - .1 Apply insulation boards to exterior face of exterior foundation walls except where otherwise indicated.
 - .2 Extend insulation at least 610 mm down from immediately under floor slabs-on-grade.
 - .3 Adhere insulation to wall by applying 2" diameter spots of adhesive to insulation boards 400 mm o.c. both ways.
- .4 Cut insulation to fit snugly around pilasters, projections, curves and irregularities on the wall surface. Fill voids with insulation.

3.4 Cleaning

- .1 Proceed in accordance with Section 01 74 11 – Cleaning.

End of Section

PART 1 GENERAL

1.1 General

- .1 Conform to the requirements of Division 1.

1.2 Related Sections

- .1 Section 06 10 00 Rough Carpentry
- .2 Section 07 21 13 Building Insulation
- .3 Section 07 92 00 Joint Sealants

1.3 References

- .1 ASTM International, (ASTM)
 - .1 ASTM D412-16 Standard Test Methods for Vulcanized Rubber and Thermoplastic Elastomers—Tension
 - .2 ASTM D624-00 (2012) Standard Test Method for Tear Strength of Conventional Vulcanized Rubber and Thermoplastic Elastomers.
 - .3 ASTM D4541-17 Standard Test Method for Pull-Off Strength of Coatings Using Portable Adhesion Testers
 - .4 ASTM E96/E96M-16 Standard Test Methods for Water Vapor Transmission of Materials
 - .5 ASTM E330/E330M-14 Standard Test Method for Structural Performance of Exterior Windows, Doors, Skylights and Curtain Walls by Uniform Static Air Pressure Difference
 - .6 ASTM E783-02 (2010), Standard Test Method for Field Measurement of Air Leakage Through Installed Exterior Windows and Doors.
 - .7 ASTM E1186-17 Standard Practices for Air Leakage Site Detection in Building Envelopes and Air Barrier Systems
 - .8 ASTM E2178-13 Standard Test Method for Air Permeance of Building Materials
 - .9 ASTM E2357-17 Standard Test Method for Determining Air Leakage of Air Barrier Assemblies
- .2 Canadian General Standards Board (CGSB)
 - .1 CGSB 37-GP-56M, Membrane, Modified, Bituminous, Prefabricated and Reinforced for Roofing.
- .3 National Air Barrier Association (NABA)
 - .1 National Air Barrier Association's (NABA) Quality Assurance Program (QAP)

1.4 Submittals

- .1 Make submittals in accordance with Section 01 33 00 – Submittal Procedures.
- .2 Submit manufacturer's printed product literature, specifications and datasheet and include product characteristics, performance criteria, physical size, finish and limitations.
- .3 Submit manufacturer's complete set of standard details for air barriers.

1.5 Performance Requirements

- .1 Select and install wall and roof components and assemblies to resist air leakage caused by static air pressure across exterior wall and roof assemblies, including windows, glass, doors, and other interruptions to integrity of wall and roof systems; to maximum air leakage rate of 0.01 L/s.m² when subjected to pressure differential of 75 Pa as measured in accordance with ASTM E783, and ASTM E 330.
- .2 Select and install wall and roof components and assemblies to resist air leakage caused by

dynamic air pressure across exterior wall and roof assemblies, including windows, glass, doors and other interruptions to integrity of wall and roof systems; to maximum air leakage rate of 0.013 L/s.m² when subjected to hourly wind design loads in accordance with NBC, using 1 in 10 year probability, as measured in accordance with ASTM E783 and ASTM E330.

- .3 If ongoing testing is required throughout air barrier system installation, perform qualitative testing methods in accordance with ASTM E1186 and ASTM D4541.
- .4 Provide continuity of air barrier materials and assemblies in conjunction with materials described in other Sections.

1.6 Quality Assurance

- .1 Quality Assurance Program: Submit evidence of current Contractor accreditation and Installer certification under the National Air Barrier Association's (NABA) Quality Assurance Program (QAP).
- .2 Submit accreditation number of the Contractor and certification number(s) of the NABA Certified Installer(s).

1.7 Sequencing

- .1 Sequence work to permit installation of materials in conjunction with related materials and seals.

1.8 Shipping, Handling and Storage

- .1 Refer to Section 01 61 00 – Common Product Requirements.
- .2 Deliver, handle and store materials in accordance with manufacturer's printed instructions.

1.9 Waste Management and Disposal

- .1 Refer to Section 01 74 19 – Construction Waste Management and Disposal.

PART 2 PRODUCTS

2.1 Materials

- .1 Materials: as required to achieve specified performance criteria; meeting specified reference standards and functionally compatible with adjacent materials and components.
- .2 Air/vapour barrier membrane components and accessories must be obtained as a single-source from the membrane manufacturer to ensure total system compatibility and integrity.

2.2 Membranes

- .1 Self-adhered air/vapour barrier transition membrane shall SBS modified bitumen, self-adhering sheet membrane complete with a cross-laminated polyethylene film, and having the following physical properties:
 - .1 Thickness: 1.0 mm (40 mils) min.
 - .2 Air leakage: <0.01 L/s.m² @ 75 Pa to ASTM E283,
 - .3 Vapour permeance: 1.6 ng/Pa.m².s (0.03 perms) to ASTM E96,
 - .4 Low temperature flexibility: -30 degrees C to CGSB 37-GP-56M,

.5 Elongation: 200% to ASTM D412-modified.

.2 Acceptable Products:

- .1 Blueskin SA by Monsey-Bakor Inc.
- .2 Perm-A-Barrier by W.R. Grace & Co.
- .3 Air Shield by W.R. Meadows
- .4 ExoAir 110 by Tremco
- .5 DELTA-VENT SA by Cosella-Dörken
- .6 Sopraseal Stick 1100T by Soprema

2.3 Adhesive and Primers

- .1 As recommended by manufacturer.

2.4 Mastics & Termination Sealants

- .1 As recommended by manufacturer.

PART 3 EXECUTION

3.1 Manufacturer's Instructions

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheets.

3.2 General

- .1 Perform Work in accordance with National Air Barrier Association - Professional Contractor Quality Assurance Program and requirements for materials and installation.

3.3 Examination

- .1 Examine all surfaces to ensure conformance to the manufacturer's recommended surface conditions.

3.4 Preparation

- .1 Prepare substrate surfaces in accordance with air barrier material manufacturer's instructions.
- .2 All surfaces which are to receive flexible air barrier must be smooth, clean, dry, frost-free and in sound condition. All moisture, frost, grease, oils, loose mortar, dust, or other foreign materials which may impede the adhesion of the air barrier must be removed.
- .3 New mortar must be cured 14 days and must be dry before air barrier membrane is applied.
- .4 Concrete must be cured 28 days and dry before air barrier membrane is applied.
- .5 Remove any and all sharp protrusions and repair any defects such as spalled or loose aggregate areas.
- .6 Do not proceed with air barrier application until all substrate defects are repaired.

3.5 Installation

- .1 Install air barrier materials continuously over substrate in accordance with manufacturer's instructions. Partial application is not acceptable, and the insulation specified elsewhere is not intended to perform as the sole air barrier.
- .2 Prime surfaces and apply membrane in strict accordance with manufacturer's printed directions.
- .3 Primed surfaces not covered by air barrier membrane during the same working day must be reprimed.
- .4 Apply membrane by heating the surface in contact with the substrate with a trigger-activated propane torch, type as recommended by the manufacturer.
- .5 Cut sheet membrane into manageable sizes, position membrane for alignment prior to removing protective film.
- .6 Install membrane horizontally, in a shingle fashion starting at lowest point. Position membrane and remove protective film and press firmly into place. Ensure minimum 50 mm overlap at all end and side laps. Promptly roll the membrane surface and all laps with a countertop roller to ensure proper surface bond and effect the seal.
- .7 Tie-in to window frames, door frames, roofing systems, metal wall cladding, and at the interface of dissimilar materials as indicated or as necessary to achieve a continuous air seal throughout the building envelope. Seal with air barrier tape. Refer to manufacturer's standard details.
- .8 Ensure all projections including wall ties, are properly sealed with a trowel or caulk application of specified sealant.

3.6 Inspection and Repair

- .1 Inspect membrane thoroughly before covering and make any corrections to punctures, tears, voids and other obvious defects which would impede the membrane from performing as intended.
- .2 Notify Consultant when sections of work are complete so as to allow for review prior to installation of insulation. Remove, replace or repair materials not satisfactory to the Consultant and wait for re-inspection before covering work.

3.7 Cleaning and Protection

- .1 Proceed in accordance with Section 01 74 11 – Cleaning.
- .2 Protect air barrier materials from damage during installation and the remainder of the construction period, according to material manufacturer's written instructions.
- .3 Coordinate with installation of materials which cover the air barrier assemblies, to ensure exposure period does not exceed that recommended by the material manufacturer.
- .4 Clean spillage and soiling from adjacent construction using cleaning agents and procedures recommended by manufacturer of affected construction and acceptable to the primary material manufacturer.

End of Section

PART 1 GENERAL

1.1 General

- .1 Conform to the requirements of Division 1.

1.2 Related Sections

- .1 Section 02 41 19.13 Selective Building Demolition
- .2 Section 06 10 00 Rough Carpentry
- .3 Section 07 21 13 Building Insulation
- .4 Section 07 62 00 Sheet Metal Flashing and Trim
- .5 Section 07 92 00 Joint Sealants

1.3 References

- .1 ASTM International (ASTM)
 - .1 ASTM C208-12 (2017) e1 Standard Specification for Cellulosic Fiber Insulating Board
 - .2 ASTM C1177/C1177M-17 Standard Specification for Glass Mat Gypsum Substrate for Use as Sheathing
 - .3 ASTM C1278/C1278M-17 Standard Specification for Fiber-Reinforced Gypsum Panel
 - .4 ASTM D226/D226M-17 Standard Specification for Asphalt-Saturated Organic Felt Used in Roofing and Waterproofing
 - .5 ASTM D1863/D1863M-05(2018) Standard Specification for Mineral Aggregate Used on Built-Up Roofs
 - .6 ASTM D2178/D2178M-15a Standard Specification for Asphalt Glass Felt Used in Roofing and Waterproofing
 - .7 ASTM D3746/D3746M-85(2015)e1 Standard Test Method for Impact Resistance of Bituminous Roofing Systems
 - .8 ASTM D4586/D4586M-07(2018) Standard Specification for Asphalt Roof Cement, Asbestos-Free
 - .9 ASTM D4601/D4601M-04(2012)e1 Standard Specification for Asphalt-Coated Glass Fiber Base Sheet Used in Roofing
 - .10 ASTM E96/E96M-16 Standard Test Methods for Water Vapor Transmission of Materials
- .2 CSA Group (CSA)
 - .1 CAN/CSA-A123.2-03 (R2018) Asphalt-Coated Roofing Sheets.
 - .2 CAN/CSA A123.3-05 (R2015) Asphalt Saturated Organic Roofing Felt
 - .3 CAN/CSA-A123.4-04 (R2018) Asphalt for Constructing Built-Up Roof Coverings and Waterproofing Systems
 - .4 CAN/CSA-A123.16-04(R2014) Asphalt-Coated Glass Base Sheet.
 - .5 CSA A123.17-05(R2014) Asphalt Glass Felt Used for Roofing and Waterproofing.
 - .6 CAN/CSA-A123.21-14 Standard Test Method for the Dynamic Wind Uplift Resistance of Mechanically Attached Membrane-Roofing Systems
 - .7 CAN/CSA A247-M86 (R1996) Insulating Fibreboard
- .3 Canadian General Services Board (CGSB)
 - .1 CAN/CGSB-37.5,Cutback Asphalt Plastic Cement.
 - .2 CGSB 37-GP-9Ma Primer, Asphalt, Unfilled, for Asphalt Roofing, Dampproofing and Waterproofing.
 - .3 CGSB 37-GP-15M Application of Asphalt Primer for Asphalt Roofing, Dampproofing and Waterproofing.
 - .4 CGSB 37-GP-19M, Cement Plastic, Cutback Tar.
 - .5 CAN/CGSB-37.29 Rubber-Asphalt Sealing Compound.

- .6 CAN/CGSB-51.33-M Vapour Retarder Sheet, Excluding Polyethylene, for Building Construction.
- .4 Underwriters Laboratories of Canada (ULC)
 - .1 ULC 102-18 Test for Surface Burning Characteristics of Building Materials and Assemblies.
 - .2 ULC 704-11 Standard for Thermal Insulation Polyurethane and Polyisocyanurate, Boards, Faced.
 - .3 ULC 770 -15 Standard Test Method for Determination of Long Term Thermal Resistance of Closed Cell Thermal Insulating Foams.
 - .4 Underwriters' Laboratories of Canada (ULC) List of Equipment and Materials Volume II Building Construction including supplements to date.
- .5 Canadian Roofing Contractors Association (CRCA) Metric Specification Manual.
- .6 Factory Mutual Engineering Corporation (FM): Loss Prevention Data, Insulated Steel Deck 1-28, FM Approval Guide including Revisions to date.

1.4 Submittals

- .1 Make submittals in accordance with Section 01 33 00 – Submittal Procedures.
- .2 Submit complete list of all products intended for use, together with samples and manufacturer's technical literature.
- .3 Submit verification that materials and products meet performance requirements specified in the Referenced Standards.
- .4 Submit shop drawings of all components and accessories and including layout drawings and details for the tapered insulation system. Submit shop drawings for prefabricated work.
- .5 Submit shop drawings detailing roof size, membrane sheet placement, location and type of penetrations, type of vapour retarder, insulation and insulation fasteners.
- .6 Submit shop drawings for tapered insulation. Indicate degree of slope and layout of sloping boards and fill boards on roof surfaces. Ensure positive drainage to roof drains.

1.5 Quality Control

- .1 The Owner will appoint an Independent Inspection and Testing Company, to be paid out of the Cash Allowances, for testing and inspection of roofing systems.

1.6 Quality Assurance

- .1 Provide built-up roofing systems including insulation and all related materials to conform to ULC Class A design criteria, as shown and as specified herein.
- .2 The roofing Contractor shall be of recognized standing with a proven record of satisfactory installations, and shall be a member in good standing of the Canadian Roofing Contractors Association and/or the Ontario Industrial Roofing Contractors Association.
- .3 Roofing work shall be executed under the full time supervision of a competent foreman.
- .4 A membrane manufacturer's representative shall be available to review installation procedure and to impact the completed installation to verify compliance with all specifications and details.

1.7 Design Criteria

- .1 General: Installed roofing membrane system shall remain watertight; and resist specified wind uplift pressures, thermally induced movement, and exposure to weather without failure.
- .2 Compatibility between components of system and adjacent materials is essential.
 - .1 Provide written declaration to Consultant stating that materials and components, as assembled in system, meet this requirement.

1.8 Shipping, Handling and Storage

- .1 Refer to Section 01 61 00 – Common Product Requirements.
- .2 Deliver, handle and store materials in accordance with manufacturer's printed instructions.
- .3 Deliver and store materials undamaged in original containers with manufacturer's label and seals intact. All packed materials shall bear the manufacturer's name brand, and applicable specification number and printed instructions for storage and application. Materials not identified shall be removed off the site.
- .4 Store liquid materials in their original undamaged containers in a clean, dry, protected location and within the temperature range required by roofing system manufacturer.
- .5 All materials shall be protected from moisture at all times. Protect roof insulation materials from physical damage and from deterioration by sunlight, moisture, soiling, and other sources. Comply with insulation manufacturer's written instructions for handling, storing, and protecting during installation.
- .6 No material shall be placed in direct contact with the earth.
- .7 Handle and store roofing materials and place equipment in a manner to avoid permanent deflection of deck.

1.9 Environmental Requirements

- .1 Apply roofing in periods only approved by the roofing inspector.
- .2 Weather Limitations: Proceed with installation only when current and forecasted weather conditions permit roofing system to be installed in accordance with manufacturer's written instructions and guarantee requirements.
- .3 Materials shall not be applied during inclement weather. Do not apply roofing over wet decks, or where frost or snow is present.

1.10 Protection

- .1 Provide adequate protection of materials and work of this trade from damage by weather, traffic and other causes. At the end of each day's work seal exposed edges of roofing membrane. Protect work of other trades from damage resulting from the work of this trade. Make good such damage at no additional expense to the Owner and to the satisfaction of the Consultant.

- .2 Protect adjacent properties and public areas in accordance with regulatory requirements and municipal by-laws.

1.11 Fire Protection

- .1 Protect roof junctions at parapets, roof curbs and upstands with a fire-resistant tape or barrier to prevent combustible materials within assemblies from ignition arising from the use of torches. Install prior to installation of base sheets.
- .2 Use a heat detector gun to spot any smouldering or concealed fire at the end of each work day. Establish a minimum one (1) hour fire watch after application.
- .3 Do not apply torch directly to dry or unprotected wood surfaces.
- .4 Maintain a clean site and have one approved ABC fire extinguisher within 6 meters of each roofing torch. Respect all safety measures described in manufacturer's technical data sheets. Do not place torches near combustible or flammable products.

1.12 Waste Management and Disposal

- .1 Refer to Section 01 74 19 – Construction Waste Management and Disposal.

1.13 Warranty

- .1 Warrant the work of this Section against defects of workmanship and material, for a period of two years from the date of Substantial Performance and agree to make good promptly any defects which occur or become apparent within the warranty period.
- .2 Defects to include but not be restricted to leaking, failure to stay in place, undue expansion, lifting, deformation, loosening and splitting of seams, joint deformation, failure to adhere, deterioration, blisters, etc.

PART 2 PRODUCTS

2.1 Materials

- .1 General
 - .1 Use materials as specified herein only.
 - .2 Compatibility between roofing system components is essential. All materials used on the roof shall be endorsed for compatibility by the applicator and the materials manufacturer.
 - .3 Materials shall conform to the reference specification numbers named including all revisions to date or shall be the product named.
- .2 Asphalt Primer: to CGSB 37-GP-9Ma, unfilled, penetrating, non-fibrated, cutback asphalt.
- .3 Substrate Board: Glass Mat, Gypsum Board: to ASTM C1177, water resistant board, 13 mm thick or as noted on drawings.
- .4 Vapour Retardant: ASTM E96 Procedure A Perm rating of 0.4 or less, bitumen resistant Type I vapour barrier in accordance with CAN/CGSB 51-33:
 - .1 GAF Materials Corp/Lexsuo Permte (Ultra) Vapour Retarder.
 - .2 DuroPerm Vapour Retarder by Johns Manville.

-
- .5 Vapour Retardant Adhesive: Non-flammable type, compatible with vapour retardant membranes and substrate:
 - .1 GAF Materials Corp/Lexsoco Permamate II adhesive.
 - .2 DuroPerm VR Adhesive by Johns Manville
 - .6 Roofing Asphalts: Type 1 and 3 oxidized asphalt conforming to CSA A123.4. Type 2 asphalt shall be used for horizontal surfaces and slopes up to 1:8, and type 3 for vertical and sloped surfaces over 1:8.
 - .7 Polyisocyanurate Base Insulation, Type 3, Class 2 manufactured with HC blowing agent laminated to heavy black non-asphaltic fibre reinforced felt facers on top and bottom surfaces. Meeting the requirements of CAN/ULC S126 and CAN/ULC S107 and conforming to CAN/ULC S704 and CAN/ULC S770 for Long Term Thermal Resistance (LTTR) R- values. Evaluated and listed by current CCMC approvals guide and approved and listed by Factory Mutual Global for Class 1-60/75/90 windstorm classification and meeting FM 4450 approval requirements for Class 1A Fire as a component in roof deck construction. Provide insulation thickness to match existing but not less than 38 mm, square edges. Minimum compressive strength of 138 Kpa.
 - .1 E'NRG'Y 3 by Johns Manville
 - .2 Lexsoco Isolex Isocyanurate
 - .3 Firestone ISO+GL
 - .4 Atlas AC Foam II by Atlas Roofing Corporation.
 - .5 Energy Guard ISO by GAF Materials Corp.
 - .6 H-Shield Iso by Carlisle Syntec Canada.
 - .8 Tapered Insulation: compatible with roofing system, slope as shown on the drawings, factory tapered to provide slope to drains (slopes as per drawings), wax-impregnated fibreboard, to CAN/ULC-S706.
 - .9 Insulation Accessories: As required, preformed crickets, sumps and mitres to match roof insulation.
 - .10 Insulation Fasteners at Steel Deck: FM approved and tested with specified underlayment substrate board to FM I-90 Uplift Classification. Self-tapping metal screw and plate fastening devices approved by the manufacturer of the substrate and of appropriate length to penetrate the top flange of the deck a minimum of 19 mm, but not long enough to extend past the bottom of the deck rib. Fasteners shall be coated with Zn-97 base coat and composite flouropolymer finish.
 - .11 Cover Board: to ASTM C208, compatible with roof system: 13 mm fibreboard overlay, 1220 x 1220 mm size. Minimum compressive strength of 310 kPa.
 - .12 Base Sheet: polyester/glass/polyester trillaminate reinforcement membrane coated with waterproofing asphalt; 1.5kg/m2 weight; to ASTM D228;
 - .13 Roofing Felt: ASTM D2178 Type IV inorganic fibreglass mat impregnated with asphalt.
 - .14 Cant Strips: ASTM C208, Type II, Grade 1 rigid board wood fiber insulation, or ASTM C728; rigid board perlite insulation cants 76 x 76 x 38 mm, preformed to 45 degree angle.
 - .1 GAF Materials Corp. Energy Guard Perlite Cant Strip or equivalent.
 - .15 Roof Surfacing Aggregate: To ASTM D1863, 9.5 mm pea gravel size well graded crushed or round, clean and dry, free from fines, splinters, dust, sand or organic impurities, soft or friable materials.

- .16 Base Sheet Flashing: Mop grade SBS modified bituminous membrane with minimum thickness of 2.2 mm and with minimum 180 g/m² polyester reinforcement. Type II, Class C, Grade 1 conforming to CGSB 37-GP-56M.
 - .1 GAF Material Corp. Rubberoid Mop Smooth Base Sheet.
 - .2 Soprema Elastophene 180 SS.

- .17 Cap Sheet Flashing: Mop grade SBS modified bituminous membrane with minimum thickness of 4.0 mm and with minimum 250 g/m² polyester reinforcement. Type I, Class A, Grade 2 conforming to CGSB 37-GP-56M.
 - .1 GAF Material Corp. Rubberoid Mop Plus.
 - .2 Soprema Sopralene 250GM.

- .18 Nails, bolts, screws and other flashings - same metal finish as sheet metal being used. The size of fastenings shall suit the applicable conditions. All nails, screws and other flashings shall be subject to the approval of the Consultant.

- .19 Caulking Sealant: Compatible with roofing materials, as specified in Section 07900.

- .20 Bituminous Paint: To CGSB 1-GP-108M.

- .21 Pitch Pockets: Lexsuco Spun Aluminum Mastic Pans.

- .22 Pourable Sealer: 2-part polyurethane sealer intended for use by the manufacturer to seal pitch pans and other penetrations.

- .23 Stack jacks (vent pipe flashings): Lexsuco or Thaler standard mill finish aluminum insulated vent stack covers applicable at all plumbing vent pipes. Rubber sleeves and sleeves supplied by other trades will not be acceptable.

- .24 Rain Collars and Clamps: Fabricated from same material as exhaust stacks, with continuously soldered seams and extending a minimum of 50 mm down face of sleeve. Allow 6 mm gap all around between rain collar and sleeve or pitch pockets. Clamps to be fabricated from same material as collar.

PART 3 EXECUTION

3.1 Existing Conditions

- .1 Examine work of other trades and notify in writing to the Consultant and Contractor that the work is acceptable or of any defects or discrepancies. Verify that work of other trades which penetrates roof deck or requires men and equipment to transverse roof deck has been completed or adequate protection is provided.

- .2 Examine surfaces for inadequate anchorage, foreign material, moisture and unevenness which would prevent the execution and quality of application of the roofing system as specified. Do not proceed with application of the roof system until defects are corrected. Installation of any part of the work without the written acceptance of such surfaces shall require immediate removal of such installed work.

3.2 Workmanship

- .1 Do workmanship in strict accordance with applicable standards in Canadian Roofing Contractors Association Roofing Specifications Manual except where specified otherwise and to the approval of the Consultant.
- .2 Regard the manufacturer's printed recommendations and specifications as the minimum requirement for materials, methods and workmanship not otherwise specified.
- .3 Do not overheat bitumen. Maximum temperature for type I, type II and type III oxidized asphalt is 245° C. Do not apply to the roof under 200° C. Once asphalt temperature exceeds 245° C the material will be considered unsatisfactory and must be removed from the site.
- .4 All plies of roofing felt except as otherwise specified shall be mopped solid and squeegeed into bitumen.
- .5 Unsuitable or damaged materials shall immediately be removed from the site.
- .6 Wherever two or more plies of roofing felt are applied to the surface of the built up roofing system, the edge of the roofing felt plies must not be left in a total raw edge thickness, but applied with progressive increases of 150 mm of each successive layer of felt applied.
- .7 Should at the conclusion of any day's work gravelling-in operations be incomplete or postponed, all newly applied roofing shall receive a continuous and uniform protective coating of bitumen.
- .8 Bitumen shall be supplied direct from the refinery. Bitumen temperature in tankers shall not exceed 190° C. Bitumen shall be transferred into standard kettles and heated to the required temperature. Tankers must be equipped with a thermometer at all times. Operator to leave the tanker lid open at all times to permit fumes to escape. Bitumen shall be maintained in the tanker at the lowest possible temperature.

3.3 Preparation

- .1 Remove existing roofing over areas shown, including stone ballast, roof membranes, flashings, cover board, insulations, cant strips and vapour retarders. Remove only enough roofing that can be replaced in the same day.
- .2 Inspect and remove or replace existing wood roof curbs and copings. New wood curbs and copings are specified in Section 06 10 00. Coordinate with others to ensure that all curbs, blocking and the like is in place, level and secure, prior to commencement of roofing.
- .3 Remove and dispose of existing metal siding and flashing assemblies at upper walls on High School.
- .4 Remove existing roof drains where required. Retrofit/extend drainage piping to suit new installation.
- .5 Remove and reinstall all mechanical equipment on the roof as necessary to facilitate application of new roof system. This includes temporary removal and replacement of any associated duct work. Temporary removal of any gas lines is the responsibility of the contractor and gas lines shall be reinstalled in accordance with applicable regulations and authorities having jurisdiction. Provide all adjustments necessary to suit new roof elevations.

- .1 Disconnection, removal and re-installation of existing equipment shall be performed by the mechanical or electrical contractor.
 - .6 Clean and prepare existing roof deck and other substrate materials suitable for new vapour retarder application in accordance with manufacturer's instructions.
- 3.4 Application: Substrate Board
- .1 Install glass mat substrate board and mechanically fasten over new metal roof deck and in accordance with manufacturer's directions.
- 3.5 Application: Vapour Retardant
- .1 Prime substrate and adhere roof vapour retarder over underlay board with approved adhesive at manufacturer's recommended rate.
 - .2 Overlap vapour retarder minimum 100 mm for side laps and 150 mm for end laps.
 - .3 Extend vapour retarder under cant strips and blocking. Extend to perimeter and deck protrusions.
 - .4 Seal roof vapour retarder to wall air/vapour barrier system with flexible flashing membranes to ensure continuity of building air/vapour barrier envelope.
 - .5 No more vapour retardant shall be applied in any one working day than can be covered with insulation and properly dried-in.
 - .6 Vapour retardant shall not be installed to bridge across expansion joints or similar devices.
 - .7 Inspect entire vapour retardant application and proceed with installation only after unsatisfactory conditions have been corrected.
- 3.6 Installation: Roof Insulation
- .1 Keep insulation dry at all times. Insulation showing evidence of having been dampened since its manufacture or separation of laminations shall not be used. Lay insulation panels in rows with all joints staggered.
 - .2 Lay board in tight contact to prevent gaps and resulting loss of thermal insulation value. Cut boards to fit neatly around projections through roof.
 - .3 Fasten through insulation to steel deck with approved screw and plate fasteners spaced in accordance with Factory Mutual requirements and reviewed shop drawings. Fasteners shall penetrate deck a minimum of 19 mm.
 - .4 Install tapered insulation in accordance with reviewed shop drawings. Adhere insulation with adhesive. Firmly set the units of roof insulation, long joints continuous and short joints staggered, into a full width mopping of hot asphalt (within 14° C of the EVT). The asphalt shall be applied at a nominal rate of 1.46 kg/m². Insulation shall be installed in (2) two layers as per the drawings. All joints must be offset a minimum of 150 mm between layers. Walk-in insulation boards to ensure full embedment in asphalt.

- .5 At roof drains, reduce the insulation thickness by 13 mm for a distance of 610 mm from the centre of the drain. Fill the flutes of the steel deck at roof drains with insulation board adhered with adhesive for a distance of 610 mm from the centre of the drain to ensure total support at all drains prior to placement of vapour retardant.
- .6 Cover board: Cover entire roof with a layer of cover board, fully adhered in a complete 100% hot mopping of asphalt type III, to the top layer of insulation. Embed cover board firmly into the hot asphalt.
- .7 Protect all exposed edges of insulation where roofing temporarily terminates at the end of a working day by forming a water cut-off. Water cut-off shall consist of 2 plies of felt continuously mopped and coated with asphalt, extending from the surface of the roof membrane minimum 200 mm onto the deck. Ensure water cut-off is continuously secured to the deck and is removed prior to proceeding with work the following day.
- .8 Insulation shall not be installed to bridge across expansion joints or control joints.

3.7 Installation: Cant Strips

- .1 Apply a continuous and uniform mopping of Type III asphalt along all intersections of roofing and vertical surfaces to the width of the cant strips. Immediately set cant strips in place. Lay true to line and level. Butt joints flush and accurately and mitre all corners.

3.8 Built Up Roofing Application

- .1 Roof membrane shall consist of 4 plies (base sheet plus 3 plies) of inorganic fibreglass and asphalt impregnated roofing felts laid in hot asphalt and covered with gravel.
- .2 Solidly mop surface of roof insulation with Type I hot asphalt at rate of 1.0 kg/m² and embed 4 plies of felts lapping each ply 700 mm over preceding one and mopping solidly between in a similar mopping of hot asphalt. Do not allow dry felts to contact each other.
- .3 Apply felts smooth, free from air pockets, wrinkles, fish mouths, prominent lap joints or tears. Lap end joints at least 150 mm and avoid end joints coinciding with underlying joints. Terminate all roofing felts at top of cant strip. Stagger the felts to finish in an even surface with all felt cant strip. Stagger the felts to finish in an even surface with all felt plies tightly sealed with asphalt at the top of all cant strips.
- .4 At parapets apply two layers of felt strip flashing, the first layer to extend 250 mm onto roofing and the second layer 200 mm and each layer carried up full height to top of vertical surface in an even line and secure to wood blocking with large headed roofing nails and to each other with Type III asphalt.
- .5 At curbs and other vertical surfaces, similarly flash with two ply of felt strip flashing, extending 300 mm high above roof level, unless otherwise shown, or extending full height of curbs, felts turned over top of curb and down face of wood blocking and nailed thereto and install flashings.
- .6 Install built-up flashings at all roof curbs, sleepers, vent pipes, ducts, and all other projections through the roof as required and as shown on the drawings.

3.9 Flashing

- .1 Cap, parapet and curb flashings shall consist of two layers of SBS modified bituminous membrane flashing hot mopped into Type III asphalt covered with sheet metal flashing specified under Section 07 62 00.
- .2 Install base sheet of SBS modified bituminous base sheet in type III asphalt ensuring full bond and extending a minimum of 150 mm onto roof surface. Properly secure flashings to their support without sags, blisters, fishmouths or wrinkles. Terminate as detailed.
- .3 Install cap sheet of SBS modified bituminous base sheet in type III asphalt ensuring full bond and extending a minimum of 200 mm onto roof surface. Properly secure flashings.
- .4 Sheet metal flashings shall be installed as specified in Section 07 62 00.

3.10 Gravel Surfacing

- .1 Temporarily block all roof hoppers when gravel is being placed to prevent gravel from falling down leaders into drains. Exercise care to remove temporary blocking when work is not proceeding to avoid flooding.
- .2 Over final ply of felt apply a flood coating of hot asphalt at rate of 3.0 kg/m² using an approved bitumen and gravel application machine and embed roofing gravel. Apply gravel at rate of 20 kg/m². Sweep up excess gravel with mechanical broom and re-pour any bare spots. Apply a second topping of asphalt and gravel using 3.0 kg/m² of asphalt and spread gravel to provide a total uniform weight (including asphalt) of not less than 36 kg/m² for both pours.

3.11 Control Joints

- .1 Supply and install control joints where indicated on the drawings. Roofing felts shall be solid mopped in place and terminate at top of cants. Install flexible flashing in the longest convenient lengths mopped in place with hot Type III asphalt, extending out onto roofing felts a distance of 300 mm from toe of cant and carried up over face of cant strip, up full height of curb and turned over wood blocking and nailed thereto with large headed roofing nails.

3.12 Mechanical and Electrical Equipment

- .1 Remove and reinstall all mechanical equipment on the existing roofs as necessary to facilitate application of new roofing. This includes temporary removal and replacement of any associated duct work. Temporary removal of any gas lines is the responsibility of the contractor and gas lines shall be reinstalled in accordance with applicable regulations and authorities having jurisdiction. Provide all adjustments necessary to suit new roof elevations.
- .2 Disconnection, removal and re-installation of existing equipment shall be performed by a qualified Mechanical or electrical contractor as approved by the Owner.
- .3 All electrical conduits and gas lines must be sufficiently supported as directed by the Consultant.
- .4 Install rain collars complete with clamping rings over all pitch pockets and stacks where vandal proof caps cannot be installed.
- .5 Provide purpose made stack jack flashings at all plumbing vents.
- .6 Seal flashing sleeves in accordance with manufacturer's directions and CRCA standard details.

3.13 Cleaning

- .1 Proceed in accordance with Section 01 74 11 – Cleaning.
- .2 Clean overspray and spillage from adjacent construction using cleaning agents and procedures recommended by manufacturer of affected construction.

3.14 Protection

- .1 Protect roofing system from damage and wear during remainder of construction period.

End of Section

PART 1 GENERAL

1.1 General

- .1 Conform to the requirements of Division 1.

1.2 Related Sections

- .1 Section 06 10 00 Rough Carpentry
- .2 Section 07 51 00 Built Up Bituminous Roofing
- .3 Section 07 92 00 Joint Sealants

1.3 References

- .1 ASTM International (ASTM)
 - .1 ASTM A653/A653M-18 Standard Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process
 - .2 ASTM D523-14 (2018) Standard Test Method for Specular Gloss
- .2 CSA Group (CSA)
 - .1 CSA B111 Wire Nails, Spikes and Staples.
 - .2 CSA 136-16 North American Specification for the Design of Cold-Formed Steel Structural Members
- .3 Canadian General Services Board (CGSB)
 - .1 CAN/CGSB 1.108-M Bituminous Solvent Type Paint.
 - .2 CAN/CGSB-37.5 Cutback Asphalt Plastic Cement.
 - .3 CAN/CGSB-51.32 Sheathing, Membrane, Breather Type.
- .4 Canadian Sheet Steel Building Institute (CSSBI)
 - .1 CSSBI - Standard Practice for Sheet Steel Cladding.
 - .2 CSSBI 20M-91 Sheet Steel Cladding for Architectural and Industrial Applications.
 - .3 CSSBI B16-94 Prefinished Sheet Steel for Building Construction.
- .5 Canadian Roofing Contractors Association (CRCA) Roofing Specifications Manual.

1.4 Submittals

- .1 Make submittals in accordance with Section 01 33 00 – Submittal Procedures.
- .2 Submit duplicate 300 x 300 mm samples of each type of sheet metal material, colour and finish when requested by the Consultant.

1.5 Design and Performance Requirements

- .1 Appearance: neatly and evenly lay out and install components. Exposed fastening devices not permitted.
- .2 Effects of Wind: resist positive and negative wind pressures without detrimental effects.
- .3 Water Control: prevent passage of water.
- .4 Thermal Movement: accommodate expansion and contraction of component parts without buckling, failure of joints, undue stress on fasteners and other detrimental effects.
- .5 Compatibility: components shall be compatible with dissimilar metals and materials with which they are in contact or fastened to so as to prevent corrosion, staining and other detrimental effects. If

required, treat or separate contact surfaces with inert and non-staining insulation material to achieve compatibility.

1.6 Quality Assurance

- .1 Work of this Section shall be performed by a qualified sheet metal contractor with a minimum of 5 years of experience in the type of work required and specified. Submit proof of experience where requested by the Consultant.

1.7 Shipping, Handling and Storage

- .1 Refer to Section 01 61 00 – Common Product Requirements.
- .2 Materials shall be handled and stored on the job in such a manner that no damage shall be done to the material or the structures.
- .3 Materials showing evidence of improper handling and storage shall be rejected and removed from the site at no additional expense to the Owner.

1.8 Waste Management and Disposal

- .1 Refer to Section 01 74 19 – Construction Waste Management and Disposal.

1.9 Warranty

- .1 Warrant the work of this Section against defects of workmanship and material, for a period of five years from the date of Substantial Performance and agree to make good promptly any defects which occur or become apparent within the warranty period.
- .2 Submit manufacturer's warrantee that pre-finished materials will not lose film integrity for 25 years and will not chalk or fade for 20 years following date of Substantial Performance.

PART 2 PRODUCTS

2.1 General

- .1 Ensure compatibility of all materials in contact with roof membrane.

2.2 Materials

- .1 Sheet Metal: 0.48 mm thick galvanized sheet steel, commercial quality to ASTM A653 Grade 'A' with a minimum yield stress of 230 MPA, and a working stress of 144 MPA, to CSA S136. Material shall have Z275 designation zinc coating.
- .2 Prefinished material shall be colour coated with manufacturer's standard finish system equivalent to Valspar WeatherXL coating system, utilizing silicone modified polyester resin, minimum dry film thickness of 1.0 ± 0.1 mils when tested to ASTM D1005.
 - .1 Colour for all sheet metal flashing and trim shall be as selected by the Owner from full range of manufacturer's standard colours.
- .3 Continuous hook on strips and metal bellows: 0.65 mm galvanized sheet steel, zinc coating designation ZF275.

- .4 Isolation Coating: Alkali resistant exterior bituminous paint to CAN/CGSB 1.108-M.
- .5 Plastic Cement: To CAN/CGSB 37.5.
- .6 Nails, Bolts, Screws and Other Fastenings: same metal finish as sheet metal being used to CSA B111. The size of fastenings shall suit the applicable conditions.
- .7 Underlay: No. 15 perforated asphalt felt to CSA A123.3-M or dry sheathing, breather type, to CAN/CGSB-51.32
- .8 Cleats: Of same material, and temper as sheet metal, minimum 50 mm wide. Thickness same as sheet metal being secured.

PART 3 EXECUTION

3.1 General

- .1 Install sheet metal work in accordance with CRCA specifications and as detailed.
- .2 Use concealed fastenings except where approved before installation.

3.2 Fabrication

- .1 Fabricate metal flashings and other sheet metal work in accordance with applicable CRCA specifications and as indicated.
- .2 Form pieces in 2440 mm maximum lengths.
- .3 Hem exposed edges on underside 13 mm. Mitre and seal corners with sealant.
- .4 Form sections square, true and accurate to size, free from distortion and other defects detrimental to appearance or performance.
- .5 Apply isolation coating (two coats) to metal surfaces to be in contact with concrete or mortar or dissimilar metals.
- .6 Install underlay under sheet metal in accordance with CRCA "FL" series details. Lap joints 100 mm.
- .7 All seams shall be of the "slip lock type" that permit adequate movement without resulting in deformation or loosening of metal flashings. Lapped joints or exposed raw edges will not be accepted. Exposed edges shall be "double back" at least 13 mm. At eaves and parapets, metal shall be hooked over continuous starter strips minimum 1 gauge thicker than the metal used for flashing. Secure starter strips at 300 mm on centre or closer as required.
- .8 Where metal terminates under fascia boards, secure metal at 610 mm centres using specified fasteners. At curbs to openings or at sleepers, provide locked or standing seams at corners. Solder mitred corners, pop rivet or form standing seams.
- .9 Secure metal flashings in reglets at 610 mm centres and further secure metal to vertical surfaces at locks as required.

- .10 All flashings shall be installed in straight lines. Irregular or badly fitted work will not be accepted. Exposed fastenings will only be permitted where concealed fastening is not possible. Provide neoprene washers for exposed fasteners.
- .11 Imperfections in metal flashing work such as holes, dents, creases, or oil-canning will not be accepted.
- .12 Fabricate and install scuppers as detailed and in accordance with CRCA specifications and standards.

3.3 Caulking of Flashings

- .1 Sealants shall be as specified in Section 07 92 00 - Joint Sealants.
- .2 Caulk all joints in flashing.
- .3 Dissimilar metals in contact, or metals in contact with adjacent surfaces shall be separated from one another to prevent corrosion, staining, or electrolysis by use of approved methods and materials.
- .4 Do caulking between metal flashing and concrete.
- .5 Caulking compound shall be applied in strict accordance with the manufacturer's application instructions. Use proper surface primers where necessary.
- .6 Colour of caulking compound shall be the integral colour of the abutting material.

3.4 Cleaning

- .1 Proceed in accordance with Section 01 74 11 – Cleaning.

End of Section

PART 1 GENERAL

1.1 General

- .1 Conform to the requirements of Division 1.

1.2 Related Sections

- .1 Section 04 22 00 Concrete Unit Masonry
- .2 Section 07 92 00 Joint Sealants
- .3 Section 09 21 16 Gypsum Board

1.3 References

- .1 ASTM International (ASTM)
 - .1 ASTM E814-13a Standard Test Method for Fire Tests of Penetration Firestop Systems
 - .2 ASTM E 119 (ANSI/UL 263) Standard Test Methods for Fire Tests of Building Construction and Materials
 - .3 ASTM E 814 (ANSI/UL 1479) Standard Test Method for Fire Tests of Penetration Firestop Systems (under positive furnace pressure of minimum .01 inches of water column)
 - .4 ASTM E 84 (ANSI/UL 723) Standard Test Method for Surface Burning Characteristics of Building Materials
 - .5 ASTM E 1966 (ANSI/UL 2079) Standard Test Method for Fire-Resistive Joint Systems
 - .6 ASTM E 2307 Standard Test Method for Determining Fire Resistance of Perimeter Fire Barriers Using Intermediate-Scale, Multi-story Test Apparatus
 - .7 ASTM E 136 Standard Test Method for Behavior of Material in a Vertical Tube Furnace at 750° C
- .2 Ontario Building Code
- .3 Underwriter's Laboratories of Canada (ULC)
 - .1 CAN/ULC S101-07, Standard Methods of Fire Endurance Tests of Building Construction and Materials
 - .2 CAN/ULC S102.2-10, Method of Test for Surface Burning Characteristics of Flooring, Floor Coverings, and Miscellaneous Materials and Assemblies
 - .3 CAN/ULC S115-11, Standard Method of Fire Tests of Firestop Systems
- .4 NFPA 252 Standard Methods of Fire Test and Door Assemblies
- .5 Health Canada/Workplace Hazardous Materials Information System (WHMIS)
 - .1 Material Safety Data Sheets (MSDS).
- .6 South Coast Air Quality Management District (SCAQMD) California State
 - .1 SCAQMD Rule 1168-03: Adhesives and Sealants.

1.4 Submittals

- .1 Make submittals in accordance with Section 01 33 00 – Submittal Procedures.
- .2 Product Data:
 - .1 Submit manufacturer's printed product literature, specifications and datasheet and include product characteristics, performance criteria, physical size, finish and limitations.
 - .2 Submit two (2) copies of WHMIS MSDS - Material Safety Data Sheets.
- .3 Shop Drawings:
 - .1 Submit shop drawings to show location, proposed material, reinforcement, anchorage, fastenings and method of installation.

- .2 Construction details should accurately reflect actual job conditions.
- .4 Samples:
 - .1 Submit duplicate 300 x 300 mm samples showing actual fire stop material proposed for project.
- .5 Quality Assurance Submittals: submit following in accordance with Section 01 45 00 - Quality Control.
 - .1 Test reports: in accordance with CAN/ULC-S101-07 for fire endurance and CAN/ULC-S102-10 for surface burning characteristics.
 - .2 Submit certified test reports from approved independent testing laboratories, indicating compliance of applied fire stopping with specifications for specified performance characteristics and physical properties
 - .3 Certificates: submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.
 - .4 Manufacturer's Instructions: submit manufacturer's installation instructions and special handling criteria, installation sequence, cleaning procedures.
- 1.5 Definitions
 - .1 Fire Stop Material: device intended to close off opening or penetration during fire or materials that fill openings in wall or floor assembly where penetration is by cables, cable trays, conduits, ducts and pipes and poke-through termination devices, including electrical outlet boxes along with their means of support through wall or floor openings.
 - .2 Single Component Fire Stop System: fire stop material that has Listed Systems Design and is used individually without use of high temperature insulation or other materials to create fire stop system.
 - .3 Multiple Component Fire Stop System: exact group of fire stop materials that are identified within Listed Systems Design to create on site fire stop system.
- 1.6 Quality Assurance
 - .1 One installer shall install all firestopping on the project. Each trade shall not firestop their own service penetrations. Installer shall be certified by fire stopping manufacturer.
 - .2 Qualifications:
 - .1 Qualified Installer: specializing in fire stopping installations with 5 years documented experience approved and trained by manufacturer.
 - .3 Pre-Installation Meetings: convene pre-installation meeting one week prior to beginning work of this Section, with contractor's representative and Consultant to:
 - .1 Verify project requirements.
 - .2 Review installation and substrate conditions.
 - .3 Co-ordination with other building subtrades.
 - .4 Review manufacturer's installation instructions and warranty requirements.
 - .4 Site Meetings:
 - .1 As part of Manufacturer's Services described in 3.5- Field Quality Control, schedule site visits, to review Work, at stages listed.
 - .2 After delivery and storage of products, and when preparatory Work is complete, but before installation begins.
 - .3 Twice during progress of Work at 25% and 60% complete.

- .4 Upon completion of Work, after cleaning is carried out.
- .5 Single Source Responsibility: Obtain through-penetration fire-stop systems for each kind of penetration and construction condition indicated from a single manufacturer.

1.7 Sustainable Requirements

- .1 Materials shall be Low VOC type conforming to SCAQMD Rule 1168-03. Maximum VOC level of firestopping materials shall be 250 g/l.

1.8 Shipping, Handling and Storage

- .1 Refer to Section 01 61 00 – Common Product Requirements.
- .2 Deliver, handle and store materials in accordance with manufacturer's printed instructions.
- .3 Deliver materials to the site in undamaged condition and in original unopened containers, marked to indicate brand name, manufacturer, ULC markings.
- .4 Storage and Protection:
 - .1 Store materials indoors in dry location and in accordance with manufacturer's recommendations in clean, dry, well-ventilated area.
 - .2 Replace defective or damaged materials with new.

1.9 Waste Management and Disposal

- .1 Refer to Section 01 74 19 – Construction Waste Management and Disposal.

PART 2 PRODUCTS

2.1 Materials

- .1 All fire stopping shall consist of ULC listed firestop system.
- .2 All firestopping material shall be:
 - .1 From one manufacturer;
 - .2 Intumescent where an appropriate system exists.
- .3 Fire stopping and smoke seal systems: ULC listed in accordance with CAN/ULC S115-11.
 - .1 Asbestos-free materials and systems capable of maintaining effective barrier against flame, smoke and gases in compliance with requirements of CAN/ULC-S115-11 and not to exceed opening sizes for which they are intended.
- .4 Service penetration assemblies: ULC listed systems tested to CAN/ULC-S115-11.
- .5 Service penetration fire stop components: ULC listed and certified by test laboratory to CAN/ULC-S115-11.
- .6 Fire-resistance rating of installed fire stopping assembly in accordance with NBC.
- .7 Fire stopping and smoke seals at openings intended for ease of re-entry such as cables: elastomeric seal.
- .8 Fire stopping and smoke seals at openings around penetrations for pipes, ductwork and other mechanical items requiring sound and vibration control: elastomeric seal.

-
- .9 Primers: to manufacturer's recommendation for specific material, substrate, and end use.
 - .10 Water (if applicable): potable, clean and free from injurious amounts of deleterious substances.
 - .11 Damming and backup materials, supports and anchoring devices: to manufacturer's recommendations, and in accordance with tested assembly being installed as acceptable to authorities having jurisdiction.
 - .12 Sealants for vertical joints: non-sagging.
 - .13 General: Provide fire-stopping systems that are produced and installed to resist the spread of fire, according to requirements indicated, and the passage of smoke and other gases.
 - .14 F-Rated Through-Penetration Fire-stop Systems: Provide through-penetration fire-stop systems with F ratings indicated, but not less than that equaling or exceeding the fire-resistance rating of the constructions penetrated.
 - .15 T-Rated Through-Penetration Fire-stop Systems: Provide through-penetration fire-stop systems with T ratings, in addition to F ratings, where indicated and where systems protect penetrating items exposed to contact with adjacent materials in occupy-able floor areas. T-rated assemblies are required where the following conditions exist:
 - .1 Where fire-stop systems protect penetrations located outside of wall cavities.
 - .2 Where fire-stop systems protect penetrations located outside fire-resistive shaft enclosures.
 - .3 Where fire-stop systems protect penetrations located in construction containing doors required to have a temperature-rise rating.
 - .4 Where fire-stop systems protect penetrating items larger than a 100 mm diameter nominal pipe or 10,000 mm² in overall cross-sectional area.
 - .16 Fire-Resistive Joint Sealants: Provide joint sealants with fire-resistance ratings indicated, but not less than that equaling or exceeding the fire-resistance rating of the construction in which the joint occurs.
 - .17 For fire-stopping exposed to view, traffic, moisture, and physical damage, provide products that do not deteriorate when exposed to these conditions.
 - .1 For piping penetrations for plumbing and wet-pipe sprinkler systems, provide moisture-resistant through-penetration fire-stop systems.
 - .2 For floor penetrations with annular spaces exceeding 4 inches or more in width and exposed to possible loading and traffic, provide fire-stop systems capable of supporting the floor loads involved either by installing floor plates or by other means.
 - .3 For penetrations involving insulated piping, provide through-penetration fire-stop systems not requiring removal of insulation.
 - .18 For firestopping exposed to view, provide products with flame-spread values of less than 25 and smoke-developed values of less than 450.
 - .19 Compatibility: Provide fire-stopping composed of components that are compatible with each other, the substrates forming openings, and the items, if any, penetrating the firestopping under conditions of service and application, as demonstrated by fire-stopping manufacturer based on testing and field experience.
 - .20 Accessories: Provide components for each fire-stopping system that are needed to install fill materials and to comply with "System Performance Requirements". Use only components specified by the fire-stopping manufacturer and approved by the qualified testing and inspecting agency for the designated fire resistance-rated systems. Accessories include but are not limited

to the following items:

- .1 Permanent forming/damming/backing materials including the following:
 - .1 Semi-refractory fibre (mineral wool) insulation.
 - .2 Ceramic fibre.
 - .3 Sealants used in combination with other forming/damming materials to prevent leakage of fill materials in liquid state.
 - .4 Fire-rated formboard.
 - .5 Joint fillers for joint sealants.
 - .2 Temporary forming materials.
 - .3 Substrate primers.
 - .4 Collars.
 - .5 Steel sleeves.
- .21 Applications: Provide fire-stopping systems composed of materials specified in this Section that comply with system performance and other requirements.
- .22 Environmental Conditions: Do not install fire-stopping when ambient or substrate temperatures are outside limits permitted by fire-stopping manufacturers or when substrates are wet due to rain, frost, condensation, or other causes.
- .23 Ventilation: Ventilate fire-stopping per fire-stopping manufacturers' instructions by natural means or, where this is inadequate, forced air circulation.
- .24 Comply with the requirements of the Workplace Hazardous Materials Information System (WHMIS) regarding use, handling, storage and disposal of hazardous materials and regarding labeling and provision of Material Safety Data Sheets (MSDS).

PART 3 EXECUTION

3.1 Manufacturer's Instructions

- .1 Compliance: comply with manufacturer's written recommendations or specifications.

3.2 Preparation

- .1 Examine sizes and conditions of voids to be filled to establish correct thicknesses and installation of materials.
- .2 Ensure that substrates and surfaces are clean, dry and frost free.
- .3 Prepare surfaces in contact with fire stopping materials and smoke seals to manufacturer's instructions.
- .4 Maintain insulation around pipes and ducts penetrating fire separation without interruption to vapour retarder
- .5 Mask where necessary to avoid spillage and over coating onto adjoining surfaces; remove stains on adjacent surfaces.

3.3 Installation

- .1 Install fire stopping and smoke seal material and components in accordance with manufacturer's certified tested system listing and as necessary to maintain fire resistance ratings of floor and wall assemblies.

- .2 Provide fire stopping for all disciplines.
- .3 Seal holes or voids made by through penetrations, poke-through termination devices, and unpenetrated openings or joints to ensure continuity and integrity of fire separation are maintained.
- .4 Fill spaces between openings, ducts, pipes and unused sleeves passing through fire separations with firestop material and install firestopping systems in accordance with the appropriate ULC system number for the products and type of penetration.
- .5 Provide temporary forming as required and remove forming only after materials have gained sufficient strength and after initial curing.
- .6 Tool or trowel exposed surfaces to neat finish.
- .7 Remove excess compound promptly as work progresses and upon completion.

3.4 Sequences of Operation

- .1 Proceed only when submittals have been reviewed by Consultant.
- .2 Mechanical pipe insulation: certified fire stop system component.
 - .1 Ensure pipe insulation installation precedes fire stopping.

3.5 Field Quality Control

- .1 Inspections: notify Consultant when ready for inspection and prior to concealing or enclosing fire stopping materials and service penetration assemblies.
- .2 Employ a ULC accredited Designated Responsible Individual (DRI) to inspect and label all fire stop applications on site.
- .3 Manufacturer's Field Services:
 - .1 Obtain written report from manufacturer verifying compliance of Work, in handling, installing, applying, protecting and cleaning of product and submit Manufacturer's Field Reports as described in PART 1.4 - SUBMITTALS.
 - .2 Provide manufacturer's field services consisting of product use recommendations and periodic site visits for inspection of product installation in accordance with manufacturer's instructions.
 - .3 Schedule site visits, to review Work, as directed in PART 1.6 - QUALITY ASSURANCE.

3.6 Commissioning

- .1 Employ a ULC accredited Designated Responsible Individual (DRI) to inspect and label all fire stop applications on site. Submit DRI's written reports within 3 days of review, verifying compliance of Work.
- .2 Perform a thorough examination of the fire stopping system to determine if the assembly is installed as per its ULC listing.
- .3 Allow for destructive testing of installed firestopping. Repair all tested assemblies.
- .4 The examination shall take place prior to close-up to confirm assembly components and

installation configuration.

- .5 Any and all deviations from the ULC listed system shall be considered grounds for rejection and replacement.

3.7 Schedule

- .1 Fire stop and smoke seal at:
 - .1 Penetrations through fire-resistance rated concrete, masonry, and gypsum board partitions and walls.
 - .2 Top of fire-resistance rated partitions.
 - .3 Intersection of fire-resistance rated partitions.
 - .4 Control and sway joints in fire-resistance rated partitions and walls.
 - .5 Penetrations through fire-resistance rated floor slabs, ceilings and roofs.
 - .6 Around mechanical and electrical assemblies penetrating fire separations.
 - .7 Rigid ducts: greater than 129 cm²: fire stopping to consist of bead of fire stopping material between retaining angle and fire separation and between retaining angle and duct, on each side of fire separation.
 - .8 All electrical outlet boxes installed in fire rated gypsum board assemblies.
 - .9 All locations required by the Ontario Building Code.
 - .10 Any other locations indicated.

3.8 Cleaning

- .1 Proceed in accordance with Section 01 74 11 – Cleaning.
- .2 On completion and verification of performance of installation, remove surplus materials, excess materials, rubbish, tools and equipment.
- .3 Remove temporary dams after initial set of fire stopping and smoke seal materials.

End of Section

PART 1 GENERAL

1.1 General

- .1 Conform to the requirements of Division 1.

1.2 Related Sections

- .1 Section 04 22 00 Concrete Unit Masonry
- .2 Section 06 10 00 Rough Carpentry
- .3 Section 06 20 00 Finish Carpentry
- .4 Section 06 40 00 Architectural Woodwork
- .5 Section 07 21 13 Building Insulation
- .6 Section 07 84 00 Firestopping
- .7 Section 08 11 00 Metal Doors and Frames

1.3 References

- .1 ASTM International (ASTM)
 - .1 ASTM C510-16 Standard Test Method for Staining and Color Change of Single- or Multicomponent Joint Sealants
 - .2 ASTM C661-15 Standard Test Method for Indentation Hardness of Elastomeric-Type Sealants by Means of a Durometer
 - .3 ASTM C719-14 Standard Test Method for Adhesion and Cohesion of Elastomeric Joint Sealants Under Cyclic Movement (Hockman Cycle) 1, 2
 - .4 ASTM C794-18 Standard Test Method for Adhesion-in-Peel of Elastomeric Joint Sealants
 - .5 ASTM C834-17 Standard Specification for Latex Sealants
 - .6 ASTM C920-18 Standard Specification for Elastomeric Joint Sealants
 - .7 ASTM C1087-16 Standard Test Method for Determining Compatibility of Liquid-Applied Sealants with Accessories Used in Structural Glazing Systems
 - .8 ASTM C1193-16 Standard Guide for Use of Joint Sealants
 - .9 ASTM C1247-14 Standard Test Method for Durability of Sealants Exposed to Continuous Immersion in Liquids
 - .10 ASTM C1248-18 Standard Test Method for Staining of Porous Substrate by Joint Sealants
 - .11 ASTM C1311-14 Standard Specification for Solvent Release Sealants
 - .12 ASTM C1330-18 Standard Specification for Cylindrical Sealant Backing for Use with Cold Liquid-Applied Sealants.
 - .13 ASTM D412-16 Standard Test Methods for Vulcanized Rubber and Thermoplastic Elastomers—Tension
 - .14 ASTM D624-00(2012) Standard Test Method for Tear Strength of Conventional Vulcanized Rubber and Thermoplastic Elastomers
 - .15 ASTM D2203-01(2018) Standard Test Method for Staining from Sealants
 - .16 ASTM D2240-15e1 Standard Test Method for Rubber Property—Durometer Hardness
- .2 U. S. Environmental Protection Agency (EPA)
 - .1 EPA 40 CFR 59, Subpart D - National Volatile Organic Compound Emission Standards for Architectural Coatings.
- .3 South Coast Air Quality Management District (SCAQMD) California State
 - .1 SCAQMD Rule 1168-03: Adhesives and Sealants.

1.4 Submittals

- .1 Make submittals in accordance with Section 01 33 00 – Submittal Procedures.

- .2 Submit product data for all sealant materials and accessories including:
 - .1 Preparation instructions and recommendations.
 - .2 Standard drawings illustrating manufacturer's recommended sealant joint profiles and dimensions applicable to Project.
- .3 Joint Sealant Schedule: Indicate joint sealant location, joint sealant type, manufacturer and product name, and colour, for each application. Utilize joint sealant designations included in this Section.
- .4 Samples:
 - .1 Samples for Colour Selection: For each joint sealant type.
 - .2 Samples for Verification: For each joint sealant product, for each colour selected.
- .5 Greenguard Certificates: For each sealant and accessory product specified to meet volatile organic emissions standards of the Greenguard Children and Schools Certification.

1.5 Quality Assurance

- .1 Installer Qualifications: Company with minimum of three years of experience specializing in work of this section, employing applicators trained for application of joint sealants required for this project, with record of successful completion of projects of similar scope, and approved by manufacturer.
- .2 Single Source Responsibility: Provide joint sealants by a single manufacturer responsible for testing of Project substrates to verify compatibility and adhesion of joint sealants.
- .3 Caulking work shall be carried out in strict accordance with manufacturer's printed directions.
- .4 Preconstruction Manufacturer Laboratory Compatibility, Staining, and Adhesion Testing: Submit samples of each substrate or adjacent material that will be in contact with or affect joint sealants. Current manufacturer test data of products on matching substrates will be acceptable.
- .5 Adhesion: Use ASTM C719 and ASTM C794 to determine requirements for joint preparation, including cleaning and priming.
- .6 Compatibility: Use ASTM C1087 to determine materials forming joints and adjacent materials do not adversely affect sealant materials and do not affect sealant colour.

1.6 Shipping, Handling and Storage

- .1 Refer to Section 01 61 00 – Common Product Requirements.
- .2 Deliver, handle and store materials in accordance with manufacturer's printed instructions.

1.7 Project Conditions

- .1 Conform to manufacturer's recommended temperatures, relative humidity, and substrate moisture content for application and curing of sealants including special conditions governing use.
- .2 Ventilate area of work by use of approved portable supply and exhaust fans.

1.8 Waste Management and Disposal

- .1 Refer to Section 01 74 19 – Construction Waste Management and Disposal.

PART 2 PRODUCTS

2.1 Manufacturer

- .1 Basis-of-Design Products: Provide joint sealant products manufactured by Tremco, Inc., Commercial Sealants and Waterproofing, 220 Wicksteed Avenue, Toronto, www.tremcosealants.com, or comparable products of other manufacturer approved by Consultant.

2.2 Materials, General

- .1 VOC Content for Interior Applications: Provide sealants and sealant primers complying with the following VOC content limits per 40 CFR 59, Subpart D (EPA Method 24):
 - .1 Architectural Sealants: 250 g/L.
 - .2 Sealant Primers for Nonporous Substrates: 250 g/L.
 - .3 Sealant Primers for Porous Substrates: 775 g/L.
- .2 Low-Emitting Sealants for Interior Applications: Provide sealants and sealant primers complying with the testing and product requirements of the California Department of Health Services' "Standard Practice for the Testing of Volatile Organic Emissions from Various Sources Using Small-Scale Environmental Chambers."
- .3 Compatibility: Provide joint sealants and accessory materials that are compatible with one another, and with adjacent materials, as demonstrated by sealant manufacturer using ASTM C1087 testing and related experience.
- .4 Joint Sealant Standard: Comply with ASTM C920 and other specified requirements for each joint sealant.
- .5 Stain Test Characteristics: Where sealants are required to be non-staining, provide sealants tested per ASTM C1248 as non-staining on porous joint substrates specified.

2.3 Silicone Joint Sealants

- .1 SJS#1: Single-Component, Nonsag, Non-Staining, Moisture-Curing Silicone Joint Sealant: ASTM C920, Type S, Grade NS, Class 100/50, Use NT; SWRI validated.
 - .1 Basis of Design Product: Tremco Spectrem 1.
 - .2 Volatile Organic Compound (VOC) Content: 1 g/L maximum.
 - .3 Volatile Organic Emissions (VOE): Not greater than Greenguard Children & Schools Certification emissions levels.
 - .4 Staining, ASTM C1248: None on concrete, marble, granite, limestone, and brick.
 - .5 Colour: As selected by Consultant from manufacturer's standard line.
- .2 SJS#5: Mildew-Resistant, Single-Component, Acid-Curing Silicone Joint Sealant: ASTM C920, Type S, Grade NS, Class 25, Use NT.
 - .1 Basis of Design Product: Tremco Tremsil 200 Sanitary.
 - .2 Volatile Organic Compound (VOC) Content: 1 g/L maximum.
 - .3 Volatile Organic Emissions (VOE): Not greater than Greenguard Children & Schools Certification emissions levels.
 - .4 Colour: White and Clear.

2.4 Urethane Joint Sealants

- .1 UJS#1: Single-Component, Nonsag, Moisture-Cure, Polyurethane Joint Sealant: ASTM C920, Type S, Grade NS, Class 50, Use NT; Greenguard certified.

- .1 Basis of Design Product: Tremco Dymonic 100.
- .2 Volatile Organic Compound (VOC) Content: 40 g/L maximum.
- .3 Volatile Organic Emissions (VOE): Not greater than Greenguard Children & Schools Certification emissions levels.
- .4 Tensile Strength ASTM D412: 350 to 450 psi
- .5 Percent Elongation ASTM D412: 800 to 900%
- .6 Modulus at 100% ASTM D412: 75 to 85 psi
- .7 Tear Strength ASTM D412: 65 to 75 psi
- .8 Smoke Development ASTM E84: 5
- .9 Colour: As selected by Consultant from manufacturer's standard line.

2.5 Latex Joint Sealants

- .1 LJS#1: Latex Joint Sealant: Siliconized acrylic latex, ASTM C834, Type OP, Grade NF.
 - .1 Basis of Design Product: Tremco Tremflex 834.
 - .2 Volatile Organic Compound (VOC) Content: 35 g/L maximum.
 - .3 Volatile Organic Emissions (VOE): Not greater than Greenguard Children & Schools Certification emissions levels.
 - .4 Colour: White, paintable.

2.6 Acoustical Sealants

- .1 AJS#1: Acoustical/Curtainwall Sealant: Single-component, non-hardening, non-sag, paintable synthetic rubber-tested to reduce airborne sound transmission through perimeter joints and openings in building construction as demonstrated by testing of similar assemblies according to ASTM E90.
 - .1 Basis of Design Product: Tremco Tremco Acoustical/Curtainwall Sealant.
 - .2 Volatile Organic Compound (VOC) Content: 160 g/L maximum.
 - .3 Colour: White, paintable.

2.7 Joint Sealant Accessories

- .1 Cylindrical Sealant Backing: ASTM C1330, Type B non-absorbent, bi-cellular material with surface skin, or Type O open-cell polyurethane, as recommended by sealant manufacturer for application.
- .2 Bond Breaker Tape: Polymer tape compatible with joint sealant and adjacent materials and recommended by sealant manufacturer.
- .3 Joint Substrate Primers: Substrate primer recommended by sealant manufacturer for application.
- .4 Cleaners: Chemical cleaners acceptable to joint sealant manufacturer.
- .5 Masking tape: Non-staining, non-absorbent tape product compatible with joint sealants and adjacent joint surfaces.

PART 3 EXECUTION

3.1 Examination

- .1 Examine joint profiles and surfaces to determine if work is ready to receive joint sealants. Verify joint dimensions are adequate for development of sealant movement capability. Verify joint surfaces are clean, dry, and adequately cured. Proceed with joint sealant work once conditions meet sealant manufacturer's written recommendations.

3.2 Preparation

- .1 Joint Surface Cleaning: Clean joints prior to installing joint sealants using materials and methods recommended by sealant manufacturer. Comply with ASTM C1193.
 - .1 Remove curing compounds, laitance, form-release agents, dust, and other contaminants.
 - .2 Clean nonporous and porous surfaces utilizing chemical cleaners acceptable to sealant manufacturer.
 - .3 Protect elements surrounding the Work of this section from damage or disfiguration. Apply masking tape to adjacent surfaces when required to prevent damage to finishes from sealant installation.

3.3 Application

- .1 Sealant and Primer Installation Standard: Comply with ASTM C1193 and manufacturer's written instructions.
- .2 Joint Backing: Select joint backing materials recommended by sealant manufacturer as compatible with sealant and adjacent materials. Install backing material at depth required to produce profile of joint sealant allowing optimal sealant movement.
 - .1 Install joint backing to maintain the following joint ratios:
 - .1 Joints up to 13 mm wide: 1:1 width to depth ratio.
 - .2 Joints greater than 13 mm wide: 2:1 width to depth ratio; maximum 13 mm joint depth.
 - .2 Install bond breaker tape over substrates when sealant backings are not used.
- .3 Masking: Mask adjacent surfaces to prevent staining or damage by contact with sealant or primer.
- .4 Joint Priming: Prime joint substrates when recommended by sealant manufacturer or when indicated by preconstruction testing or experience. Apply recommended primer using sealant manufacturer's recommended application techniques.
- .5 Liquid Sealant Application: Install sealants using methods recommended by sealant manufacturer, in depths recommended for application. Apply in continuous operation from bottom to top of joint vertically and horizontally in a single direction. Apply using adequate pressure to fill and seal joint width.
 - .1 Tool sealants immediately with appropriately shaped tool to force sealants against joint backing and joint substrates, eliminating voids and ensuring full contact.
 - .2 Install sealant free of air pockets, foreign embedded matter, ridges, and sags.
 - .3 Tool exposed joint surface concave using tooling agents approved by sealant manufacturer for application.
- .6 Cleaning: Remove excess sealant using materials and methods approved by sealant manufacturer that will not damage joint substrate materials.
 - .1 Remove masking tape immediately after tooling joint without disturbing seal.
 - .2 Remove excess sealant from surfaces while still uncured.
- .7 Installation of Acoustical Sealant: At sound-rated assemblies and elsewhere as indicated, seal construction at perimeters, behind control joints, and at openings and penetrations on both sides of assemblies with a continuous bead of acoustical sealant. Comply with ASTM C919 and with manufacturer's written recommendations.

3.4 Exterior Joint Sealant Schedule

- .1 Exterior joints between different materials listed above.
 - .1 SJS#1: Single-component neutral-curing non-staining silicone sealant.
 - .2 UJS#1: Single-component non-sag urethane sealant.

3.5 Interior Joint Sealant Schedule

- .1 Interior perimeter joints of interior frames.
 - .1 LJS#1: Siliconized acrylic latex
- .2 Interior sanitary joints between plumbing fixtures, food preparation fixtures, and casework and adjacent walls, floors, and counters.
 - .1 SJS#5: Mildew-Resistant, Single-Component, nonsag, acid-curing silicone joint sealant.
- .3 Interior non-moving joints between interior painted surfaces and adjacent materials.
 - .1 LJS#1: Siliconized acrylic latex
 - .2 Joint-Sealant Colour: Paintable.
- .4 Interior exposed and non-exposed acoustical applications:
 - .1 AJS#1: Acoustical joint sealant.

3.6 Cleaning

- .1 Proceed in accordance with Section 01 74 11 – Cleaning.

End of Section

PART 1 GENERAL

1.1 General

- .1 Conform to the requirements of Division 1.

1.2 Related Sections

- .1 Section 04 22 00 Concrete Unit Masonry
- .2 Section 06 10 00 Rough Carpentry
- .3 Section 07 92 00 Joint Sealants
- .4 Section 08 71 10 Door Hardware
- .5 Section 09 21 16 Gypsum Board
- .6 Section 09 91 23 Interior Painting

1.3 References

- .1 ASTM International (ASTM)
 - .1 ASTM A653/A653M-15e1 Standard Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process
 - .2 ASTM B29-14 Standard Specification for Refined Lead
 - .3 ASTM B749-14 Standard Specification for Lead and Lead Alloy Strip, Sheet and Plate Products.
 - .4 ASTM E90-09 (2016) Standard Test Method for Laboratory Measurement of Airborne Sound Transmission Loss of Building Partitions and Elements.
 - .5 ASTM E413-16 Classification for Rating Sound Insulation.
 - .6 ASTM E1332-16, Standard Classification for Rating Outdoor-Indoor Sound Attenuation.
- .2 Canadian General Standards Board (CGSB)
 - .1 CAN/CGSB-1.181-99, Ready-Mixed Organic Zinc-Rich Coating.
 - .2 CGSB 41-GP-19M-84, Rigid Vinyl Extrusions for Windows and Doors.
- .3 Canadian Standards Association (CSA International)
 - .1 CSA-G40.20-13/G40.21-13, General Requirements for Rolled or Welded Structural Quality Steel/Structural Quality Steel.
 - .2 CSA W59-13, Welded Steel Construction (Metal Arc Welding).
- .4 Canadian Steel Door Manufacturers' Association (CSDMA)
 - .1 CSDMA, Recommended Specifications for Commercial Steel Doors and Frames, 2006.
 - .2 CSDMA, Selection and Usage Guide for Commercial Steel Door and Frame Products, 2009.
- .5 Underwriters Laboratories Canada (ULC)
 - .1 CAN/ULC-S104-10, Standard Method for Fire Tests of Door Assemblies.
 - .2 CAN/ULC-S105-09, Standard Specification for Fire Door Frames Meeting the Performance Required by CAN/ULC-S104.
 - .3 CAN/ULC-S701-11, Standard for Thermal Insulation, Polystyrene, Boards and Pipe Covering.
 - .4 CAN/ULC-S702-14, Standard for Thermal Insulation, Mineral Fibre, for Buildings.
 - .5 CAN/ULC-S704-11, Standard for Thermal Insulation, Polyurethane and Polyisocyanurate Boards, Faced.
- .6 National Fire Protection Association(NFPA)
 - .1 NFPA 80-2013, Standard for Fire Doors and Other Opening Protectives.
 - .2 ANSI/NFPA 252-2012 Standard Methods of Fire Tests of Door Assemblies.
 - .3 ANSI/UL10B Fire Tests of Door Assemblies.
 - .4 ANSI/UL10C Standard for Positive Pressure Fire Tests of Door Assemblies.

1.4 Submittals

- .1 Make submittals in accordance with Section 01 33 00 – Submittal Procedures.
- .2 Provide shop drawings
 - .1 Indicate each type of door, material, steel core thicknesses, mortises, reinforcements, location of exposed fasteners, openings, arrangement of hardware, and finishes.
 - .2 Indicate each type frame material, core thickness, reinforcements, location of anchors and exposed fastenings, reinforcing, fire rating and finishes.
 - .3 Include schedule identifying each unit, with door marks and numbers relating to numbering on drawings and door schedule.

1.5 Shipping, Handling and Storage

- .1 Refer to Section 01 61 00 – Common Product Requirements.
- .2 Deliver, handle and store materials in accordance with manufacturer's printed instructions.

1.6 Requirements of Regulatory Agencies

- .1 Steel fire rated doors and frames: labeled and installed by an organization accredited by Standards Council of Canada in conformance with CAN4-S104M (NFPA 252) for ratings specified or indicated.
- .2 Provide fire labeled frame products for those openings requiring fire protection ratings, as scheduled. Test products in strict conformance with CAN4-S104, ASTM E 152 or NFPA 252 and list by nationally recognized agency having factory inspection service and construct as detailed in Follow-up Service Procedures/Factory Inspection Manuals issued by listing agency to individual manufacturers.

1.7 Testing and Performance

- .1 Fire labeled products shall be provided for those openings requiring fire protection ratings as scheduled on the drawings. Products shall be tested in strict conformance with CAN4-S104 and listed by Underwriters Laboratory of Canada Ltd. or Warnock Hersey under an active Factory Inspection Program.
- .2 Product quality shall meet the standards established by the Canadian Steel Door Manufacturer's Association.
- .3 Door construction shall meet acceptance criteria of ANSI A224.1 and shall be certified as meeting Level A (1,000,000 cycles) and Twist Test Acceptance Criteria deflection not to exceed 6.4 mm/13.6 kg force, total deflection at 136.1 kg force not to exceed 64 mm and permanent deflection not to exceed 3.0 mm when tested in strict conformance with ANSI A250.4. Test shall be conducted by an independent nationally recognized accredited laboratory.
- .4 Core materials for insulated doors shall attain a thermal resistance rating of RSI 2.17 when tested in accordance with ASTM C177 or ASTM C518.

1.8 Waste Management and Disposal

- .1 Refer to Section 01 74 19 – Construction Waste Management and Disposal.

1.9 Warranty

- .1 Warrant the work of this Section against defects of workmanship and material, for a period of one (1) year from the date of Substantial Performance and agree to make good promptly any defects which occur or become apparent within the warranty period.

PART 2 PRODUCTS

2.1 Materials

- .1 Hot dipped galvanized steel sheet: to ASTM A 653M, ZF75, minimum base steel thickness in accordance with CSDMA Table 1 - Thickness for Component Parts.
- .2 Reinforcement channel: to CSA G40.20/G40.21, Type 44W, coating designation to ASTM A 653M, ZF75.

2.2 Door Core Material

- .1 Interior Doors: Structural small cell, 24.5mm maximum kraft paper 'honeycomb', weight 36.3 kg per ream minimum, density: 16.5 kg/m³ minimum sanded to required thickness. ULC approved.

2.3 Primer

- .1 Touch-up prime CAN/CGSB-1.181, organic zinc rich, rust inhibitive.
 - .1 Maximum VOC limit 50 g/L to GC-03.

2.4 Adhesives

- .1 Adhesive: maximum VOC content 50 g/L to SCAQMD Rule 1168.
- .2 Honeycomb cores and steel components: heat resistant, spray grade, resin reinforced neoprene/rubber (polychloroprene) based, low viscosity, contact cement.
- .3 Lock-seam doors: fire resistant, resin reinforced polychloroprene, high viscosity, low VOC sealant/adhesive or U.L.C. approved equivalent.

2.5 Accessories

- .1 Door silencers: single stud rubber/neoprene type, to CGSB-60-GP6 Type 6/180.
- .2 Metallic paste filler: to manufacturer's standard.
- .3 Sealant: As specified in Section 07 92 00.
- .4 Fiberglass: to CAN/ULC-S702-09-AM1, loose batt type, minimum density of 24 kg/m³.

2.6 Frame Fabrication - General

- .1 Fabricate frames in accordance with CSDMA specifications.
- .2 Fabricate frames to profiles and maximum face sizes as indicated.
- .3 Frames: 1.6 mm welded type construction.

- .4 Blank, reinforce, drill and tap frames for mortised, templated hardware, and electronic hardware using templates provided by finish hardware supplier. Reinforce frames for surface mounted hardware.
- .5 Protect mortised cutouts with steel guard boxes.
- .6 Prepare frame for door silencers, 3 for single door, 2 at head for double door.
- .7 Manufacturer's nameplates on frames and screens are not permitted.
- .8 Conceal fastenings except where exposed fastenings are indicated.
- .9 Provide factory-applied touch up primer at areas where zinc coating has been removed during fabrication.
- .10 Prepare frames to receive electrical conduit for door operators where indicated and required.

2.7 Frame Anchorage

- .1 Provide appropriate anchorage to floor and wall construction.
- .2 Locate each wall anchor immediately above or below each hinge reinforcement on hinge jamb and directly opposite on strike jamb.
- .3 Provide 2 anchors for rebate opening heights up to 1520 mm and 1 additional anchor for each additional 760 mm of height or fraction thereof.
- .4 Locate anchors for frames in existing openings not more than 150 mm from top and bottom of each jambs and intermediate at 660 mm on centre maximum.

2.8 Frames – Welded Type

- .1 Welding in accordance with CSA W59.
- .2 Accurately mitre or mechanically joint frame product and securely weld on inside of profile.
- .3 Cope accurately and securely weld butt joints of mullions, centre rails and sills.
- .4 Grind welded joints and corners to a flat plane, fill with metallic paste and sand to uniform smooth finish.
- .5 Securely attach floor anchors to inside of each jamb profile.
- .6 Weld in 2 temporary jamb spreaders per frame to maintain proper alignment during shipment.

2.9 Door Fabrication - General

- .1 Doors: swing type, flush.
- .2 All interior doors: insulated steel construction with honeycomb core laminated to face sheets under pressure.

- .3 Fabricate doors with longitudinal edges locked seam locked seamed, adhesive assisted welded. Seams: visible grind welded joints to a flat plane, fill with metallic paste filler and sand to a uniform smooth finish.
- .4 Doors: manufacturers' proprietary construction, tested and/or engineered as part of a fully operable assembly, including door, frame, gasketing and hardware in accordance with ASTM E330.
- .5 Blank, reinforce, drill doors and tap for mortised, templated hardware and electronic hardware.
- .6 Factory prepare holes 12.7 mm diameter and larger except mounting and through-bolt holes, on site, at time of hardware installation.
- .7 Reinforce doors where required, for surface mounted hardware.
- .8 Provide inverted, recessed, spot welded channels to top and bottom of interior doors.
- .9 Provide factory-applied touch-up primer at areas where zinc coating has been removed during fabrication.
- .10 Manufacturer's nameplates on doors are not permitted.

2.10 Hollow Steel Construction

- .1 Form face sheets for interior doors from 1.2 sheet steel.
- .2 Reinforce doors with vertical stiffeners, securely welded to face sheets at 150 mm on centre maximum.
- .3 Fill voids between stiffeners of interior doors with temperature rise rated core.

2.11 Finishes

- .1 Doors and frames shall wipe coat zinc, ready for painting.

PART 3 EXECUTION

3.1 Manufacturer's Instructions

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and data sheets.

3.2 Installation – General

- .1 Install doors and frames to CSDMA Installation Guide, NAAMM-HMMA 840, Installation Guide for Commercial Steel Doors and Frames and for fire rated product, NFPA 80.

3.3 Frame Installation

- .1 Set frames plumb, square, level and at correct elevation.
- .2 Secure anchorages and connections to adjacent construction.
- .3 Make allowances for deflection of structure to ensure structural loads are not transmitted to frames.

.4 Brace frames rigidly in position while building-in. Install temporary horizontal wood spreader at third points of door opening to maintain frame width. Provide vertical support at centre of head for openings over 1200 mm wide. Remove temporary spreaders after frames are built-in.

.5 Caulk perimeter of frames.

3.4 Door Installation

.1 Install doors and hardware in accordance with hardware templates and manufacturer's instructions and Section 08 71 00 - Door Hardware.

.2 Provide even margins between doors and jambs and doors and finished floor and thresholds as follows:

- .1 Hinge side: 1.0 mm.
- .2 Latchside and head: 1.5 mm.
- .3 Finished floor and thresholds: 13 mm.
- .4 Adjust operable parts for correct function.

.3 Coordinate with Section 08 71 10 for preparation and installation of automatic door operators.

3.5 Finish Repairs

.1 Touch up with primer, finishes damaged during installation.

.2 Fill exposed frame anchors and surfaces with imperfections with metallic paste filler and sand to a uniform smooth finish.

3.6 Cleaning

.1 Proceed in accordance with Section 01 74 11 – Cleaning.

End of Section

PART 1 GENERAL

1.1 General

- .1 Conform to the requirements of Division 1.

1.2 Related Sections

- .1 Section 06 20 00 Finish Carpentry
- .2 Section 08 11 00 Metal Doors and Frames

1.3 References

- .1 American National Standards Institute (ANSI) / Builders Hardware Manufacturers Association (BHMA)
 - .1 ANSI/DHI A115.1G-1994 Installation Guide for Doors and Hardware
 - .2 ANSI/ICC A117.1-2017 Accessible and Usable Buildings and Facilities
 - .3 ANSI/BHMA A156.1-2013 American National Standard for Butts and Hinges.
 - .4 ANSI/BHMA A156.2-2011 Bored and Preamsembled Locks and Latches.
 - .5 ANSI/BHMA A156.4-2013 Door Controls - Closers.
 - .6 ANSI/BHMA A156.5-2014 Auxiliary Locks and Associated Products.
 - .7 ANSI/BHMA A156.6-2010 Architectural Door Trim.
 - .8 ANSI/BHMA A156.10-2011 Power Operated Pedestrian Doors.
 - .9 ANSI/BHMA A156.12-2013 Interconnected Locks and Latches.
 - .10 ANSI/BHMA A156.13-2012 Mortise Locks and Latches Series 1000.
 - .11 ANSI/BHMA A156.15-2011 Release Devices - Closer Holder, Electromagnetic and Electromechanical.
 - .12 ANSI/BHMA A156.16-2013 Auxiliary Hardware.
 - .13 ANSI/BHMA A156.18-2012 Materials and Finishes.
 - .14 ANSI/BHMA A156.19-2013 Power Assist and Low Energy Power - Operated Doors.
- .2 Canadian Steel Door Manufacturers' Association (CSDMA)
 - .1 CSDMA Canadian Metric Guide for Steel Doors and Frames (Modular Construction): Standard Hardware Location Dimensions.
- .3 National Wood Window and Door Association (NWWDA)
- .4 Door Hardware Institute (DHI)
- .5 Accessibility for Ontarians with Disabilities Act (AODA)

1.4 Submittals

- .1 Make submittals in accordance with Section 01 33 00 – Submittal Procedures.
- .2 Product Data:
 - .1 Submit manufacturer's printed product literature, specifications and data sheets.
- .3 Samples:
 - .1 Identify each sample by label indicating applicable specification paragraph number, brand name and number, finish and hardware package number.
 - .2 After approval samples will be returned for incorporation in the Work.
- .4 Hardware List:
 - .1 Submit contract hardware list.
 - .2 Indicate specified hardware, including make, model, material, function, size, finish and other pertinent information.

- .5 Manufacturer's Instructions: Submit manufacturer's installation instructions.
- .6 Provide operation and maintenance data for door closers, locksets, door holders, electrified hardware and fire exit hardware for incorporation into Operations and Maintenance Manuals specified in Section 01 78 00 - Closeout Submittals.

1.5 Quality Assurance

- .1 Regulatory Requirements:
 - .1 Hardware for doors in fire separations and exit doors certified by a Canadian Certification Organization accredited by Standards Council of Canada.
 - .2 Test Reports: certified test reports showing compliance with specified performance characteristics and physical properties.
 - .3 Certificates: product certificates signed by manufacturer certifying materials comply with specified performance characteristics and criteria and physical requirements.
- .2 Pre-installation Meetings: conduct pre-installation meeting to verify project requirements, manufacturer's installation instructions and manufacturer's warranty requirements.

1.6 Shipping, Handling and Storage

- .1 Refer to Section 01 61 00 – Common Product Requirements.
- .2 Deliver, handle and store materials in accordance with manufacturer's printed instructions.
- .3 Package each item of hardware including fastenings, separately or in like groups of hardware, label each package as to item definition and location.
- .4 Receive the delivery of the Finishing Hardware and identify all items against the Finishing Hardware Schedule. Ensure each hardware item is accompanied by the correct template, installation instructions, special tools, fastening devices and other loose items. Advise the finish hardware supplier and Consultant in writing of errors or omissions.
- .5 Storage and Protection: Store finishing hardware in locked, clean and dry area.
- .6 Remove all hardware from doors and frames prior to painting. After painting is complete and dry, reinstall all hardware to manufacturer's recommendations.

1.7 Waste Management and Disposal

- .1 Refer to Section 01 74 19 – Construction Waste Management and Disposal.

1.8 Warranty

- .1 Warrant all hardware against defects of workmanship and material, for a period of one year, except for door closers which shall be warranted for ten years from the date of Substantial Performance and agree to make good promptly any defects which occur or become apparent within the warranty period.

PART 2 PRODUCTS

2.1 Materials

- .1 All hardware shall be supplied as specified in the Finishing Hardware Schedule.
- .2 All finishes shall be as indicated in the Finishing Hardware Schedule by international codes.
- .3 All door handles shall be lever type meeting requirements of the Ontario Building Code.
- .4 Power Door Operators and controls shall be CSA approved and shall meet the requirements of the Ontario Building Code and the Accessibility for Ontarians with Disabilities Act (AODA).

2.2 Fastenings

- .1 Use only fasteners provided by manufacturer. Failure to comply may void warranties and applicable licensed labels.
- .2 Supply screws, bolts, expansion shields and other fastening devices required for satisfactory installation and operation of hardware.
- .3 Exposed fastening devices to match finish of hardware.
- .4 Where pull is scheduled on one side of door and push plate on other side, supply fastening devices, and install so pull can be secured through door from reverse side. Install push plate to cover fasteners.
- .5 Use fasteners compatible with material through which they pass.

2.3 Electrified Devices

- .1 Electrified exit devices shall conform to all traditional exit device standards as specified above. All power requirements for exit devices used must utilize a continuous circuit electric hinge for clean design and no visible means of interrupting power to device.
- .2 All exit devices with electric latch retraction shall provide for a remote means of unlocking for momentary or maintained periods of time.
- .3 Exit devices with electrified trim shall be fail-secure unless otherwise specified.

2.4 Keying

- .1 Keying: All permanent cylinders to be grandmaster-keyed as directed by the Owner. The factory shall key all locks and cylinders and maintain keying records. The factory shall establish a System Information Document (SID) to designate primary system administrators and require a separate letter of authorization for all future shipments of keyed products.
- .2 Remove all construction cores and install all permanent cores. Unless otherwise directed by the Owner.
- .3 Construction master/change keys are to be delivered by the contractor directly to The Owner.

- .4 Ship all permanent cylinders and keys separately. Identify door number and keyset symbol on each envelope for direct factory delivery to the owner.
- .5 Furnish the following:
 - .1 Key Management Software: KW-SSN1. Confirm requirement of new or upgraded software with Owner.

PART 3 EXECUTION

3.1 Manufacturer's Instructions

- .1 Compliance: comply with manufacturer's written data, including product technical bulletins, product catalogue installation instructions, product carton installation instructions, and data sheets.
- .2 Furnish metal door and frame manufacturers with complete instructions and templates for preparation of their work to receive hardware.
- .3 Furnish manufacturers' instructions for proper installation of each hardware component.

3.2 Examination

- .1 Before installing any hardware, carefully check all architectural drawings of the work requiring hardware, verify door swings, door and frame materials and operating conditions, and assure that all hardware will fit the work to which it is to be attached.
- .2 Check all shop drawings and frame and door lists affecting hardware type and installation, and certify to the correctness thereof, or advise the hardware supplier and Consultant in writing of required revisions.

3.3 Templates

- .1 Check the hardware schedule, drawings and specifications, and furnish promptly to the applicable trades any patterns, templates, template information and manufacturer's literature required for the proper preparation for and application of hardware, in ample time to facilitate the progress of the work.

3.4 Installation

- .1 Installation of hardware shall be in accordance with ANSI A115.1G, manufacturer's templates and instructions.
- .2 Install each item of mechanical and electromechanical hardware and access control equipment to comply with the manufacturer's written instructions and according to specifications. All items to be installed with fasteners identified by manufacturer's installation instructions unless otherwise noted.
- .3 Mounting Heights: Install door hardware at heights indicated in the following applicable publications unless; specifically indicated or required by local governing regulations, requirements to match for special templates, necessary coordination with door elevations, and or to ensure consistency with pairs of doors.
 - .1 DHI's "Recommended Locations for Architectural Hardware for Standard Steel Doors and Frames"
 - .2 DHI's "Recommended Locations for Architectural Hardware for Wood Flush Doors"
 - .3 ANSI/ICC A117.1 Accessibility Guidelines for Buildings and Facilities

- .4 NWWDA
- .5 AODA

- .4 Power door operator products and accessories are required to be installed by an AAADM certified technician as approved by the manufacturer. Adjust for proper opening and closing operation after final balancing of HVAC system.
- .5 Coordinate installation of electric door strikes, keypad locks, card readers, washroom duress systems, and other electronic door control and security devices with Electrical contractor including supply and installation of wiring and all terminations.
- .6 All hardware shall be installed by carpenters, skilled in the application of architectural hardware and satisfactory to the hardware supplier. Refer to Section 06 20 00 - Finish Carpentry. Instruction sheets, details and templates shall be read and understood before installation.
- .7 Install all materials as listed in the Finishing Hardware Schedule on the doors and frames listed. Interchanging of hardware will not be allowed.
- .8 Use only manufacturer's supplied fasteners. Failure to comply may void manufacturer's warranties and applicable licensed labels. Use of "quick" type fasteners, unless specifically supplied by manufacturer, is unacceptable.
- .9 Where door stop contacts door pulls, mount stop to strike bottom of pull.
- .10 Remove construction cores when directed by Owner's Representative.
- .11 After installation, templates, installation instructions and details shall be put in a file and turned over to the Owner, when building is Substantially Performed.

3.5 Field Quality Control

- .1 The Contractor shall be solely responsible for and have control over construction means, methods, techniques, sequences and procedures for coordinating all portions of work under the Contract, unless the Contract Documents give other specific instructions.
- .2 Conduct periodic inspections to ensure that door frames are installed plumb, level and square with verification by installer prior to installation of doors and door hardware.
- .3 Hardware supplier to attend site meetings as required to ensure proper execution of the guidelines set forth herein.
- .4 Hardware supplier will perform final field inspection of installed door hardware after final adjustment of all products and will document and report any deficiencies or omissions for correction and written acceptance by the Contractor.

3.6 Adjusting

- .1 Adjust door hardware, operators, closers and controls for optimum, smooth operating condition, safety and for weather tight closure.
- .2 Lubricate hardware, operating equipment and other moving parts.
- .3 Adjust door hardware to provide tight fit at contact points with frames.

3.7 Demonstration

- .1 Instruct Owner's maintenance personnel in the proper adjustment, operation and maintenance of mechanical and electromechanical door hardware, electronic devices and maintenance of finishes.

3.8 Cleaning

- .1 Proceed in accordance with Section 01 74 11 – Cleaning.
- .2 Perform cleaning after installation to remove construction and accumulated environmental dirt.
- .3 Clean hardware with damp rag and approved non-abrasive cleaner, and polish hardware in accordance with manufacturer's instructions.
- .4 Remove protective material from hardware items where present.

End of Section

CONSULTANT : **KEVIN WILBUR**
CONTRACT # :

DATE :
REV.#1:



RIVETT ARCHITECTURAL HARDWARE LTD.

FINISHING HARDWARE SCHEDULE FOR

**PICKERING FIREHALL
INTERIOR ALTERATIONS
553 KINGSTON ROAD
PICKERING, ONTARIO**

ARCHITECT/ENGINEER/CONSULTANT

BBA

CUSTOMER :

SUBMITTED BY :

	RIVETT ARCHITECTURAL HARDWARE LTD. 111 INDUSTRIAL DR., WHITBY, ONTARIO CANADA L1N 5Z9 TEL-905-668-4455 FAX-905-668-4433
--	---

kevin@rivett.com

OVER FORTY-TWO YEARS OF EXCELLENCE

HARDWARE INFORMATION AND SPECIFICATIONS

October 30, 2019

- FINISH:** ALL FINISHES SHALL BE AS INDICATED IN THE FINISHING HARDWARE SCHEDULE BY INTERNATIONAL CODES.
- KEYING:** LOCKS COME WITH STANDARD CORE. FINAL KEYING BY OWNER.
- INSTALLATION:** ALL HARDWARE SHALL BE INSTALLED AND ADJUSTED COMPLETE AS PER THE MANUFACTURERS PRINTED INSTRUCTIONS AND TEMPLATES, BY SKILLED CARPENTERS IN THE APPLICATION OF FINISHING HARDWARE.
- PRODUCTS:** MANUFACTURER'S PRODUCTS SHALL ALL BE AS SPECIFIED. ANY EQUALS MAYBE APPROVED IN WRITING IF THEY ARE EQUAL IN DESIGN, FUNCTION, QUALITY, AND FINISH AS LISTED HEREIN.
- | | |
|------------------|------------------------|
| HINGES BY HAGER | TRIM HARDWARE BY HAGER |
| LOCKS BY SCHLAGE | SEALS BY K.N. CROWDER |
| CLOSERS BY LCN | |
- HANDLING:** WHERE DOORS AND FRAMES ARE TO BE FIELD PAINTED OR FINISHED, ALL HARDWARE SHALL BE REMOVED BY THE GENERAL CONTRACTOR, PRIOR TO SAME. AFTER FINISHING HAS BEEN COMPLETED, THE GENERAL CONTRACTOR SHALL RE-INSTALL ALL THE HARDWARE TO MANUFACTURERS RECOMMENDATIONS.
- PACKING:** LABEL ALL FINISHING HARDWARE WITH DOOR NUMBERS AND ITEM NUMBERS. THE GENERAL CONTRACTOR SHALL RECEIVE IN A LOCKED DRY STORAGE AREA AND ADVISE WITHIN 24 HOURS OF ANY SHORTAGES.
- SUBMITTAL:** BEFORE MATERIAL IS ORDERED, SUBMIT (1) ONE COPY OF THE COMPLETED HARDWARE SCHEDULE FOR FINAL APPROVAL. SUPPLY ALL NECESSARY TEMPLATES REQUIRED FOR FABRICATION.
- WARRANTY:** THE WARRANTY PERIOD SHALL BE ONE (1) YEAR GENERALLY AND TEN (10) YEARS FOR DOOR CLOSERS, THIS SHALL BE SENT TO THE GENERAL CONTRACTOR ON COMPLETION.
- OMISSIONS:** ANY ITEMS OF FINISHING HARDWARE REQUIRED FOR THIS PROJECT AND NOT INCLUDED IN THIS SPECIFICATION AND/OR SCHEDULE WILL BE ADDED TO THE CONTRACT AFTER AN APPROVED CHANGE NOTICE HAS BEEN ISSUED BY THE ARCHITECT.
- QUALITY:** PERSONNEL WHO WILL BE RESPONSIBLE FOR SCHEDULING, ORDERING AND CO-ORDINATION HARDWARE FOR THIS PROJECT SHALL BE AN EXPERIENCED HARDWARE CONSULTANT AND WITH AN EXPERIENCED HARDWARE DISTRIBUTOR BOTH OF WHICH SHALL HAVE A MINIMUM OF FIVE YEARS EXPERIENCE. THE ARCHITECT MAY REQUEST A QUALIFICATION FORM SUBMITTED.

SYMBOLS

RIVETT ARCHITECTURAL HARDWARE LTD.

October 30, 2019

FINISHES

B.H.M.A.	CANADIAN	U.S.A.	DESCRIPTION
600	CP	USP	PRIMED FOR PAINT
602	C2C	US2C	CADMIUM PLATED
603	C2G	US2G	ZINC PLATED
605	C3	US3	BRIGHT BRASS CLEAR COATED
606	C4	US4	SATIN BRASS CLEAR COATED
609	C5	US5	SATIN BRASS BLACKENED CLEAR COAT
612	C10	US10	SATIN BRONZE CLEAR COATED
613	C10B	US10B	OXIDIZED SATIN BRONZE OIL RUBBED
619	C15	US15	SATIN NICKEL PLATED CLEAR COATED
625	C26	US26	BRIGHT CHROMIUM PLATED
626	C26D	US26D	SATIN CHROMIUM PLATED
627	C27	US27	SATIN ALUMINUM CLEAR COATED
628	C28	US28	SATIN ALUMINUM CLEAR ANODIZED
629	C32	US32	BRIGHT STAINLESS STEEL
630	C32D	US32D	SATIN STAINLESS STEEL
689	SBL	USP28	ALUMINUM PAINT
690	DBL	USP20	DARK BRONZE PAINT

HANDING

LH	LEFT HAND	LHA	LEFT HAND ACTIVE
RH	RIGHT HAND	RHA	RIGHT HAND ACTIVE
LHR	LEFT HAND REVERSE	LHRA	LEFT HAND REVERSE ACTIVE
RHR	RIGHT HAND REVERSE	RHRA	RIGHT HAND REVERSE ACTIVE

WORDS

ALUM	ALUMINUM	NRP	NON REMOVABLE PIN
ASA	ASA STRIKE	PR	PAIR
BS	BACKSET	SEC	SECTION
CC	CANCELED	SGLE	SINGLE
CYL	CYLINDER	STD	STANDARD
DA	DOUBLE ACTING	TB	THRU BOLTS
DS	DEAD STOP	ULA	UNDERWRITERS LABELED 3 HOUR RATED
EA	EACH	ULB	UNDERWRITERS LABELED 1 1/2 HOUR RATED
ELEV	ELEVATION	ULC	UNDERWRITERS LABELED 3/4 HOUR RATED
HDWE	HARDWARE	ULD	UNDERWRITERS LABELED 1/3 HOUR RATED
HO	HOLD OPEN	UL	UNDERWRITERS FIRE LABELED
MM	MILLIMETERS	161	STANDARD CYLINDER LOCK CUTOUT


DOORS & FRAMES

FS	FRAME SINGLE "KD"	FD	FRAME DOUBLE "KD"
FSW	FRAME SINGLE WELDED	FDW	FRAME DOUBLE WELDED
FSWTH	FRAME SINGLE WELDED THERMO	FDWTB	FRAME DOUBLE WELDED THERMO
FSTB	FRAME SINGLE THERMO "KD"	FDWDE	FRAME WELDED DOUBLE EGRESS
FSDW	FRAME SINGLE DRYWALL	FDWCS	FRAME WELDED CONTRA SWING
FSDWW	FRAME SGLE DRYWALL WELDED	FDDW	FRAME DOUBLE DRYWALL "KD"
D	DOOR "D" SERIES HONEYCOMB CORE	-14	14 GAUGE STEEL DOOR OR FRAME
H	DOOR "H" SERIES STEEL STIFFENED	-16	16 GAUGE STEEL DOOR OR FRAME
E	DOOR "E" SERIES EMBOSSED	-18	18 GAUGE STEEL DOOR OR FRAME
Z	DOOR "Z" SERIES STEEL STIFFENED	-20	20 GAUGE STEEL DOOR OR FRAME
M	FLUSH FACE DOOR	PSF	PRESSED STEEL FRAME
G	HALF LITED DOOR	WF	WOOD FRAME
NL	NARROW LITED DOOR	HMD	HOLLOW METAL DOOR
L	LOUVERED DOOR	HCWD	HOLLOW CORE WOOD DOOR
2G	TWO LITED DOOR	SCWD	SOLID CORE WOOD DOOR
V	VIEW LITED DOOR	PL	PLASTIC LAMINATED DOOR
KD	KNOCK DOWN	FR	FRAME
TRR	TEMPERATURE RISE RATED	CIF	CHANNEL IRON FRAME
STC	SOUND TRANSMISSION	DR	DOOR

KEYING

GGMK	GREAT GRAND MASTER KEY	KD	KEYED DIFFERENT
GMK	GRAND MASTER KEY	KA	KEYED ALIKE
MK	MASTER KEY	CMK	CONSTRUCTION MASTER KEY
EMK	EMERGENCY MASTER KEY	SK	SEPARATE KEY NO MASTERS
BK	BLOCK-O KEYED	CC	CONSTRUCTION CORE
RM	REMOVABLE CORE	CK	CUT KEYS

HARDWARE LOCATION DIAGRAM



ALL HARDWARE MOUNTING LOCATIONS SHALL BE AS PER LOCATIONS DIAGRAM AND HELD CONSISTENT THROUGHOUT THE PROJECT, UNLESS INDICATED ELSEWHERE IN THE ARCHITECTS DRAWINGS, FINISHING HARDWARE SCHEDULE OR AS DIRECTED BY

Rivett Architectural Hardware Ltd.

Door Listing

PICKERING FIREHALL RENOS - PICKERING, ONTARIO

Schedule 90809

Date Oct 30-19

Door Number	Set Number
103	1
104	2

Rivett Architectural Hardware Ltd.

Hardware Schedule

PICKERING FIREHALL RENOS - PICKERING, ONTARIO

Schedule 90809
Date Oct 30-19

Set # 1

1 SINGLE DR # 103 CORRIDOR 102 TO NEW LOCKER ROOM

RH

1 - 3'-2" x 7'-0" x 1-3/4" x M/HMD x PSF

Qty

: : 3 EA HINGE BB1168-114 X 101- 626
: : 1 EA PUSH PLATE 30S X 127 X 508 X 630
: : 1 EA DOOR PULL 31G X 8" X 630
: : 1 EA CLOSER 4040XP X 689
: : 1 EA KICKPLATE 190S X 203 X 914 X 630
: : 1 EA WALL STOP 232W X 626

Set # 2

1 SINGLE DR # 104 CORRIDOR 102 TO NEW UNIVERSAL W/RM 104

LH

1 - 3'-2" x 7'-0" x 1-3/4" x HMD x PSF

door grill by mechanical

Qty

: : 3 EA HINGE BB1168-114 X 101- 626
: : 1 EA STOREROOM LOCK ND80PD X RHO X ASA X 626
: : 1 EA ELECTRIC STRIKE FAIL SAFE 1006 X FS X CLB X 630
low voltage wiring to strike by EC. Door is always unlocked until someone presses "PUSH-TO--LOCK" button. Door is locked and outside "PRESS TO OPEN" button is disabled. When occupant leaves by using lever or "PRESS TO OPEN" button, system resets itself
: : 1 EA CONCEALED STOP 104S X 630
template installation to stop door at 95 degrees
: : 1 EA DOOR OPERATOR ADD ON SW200i ADD FOR INSWING ARM
: : 1 EA DOOR OPERATOR SW200i X SINGLE HSG X 628
110v to head of frame by EC
: : 1 EA OCCUPIED & EMERGENCY KIT RECES #OCC-1-EMR-R KIT
all single gang junction boxes and low voltage wiring to push buttons by EC. (three on outside wall and 4 on inside wall. Locations to be confirmed by architect.
: : 1 EA KICKPLATE 190S X 203 X 914 X 630
: : 1 EA COAT HOOK 901P X 626

PART 1 GENERAL

1.1 General

- .1 Conform to the requirements of Division 1.

1.2 Related Sections

- .1 Section 06 10 00 Rough Carpentry
- .2 Section 07 92 00 Joint Sealants
- .3 Section 09 22 16 Non-Structural Metal Framing
- .4 Section 09 91 23 Interior Painting

1.3 References

- .1 ASTM International (ASTM)
 - .1 ASTM C475/C475M-17 Standard Specification for Joint Compound and Joint Tape for Finishing Gypsum Board.
 - .2 ASTM C514-04(2014) Standard Specification for Nails for the Application of Gypsum Board
 - .3 ASTM C840-17a Standard Specification for Application and Finishing of Gypsum Board
 - .4 ASTM C954-15 Standard Specification for Steel Drill Screws for the Application of Gypsum Panel Products or Metal Plaster Bases to Steel Studs from 0.033 in. (0.84 mm) to 0.112 in. (2.84 mm) in Thickness
 - .5 ASTM C1002-16 Standard Specification for Steel Self-Piercing Tapping Screws for Application of Gypsum Panel Products or Metal Plaster Bases to Wood Studs or Steel Studs
 - .6 ASTM C1047-14a Standard Specification for Accessories for Gypsum Wallboard and Gypsum Veneer Base
 - .7 ASTM C1178/C1178M-13 Standard Specification for Coated Glass Mat Water-Resistant Gypsum Backing Panel
 - .8 ASTM C1396/C1396M - 17 Standard Specification for Gypsum Board
 - .9 ASTM E90-09 Standard Test Method for Laboratory Measurement of Airborne Sound Transmission Loss of Building Partitions and Elements
 - .10 ASTM E814-13a Standard Test Method for Fire Tests of Penetration Firestop Systems
 - .11 ASTM E1966-15 Standard Test Method for Fire-Resistive Joint Systems
- .2 Canadian General Services Board (CGSB)
 - .1 CAN/CGSB-51.34, Vapour Barrier, Polyethylene Sheet for Use in Building Construction.
 - .2 CAN/CGSB 19-GP-21M Sealing and Bedding Compound for Acoustical Purposes
- .3 CAN/ULC-S102, Building Materials and Assemblies, Standard Method of Test for Surface Burning Characteristics of.
- .4 Underwriters Laboratories of Canada (ULC)
 - .1 ULC List of Equipment and Material, Volume III, Fire Resistance Ratings.

1.4 Submittals

- .1 Make submittals in accordance with Section 01 33 00 – Submittal Procedures.
- .2 Submit WHMIS Material Data Safety Sheets (MSDS) for all products, prior to delivery of products to the site.

1.5 Quality Assurance

- .1 Dry wall installers: minimum 5 years proven experience.

1.6 Shipping, Handling and Storage

- .1 Refer to Section 01 61 00 – Common Product Requirements.
- .2 Deliver, handle and store materials in accordance with manufacturer's printed instructions.
- .3 Use all means necessary to protect gypsum board materials before, during and after installation and to protect the installed work and materials of other trades affected by this work. Store materials in a dry area inside the building. Do not remove wrapping until ready for use. Prevent damage to all edges and surfaces.

1.7 Environmental Requirements

- .1 Maintain temperature minimum 10 ° C, maximum 21 °C for 48 hours prior to and during application of gypsum boards and joint treatment, and for at least 48 hours after completion of joint treatment.
- .2 Apply board and joint treatment to dry, frost free surfaces.
- .3 Ventilation: Ventilate building spaces as required to remove excess moisture that would prevent drying of joint treatment material immediately after its application.

1.8 Waste Management and Disposal

- .1 Refer to Section 01 74 19 – Construction Waste Management and Disposal.

PART 2 PRODUCTS

2.1 Gypsum Board

- .1 To CSA A82.27-M and ASTM C1396/C1396M. Standard for non-rated applications, Type X for rated applications, 1220 mm wide x maximum practical length, ends square cut, edges tapered with round edge, 12.7 mm thick or to thickness indicated on drawings. All fire rated board shall be minimum 16 mm thickness.
- .2 Glass mat water-resistant gypsum board: to ASTM C1178/C1178M with glass mat facings, both sides, regular and Type X, thicknesses as indicated on drawings, 1200 mm wide x maximum practical length, ends square cut, long edges tapered.
- .3 Abuse Resistant Gypsum Board: CGC Fibrerock abuse resistant fibre/gypsum panels, 16 mm thickness.
- .4 Water and Moisture Resistant Board: to CSA A82.27 and ASTM C1396, 12.7 mm thick, 1220 mm wide with tapered edges.

2.2 Fastening and Adhesives

- .1 Drywall Screws: To ASTM C954 or ASTM C1002 self-drilling, self-tapping, case hardened, length to suit board thickness and provide minimum 12 mm penetration into support.
- .2 Joint Tape: To ASTM C475, 50 mm perforated with preformed seam, mould and mildew resistant.
 - .1 Joint tape for abuse resistant gypsum board: CGC Mould Resistant Fiberglass Drywall Tape.
- .3 Joint Filler and Topping: To ASTM C475 vinyl or latex base, slow setting.

- .4 Laminating Compound: To CSA A82.31-M, asbestos-free.

2.3 Acoustic Insulation

- .1 Acoustic Insulation: Mineral Fibre Acoustic Insulation:
 - .1 Mineral Fibre Acoustic Insulation: To ASTM C665, Mineral fibre blanket insulation, minimum density of 40 kg/m²:
 - .1 AFB Acoustical Fire Batts manufactured by Roxul Inc.
 - .2 STC contribution and fire resistance (hr): Refer to NBC 2015, tables A-9.10.3.1-A/B and Product Data Sheet for various assemblies contributing to acoustic performance and fire resistance.
 - .3 Surface burning characteristics to CAN/ULC-S102:
 - .1 flame spread: 15
 - .2 smoke developed: 5
 - .3 Smoulder resistance: to ULC S129.
 - .4 Non-combustible: to CAN4-S114.
 - .4 Thickness to suit depth of wall framing and as indicated.
- .2 Acoustic sealant: To CGSB 19-GP-21M, ASTM E814 and ASTM E1966, with STC performance rating of 55 to ASTM E90-09.

2.4 Accessories

- .1 Casing Beads, Corner Beads and Edge Trim: To ASTM C 1047, 0.5 mm gauge base thickness commercial grade sheet steel with G90 zinc finish to ASTM A525-80A; perforated flanges; one piece length per location.
- .2 Insulating Strip: Rubberized, moisture resistant, 3.0 mm thick, 12 mm wide closed cell neoprene strip, with self-sticking permanent adhesive on one face; lengths as required.
- .3 Control Joints shall be DRM-50-25 2PC extruded aluminum as manufactured by Fry Reglet Corporation to provide a ¼" reveal.
- .4 Sealants: as specified in Section 07 92 00 - Joint Sealants.

PART 3 EXECUTION

3.1 General

- .1 Prior to installation of gypsum wallboard, ensure that all required vapour barriers, air seals, gaskets and the like installed under another Section have been inspected and accepted by Municipal authorities and the Consultant. Failure to do so will result in removal of all gypsum board installed prior to approval and replacement, at no additional cost to the Owner.
- .2 Unless otherwise indicated on the drawings, all gypsum board partitions shall extend from floor level to the underside of floor or roof structures above.

3.2 Acoustic insulation

- .1 Install acoustic blankets full width and length, with tight joints, between wall framing and around

penetrating electrical service boxes, piping, air ducts and frames.

- .2 Place acoustic blankets where indicated on the Drawings and to thickness required to obtain acoustic performance indicated for the assembly.
- .3 Place acoustic blankets between studs ensuring friction fit, free of sags, folds or open joints that may let sound pass through.
- .4 Install blankets from the bottom up, tightly adjusted and trim accurately with a utility knife.

3.3 Gypsum Board Application

- .1 Do application and finishing of gypsum board in accordance with ASTM C 840 except where specified otherwise.
- .2 Do not apply gypsum board until bucks, anchors, blocking, electrical, and mechanical work are approved.
- .3 Do not apply gypsum board to ceilings until insulation, vapour retarder and air seals have been installed and inspected by others, including consultant, owner and municipal building inspectors.
- .4 Apply gypsum board at right angles to framing members or furring using screw fasteners. Maximum spacing of screws 300 mm o.c.
- .5 Install fibre gypsum abuse resistant panels at all ceilings and bulkheads except as noted below. Treat joints with fibreglass reinforced joint tape in accordance with manufacturer's instructions.
- .6 Apply water resistant gypsum wallboard where indicated. Apply water resistant sealant to edges, ends and cut outs which expose gypsum core.
- .7 Install Hi-Density Water Resistant Gypsum Sheathing in showers and other wet areas.
- .8 Laminate gypsum board to existing masonry wall surfaces where indicated.
- .9 Carry gypsum board from floor to underside of floor or roof structure above. Furr out and carry gypsum board around any structural members as may be required. Neatly cope gypsum board to fill deck flutes where gypsum board abuts floor or roof deck.

3.4 Accessories

- .1 Erect accessories straight, plumb or level, rigid and at proper plane. Use full length pieces where practical. Make joints tight, accurately aligned and rigidly secured. Mitre and fit corners accurately, free from rough edges.
- .2 Install casing beads where gypsum board butts against surfaces having no trim concealing junction and where indicated.
- .3 Install insulating strips continuously at edges of gypsum board or casing beads abutting exterior door or window frames, to provide thermal break.
- .4 Install continuous bead of acoustic sealant at all penetrations through sound control partitions.
- .5 Provide control joints in gypsum board facing. Control joints shall be supported with metal studs or furring channels on both sides of the joint. Control joints shall be provided:

- .1 At abutting structural elements, steel columns.
- .2 At expansion or control joints in the substrate;
- .3 At maximum 20' spacings on long partition and bulkhead runs;
- .4 At each door jamb.

3.5 Access Doors

- .1 Install access doors to electrical and mechanical fixtures specified in respective Sections.
- .2 Rigidly secure frames to furring or framing systems, to satisfy fire rating requirements.

3.6 Taping and Filling

- .1 Finish face panel joints and internal angles with joint system consisting of joint compound, joint tape and taping compound installed according to manufacturer's directions and feathered out onto panel faces.
- .2 Finish corner beads, control joints and trims as required with two coats of joint compound and one coat of taping compound, feathered out onto panel faces.
- .3 Fill screw head depressions with joint and taping compounds to bring flush with adjacent surface of gypsum board so as to be invisible after painting is completed.
- .4 Sand lightly to remove burred edges and other imperfections. Avoid sanding adjacent surface of board.
- .5 Completed installation to be smooth, level or plumb, free from waves and other defects and ready for painting.

3.7 Cleaning

- .1 Proceed in accordance with Section 01 74 11 – Cleaning.
End of Section

PART 1 GENERAL

1.1 General

- .1 Conform to the requirements of Division 1.

1.2 Related Sections

- .1 Section 09 21 16 Gypsum Board

1.3 References

- .1 ASTM International (ASTM).
 - .1 ASTM A653/A653M-17 Standard Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process
 - .2 ASTM C645-14e1 Standard Specification for Nonstructural Steel Framing Members
 - .3 ASTM C754-17 Standard Specification for Installation of Steel Framing Members to Receive Screw-Attached Gypsum Panel Products
 - .4 ASTM C1002-16 Standard Specification for Steel Self-Piercing Tapping Screws for Application of Gypsum Panel Products or Metal Plaster Bases to Wood Studs or Steel Studs
 - .5 ASTM E90-09(2016) Standard Test Method for Laboratory Measurement of Airborne Sound Transmission Loss of Building Partitions and Elements
 - .6 ASTM E814 - 13a(2017) Standard Test Method for Fire Tests of Penetration Firestop Systems
 - .7 ASTM E1966-15 Standard Test Method for Fire-Resistive Joint Systems
- .2 Canadian General Services Board (CGSB).
 - .1 CAN/CGSB-1.40-97, Primer, Structural Steel, Oil Alkyd Type.
- .3 Underwriters Laboratories of Canada (ULC)
 - .1 ULC List of Equipment and Material, Volume III, Fire Resistance Ratings.
- .4 CSSBI Lightweight Steel Framing Manual

1.4 Submittals

- .1 Make submittals in accordance with Section 01 33 00 – Submittal Procedures.
- .2 Submit WHMIS Safety Data Sheets (SDS) for all products, prior to delivery of products to the site.

1.5 Quality Assurance

- .1 Test Reports: certified test reports showing compliance with specified performance characteristics and physical properties.
- .2 Certificates: product certificates signed by manufacturer certifying materials comply with specified performance characteristics and criteria and physical requirements.
- .3 Pre-Installation Meetings: conduct pre-installation meeting to verify project requirements, manufacturer's installation instructions and manufacturer's warranty requirements.

1.6 Shipping, Handling and Storage

- .1 Refer to Section 01 61 00 – Common Product Requirements.
- .2 Deliver, handle and store materials in accordance with manufacturer's printed instructions.

1.7 Waste Management and Disposal

- .1 Refer to Section 01 74 19 – Construction Waste Management and Disposal.

PART 2 PRODUCTS

2.1 Metal Stud Framing Systems

- .1 Non-load bearing channel stud framing: to ASTM C645, stud size as indicated, roll formed from 0.53 mm thickness hot dipped galvanized steel sheet, for screw attachment of gypsum board. Knock-out service holes at 460 mm centres.
 - .1 Gauge of materials to conform to referenced standards unless noted otherwise.
- .2 Floor and ceiling tracks: to ASTM C645, in widths to suit stud sizes, 32 mm flange height.
- .3 Metal channel stiffener: 1.4 mm thick cold rolled steel, coated with rust inhibitive coating.
- .4 Tie Wire: 0.90 mm, galvanized, soft annealed, steel wire or clip as recommended by the manufacturer of furring channels.

2.2 Metal Furring and Suspension Systems

- .1 Metal Furring Runners, Hangers, Tie Wires, Inserts, Anchors: To CSA A82.30-M, electro-zinc coated steel.
- .2 Runner Channels: 38 x 19 x 0.59 mm and 38 x 9.5 x 0.45 mm, hot dip or electro-galvanized sheet steel. Use of various sizes governed by applied loads and applicable spans.
- .3 Drywall Furring Channel: Channel shaped furring member for screw attachment of drywall with knurled face. For interior use. Furring masonry or concrete surfaces. Cross furring under steel joist or suspended metal channels in suspended ceiling systems: 70 x 22 x 0.9 mm with knurled face, hot dip or electro-galvanized sheet steel. Bailey D-1001.
- .4 Hangers: minimum 4.1 mm diameter (or as required by ULC fire rating design requirements) mild steel rods.

2.3 Fasteners

- .1 Powder activated fasteners: to suit structural conditions and fastening requirements and in accordance with manufacturer's recommendations: Ramset; Hilti; or approved equivalent.
- .2 Sheet Metal Screws: To CSA A82.31-M, and ASTM C1002, self-drilling, self-tapping, case hardened, length to suit board thickness and provide minimum 12 mm penetration into support.

2.4 Accessories

- .1 Acoustic sealant: To ASTM E814 and ASTM E1966, with STC performance rating of 55 to ASTM E90.
- .2 Insulating strip: rubberized, moisture resistant 3 mm thick foam strip, 12 mm wide, with self-sticking adhesive on one face, lengths as required.
- .3 Zinc Rich Paint: to CGSB 1-GP-181M. Low VOC type.

PART 3 EXECUTION

3.1 Erection

- .1 Unless otherwise indicated on the drawings, all gypsum board partitions shall extend from floor level to the underside of floor or roof structures above.
- .2 Align partition tracks at floor and ceiling and secure at 600 mm on centre maximum.
- .3 Install damp proof course under stud shoe tracks of partitions on slabs on grade.
- .4 Place studs vertically at 400 mm on centre unless noted otherwise and not more than 50 mm from abutting walls, and at each side of openings and corners. Position studs in tracks at floor and ceiling. Cross brace steel studs as required to provide rigid installation to manufacturer's instructions.
- .5 Erect metal studding to tolerance of 1:1000.
- .6 Attach studs to bottom and ceiling track using screws.
- .7 Co-ordinate simultaneous erection of studs with installation of service lines. When erecting studs ensure web openings are aligned.
- .8 Co-ordinate erection of studs with installation of door/window frames and special supports or anchorage for work specified in other Sections.
- .9 Provide two studs extending from floor to ceiling at each side of openings wider than stud centres specified. Secure studs together, 50 mm apart using column clips or other approved means of fastening placed alongside frame anchor clips.
- .10 Install heavy gauge single jamb studs at openings.
- .11 Erect track at head of door/window openings and sills of window openings to accommodate intermediate studs. Secure track to studs at each end, in accordance with manufacturer's instructions. Install intermediate studs above and below openings in same manner and spacing as wall studs.
- .12 Frame openings and around built-in equipment, cabinets, access panels, on four sides. Extend framing into reveals. Check clearances with equipment suppliers.
- .13 Provide 40 mm stud or furring channel secured between studs for attachment of fixtures behind lavatory basins, toilet and bathroom accessories, and other fixtures including grab bars and towel rails, attached to steel stud partitions.
- .14 Install steel studs or furring channel between studs for attaching electrical and other boxes.
- .15 Extend partitions to minimum 200 mm above ceiling height except where noted otherwise on drawings.
- .16 Maintain clearance under beams and structural slabs to avoid transmission of structural loads to studs. Use 50 mm leg ceiling tracks.
- .17 Install continuous insulating strips to isolate studs from un-insulated surfaces.

- .18 Install two continuous beads of acoustical sealant under studs and tracks around perimeter of sound control partitions.

3.2 Wall Furring

- .1 Install wall furring for gypsum board wall finishes in accordance with CSA A82.31-M, except where specified otherwise and shown on drawings.
- .2 Frame openings and around built-in equipment, cabinets, access panels, etc., on four sides. Extend furring into reveals. Check clearances with equipment suppliers.
- .3 Furr duct shafts, beams, columns, pipes and exposed services where indicated.

3.3 Suspended and Furred Ceilings and Bulkheads

- .1 Erect hanger and runner channels for suspended gypsum board ceilings in accordance with CSA A82.31-M except where specified otherwise and indicated on drawings.
- .2 Securely anchor hanger to structural supports 1220 mm o.c. maximum along runner channels and not more than 150 mm from ends. Under no circumstances shall hanger wires be secured to or supported from mechanical or electrical materials or equipment or penetrate mechanical ductwork.
- .3 Space runner or furring channels as shown on drawings and not more than 610 mm o.c. maximum nor 150 mm from walls. Run channels in long direction of board. Bend hanger sharply under bottom flange of runner and securely wire in place with a saddle tie. Provide channels below mechanical or electrical equipment and mechanical ductwork to maintain maximum spacing.
- .4 Install furring channels transversely across runner channels in short direction of wallboard at 610 mm o.c. maximum or 150 mm from walls and interruptions in ceiling continuity. Secure channels to support with furring clips or wire. Where splicing is necessary lap minimum 200 mm and wire tie each end with double loops of 0.90 mm gauge galvanized tie wire, 25 mm from each end of overlap.
- .5 Support light fixtures by providing additional ceiling suspension hangers within 150 mm of each corner and at maximum 610 mm around perimeter of fixture. Coordinate with Electrical.
- .6 Install work level to tolerance of 1:1200.
- .7 Frame with furring channels, perimeter of openings for access panels, light fixtures, diffusers, grilles, etc.
- .8 Install furring channels parallel to, and at exact locations of steel stud partition header track.
- .9 Furr for gypsum board faced vertical bulkheads within or at termination of ceilings.

3.4 Gypsum Board

- .1 Installation of gypsum board is specified in Section 09 21 16

3.5 Cleaning

- .1 Proceed in accordance with Section 01 74 11 – Cleaning.
- .2 Upon completion of installation, remove surplus materials, rubbish, tools and equipment barriers.

End of Section

PART 1 GENERAL

1.1 General

- .1 Conform to the requirements of Division 1.

1.2 Related Sections

- .1 Section 03 30 00 Cast-in-Place Concrete
- .2 Section 04 20 00 Concrete Unit Masonry
- .3 Section 07 92 00 Joint Sealants
- .4 Section 09 65 19 Resilient Flooring
- .5 Section 09 91 23 Interior Painting

1.3 References

- .1 ASTM International (ASTM)
 - .1 ASTM C207-06(2011) Standard Specification for Hydrated Lime for Masonry Purposes
- .2 American National Standards Institute (ANSI)
 - .1 ANSI A108/A118/A136.1:2017 American National Specifications for the Installation of Ceramic Tile.
 - .2 ANSI A137.1: 2017 American National Standard Specifications for Ceramic Tile
- .3 Canadian General Standards Board (CGSB)
 - .1 CGSB 71 GP 22M 1978 Adhesive, Organic, for Installation of Ceramic Wall Tile
 - .2 CAN/CSA A5-93, Portland Cement
 - .3 CAN/CGSB 25.20-95, Surface Sealer for Floors.
- .4 International Standards Organization (ISO)
 - .1 ISO 10545 Series, Ceramic Tiles, Standards for Testing
 - .2 ISO 13006-2012, Ceramic Tiles, Definitions, Classifications, Characteristics and marking.
 - .3 ISO 13007-2010, Ceramic Tiles, Grouts and Adhesives.
- .5 Terrazzo, Tile and Marble Association of Canada (TTMAC)
 - .1 TTMAC 2016-2017 Specifications Guide 09 30 00, Tile Installation Manual.
 - .2 TTMAC Hard Surface Maintenance Guide.

1.4 Submittals

- .1 Make submittals in accordance with Section 01 33 00 – Submittal Procedures.
- .2 Submit duplicate samples of tile to the Consultant and Owner for approval. Samples to be submitted on 300 x 600 mm sample board for each colour, texture, size and pattern of tile. Grout sample joints for representative sample of final installation.
- .3 Trim Accessories: submit duplicate samples of each trim.
- .4 Shop drawings: submit tiling plans giving all details of special fittings, expansion joints, joint layout, etc.
- .5 Maintenance Data: Provide maintenance data for tile work, for incorporation into Maintenance Manuals specified under Section 01 78 00.

1.5 Quality Assurance

- .1 Do tile work in accordance with Installation Manual 200, Ceramic Tile, by Terrazzo, Tile and Marble Association of Canada (TTMA), except where this specification is more stringent.
- .2 For the actual installation of ceramic wall and floor tile, use only skilled tradesmen who are familiar with the referenced standards and with the requirements for this Work.
- .3 The setting material manufacturer's representative shall review the details with the Contractor prior to the start of work. Instruct the Contractor on the proper installation procedures to ensure compliance with the guarantee requirements.

1.6 Shipping, Handling and Storage

- .1 Refer to Section 01 61 00 – Common Product Requirements.
- .2 Deliver packaged materials in original unopened containers.
- .3 Keep delivered material dry and free from stains. Store cementitious material off damp surfaces.
- .4 Use all means necessary to protect floor and wall tile materials, before, during and after installation and to protect the installed work and materials of all other trades.
- .5 In the event of damage, immediately make all repairs and replacements necessary to the approval of the Consultant and at no additional cost to the Owner.
- .6 Deliver, handle and store materials in accordance with manufacturer's printed instructions.

1.7 Environmental Conditions

- .1 Maintain air temperature and structural base temperature at ceramic tile installation area above 12° for 48 hours before, during and after installation.

1.8 Qualifications

- .1 Installer of ceramic tiles shall have a minimum of 10 years of experience including at least five projects of similar scope and scale. Submit documented proof of experience prior to commencing work of this Section.

1.9 Scheduling

- .1 Arrange for production and shipment of the tile in sufficient time to avoid delays. Substitutions will not be considered due to last minute unavailability of the tile. Any extra costs incurred to ensure the timely delivery of the tile will be at the Contractors expense.

1.10 Waste Management and Disposal

- .1 Refer to Section 01 74 19 – Construction Waste Management and Disposal.

1.11 Warranty

- .1 Warrant the work of this Section against defects of workmanship and material, for a period of five years from the date of Substantial Performance and agree to make good promptly any defects which occur or become apparent within the warranty period.

PART 2 PRODUCTS

2.1 Materials

- .1 Materials shall be graded and containers grade sealed, delivered to the job site in their original packages or containers with the manufacturer's labels and seals intact.
- .2 Tile and grout colour shall be selected by the Owner from the manufacturer's standard range of colours.
- .3 Tile shall conform to ANSI A137.1.
- .4 Floor tile shall have coefficient of slip resistance conforming to ANSI A137.1.
- .5 Provide coves, corners, reveals, surf caps, inners and outers as required to complete the work.

2.2 Ceramic Tile

- .1 T-1: Ceramic Floor Tile: Olympia Quebec series 50 x 50 mm unglazed porcelain slip resistant tile. Up to two (2) colours will be selected.
- .2 T-2: Ceramic Wall Tile: Olympia Colour & Dimension Collection, bright glazed, 102 x 408 mm. Up to two (2) colours will be selected (80% field colour, 20% Accent colours).
- .3 T-3: Ceramic Floor Tile (Showers): Olympia Quebec series 50 x 50 mm unglazed porcelain slip resistant tile. Up to two (2) colours will be selected.
- .4 T-4: Ceramic Wall Tile: Olympia Colour & Dimension Collection, bright glazed, 102 x 408 mm. Up to two (2) colours will be selected (80% field colour, 20% Accent colours).

2.3 Mortar, Grout, Additives and Adhesives

- .1 The products of one manufacturer shall be used throughout the project to ensure compatibility of materials. Manufacturers of commercial mortar, grout and adhesive having product considered acceptable for use:
 - .1 Laticrete
 - .2 Mapei
 - .3 Flextile
- .2 Water: Fresh, clean, potable, free from deleterious matter, acids or alkalis.
- .3 Floors: (thinset) T.T.M.A. Detail #317 SP-2000 "A".
 - .1 Thinset mortar: Laticrete 4237 latex additive plus 211 Crete filler powder or Mapei Kerabond mixed with Keralastic high performance latex admixture or Flextile 52 thin set.
 - .2 Levelling Compound (if required): Laticrete 3701 latex or 226 Mapecem mortar mixed with Planicrete 50.
 - .3 Grout: Laticrete Latapoxy SP100, solid epoxy grout or Mapei Kerapoxy. Colours to Owner's selection.
- .4 Washroom Floors (Thinset): T.T.M.A. Detail #317 SP-2000 "A".
 - .1 Patch existing structural concrete slabs as required.

- .2 Waterproofing membrane, Laticrete 9235 liquid applied reinforced membrane or Mapei PRP-315 with fiberglass mesh and all Mapei PRP-315 waterproofing accessories.
- .3 Thinset mortar: Laticrete 4237 latex additive plus 211 Crete filler powder or Mapei "Kerabond" mixed with "Keralastic" high performance latex admixture.
- .4 Levelling Compound (if required): Laticrete 3701 latex and 226 "Mapecem" mortar mixed with "Planicrete 50".
- .5 Grout: Laticrete "Latapoxy" SP100, solid epoxy grout or Mapei "Kerapoxy". Colours to Owner's future selection or as indicated on Finish Schedule.
- .6 Note: where floors do not require membrane (only where indicated as requiring no membrane) thin set as for other floors but with no membrane.

.4 Walls:

- .1 Concrete and Concrete Block: T.T.M.A.C. Detail #303W-2000:
 - .1 Levelling Coat: Laticrete 3701 or Mapei Mapecem mixed with Planicrete 50.
 - .2 Thinset mortar: Laticrete 4237 latex additive plus 211 Crete filler powder or Mapei Kerabond mixed with Keralastic high performance latex admixture.
 - .3 Grout: Laticrete Latapoxy SP100 solid epoxy grout or Kerapoxy. Colours to Owner's selection.
- .2 Gypsum Board: T.T.M.A.C. Detail #304W-2009/2010:
 - .1 Levelling Coat: Laticrete 3701 or Mapei Mapecem mixed with Planicrete 50.
 - .2 Thinset mortar: Laticrete 4237 latex additive plus 211 Crete filler powder or Mapei Kerabond mixed with Keralastic high performance latex admixture.
 - .3 Grout: Flextile Polymer modified unsanded grout, Laticrete Latapoxy SP100 solid epoxy grout or Mapei Kerapoxy. Colours to Owner's selection.

2.4 Patching and Levelling Compound

- .1 Portland cement base, acrylic polymer compound, manufactured specifically for resurfacing and levelling concrete floors. Products containing gypsum are not acceptable.
- .2 Have not less than the following physical properties:
 - .1 Compressive strength - 25 MPa.
 - .2 Tensile strength - 7 MPa.
 - .3 Flexural strength - 7 MPa.
 - .4 Density - 1.9.
- .3 Capable of being applied in layers up to 50 mm thick, being brought to feather edge, and being trowelled to smooth finish.
- .4 Ready for use in 48 hours after application.

2.5 Floor Sealer and Protective Coating

- .1 To tile and grout manufacturer's recommendations.

2.6 Accessories

- .1 Reducers, edge trim, and transition strips: Schluter Systems purpose made aluminum.
- .2 Stair Nosing: Schluter TREP-G, 55mm wide, Colours to be selected by the Owner.

- .3 CT Edge Protection: Schluter RONDEC, size to suit tile thickness. Satin anodized aluminum. Trim to come with all connectors or end caps required for a complete and finished installation. As a minimum, provide edge protection at the following locations:
 - .1 Top of PC Base;
 - .2 Top of CT wall tile;
 - .3 All outside corners of wall tile or porcelain ceramic tile base.
- .4 Transition Strip: (Porcelain ceramic tile to resilient flooring): Schluter RENO.V, satin anodized aluminum transition strips.
- .5 Cleavage plane: polyethylene film to CAN/CGSB-51.34-M86.
- .6 Sealant: as specified in Section 07 92 00.

PART 3 EXECUTION

3.1 Surface Conditions

- .1 Surfaces on which wall and floor tile is to be applied, shall be thoroughly cleaned down.
- .2 Concrete must be cured a minimum of 35 days before installation of ceramic tile.
- .3 Drywall surfaces on which wall and floor tile is to be applied, shall be free from dust, excess plaster and shall be plain and true without any irregularities.
- .4 Concrete floor slabs, concrete and masonry walls on which floor and wall tile are to be applied, shall be thoroughly cleaned down and all dust, efflorescence, dirt, etc. removed. Concrete and masonry wall surfaces to which wall tile is to be applied shall be levelled off as required with mortar adhesive to produce true flat surfaces.
- .5 In the event of discrepancies, immediately notify the Consultant and do not proceed with installation in such areas until all such discrepancies have been fully resolved.
- .6 Install transition strips, reducers and edge trim at exposed edges of all tiled walls and floors in accordance with manufacturer's instructions.
- .7 Ensure that conditions are suitable to receive membrane and tile. Report any adverse conditions to the Consultant. Commencement of the work will indicate acceptance of the surfaces to receive the tile.
- .8 Remove from the job site all damaged or broken items caused by improper handling or storage.
- .9 Ensure that all materials are fresh before starting work by recommended tests on site to ensure proper, permanent bonds.
- .10 Check that conditions of temperature, humidity, traffic and usage are suitable as required by Installation Manual specifications. Minimum temperature to be not less than 10°C.
- .11 Check that surfaces ready to receive tiling are cured, level and/or graded, plumb, smooth, firm, free from loose particles, droppings, projection, grease, solvent, paint and other foreign matter and from other unsuitable conditions.

3.2 Installation

- .1 Expansion joints which are required for structural reasons must be continued to the same width in the bedding mortar and tile cladding. Clean out joint when dry and apply a pore sealed backfill material and fill with sealant. Refer to Section 07 92 00.
- .2 Waterproof membrane and setting materials shall be installed in strict accordance with manufacturer's instructions.
- .3 Fit tile around corners, fitments, fixtures, and other built-in objects to maintain uniform joint appearance. Utilize appropriate accessory tiles at corners and junctions. Cut edges smooth, even and free from chipping. Edges resulting from splitting not acceptable.
- .4 Joints between tiles shall be uniform in width, plumb, straight, evenly spaced with adjacent tile flush and planeness in accordance with surface tolerance specified.
- .5 Install tile on substrates as noted on drawings and specified herein utilizing specified setting materials in strict accordance with manufacturers written instructions. Follow T.T.M.A.C. guidelines for expansion and control joints.
- .6 Locate and install control joints utilizing colour matched sealant at all corners and where recommended by substrate and tile manufacturers and where indicated on drawings and approved by the Consultant.
- .7 Unless specifically noted otherwise, all tile wall base is to be constructed using special trim shapes such as mosaic coves and mosaic bull nose tiles as part of a tile mosaic cove base (with TMCB designation) and cove where continuous with wall tile (with-C designation). Use special inside and outside trim shapes for all edges and corners. Install pre-manufactured trim where indicated.
- .8 Refer to room finish schedule for additional information.
- .9 Unless specifically noted otherwise, in areas where ceramic tile is indicated, provide ceramic tile base. Base to be 100 mm high with additional cut tiles to allow for slope in floor.
- .10 All materials to be installed as per manufacturer's instructions.
- .11 Seal ceramic tile prior to grouting with penetrating sealer when required or recommended by tile manufacturer.

3.3 Grouting

- .1 Grout all tile using specified grout in strict accordance with manufacturers written instructions all to give a flush, hard joint.
- .2 Joints in tile floor and base shall be filled solid and flush with grout.
- .3 Joints in wall tile shall be filled solid and flush with grout.
- .4 Prepare joints and mix grout in accordance with manufacturer's printed instructions. Force maximum amount of grout into joints, avoiding air traps or voids.

- .5 Remove all excess grout by washing diagonally across the joints. Check for voids, air pockets and gaps and fill same. Remove all discoloured grout and replace with new.
- .6 Cure all joints.

3.4 Extra Stock

- .1 Upon completion of the installation and as a condition of acceptance, deliver to the Owner 1% of tile and accessory tiles in each colour and pattern of ceramic tiles installed under this section for the Owners maintenance program. Identify each carton for location and installation date. Submission must be made all at one time and prior to Substantial Performance.

3.5 Cleaning

- .1 Proceed in accordance with Section 01 74 11 – Cleaning.
- .2 On completion, check work and replace defective, upset or misaligned tile. Make good skips, voids or excess grouting to the Consultant's approval.
- .3 Immediately following removal of grout from surface of ceramic tile, remove dust and wipe clean.
- .4 Thoroughly clean and polish all exposed surfaces of ceramic wall tile.
- .5 Leave tiles clean, free of any apparent cement or epoxy film. Any epoxy film shall be removed with epoxy film remover within 24 hours maximum from commencement of grouting. Ensure compatibility of epoxy film remover with grout materials.
- .6 Protect tiling during the works and until completion of the work with recommended methods and materials.

End of Section

PART 1 GENERAL

1.1 General

- .1 Conform to the requirements of Division 1.

1.2 Related Sections

- .1 Section 09 21 16 Gypsum Board Assemblies
- .2 Section 09 53 00 Acoustic Suspension

1.3 References

- .1 ASTM International (ASTM)
 - .1 ASTM C423-17 Standard Test Method for Sound Absorption and Sound Absorption Coefficients by the Reverberation Room Method
 - .2 ASTM E1264-14 Standard Classification for Acoustical Ceiling Products
 - .3 ASTM E1477-98a(2017) Standard Test Method for Luminous Reflectance Factor of Acoustical Materials by Use of Integrating-Sphere Reflectometers
- .2 Canadian General Standards Board (CGSB)
 - .1 CAN/CGSB-92.1-M89, Sound Absorptive Prefabricated Acoustical Units.
- .3 Canadian Standards Association (CSA International)
 - .1 CSA B111-1974 (R2003), Wire Nails, Spikes and Staples.
- .4 Underwriters Laboratories of Canada (ULC)
 - .1 CAN/ULC-S102-10 Standard Method of Test for Surface Burning Characteristics of building Materials and Assemblies

1.4 Submittals

- .1 Make submittals in accordance with Section 01 33 00 – Submittal Procedures.
- .2 Submit duplicate 300 x 300 mm samples of each type of acoustical units.

1.5 Environmental Requirements

- .1 Permit wet work to dry before beginning to install.
- .2 Maintain uniform minimum temperature of 15° C and humidity of 20-40% before and during installation.
- .3 Store materials in work area 48 hours prior to installation

1.6 Shipping, Handling and Storage

- .1 Refer to Section 01 61 00 – Common Product Requirements.
- .2 Deliver, handle and store materials in accordance with manufacturer's printed instructions.
- .3 Protect on site stored or installed absorptive material from moisture damage.

1.7 Waste Management and Disposal

- .1 Refer to Section 01 74 19 – Construction Waste Management and Disposal.

- .2 Remove from site and dispose of packaging materials at appropriate recycling facilities.
- .3 Collect and separate for disposal packaging material in appropriate on-site bins for recycling in accordance with Waste Management Plan (WMP).

1.8 Extra Materials

- .1 Provide extra materials of acoustic units in accordance with Section 01 78 00 - Closeout Submittals.
- .2 Provide acoustical units amounting to 5% of gross ceiling area for each pattern and type required for project.
- .3 Ensure extra materials are from same production run as installed materials.
- .4 Deliver to Owner upon completion of the work of this section.

PART 2 PRODUCTS

2.1 Materials

- .1 Acoustic units for suspended ceiling system: to CAN/CGSB-92.1-M and ASTM E 1264
- .2 Panel Type 1: CGC Fissured.
 - .1 Class A.
 - .2 Composition: Water Felted Mineral Fiber
 - .3 Pattern regular fissured.
 - .4 Texture: medium.
 - .5 Flame spread: ASTM E1264-98, Class A (U.L.C.), 25 or less.
 - .6 Smoke developed 50 or less in accordance with CAN/ULC-S102-10.
 - .7 Noise Reduction Coefficient (NRC): ASTM C423; Classified with UL label, 0.55
 - .8 Ceiling Attenuation Class (CAC): ASTM C1414; Classified with UL label, 35
 - .9 Light Reflectance (LR) range of 0.81 to ASTM E1477-98a (2003).
 - .10 Dimensional Stability: Standard
 - .11 Edge Profile: Square Lay-In
 - .12 Colour: White.
 - .13 Size 610 x 1219 x 16 mm thick.
 - .14 Shape flat.
 - .15 Surface coverings: Ecolabel certified paint.
- .3 Alternate manufacturer: Products as manufactured by Armstrong Industries or Certaineed are acceptable, subject to Owner's approval of style, finish, performance characteristics and texture.
- .4 Staples, nails and screws: to CSA B111 non-corrosive finish as recommended by acoustic unit manufacturer.
- .5 Ceiling Suspension System: as specified in Section 09 53 00.

PART 3 EXECUTION

3.1 Examination

- .1 Do not install acoustical panels until work above ceiling has been inspected by Consultant.

3.2 Installation

- .1 Install acoustical panels and tiles in ceiling suspension system.

3.3 Application

- .1 Install acoustical units parallel to building lines with edge unit not less than 50% of unit width, with directional pattern running in same direction. Refer to reflected ceiling plan.
- .2 Scribe acoustic units to fit adjacent work. Butt joints tight, terminate edges with moulding

3.4 Interface with Other Work

- .1 Co-ordinate with Section 09 53 00 - Acoustical Suspension.
- .2 Co-ordinate ceiling work to accommodate components of other sections to be built into acoustical ceiling including mechanical and electrical work.

3.5 Cleaning

- .1 Proceed in accordance with Section 01 74 11 – Cleaning.

End of Section

PART 1 GENERAL

1.1 General

- .1 Conform to the requirements of Division 1.

1.2 Related Sections

- .1 Section 09 21 16 Gypsum Board Assemblies
- .2 Section 09 51 13 Acoustic Panel Ceilings

1.3 References

- .1 ASTM International (ASTM)
 - .1 ASTM A641/A641M-09a (2014) Standard Specification for Zinc-Coated (Galvanized) Carbon Steel Wire.
 - .2 ASTM C635/C635M-13a Standard Specification for the Manufacture, Performance, and Testing of Metal Suspension Systems for Acoustical Tile and Lay in Panel Ceilings.
 - .3 ASTM C636/C636M-13, Standard Practice for Installation of Metal Ceiling Suspension Systems for Acoustical Tile and Lay-In Panels.

1.4 Submittals

- .1 Make submittals in accordance with Section 01 33 00 – Submittal Procedures.
- .2 Submit when requested, one representative model of each type of ceiling suspension system.
 - .1 Ceiling system to show basic construction and assembly, treatment at walls, recessed fixtures, splicing, interlocking, finishes, acoustical unit installation.

1.5 Design Requirements

- .1 Maximum deflection: 1/360th of span to ASTM C635 deflection test.

1.6 Shipping, Handling and Storage

- .1 Refer to Section 01 61 00 – Common Product Requirements.
- .2 Deliver, handle and store materials in accordance with manufacturer's printed instructions.

1.7 Waste Management and Disposal

- .1 Refer to Section 01 74 19 – Construction Waste Management and Disposal.

PART 2 PRODUCTS

2.1 Materials

- .1 Components: All main beams and cross tees shall be commercial quality hot-dipped galvanized steel as per ASTM C635. Main beams and cross tees shall be double-web steel construction with type exposed flange design. Exposed surfaces chemically cleansed, capping pre-finished galvanized steel in baked polyester paint. Main beams and cross tees shall have rotary stitching.
- .2 Face width: 7/8"

- .3 Edge Moldings and Trim: Hemmed angle moulding to match main beams and cross tees.
- .4 Structural Classification: Intermediate Duty System, ASTM C635.
- .5 Colour: White and match the actual colour of the specified ceiling tile.
- .6 Standard of Acceptance:
 - .1 Armstrong Prelude XL
 - .2 Donn DXT
 - .3 Certainteed Classic Environmental Stab.
- .7 Attachment Devices: Size for five times design load indicated in ASTM C635, Table 1, Direct Hung unless otherwise indicated.
- .8 Wire for Hangers and Ties: ASTM A641, Class 1 zinc coating, soft annealed, with a yield stress load of at least three times design load, but not less than 12 gauge.

PART 3 EXECUTION

3.1 Manufacturer's Instructions

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheets.

3.2 Installation

- .1 Install suspension system and panels in compliance with ASTM C636; CISCA Seismic Guidelines; approved construction drawings; with the authorities having jurisdiction; and in accordance with the manufacturer's installation instructions.
- .2 Install wall moldings at intersection of suspended ceiling and vertical surfaces.
- .3 Do not erect ceiling suspension system until work above ceiling has been inspected by Consultant.
- .4 Secure hangers to overhead structure using attachment methods as indicated by manufacturer. Do not suspend ceiling systems from building services including plumbing lines, conduit, cable trays or duct work.
- .5 Install hangers spaced at maximum 48" centres and within 6" from ends of main tees. Install hanger wires plumb and straight.
- .6 Lay out centre line of ceiling both ways, to provide balanced borders at room perimeter with border units not less than 50% of standard unit width.
- .7 Ensure suspension system is coordinated with location of related components.
- .8 Completed suspension system to support super-imposed loads, such as lighting fixtures, diffusers, grilles, and speakers.

- .9 Support at light fixtures and diffusers with additional ceiling suspension hangers within 150 mm of each corner and at maximum 24" around perimeter of fixture.
- .10 Interlock cross member to main runner to provide rigid assembly.
- .11 Frame at openings for light fixtures, air diffusers, speakers and at changes in ceiling heights.
- .12 Install access splines to provide ceiling access.
- .13 Finished ceiling system to be square with adjoining walls and level within 1:1000

3.3 Cleaning

- .1 Proceed in accordance with Section 01 74 11 – Cleaning.
- .2 Touch up scratches, abrasions, voids and other defects in painted surfaces

End of Section

PART 1 GENERAL

1.1 General

- .1 Conform to the requirements of Division 1.

1.2 Related Sections

- .1 Section 03 30 00 Cast-in-Place Concrete
- .2 Section 09 68 13 Carpet Tile

1.3 References

- .1 ASTM International (ASTM)
 - .1 ASTM E84-17 Standard Test Method for Surface Burning Characteristics of Building Materials
 - .2 ASTM F710-17 Standard Practice for Preparing Concrete Floors to Receive Resilient Flooring
 - .3 ASTM F1066-04(2014)e1 Standard Specification for Vinyl Composition Floor Tile
 - .4 ASTM F1344-15 Standard Specification for Rubber Floor Tile
 - .5 ASTM F1861-16 Standard Specification for Resilient Wall Base
- .2 Canadian General Standards Board (CGSB)
 - .1 CAN/CGSB-25.20, Surface Sealer for Floors.
 - .2 CAN/CGSB-25.21, Detergent-Resistant Floor Polish.
- .3 Underwriters Laboratories of Canada (ULC)
 - .1 CAN/ULC-S102.2, Surface Burning Characteristics of Flooring, Floor Covering and Miscellaneous Materials and Assemblies.
- .4 South Coast Air Quality Management District (SCAQMD), California State
 - .1 SCAQMD Rule 1168-03, Adhesives and Sealants Applications.

1.4 Submittals

- .1 Make submittals in accordance with Section 01 33 00 – Submittal Procedures.
- .2 Submit duplicate samples of manufacturer's full range of colours for specified products for selection of colours by the Owner.
- .3 Before any resilient flooring materials are delivered to the job site, submit to the Owner, a complete list of all materials proposed to be furnished and installed under this portion of the Work, stating manufacturer's name and catalogue number for each item, and product samples in colours specified.
- .4 Accompanying the materials list, submit two copies of the manufacturer's current recommended method of installation for each item.
- .5 Provide maintenance data for resilient flooring for incorporation into Operation and Maintenance Manual specified in Section 01 78 00 – Closeout Submittals.

1.5 Shipping, Handling and Storage

- .1 Refer to Section 01 61 00 – Common Product Requirements.
- .2 Deliver, handle and store materials in accordance with manufacturer's printed instructions.

- .3 Use all means necessary to protect resilient flooring materials before, during and after installation and to protect the installed work and materials of all other trades.

1.6 Extra Materials

- .1 Provide extra stock materials of resilient flooring, base and adhesives in accordance with Section 01 78 00 – Closeout Submittals.
- .2 Provide one carton of each colour, pattern and type flooring material required for this project for maintenance use.
- .3 Provide one container of adhesive.
- .4 Extra materials to be from same production run as installed materials.
- .5 Clearly identify each container of floor tile and each container of adhesive.

1.7 Environmental Requirements

- .1 Maintain air temperature and structural base temperature at floor installation area above 20° C for 48 hours before, during and after installation.

1.8 Waste Management and Disposal

- .1 Refer to Section 01 74 19 – Construction Waste Management and Disposal.

1.9 Warranty

- .1 Warrant the work of this Section against defects of workmanship and material, for a period of ten years from the date of Substantial Performance and agree to make good promptly any defects which occur or become apparent within the warranty period.

PART 2 PRODUCTS

2.1 Materials

- .1 VCT-1: Vinyl Composition Tile Armstrong Standard Excelon Imperial Texture. Up to three colours will be selected. VCT to CSA A126.1 or ASTM F1066, 305 x 305 x 3.0 mm thick, non-asbestos, Class 2 through pattern tile with static load of not less than 517 kPa and U.L.C. flame spread rating of 75 or less.
- .2 RB-1: Resilient Base, Johnsonite Traditional Rubber Wall Base. Up to two colours will be selected. Base to ASTM F1861, 100 mm high thermoplastic rubber, not less than 3.0 mm gauge with preformed internal and external corners. Base at resilient tile shall have standard toe.
- .3 Primers, Adhesives and Caulking: non-flammable, solvent free, waterproof, recommended by flooring manufacturer for specific material on applicable substrate, above, at or below grade.
- .4 Sub-floor filler and leveler shall be white premixed latex compatible with flooring products and adhesive as recommended by flooring manufacturer for specific flooring types.
- .5 Metal edge strips: aluminum extruded, smooth, mill finish with lip to extend under floor finish, shoulder flush with top of adjacent floor finish.

- .6 Transition strips, mouldings and adaptors shall be rubber or vinyl, manufactured by Johnsonite, Roppe or Burke Mercer with lip to extend under floor tile with tapered edge, colour matched to flooring.
- .7 Sealer: to CAN/CGSB25.20, Type 2-water based, type recommended by flooring manufacturer.
- .8 Wax: to CAN/CGSB-25.21, type recommended by flooring manufacturer.
- .9 All colours and patterns shall be as selected by the Owner from the complete range of manufacturer's colours and patterns.

PART 3 EXECUTION

3.1 Surface Conditions

- .1 Conform to requirements of ASTM F710.
- .2 Prior to all work of this Section, carefully inspect the installed work of all other trades and verify that all such work is complete to the point where this installation may properly commence.
- .3 Confirm that resilient flooring and base may be installed in accordance with the original design and the manufacturer's recommendations.
- .4 Ensure concrete floors are dry, by using test methods recommended by tile manufacturer. Concrete must be cured a minimum of 35 days prior to commencement of resilient flooring application.
- .5 In the event of discrepancy, immediately notify the Consultant.
- .6 Do not proceed with installation in areas of discrepancy until all such discrepancies have been fully resolved.

3.2 Sub Floor Treatment

- .1 Remove sub-floor ridges and bumps. Fill low spots, cracks, joints, holes and other defects with sub-floor filler.
- .2 Install sub floor to manufacturer's recommended standard limits and deviations.
- .3 Remove all substance and materials affecting adhesive bond.
- .4 Vacuum clean floors.
- .5 Clean floor and apply filler; trowel and float to leave smooth, flat hard surface. Prohibit traffic until filler is cured and dry.
- .6 Prime or seal substrates to flooring and adhesive manufacturer's instructions.
- .7 Allow for excessive leveling of existing slabs.

3.3 Application

- .1 Provide a high ventilation rate, with maximum outside air, during installation, and for 48 hours after installation. Whenever possible, ventilate directly to outside. Do not allow contaminated air to re-circulate through the building ventilation system.
- .2 Install all resilient flooring in strict accordance with the manufacturer's printed instructions and recommendations.
- .3 Do not lay floor coverings and base until all trades, except painter, have completed their work and just prior to completion of the building.
- .4 Apply adhesive uniformly with recommended trowels, at coverage as recommended by the manufacturer. Do not spread more adhesive than can be covered before initial set takes place.
- .5 Lay flooring with joints parallel to building lines unless otherwise indicated, to produce symmetrical tile pattern. Patterns shall be as directed by the Owner. Allow for one field tile and one accent tile in each room or space. Border tiles shall be minimum ½ tile width.
- .6 Install flooring to square grid pattern with all joints aligned unless otherwise indicated.
- .7 As installation progresses, and after installation, roll flooring in 2 directions with a 45 kg roller to ensure full adhesion.
- .8 Cut and fit tile neatly around fixed objects.
- .9 Install feature strips or feature tiles where directed. Fit joints tightly.
- .10 Continue flooring throughout areas to receive movable type partitions or fitments without interrupting floor pattern.
- .11 Install flooring full depth of closets, toe spaces, and recesses.
- .12 Terminate flooring at centre line of door in openings where adjacent floor finish or colour is dissimilar.
- .13 Install transition strips at unprotected or exposed edges where flooring terminates. Locate transition strip at centre line of door where a door occurs.

3.4 Base Application

- .1 Lay out base to keep number of joints to a minimum. Locate joints at maximum available spacing or at internal or pre moulded corners.
- .2 Clean substrate and prime with one coat of adhesive.
- .3 Apply adhesive to back of base.
- .4 Set base against wall and floor surfaces tightly by using a 3 kg hand roller.
- .5 Install straight and level to variation of 1:1000.

- .6 Scribe and fit to door frames and other obstructions. Use pre-moulded end pieces at flush door frames.
- .7 Cope internal corners. Use pre moulded corner units for right angle external corners. Use formed straight base materials for external corners of other angles, minimum 300 mm each leg.
- .8 Provide rubber base at all locations specified, regardless of floor finish.

3.5 Cleaning

- .1 Proceed in accordance with Section 01 74 11 – Cleaning.
- .2 Remove excess adhesive from resilient floor coverings, base and adjacent finished surfaces as the work progresses.
- .3 Clean, seal and wax floor and base surfaces to manufacturer's instructions. In carpeted areas, clean base before installation of carpet.

3.6 Protection

- .1 Protect new floors until time of final inspection.
- .2 Prohibit traffic on floors for 48 hours after installation.
- .3 Immediately prior to final inspection, remove protection, clean, dry or damp mop resilient flooring and apply one additional coat of wax.

End of Section

PART 1 GENERAL

1.1 General

- .1 Conform to the requirements of Division 1.

1.2 Related Sections

- .1 Section 03 30 00 Cast-in-Place Concrete
- .2 Section 07 92 00 Joint Sealants
- .3 Section 09 65 19 Resilient Flooring

1.3 References

- .1 ASTM International (ASTM)
 - .1 ASTM D2859-16 Standard Test Method for Ignition Characteristics of Finished Textile Floor Covering Materials
 - .2 ASTM E662-17a Standard Test Method for Specific Optical Density of Smoke Generated by Solid Materials ASTM E648-15e1 Standard Test Method for Critical Radiant Flux of Floor-Covering Systems Using a Radiant Heat Energy Source
 - .3 ASTM F710-17 Standard Practice for Preparing Concrete Floors to Receive Resilient Flooring
 - .4 ASTM F1869-16a Standard Test Method for Measuring Moisture Vapor Emission Rate of Concrete Subfloor Using Anhydrous Calcium Chloride
 - .5 ASTM F2170-17 Standard Test Method for Determining Relative Humidity in Concrete Floor Slabs Using in situ Probes
- .2 Canadian General Standards Board (CGSB):
 - .1 CAN/CGSB-4.129-93: Carpet for Commercial Use;
 - .2 CAN/CGSB-4-GP-156: Direct Glue-Down Carpet, Guide to Selection and Installation.
- .3 Carpet and Rug Institute (CRI)
 - .1 CRI 104-2002, Standard for Installation of Commercial Carpet;
 - .2 CRI Indoor Air Quality Carpet Testing Program.
- .4 American Association of Textile Chemists and Colorists:
 - .1 Color Fastness to Lightfastness ASTCC 16-E;
- .5 American Association of Textile Chemists and Colorists (AATCC):
 - .1 Electrostatic Propensity of Carpet, AATCC -134 under 3.5KV;
- .6 Underwriters' Laboratories of Canada (ULC):
 - .1 CAN/ULC-S102.2, Surface Burning Characteristics of Flooring, Floor Covering and Miscellaneous Materials and Assemblies.

1.4 Submittals

- .1 Make submittals in accordance with Section 01 33 00 – Submittal Procedures.
- .2 Samples: Submit duplicate 610 mm square pieces of full line of each type of carpet tile specified for selection of colours by the Owner.
- .3 Submit carpet layout with a complete list of all materials proposed to Owner for review prior to start of work.
- .4 Submit two copies of the manufacture's current recommended method of installation for each item.

- .5 Provide maintenance data for carpet for inclusion in Operation and Maintenance Manual specified in Section 01 78 00.

1.5 Quality Assurance

- .1 Flooring contractor shall be approved by the material manufacturer and shall have completed a minimum of three projects of similar scope.

1.6 Shipping, Handling and Storage

- .1 Refer to Section 01 61 00 – Common Product Requirements.
- .2 Deliver, handle and store materials in accordance with manufacturer's printed instructions.
- .3 Use all means necessary to protect carpet materials before, during and after installation and to protect the installed work and materials of all other trades.
- .4 In the event of damage, immediately make all repairs and replacements necessary to the approval of the Consultant and at no additional cost to the Owner.

1.7 Waste Management and Disposal

- .1 Refer to Section 01 74 19 – Construction Waste Management and Disposal.

1.8 Warranty

- .1 Warrant the work of this Section against defects of workmanship and material, for a period of two (2) years from the date of Substantial Performance and agree to make good promptly any defects which occur or become apparent within the warranty period.

PART 2 PRODUCTS

2.1 Manufacturers

- .1 Carpet tile meeting the specified requirements and manufactured by one of the following may be acceptable, subject to approval by the Owner of material colour range and patterns:
 - .1 Interface Flooring Systems (Canada) Inc.
 - .2 Mannington Commercial
 - .3 The Mohawk Group
 - .4 Patcraft Commercial Carpet and Commercial Flooring
 - .5 Tandus Flooring
 - .6 Shaw Contract Group

2.2 Materials

- .1 Carpet Tile: Modular, Class 2 through pattern tile with static load of not less than 517 kPa, single dye lot base.
 - .1 Basis of specification and standard of acceptance: Shaw Contract Group:
 - .1 Field Tile: Hype, No Rules Collection.
 - .2 Accent Tile: Selected by the Owner from manufacturer's Solid Colour collection with physical and performance properties matching the field tile.
- .2 Carpet tile construction shall meet or exceed the following:

- .1 Fibre: Shaw eco-solution Q nylon.
 - .2 Dye Method: 100% Solution Dyed.
 - .3 Tufted Yarn Weight: 16 oz. minimum.
 - .4 Pile Characteristics: Multi-level loop.
 - .5 Gauge: 1/12 minimum.
 - .6 Stitches per inch: 9.00 minimum.
 - .7 Finished pile thickness: 0.092 inches.
 - .8 Average Density: 6,261 oz./yd.
 - .9 Tile size: 610 x 610 mm
 - .10 Secondary Backing System: Shaw ecoworx tile
 - .1 Recyclable content.
 - .2 Maintaining a 100% true moisture barrier between the secondary backing and the substrate below.
 - .11 Colour and Pattern: Owner to select from manufacturers standard colour range.
 - .1 Make allowance for a minimum of three (3) colours including one field tile and three sold colour tiles.
 - .12 Inherent Static Control less than 3.5 Kilovolts at 21°C and 20% relative humidity.
 - .13 Delimitation to ASTM D3936 to min 2.5 Lbs/in.
 - .14 Soil/Stain protection.
- .3 Adhesive: Pressure Sensitive Adhesive or as recommended by manufacturer.
- .4 Accessories:
 - .1 Trim & Accessories: Finercraft Plastic Products Inc.
 - .2 Rubber base: as specified in Section 09 65 19.
 - .3 Carpet Protection: Non-staining, heavy duty Kraft paper or 6 mil thick polyethylene film.
 - .4 Leveling and Patching Compounds: Portland cement-based formulation provided by or recommended by carpet tile manufacturer. Do not use gypsum based compounds.
- .5 All products shall meet the flame spread and smoke developed criteria under CAN/ULC-S102.2.

PART 3 EXECUTION

3.1 Inspection

- .1 The labels on each carton shall indicate product style, pattern, colour, run number and dye lot. Confirm that the style, pattern and colour match the specifications for each area of installation. Do not mix run numbers or dye lots on the same area

3.2 Surface Conditions

- .1 Prior to all work of this Section, carefully inspect the installed work of all other trades and verify that all such work is complete to the point where this installation may properly commence.
- .2 Confirm that carpet tile may be installed in accordance with the original design and the manufacturer's recommendations.
- .3 In the event of discrepancy, immediately notify the Consultant.
- .4 Do not proceed with installation in areas of discrepancy until all such discrepancies have been fully resolved.

- .5 The temperature of the job site must stay within 15°C and 25°C throughout the installation and for 2-3 days beforehand.
- .6 Concrete Subfloors: Verify that concrete slabs comply with the following:
 - .1 Prepare concrete subfloors in accordance with ASTM F710-03.
 - .2 Concrete floors must be thoroughly cured (minimum 90 days) prior to tile installation.
 - .3 Remove coatings, including curing compounds, existing floor covering adhesive residues, and other substances that are incompatible with adhesives and that contain soap, wax, oil, or silicone, without using solvents. Use mechanical methods recommended in writing by the carpet manufacturer.
 - .4 Slab substrates are dry and free of curing compounds, sealers, hardeners, and other materials that may interfere with adhesive bond. Determine adhesion and dryness characteristics by performing bond and moisture tests recommended by the carpet manufacturer.
 - .5 Test the moisture emission and alkalinity levels of the concrete as per manufacturer's instructions and referenced standards.
 - .6 Use leveling and patching compounds recommended by flooring manufacturer for filling cracks, holes and depressions in the substrate. Surface shall be smooth, level and at proper elevation. Remove ridges, roughness and protrusions from concrete surfaces by grinding.

3.3 Installation

- .1 Do not lay carpet tiles until all trades, except painter, have completed their work and just prior to completion of the building.
- .2 Install carpet tile using a minimum number of pieces of carpet tile.
- .3 Install all carpet tiles in strict accordance with the manufacturer's recommendations and written installation instructions and CRI 104, Section 14, "Carpet Modules".
- .4 Fill all cavities, cracks, joints and all other surface imperfections in concrete substrate with latex fill or other approved subfloor filler in order to produce a smooth, flat, hard surface for receipt of carpet tile. Scrape off all ridges, droppings, scale and other projections. Clean floor with an industrial vacuum cleaner. Remove all substance and materials affecting adhesive bond.
- .5 Install carpet tile pattern parallel to walls and borders
- .6 Dry fit (without adhesive) tiles along the entire length of vertical and horizontal centre lines. Make necessary adjustments prior to commencing installation.
- .7 Provide full coverage spread of specified release adhesive. Protect all elements and baseboards with plastic or other material before spraying. Apply adhesive in accordance to manufacturer's recommendations.
- .8 Lay tiles in the step or pyramid pattern in accordance to manufacturer's recommendations.
- .9 Tiles adjacent to fixtures, architectural elements and walls shall be cut. Follow the manufacturer's guidelines. Where tiles terminate at doorways, or where tiles of different type or colour butt together the joint shall centre on the door. Provide and install reducer strips where carpet tiles terminate against a concrete floor where no applied architectural floor finish is required. Reducer strip shall be installed below centre of door where a door occurs.

- .10 Lay tiles with all joints square and tightly butted together. Start installation from centre of rooms to ensure equal maximum size edge tiles. Pattern and direction of tile shall be as directed by the Consultant.
- .11 Lay tiles at full depth of closets, toe spaces, and recesses. Cut and fit tiles tightly against openings, breaks, frames, fixtures, columns and other vertical surfaces. Apply adhesive to provide watertight joint around all cut areas.
- .12 Roll carpet tile for complete contact of carpet tile with adhesive and substrate.
- .13 Resilient base shall be installed under Section 09 65 19.

3.4 Maintenance Materials

- .1 Submit in accordance with Section 01 78 00.
- .2 Prior to installation, provide extra materials as described below. Extra materials to be packaged with protective covering for storage. Identify extra materials with labels describing contents.
- .3 Extra Stock: Provide full size units equal to one carton of each type, colour and pattern required. Store on site as directed.
- .4 Maintenance materials to be from the same product run as installation materials.

3.5 Cleaning

- .1 Proceed in accordance with Section 01 74 11 – Cleaning.
- .2 Inspect the entire installation, paying close attention to joint and any tiles that have been cut.
- .3 Remove surplus adhesive from carpet tiles as the work progresses.
- .4 Five days after installation of coverings, clean and finish floor tiles in accordance with flooring manufacturer's recommendations. Protect with non-staining building paper.
- .5 Immediately prior to final inspection, remove protection and vacuum the floor with a pile lifter.

End of Section

PART 1 GENERAL

1.1 General

- .1 Conform to the requirements of Division 1.

1.2 Related Sections

- .1 Section 04 22 00 Concrete Unit Masonry
- .2 Section 06 20 00 Finish Carpentry
- .3 Section 08 11 00 Metal Doors and Frames
- .4 Section 09 21 16 Gypsum Board

1.3 References

- .1 Environmental Protection Agency (EPA)
 - .1 Test Method for Measuring Total Volatile Organic Compound Content of Consumer Products, Method 24 (for Surface Coatings).
- .2 Health Canada/Workplace Hazardous Materials Information System (WHMIS)
 - .1 Material Safety Data Sheets (MSDS).
- .3 Master Painters Institute (MPI)
 - .1 MPI Architectural Painting Specifications Manual, 2004.
 - .2 Standard GPS-1-05, MPI Green Performance Standard for Painting and Coatings.
- .4 National Fire Code of Canada.
- .5 Society for Protective Coatings (SSPC)
 - .1 Systems and Specifications, SSPC Painting Manual 2005.
- .6 Underwriters Laboratories of Canada (ULC)
 - .1 CAN/ULC-S102-10, Standard Method of Test for Surface Burning Characteristics of Building Materials and Assemblies
- .7 South Coast Air Quality Management District, California State (SCAQMD)
 - .1 SCAQMD Rule 1113-96, Architectural Coatings.
- .8 Green Seal GS-11 Green Seal Environmental Standard for Paints and Coatings, January 1997.

1.4 Submittals

- .1 Make submittals in accordance with Section 01 33 00 – Submittal Procedures.
- .2 Product Data:
 - .1 Submit manufacturer's printed product literature, specifications and datasheet and include product characteristics, performance criteria, physical size, finish and limitations.
- .3 Samples:
 - .1 Submit full range colour sample chips to indicate where colour availability is restricted.
 - .2 Submit duplicate 200 x 300 mm sample panels of each paint, stain, clear coating and special finish with specified paint or coating in colours, gloss/sheen and textures required to MPI Architectural Painting Specification Manual standards.
 - .3 Retain reviewed samples on-site to demonstrate acceptable standard of quality for appropriate on-site surface.
- .4 Certificates: submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties and SCAQMD Rule 1113-96.
- .5 Closeout Submittals: submit maintenance data for incorporation into manual specified in Section 01 78 00 - Closeout Submittals include following:

- .1 Product name, number, type and use.
- .2 Colour numbers.
- .3 MPI Environmentally Friendly classification system rating.

1.5 Quality Control

- .1 Provide mock-up in accordance with Section 01 45 00 - Quality Control.
- .2 Mock-Ups:
 - .1 Prepare and paint designated surface, area, room or item (in each colour scheme) to specified requirements, with specified paint or coating showing selected colours, gloss/sheen and textures. Locate where directed.
 - .2 Mock-up will be used to judge workmanship, substrate preparation, operation of equipment and material application and workmanship to MPI Architectural Painting Specification Manual standards.
 - .3 Allow 24 hours for inspection of mock-up before proceeding with work.
 - .4 When accepted, mock-up will demonstrate minimum standard of quality required for this work. Approved mock-up may remain as part of finished work.

1.6 Quality Assurance

- .1 Qualifications:
 - .1 Contractor: to have a minimum of five years proven satisfactory experience.
 - .2 Qualified journeypersons as defined by local jurisdiction to be engaged in painting work.
 - .3 Apprentices: may be employed provided they work under direct supervision of qualified journeyperson in accordance with trade regulations.
- .2 Conform to latest MPI requirements for painting work including preparation and priming.
- .3 Materials: in accordance with MPI Painting Specification Manual "Approved Product" listing and from a single manufacturer for each system used.
- .4 Paint materials to be highest quality product of an approved manufacturer listed in MPI Painting Specification Manual and to be compatible with other coating materials as required.

1.7 Shipping, Handling and Storage

- .1 Refer to Section 01 61 00 – Common Product Requirements.
- .2 Deliver and store materials in original containers, sealed, with labels intact. Labels to indicate:
 - .1 Manufacturer's name and address.
 - .2 Type of paint or coating.
 - .3 Compliance with applicable standard.
 - .4 Colour number in accordance with established colour schedule.
- .3 Remove damaged, opened and rejected materials from site.
- .4 Provide and maintain dry, temperature controlled, secure storage.
- .5 Observe manufacturer's recommendations for storage and handling.
- .6 Store materials and supplies away from heat generating devices.
- .7 Store materials and equipment in well-ventilated area with temperature range 7°C to 30° C.

- .8 Store temperature sensitive products above minimum temperature as recommended by manufacturer.
- .9 Keep areas used for storage, cleaning and preparation, clean and orderly to approval of Owner. After completion of operations, return areas to clean condition to approval of Owner.
- .10 Remove paint materials from storage only in quantities required for same day use.
- .11 Comply with requirements of Workplace Hazardous Materials Information System (WHMIS) regarding use, handling storage, and disposal of hazardous materials.

1.8 Fire Safety Requirements

- .1 Provide one 9 kg Type ABC dry chemical fire extinguisher adjacent to storage area.
- .2 Store oily rags, waste products, empty containers and materials subject to spontaneous combustion in ULC approved, sealed containers and remove from site on a daily basis.
- .3 Handle, store, use and dispose of flammable and combustible materials in accordance with National Fire Code of Canada requirements.

1.9 Waste Management and Disposal

- .1 Refer to Section 01 74 19 – Construction Waste Management and Disposal.
- .2 Remove from site and dispose of packaging materials at appropriate recycling facilities.
- .3 Place materials defined as hazardous or toxic in designated containers. Handle and dispose of hazardous materials in accordance with Municipal regulations.
- .4 Ensure emptied containers are sealed and stored safely.
- .5 Unused materials must be disposed of at official hazardous material collections site as approved by Owner.
- .6 Paint, stain and wood preservative finishes and related materials (thinners, and solvents) are regarded as hazardous products and are subject to regulations for disposal. Information on these controls can be obtained from Provincial Ministries of Environment and Regional levels of Government.
- .7 Material which cannot be reused must be treated as hazardous waste and disposed of in an appropriate manner.
- .8 Place materials defined as hazardous or toxic waste, including used sealant and adhesive tubes and containers, in containers or areas designated for hazardous waste.
- .9 To reduce the amount of contaminants entering waterways, sanitary/storm drain systems or into ground follow these procedures:
 - .1 Retain cleaning water for water-based materials to allow sediments to be filtered out.
 - .2 Retain cleaners, thinners, solvents and excess paint and place in designated containers and ensure proper disposal.
 - .3 Return solvent and oil soaked rags used during painting operations for contaminant recovery, proper disposal, or appropriate cleaning and laundering.
 - .4 Dispose of contaminants in approved legal manner in accordance with hazardous waste

- regulations.
- .5 Empty paint cans are to be dry prior to disposal or recycling (where available).
- .10 Where paint recycling is available, collect waste paint by type and provide for delivery to recycling or collection facility.
- 1.10 Maintenance
- .1 Extra Materials:
- .1 Submit maintenance materials in accordance with Section 01 78 00 - Closeout Submittals.
 - .2 Deliver to extra materials from same production run as products installed. Package products with protective covering and identify with descriptive labels.
 - .3 Quantity: provide one four litre can of each type and colour of primer stain finish coating. Identify colour and paint type in relation to established colour schedule and finish system.
 - .4 Delivery, storage and protection: comply with Owner's requirements for delivery and storage of extra materials.
- 1.11 Ambient Conditions
- .1 Heating, Ventilation and Lighting:
- .1 Ventilate enclosed spaces in accordance with Section 01 51 00 – Temporary Utilities.
 - .2 Provide heating facilities to maintain ambient air and substrate temperatures above 10° C for 24 hours before, during and after paint application until paint has cured sufficiently.
 - .3 Provide continuous ventilation for seven days after completion of application of paint.
 - .4 Provide temporary ventilating and heating equipment where permanent facilities are not available or supplemental ventilating and heating equipment if ventilation and heating from existing system is inadequate to meet minimum requirements.
 - .5 Provide minimum lighting level of 323 Lux on surfaces to be painted.
- .2 Temperature, Humidity and Substrate Moisture Content Levels:
- .1 Unless pre-approved written approval by Consultant and product manufacturer, perform no painting when:
 - .1 Ambient air and substrate temperatures are below 10° C.
 - .2 Substrate temperature is above 32° C unless paint is specifically formulated for application at high temperatures.
 - .3 Substrate and ambient air temperatures are not expected to fall within MPI or paint manufacturer's prescribed limits.
 - .4 The relative humidity is under 85% or when the dew point is more than 3° C variance between the air/surface temperature. Paint should not be applied if the dew point is less than 3° C below the ambient or surface temperature. Use sling psychrometer to establish the relative humidity before beginning paint work.
 - .2 Ensure that conditions are within specified limits during drying or curing process, until newly applied coating can itself withstand 'normal' adverse environmental factors.
 - .3 Perform painting work when maximum moisture content of the substrate is below:
 - .1 Allow new concrete to cure minimum of 28 days.
 - .2 15% for wood.
 - .3 12% for plaster and gypsum board.
 - .4 Test for moisture using calibrated electronic Moisture Meter. Test concrete floors for moisture using "cover patch test".
 - .5 Test concrete and plaster surfaces for alkalinity as required.
 - .6 Surface and Environmental Conditions:
 - .1 Apply paint finish in areas where dust is no longer being generated by related construction operations or when wind or ventilation conditions are such that airborne particles will not affect quality of finished surface.

- .2 Apply paint to adequately prepared surfaces and to surfaces within moisture limits.
- .3 Apply paint when previous coat of paint is dry or adequately cured.
- .7 Additional interior application requirements:
 - .1 Apply paint finishes when temperature at location of installation can be satisfactorily maintained within manufacturer's recommendations.

PART 2 PRODUCTS

2.1 Materials

- .1 Products to meet requirements of GS-03, GS-11 or SCAQMD Rule 1113-96
- .2 Paint materials listed in the MPI Approved Products List (APL) are acceptable for use on this project.
- .3 Provide paint materials for paint systems from single manufacturer.
- .4 Only qualified products with E2 or E3 "Environmentally Friendly" rating are acceptable for use on this project.
- .5 Linseed oil, shellac, and turpentine: highest quality product from approved manufacturer listed in MPI Architectural Painting Specification Manual, compatible with other coating materials as required.
- .6 Paints, coatings, adhesives, solvents, cleaners, lubricants, and other fluids:
 - .1 Water-based, Water clean-up.
 - .2 Non-flammable, biodegradable.
 - .3 Manufactured without compounds which contribute to ozone depletion in the upper atmosphere.
 - .4 Manufactured without compounds which contribute to smog in the lower atmosphere.
 - .5 Do not contain methylene chloride, chlorinated hydrocarbons or toxic metal pigments.
 - .6 Recycled content of 15% post-consumer and ½ post-industrial waste.
- .7 Formulate and manufacture water-borne surface coatings with no aromatic solvents, formaldehyde, halogenated solvents, mercury, lead, cadmium, hexavalent chromium or their compounds.
- .8 Flash point: 61°C or greater for water-borne surface coatings and recycled water-borne surface coatings.
- .9 Ensure manufacture and process of both water-borne surface coatings and recycled water-borne surface coatings does not release:
 - .1 Matter in undiluted production plant effluent generating 'Biochemical Oxygen Demand' (BOD) in excess of 15 mg/L to natural watercourse or sewage treatment facility lacking secondary treatment.
 - .2 Total Suspended Solids (TSS) in undiluted production plant effluent in excess of 15 mg/L to natural watercourse or a sewage treatment facility lacking secondary treatment.
- .10 Recycled water-borne surface coatings to contain 50% post-consumer material by volume.
- .11 Recycled water-borne surface coatings must not contain:
 - .1 Lead in excess of 600.0 ppm weight/weight total solids.
 - .2 Mercury in excess of 50.0 ppm weight/weight total product.
 - .3 Cadmium in excess of 1.0 ppm weight/weight total product.
 - .4 Hexavalent chromium in excess of 3.0 ppm weight/weight total product.

- .5 Organochlorines or polychlorinated biphenyls (PCBS) in excess of 1.0 ppm weight/weight total product.

2.2 Colours

- .1 Owner will provide Colour Schedule.
- .2 Colour schedule will be based upon selection of eight base colours and six deep tint accent colours.
- .3 Selection of colours will be from manufacturer's full range of colours.
- .4 Where specific products are available in restricted range of colours, selection based on limited range.
- .5 Second coat in three coat system to be tinted slightly lighter colour than top coat to show visible difference between coats.

2.3 Mixing and Tinting

- .1 Perform colour tinting operations prior to delivery of paint to site.
- .2 Use and add thinner in accordance with paint manufacturer's recommendations. Do not use kerosene or similar organic solvents to thin water-based paints.
- .3 Thin paint for spraying in accordance with paint manufacturer's instructions.
- .4 Re-mix paint in containers prior to and during application to ensure break-up of lumps, complete dispersion of settled pigment, and colour and gloss uniformity.

2.4 Gloss/Sheen Ratings

- .1 Paint gloss: defined as sheen rating of applied paint, in accordance with following values:

Gloss Level Category/	Units @ 60 Degrees	Units @ 85 Degrees
G1 – matte finish	0 to 5	Max. 10
G2 – velvet finish	0 to 10	10 to 35
G3 – eggshell finish	10 to 25	10 to 35
G4 – satin finish	20 to 35	Min. 35
G5 – semi-gloss finish	35 to 70	
G6 – gloss finish	70 to 85	
G7 – high gloss finish	> 85	

- .2 Gloss level ratings of painted surfaces as specified and as noted on Finish Schedule.

2.5 Interior Painting Systems

- .1 Concrete Masonry Units:
 - .1 INT 4.2D High performance architectural latex G5 semi-gloss finish.
- .2 Concrete Masonry Units at wet areas and change rooms:
 - .1 INT 4.2G Epoxy (tile-like) finish.
- .3 Galvanized Metal: interior doors, frames, misc. steel, pipes, and ducts.

- .1 INT 5.3A Latex G5 semi-gloss finish
- .4 Gypsum Board: Walls and Bulkheads.
 - .1 INT 9.2A Latex G3 eggshell finish over latex sealer.
- .5 Gypsum Board: Ceilings and Bulkheads (wet areas and change rooms)
 - .1 INT 9.2E Epoxy (tile like) finish
- .6 Gypsum Board: Ceilings and Bulkheads:
 - .1 INT 9.2A Latex G2 velvet finish over latex sealer.
- .7 All other surfaces not noted above: high performance finish suitable for commercial and institutional environment and in accordance with MPI painting manual.

PART 3 EXECUTION

3.1 General

- .1 Perform preparation and operations for interior painting in accordance with MPI Architectural Painting Specifications Manual except where specified otherwise.
- .2 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and application instructions, and data sheets.

3.2 Examination

- .1 Investigate existing substrates for problems related to proper and complete preparation of surfaces to be painted. Report to Consultant damages, defects, unsatisfactory or unfavourable conditions before proceeding with work.

3.3 Preparation

- .1 Protection:
 - .1 Protect existing building surfaces and adjacent structures from paint spatters, markings and other damage by suitable non-staining covers or masking and in accordance with paint manufacturers and MPI recommendations. If damaged, clean and restore surfaces as directed by Consultant.
 - .2 Protect items that are permanently attached such as Fire Labels on doors and frames.
 - .3 Protect factory finished products and equipment.
- .2 Surface Preparation:
 - .1 Remove electrical cover plates, light fixtures, surface hardware on doors, bath accessories and other surface mounted equipment, fittings and fastenings prior to undertaking painting operations. Identify and store items in secure location and re-install after painting is completed.
 - .2 Move and cover furniture and portable equipment as necessary to carry out painting operations. Replace as painting operations progress.
 - .3 Place "WET PAINT" signs in occupied areas as painting operations progress.
- .3 Clean and prepare surfaces in accordance with MPI Architectural Painting Specification Manual requirements. Refer to MPI Manual in regard to specific requirements and as follows:
 - .1 Remove dust, dirt, and other surface debris by vacuuming, wiping with dry, clean cloths, or compressed air.
 - .2 Wash surfaces with a biodegradable detergent and bleach where applicable and clean warm water using a stiff bristle brush to remove dirt, oil and other surface contaminants.

- .3 Rinse scrubbed surfaces with clean water until foreign matter is flushed from surface.
 - .4 Allow surfaces to drain completely and allow to dry thoroughly.
 - .5 Prepare surfaces for water-based painting, water-based cleaners should be used in place of organic solvents.
 - .6 Use trigger operated spray nozzles for water hoses.
 - .7 Many water-based paints cannot be removed with water once dried. Minimize use of mineral spirits or organic solvents to clean up water-based paints.
- 4 Prevent contamination of cleaned surfaces by salts, acids, alkalis, other corrosive chemicals, grease, oil and solvents before prime coat is applied and between applications of remaining coats. Apply primer, paint, or pretreatment as soon as possible after cleaning and before deterioration occurs.
 - 5 Where possible, prime non-exposed surfaces of new wood surfaces before installation. Use same primers as specified for exposed surfaces.
 - .1 Apply vinyl sealer to MPI #36 over knots, pitch, sap and resinous areas.
 - .2 Apply wood filler to nail holes and cracks.
 - .3 Tint filler to match stains for stained woodwork.
 - 6 Sand and dust between coats as required to provide adequate adhesion for next coat and to remove defects visible from a distance up to 1000 mm.
 - 7 Clean metal surfaces to be painted by removing rust, loose mill scale, welding slag, dirt, oil, grease and other foreign substances in accordance with MPI requirements and SSPC-SP 6. Remove traces of blast products from surfaces, pockets and corners to be painted by brushing with clean brushes blowing with clean dry compressed air or vacuum cleaning.
 - 8 Touch up of shop primers with primer as specified.
 - 9 Do not apply paint until prepared surfaces have been accepted by Consultant.

3.4 Application

- .1 Brush and Roller Application:
 - .1 Apply paint in uniform layer using brush and/or roller type suitable for application.
 - .2 Work paint into cracks, crevices and corners.
 - .3 Paint surfaces and corners not accessible to brush using spray, daubers and/or sheepskins. Paint surfaces and corners not accessible to roller using brush, daubers or sheepskins.
 - .4 Brush and/or roll out runs and sags, and over-lap marks. Rolled surfaces free of roller tracking and heavy stipple.
 - .5 Remove runs, sags and brush marks from finished work and repaint.
- .2 Spray application:
 - .1 Provide and maintain equipment that is suitable for intended purpose, capable of atomizing paint to be applied, and equipped with suitable pressure regulators and gauges.
 - .2 Keep paint ingredients properly mixed in containers during paint application either by continuous mechanical agitation or by intermittent agitation as frequently as necessary.
 - .3 Apply paint in uniform layer, with overlapping at edges of spray pattern. Back roll first coat application.
 - .4 Brush out immediately all runs and sags.
 - .5 Use brushes and rollers to work paint into cracks, crevices and places which are not adequately painted by spray.
- .3 Use dipping, sheepskins or daubers only when no other method is practical in places of difficult

access.

- .4 Apply coats of paint continuous film of uniform thickness. Repaint thin spots or bare areas before next coat of paint is applied.
- .5 Allow surfaces to dry and properly cure after cleaning and between subsequent coats for minimum time period as recommended by manufacturer.
- .6 Sand and dust between coats to remove visible defects.
- .7 Finish surfaces both above and below sight lines as specified for surrounding surfaces.
- .8 Finish alcoves as specified for adjoining rooms.
- .9 Finish top, bottom, edges and cutouts of doors after fitting as specified for door surfaces.

3.5 Mechanical/Electrical Equipment

- .1 Paint finished area exposed conduits, piping, hangers, ductwork and other mechanical and electrical equipment with colour and finish to match adjacent surfaces.
- .2 Mechanical and electrical rooms: paint exposed conduits, piping, hangers, ductwork and other mechanical and electrical equipment.
- .3 Other unfinished areas: leave exposed conduits, piping, hangers, ductwork and other mechanical and electrical equipment in original finish and touch up scratches and marks.
- .4 Touch up scratches and marks on factory painted finishes and equipment with paint as supplied by manufacturer of equipment.
- .5 Do not paint over nameplates.
- .6 Keep sprinkler heads free of paint.
- .7 Paint inside of ductwork where visible behind grilles, registers and diffusers with primer and one coat of matt black paint.
- .8 Paint fire protection piping red.
- .9 Paint disconnect switches for fire alarm system and exit light systems in red enamel.
- .10 Paint natural gas piping yellow.
- .11 Paint both sides and edges of backboards for telephone and electrical equipment before installation. Leave equipment in original finish except for touch-up as required, and paint conduits, mounting accessories and other unfinished items.
- .12 Do not paint interior transformers and substation equipment.

3.6 Field Quality Control

- .1 Manufacturer's Field Services:
 - .1 Provide manufacturer's field services consisting of product use recommendations and periodic site visits for inspection of product installation in accordance with manufacturer's instructions.

.2 Standard of Acceptance:

- .1 Walls: no defects visible from a distance of 1000 mm at 90 degrees to surface.
- .2 Ceilings: no defects visible from floor at 45 degrees to surface when viewed using final lighting source.
- .3 Final coat to exhibit uniformity of colour and uniformity of sheen across full surface area.

3.7 Restoration

- .1 Clean and re-install hardware items removed before undertaken painting operations.
- .2 Remove protective coverings and warning signs as soon as practical after operations cease.
- .3 Remove paint splashings on exposed surfaces that were not painted. Remove smears and spatter immediately as operations progress, using compatible solvent.
- .4 Protect freshly completed surfaces from paint droppings and dust to approval of Consultant. Avoid scuffing newly applied paint.
- .5 Restore areas used for storage, cleaning, mixing and handling of paint to clean condition as approved by Consultant.

3.8 Cleaning

- .1 Proceed in accordance with Section 01 74 11 – Cleaning.

End of Section

PART 1 GENERAL

1.1 General

- .1 Conform to the requirements of Division 1.

1.2 Related Sections

- .1 Section 05 50 00 Metal Fabrications
- .2 Section 10 28 10 Toilet and Bath Accessories

1.3 References

- .1 ASTM International (ASTM)
 - .1 ASTM A480/A480M-22 Standard Specification for General Requirements for Flat-Rolled Stainless and Heat-Resisting Steel Plate, Sheet, and Strip
 - .2 ASTM E84-22 Standard Test Method for Surface Burning Characteristics of Building Materials
- .2 CSA Group (CSA)
 - .1 CSA-B651-12 Accessible Design for the Built Environment.
- .3 American National Standards Association (ANSI)
 - .1 ANSI/NEMA LD 3-2005 High-Pressure Decorative Laminates (HPDL)
- .4 Underwriters Laboratories of Canada (ULC)
 - .1 CAN/ULC-S102 Surface Burning Characteristics of Building Materials and Assemblies
- .5 Accessibility for Ontarians with Disabilities Act (AODA)

1.4 Submittals

- .1 Make submittals in accordance with Section 01 33 00 – Submittal Procedures.
- .2 Product Data:
 - .1 Submit manufacturer's printed product literature for toilet partitions or components, specifications and datasheet and include product characteristics, performance criteria, physical size, finish and limitations.
 - .2 Submit duplicate copies of manufacturer's standard colour charts for selection by the Consultant.
- .3 Shop Drawings:
 - .1 Shop drawings: Indicate partition layout.
 - .2 Show and describe in detail materials, finishes, dimensions, details of connections and fastenings, elevations, plans, sections, thicknesses, metal thickness, hardware and any other pertinent information.
- .4 Samples:
 - .1 Submit duplicate 300 x 300 mm samples of panel showing finish on both sides, two finished edges and core construction.
 - .2 Submit duplicate representative samples of each hardware item, including brackets, fastenings and trim.
- .5 Quality Control Submittals: submit following in accordance with Section 01 45 00 - Quality Control.
 - .1 Manufacturer's Instructions: submit manufacturer's installation instructions and special handling criteria, installation sequence and cleaning procedures.
- .6 Closeout Submittals:
 - .1 Provide maintenance data for plastic toilet compartments for incorporation into manual

specified in Section 01 78 00 - Closeout Submittals.

1.5 Shipping, Handling and Storage

- .1 Refer to Section 01 61 00 – Common Product Requirements.
- .2 Deliver, handle and store materials in accordance with manufacturer's printed instructions.
- .3 Protect finished surfaces during shipment and installation. Do not remove until immediately prior to final inspection.

1.6 Waste Management and Disposal

- .1 Refer to Section 01 74 19 – Construction Waste Management and Disposal.

1.7 Warranty

- .1 Warrant the work of this Section against defects of workmanship and material, for a period of two years from the date of Substantial Performance and agree to make good promptly any defects which occur or become apparent within the warranty period.

PART 2 PRODUCTS

2.1 Approved Manufacturers

- .1 Compartments and cubicles as manufactured by the following may be used subject to approval of product specifications and details by the Consultant:
 - .1 Bobrick Washroom Equipment of Canada Ltd.
 - .2 Buddsteel Architectural Products. Teeswater Ontario
 - .3 Edwards Door Systems Ltd. Sarnia, Ontario
 - .4 ASI Watrous
 - .5 Bradley Corporation

2.2 Design

- .1 Solid phenolic core overhead braced toilet partitions with operational full height vandal resistant hardware.
 - .1 Standard of acceptance: Bobrick Model 1092G Series.
- .2 Urinal Screens: Solid phenolic core wall hung urinal screens
 - .1 Standard of Acceptance: Bobrick 1095 Sierra Series, Wall-Hung Urinal Privacy Screens.
 - .1 Brackets: 3 mm, double thickness.
- .3 Supply and install all required toilet partitions, change cubicles and urinal screens complete with all required hardware and accessories.
- .4 All cubicles shall have gap free design with zero sight lines.
- .5 Colours will be selected by the Consultant from the manufacturer's standard range of colours. Up to two colours will be selected.

2.3 Materials

- .1 Materials shall meet NFPA Class B, UBC Class II, CAN/ULC S102 Fire resistance standards as follows:
 - .1 Flame Spread Index: 45 for panels and stiles.
 - .2 Smoke Developed Index: 120 for panels, 95 for stiles.
 - .3 Class B.
- .2 Solid phenolic material for stiles, panels, doors and screens.
 - .1 Phenolic Construction: Solidly fused high pressure laminate with matte-finish melamine surfaces; integrally bonded coloured face sheets and black phenolic-resin core.
 - .2 Phenolic Edges: Black; brown edges not acceptable.
- .3 Finished Thickness:
 - .1 Stiles and Doors: 19 mm
 - .1 Finished thickness of doors and stiles to ensure flush front.
 - .2 Panels and Screens: 13 mm

2.4 Hardware

- .1 Stiles: Floor-Anchored stiles furnished with expansion shields and threaded rods.
 - .1 Leveling Devices: 5 mm thick, corrosion-resistant, chromate-treated, double zinc-plated steel angle leveling bar bolted to stile; furnished with 10 mm diameter threaded rods, hex nuts, lock washers, flat washers, spacer sleeves, expansion anchors, and shoe retainers.
 - .2 Stile Shoes: One-piece, 0.8 mm, 18-8, Type 304 stainless steel, 102 mm height; tops with 90 degree return to stile. One-piece shoe capable of adapting to 19 mm or 25 mm stile thickness and capable of being fastened (by clip) to stiles starting at wall line.
- .2 Compliance: Operable with one hand, without tight grasping, pinching, or twisting of the wrist, and force to operate does not exceed five pounds. Door pull: Barrier-free type suited for out-swinging doors, stainless steel. Conform to AODA and Ontario Building Code requirements.
- .3 Emergency Access: Hinges, latch allow door to be lifted over keeper from outside compartment.
- .4 Materials: 18-8, Type 304, heavy-gauge stainless steel with satin finish. Chrome-plated "Zamak", aluminum, or extruded plastic hardware not acceptable.
- .5 Fastening: Hardware secured to door and stile by through-bolted, theft-resistant, pin-in-head Torx stainless steel machine screws into factory-installed, threaded brass inserts. Fasteners secured directly into core not acceptable.
- .6 Threaded Brass Inserts: Factory-installed; withstand direct pull force exceeding 680 kg per insert.
- .7 Coat hook: combination hook and rubber door bumper, stainless steel. Projecting no more than 29 mm from face of door
- .8 Mounting: Hinges, keepers, latches, clothes hooks and their fasteners concealed inside compartment. Exposed hinges, keepers, latches, clothes hooks and their fasteners on exterior of compartment not acceptable with the exception of accessible compartments.
- .9 Hardware Type: Institutional hardware (Bobrick Type .67 or equivalent).
 - .1 Latching: 2 mm sliding door latch, 2 mm keeper; latch slides on shock-resistant nylon track. Twist-style door latch operation not acceptable.
 - .2 Hinges: Full height, 1.6 mm stainless steel with satin finish, self-closing, 3 section hinges.
 - .3 Mounting Brackets: 1.3 mm stainless steel and extend full height of panel.

- .4 U-Channels: Secure panels to stiles.
- .5 Angle Brackets: Secure stiles-to-walls and panels-to-walls.

2.5 Fabrication

- .1 Shop fabricate partitions and screens. Take site measurements for areas where partitions are to be located and fabricate partitions to suit site dimensions.
- .2 Fabricate to reviewed shop drawings and manufacturer's standards.
- .3 Toilet Partition Doors: 1473 mm high; 610 and 810 mm wide. Provide 305mm floor clearance
- .4 Urinal Screens: 1070 mm high x 456 mm wide.

PART 3 EXECUTION

3.1 Manufacturer's Instructions

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheets.

3.2 Examination

- .1 Check areas scheduled to receive compartments for correct dimensions, plumbness of walls, and soundness of surfaces that would affect installation of mounting brackets.
- .2 Verify spacing of plumbing fixtures to assure compatibility with installation of compartments.
- .3 Do not begin installation of compartments until conditions are satisfactory.

3.3 Installation

- .1 Ensure supplementary anchorage is in place.
- .2 Do work in accordance with CSA-B651.
- .3 Install products in strict compliance with manufacturer's written instructions and recommendations, including the following:
 - .1 Verify blocking and supports in walls and ceilings have been installed properly at points of attachment.
 - .2 .Verify location does not interfere with door swings or use of fixtures.
 - .3 Use fasteners and anchors suitable for substrate and project conditions
 - .4 Install units rigid, straight, plumb, and level.
 - .5 Conceal evidence of drilling, cutting, and fitting to room finish.
 - .6 Test for proper operation.
- .4 Adjust hardware for proper operation after installation. Set hinge cam on in-swinging doors to hold doors open when unlatched. Set hinge cam on out-swinging doors to hold unlatched doors in closed position.

3.4 Cleaning

- .1 Proceed in accordance with Section 01 74 11 – Cleaning.

- .2 Touch-up, repair or replace damaged products.
- .3 Clean exposed surfaces of compartments, hardware, and fittings.
- .4 On completion and verification of performance of installation, remove surplus materials, excess materials, rubbish, tools and equipment.

End of Section

PART 1 GENERAL

1.1 General

- .1 Conform to the requirements of Division 1.

1.2 Related Sections

- .1 Section 09 21 16 Gypsum Board
- .2 Section 10 51 13 Lockers

1.3 References

- .1 ASTM International (ASTM)
 - .1 ASTM A653/A653M-15e1 Standard Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process
 - .2 ASTM A924/A924M-17a Standard Specification for General Requirements for Steel Sheet, Metallic-Coated by the Hot-Dip Process
 - .3 ASTM B456-17 Standard Specification for Electrodeposited Coatings of Copper Plus Nickel Plus Chromium and Nickel Plus Chromium
- .2 Canadian General Standards Board (CGSB)
 - .1 CAN/CGSB-1.81-M90, Air Drying and Baking Alkyd Primer for Vehicles and Equipment.
 - .2 CAN/CGSB-1.88-92, Gloss Alkyd Enamel, Air Drying and Baking.
 - .3 CGSB 31-GP-107Ma-90, Non-inhibited Phosphoric Acid Base Metal Conditioner and Rust Remover.
- .3 Canadian Standards Association (CSA)
 - .1 CSA-B651-12, Accessible Design for the Built Environment.
 - .2 CAN/CSA G164-M92 (R2003), Hot Dip Galvanizing of Irregularly Shaped Articles.

1.4 Submittals

- .1 Make submittals in accordance with Section 01 33 00 – Submittal Procedures.
- .2 Shop Drawings:
 - .1 Indicate size and description of components, base material, surface finish inside and out, hardware and locks, attachment devices, description of rough-in-frame, building-in details of anchors for grab bars.
- .3 Samples:
 - .1 Submit samples when requested.
 - .2 Samples to be returned for inclusion into work.
- .4 Closeout Submittals:
 - .1 Provide maintenance data for toilet and bath accessories for incorporation into manual specified in Section 01 78 00 - Closeout Submittals.

1.5 Shipping, Handling and Storage

- .1 Refer to Section 01 61 00 – Common Product Requirements.
- .2 Deliver, handle and store materials in accordance with manufacturer's printed instructions.

1.6 Waste Management and Disposal

- .1 Refer to Section 01 74 19 – Construction Waste Management and Disposal.

1.7 Extra Materials

- .1 Provide special tools required for accessing, assembly/disassembly or removal for toilet and bath accessories in accordance with requirements specified in Section 01 78 00 - Closeout Submittals.
- .2 Deliver special tools to Owner.

PART 2 PRODUCTS

2.1 Materials

- .1 Sheet steel: to ASTM A653 with ZF001 designation zinc coating.
- .2 Stainless steel sheet metal: Type 304, with Brushed finish.
- .3 Stainless steel tubing: Type 304, commercial grade, seamless welded, minimum 1.2 mm wall thickness.
- .4 Fasteners: concealed screws and bolts hot dip galvanized, exposed fasteners to match face of unit. Expansion shields fibre, lead or rubber as recommended by accessory manufacturer for component and its intended use.

2.2 Manufacturers

- .1 Products and components listed are minimum standard of acceptance. Alternative products by recognized manufacturers of toilet and bath accessories may be accepted subject to review by the Consultant of manufacturer's product information and specifications.
- .2 Acceptable manufacturers include:
 - .1 Bobrick
 - .2 Bradley
 - .3 Frost
 - .4 Hafele
 - .5 Richelieu
 - .6 Watrous

2.3 Components

- .1 TPD: Toilet Tissue Dispenser:
 - .1 Supplied by Owner, installed by contractor.
- .2 SD: Soap Dispenser: Liquid wall mounted soap dispenser.
 - .1 Supplied by Owner, installed by contractor.
- .3 PTD: Paper Towel Dispenser:
 - .1 Supplied by Owner, installed by contractor.
- .4 GB1: Grab Bar, 38 mm diameter x 1.6 mm wall tubing of stainless steel, 76 mm diameter wall flanges, concealed screw attachment, flanges welded to tubular bar, provided with steel back

plates and all accessories. Knurl bar at area of hand grips. Grab bar material and anchorage to withstand downward pull of 2.2 kN. 600 mm long.

- .1 Bobrick B-6806.99 x 24
- .5 GB2: Barrier Free Grab Bars (L-shaped) 760 x 760 38 mm dia. Peened finish c/w mounting kits.
 - .1 Bobrick 6898.99, 90° Angle Grab Bar.
- .6 RSS: Retractable Shower Seat (left hand and right hand) Refer to drawings for locations.
 - .1 Bobrick B-5191
- .7 SC: Shower Rod, Curtain and Hooks: Bobrick B-6047, 32 mm diameter rod, 65 mm square flanges, Bobrick 204-2 white vinyl curtain and Bobrick B-204-1 Curtain Hooks.
- .8 Framed Mirror: Bobrick B-165 1830.
- .9 SND: Sanitary Napkin Disposal: Satin-finish stainless steel surface mounted disposal unit. Door with tumbler lock. Self-closing panel cover to cover disposal opening. Removable, leak-proof, 4.6 litre plastic receptacle. Unit size 270 x 385 x 105mm.
 - .1 Bobrick B-254 Classic Series Sanitary Napkin Waste Receptacle.
- .10 Stainless Steel Shelf: To CSA B651-12. 455 mm long x 100mm wide, 1.2mm type 304 stainless steel, satin finish. 19mm return edge; front edge hemmed for safety. 1.6mm brackets.
 - .1 Bobrick B295 x 18 or equivalent
- .11 Coat Hook: Bobrick B-6707

2.4 Fabrication

- .1 Weld and grind joints of fabricated components flush and smooth. Use mechanical fasteners only where approved.
- .2 Wherever possible form exposed surfaces from one sheet of stock, free of joints.
- .3 Brake form sheet metal work with 1.5 mm radius bends.
- .4 Form surfaces flat without distortion. Maintain flat surfaces without scratches or dents.
- .5 Back paint components where contact is made with building finishes, to prevent electrolysis.
- .6 Hot dip galvanize concealed ferrous metal anchors and fastening devices to CSA G164-M92 (R2003).
- .7 Shop assemble components and package complete with anchors and fittings.
- .8 Deliver inserts and rough-in frames to job site at appropriate time for building-in. Provide templates, details and instructions for building in anchors and inserts.
- .9 Provide steel anchor plates and components for installation on studding and building framing.

2.5 Finishes

- .1 Chrome and nickel plating: to ASTM B456, satin finish.
- .2 Baked enamel: condition metal by applying one coat of metal conditioner to CGSB 31-GP-107Ma,

apply one coat Type 2 primer to CAN/CGSB-1.81 and bake, apply two coats Type 2 enamel to CAN/CGSB-1.88 and bake to hard, durable finish. Sand between final coats. Colour selected from standard range by Owner's Representative.

- .3 Manufacturer's or brand names on face of units not acceptable.

PART 3 EXECUTION

3.1 Installation

- .1 Install toilet and bath accessories in accordance with the Ontario Building Code, CSA B651-12 and manufacturer's instructions.
- .2 Coordinate installation of hand and hair dryers with Electrical.
- .3 Install and secure accessories rigidly in place as follows:
 - .1 Stud walls: install steel back-plate to stud prior to plaster or drywall finish. Provide plate with threaded studs or plugs.
 - .2 Hollow masonry units or existing plaster/drywall: use toggle bolts drilled into cell/wall cavity.
 - .3 Solid masonry or concrete: use bolt with lead expansion sleeve set into drilled hole.
- .4 Install grab bars on built-in anchors provided by manufacturer.
- .5 Use tamper proof screws/bolts for fasteners.
- .6 Fill units with necessary supplies shortly before final acceptance of building.
- .7 Install products in strict compliance with manufacturer's written instructions and recommendations, including the following:
 - .1 Verify blocking has been installed properly.
 - .2 Verify location does not interfere with door swings or use of fixtures.
 - .3 Comply with manufacturer's recommendations for backing and proper support.
 - .4 Use fasteners and anchors suitable for substrate and project conditions
 - .5 Install units rigid, straight, plumb, and level, in accordance with manufacturer's installation instructions and approved shop drawings.
 - .6 Conceal evidence of drilling, cutting, and fitting to room finish.
 - .7 Test for proper operation.

3.2 Schedule

- .1 Locate accessories where indicated. Exact locations determined by Owner.

3.3 Cleaning

- .1 Proceed in accordance with Section 01 74 11 – Cleaning.
- .2 Clean exposed surfaces of compartments, hardware, and fittings using methods acceptable to the manufacturer.
- .3 Touch-up, repair or replace damaged products until Substantial Performance.

End of Section

PART 1 GENERAL

1.1 General

- .1 Conform to the requirements of Division 1.

1.2 Related Sections

- .1 Section 06 10 00 Rough Carpentry
- .2 Section 08 50 00 Aluminum Doors, Windows and Screens

1.3 References

- .1 ASTM International (ASTM)
 - .1 ASTM D5116-17 Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Materials/Products
 - .2 ASTM D6670-18 Standard Practice for Full-Scale Chamber Determination of Volatile Organic Emissions from Indoor Materials/Products
- .2 Underwriters Laboratories of Canada (ULC)
 - .1 ULC 109-14 Flame Tests of Flame Resistant Fabrics and Films
- .3 National Fire Protection Association (NFPA)
 - .1 NFPA 701 Standard Methods of Fire Tests for Flame Propagation of Textiles and Films
- .4 Canadian Electrical Code.

1.4 Submittals

- .1 Make submittals in accordance with Section 01 33 00 – Submittal Procedures.
- .2 Submit shop drawings. Clearly indicate, by large scale details, anchorage, assembly, materials, components, finishes, and perimeter construction conditions.
- .3 Submit duplicate 300 mm x 300 mm samples of fabrics in selected colours.
- .4 Submit manufacturer's maintenance data in the form of printed instructions for cleaning and maintaining roller shades, for inclusion in Operation and Maintenance Manuals specified in section 01 78 00 – Closeout Submittals

1.5 Quality Assurance

- .1 Work of this Section shall be by forces in the direct employ or under control of the system manufacturer, skilled, trained and experienced in work of similar scope and complexity.
- .2 Manufacturer Qualifications: Company specializing in manufacturing the Products specified in this section, with a minimum of ten years of experience.
- .3 Mock-Ups: Erect one full size mock-up of each roller shade type for review. Completed and accepted mock-up shall act as the standard to which the balance of the work will be judged.

1.6 Shipping, Handling and Storage

- .1 Refer to Section 01 61 00 – Common Product Requirements.
- .2 Test all operable components prior to shipping.

- .3 Deliver, handle and store materials in accordance with manufacturer's printed instructions.

1.7 Waste Management and Disposal

- .1 Refer to Section 01 74 19 – Construction Waste Management and Disposal.

1.8 Warranty

- .1 Warrant the work of this Section against defects of workmanship and material, for a period of two years from the date of Substantial Performance and agree to make good promptly any defects which occur or become apparent within the warranty period.
- .2 Manufacturer's Warranty: Submit manufacturer's standard 10 year product warranty executed by an authorized company official.

PART 2 PRODUCTS

Manufacturers

- .1 Roller Shade System shall be glazing frame mounted non-electrically Operated Solar Shades as manufactured by Sheerweave Products Limited.
- .2 Basis of Design:
 - .1 The Sheerweave 4000 (5%) U62
- .3 Subject to compliance with the contract documents, acceptable equivalent products of the following manufacturers may be used upon approval:
 - .1 Elite Window Fashions
 - .2 Lighting Harvesting Shading Solutions
 - .3 Mechoshade Systems Inc.
 - .4 Nysan Solar Control
 - .5 Sun Glow Window Covering Products of Canada
 - .6 SunProject Inc.

2.2 Hardware – Manually Controlled Shades

- .1 Chain Operated with infinite positioning. Left or right hand operation and banding as applicable to project conditions.
 - .1 Drive assembly:
 - .1 Must allow fingertip control and include a built-in shock absorber system to prevent chain breakage under normal operating conditions.
 - .2 Factory set for size and travel of shades.
 - .3 Capable of being field adjusted from the exterior of the shade unit without having to disassemble the hardware.
 - .4 Drive Chain: No. 10 stainless steel bead chain formed in a continuous loop. The chain shall have passed a 40kg load test. Chain may be positioned at either, or both ends of the shade without disassembly of the shade unit.
 - .1 Supply and install child safe chain retainers.
 - .5 Supply and install counter balancing mechanism designed to offset the weight of the shade and give fingertip control.
 - .2 Control shades and room darkening shades independently.

- .1 Audio-Visual (office environment) interface control:
 - .1 Shade manufacturer shall provide low voltage interface ready MC2 relay system to allow shade operation control from audio-visual equipment not supplied or installed under this section.
- .2 Control shades and room darkening shades independently.

2.3 Assembly

- .1 Supply and install fully factory assembled shade units consisting of 2 shade brackets, shade tube, extruded aluminum fascia, hembar and fabric as specified.
- .2 Factory modify housings where necessary to bypass columns and other obstructions.
- .3 End Brackets: 2 piece molded ABS construction with nylon drive sprocket. Bracket colour coordinated with fascia colour.
- .4 Shade tube; Minimum 1.52 mm thick extruded aluminum with 3 equally spaced continuous stiffening fins, non-sag design, maximum deflection under full load of fabric L/700.
- .5 Fascia: One piece extruded aluminum 1.7 mm thickness complete with three continuous screw flutes. Anodized. Colour as selected by the Consultant. Extruded aluminum snap lock fascia which continuously fits on the end and center brackets as a one-piece section.
- .6 Hembar: extruded aluminum with matching plastic end finials.
- .7 Blackout Shade Features: 13 mm pile mounted in prefinished 38 x 28 mm extruded aluminum side and bottom channels finished to match window framing. Include dynamic hembar to allow for variances in windowsill level.

2.4 Shade Mounting System

- .1 Extruded aluminum bracket designed to accept preassembled shade system.
 - .1 Brackets shall be used to facilitate the alignment with shade opening.
- .2 Modular Construction: shades must be removable as a complete modular unit without any component disassembly required.

2.5 Aluminum Finish

- .1 Exposed aluminum: Baked enamel, Dark Grey
- .2 Unexposed aluminum: mill finish.

2.6 Shade Fabric

- .1 Sun control fabric: dimensionally stable shade fabric.
 - .1 Acceptable Products: 5% open area:
 - .1 sheerweave, Style 4000.
 - .2 ECO / Granite.
- .2 Blackout shade fabric: dimensionally stable blackout fabric.
 - .1 To be selected from manufacturer's full range.

- .3 Performance: fabric shall hang flat, without buckling or distortion. Edge, where trimmed, shall hang true and straight, without shifting sideways more than 3 mm in either direction due to warp distortion or weave design.
- .4 Fabric shall be certified by an independent laboratory to pass the small scale vertical burn requirements test ULC S109 and NFPA 701.

2.7 Fabrication

- .1 Finished assemblies shall be square, true to size and free from distortion, twist or other defects that could affect their strength, operation or appearance.
- .2 Factory applied finish shall be uniform, smooth and without blemishes.
- .3 The fabric shall be colour fast, retain its shape, not be affected by moisture or heat, and shall be non-flammable. Cut fabric to eliminate glare and reflection from shining surfaces while maintaining exterior view. The top of the fabric shall be retained in the recessed spline of the shade roller and the bottom of the fabric shall be retained by the hem bar.

PART 3 EXECUTION

3.1 Installation

- .1 Install shading devices in accordance with manufacturer's instructions.
- .2 Take field measurements prior to fabrication to ensure fit.
- .3 Fabric shall be premeasured and manufactured off-site.
- .4 Install square, plumb, true to line, adequately anchored, maintaining uniform clearances, accurate alignment levels and parallel with the window plane. Fabric shall not travel more than 3 mm in either direction within channels after installation.
- .5 Adjust operable parts for correct function.
- .6 Secure with non-corrosive fasteners, concealed in final assembly.
- .7 Fabric shall hang flat, without buckling or distortion. The edge, when trimmed, shall hang straight without raveling. An unguided roller shade cloth shall roll true and straight, without shifting sideways more than + 3 mm in either direction due to warp distortion, or weave design.
- .8 Black out shades shall be installed to eliminate passage of light from exterior.
- .9 Electrical wiring, hook-up, switches, motorized shades: in accordance with Division 26 requirements.
- .10 Adjust to provide for operation without binding.
- .11 Refinish damaged or defective work so that no variation in surface appearance is discernable.

3.2 Demonstration

- .1 Prior to acceptance of system, arrange for demonstration of equipment with authorized representatives of the Owner, to be performed by representative of shade manufacturer to assure proper function, operation and explanation.
- .2 Conduct comprehensive demonstration for Owner's staff on operation and care of interior window treatments.

3.3 Cleaning

- .1 Proceed in accordance with Section 01 74 11 – Cleaning.

End of Section

Electrical Specifications

for

**City Of Pickering Fire Hall
553 Kingston Road
Pickering, Ontario**

HCC PROJECT #17264

The undersigned has reviewed and takes responsibility for this design and has the qualifications and meets the requirements set out in the Ontario Building Code to be a designer.

***QUALIFICATION INFORMATION**

Required unless design is exempt under DIV C 3.2.5.1 of the building code

HOWARD COHEN 24553
NAME SIGNATURE BCIN

***REGISTRATION INFORMATION**

Required unless design is exempt under DIV C 3.2.4.1 of the building code

HCC ENGINEERING LIMITED 28954
FIRM NAME BCIN

HCC ENGINEERING LIMITED

**40 Eglinton Avenue East
Suite 600**

**Toronto, Ontario
M4P 3A2**

Tel: (416) 932-2423

Issued For Tender

March 20, 2020

Electrical Table of Contents

SECTION TITLE	SECTION NUMBER
General Conditions	26 05 00
Common Work Results - Electrical	26 05 01
Wire and Box Connectors (0-1000V)	26 05 20
Wires and Cables	26 05 21
Grounding	26 05 27
Hangers and Supports for Electrical Systems	26 05 29
Splitter, Junction, Pull Boxes and Cabinets	26 05 31
Outlet Boxes, Conduit Boxes And Fittings	26 05 32
Conduits, Conduit Fastenings and Conduit Fittings	26 05 34
Wiring Devices	26 27 26
Fuses – Low Voltage	26 28 13.01
Disconnect Switches - Fused and Non-Fused	26 28 23
Interior Lighting	26 51 00
Electrical Identification	26 60 01
Testing and Commissioning of Electrical Systems	26 60 02
Panel Schedules	

SECTION 26 05 00: GENERAL CONDITIONS.

1.1 Project Description:

1. The project encompasses the 553 Kingston Road, Pickering facility. In general, the work shall include, without being limited to the following:
 1. Provide new 120/240 Volt utility power service.
 2. Provide communications conduit systems, grounding systems, lighting, lighting control, fire alarm system, etc as shown on the drawings.
2. The electrical contractor shall provide a comprehensive Methods of Procedures (MOP's) two weeks prior to each and every power shutdown. MOP's must include a detailed sequence of operations to be completed during the respective shutdown as well as a back out plan. MOP's must be approved by the client, landlord and the electrical engineer prior to any work taking place.

1.2 Sub-Contractors:

1. The Contractor may not assign or sub-contract any work without the prior written consent of the Construction Manager or his designated representative. A list of sub-contractors must be submitted with the tender response.

1.3 Substantial Completion Of Contract

1. All the equipment and wire must be cleaned and tested, before acceptance by the consultant.
2. This Contractor shall guarantee all equipment and work furnished under this Division for a period of **two (2) years** or such longer periods as may be provided in the warranty of the manufacturer of individual components, whichever is longer from the date of final acceptance by the Engineer. This contractor shall correct all defects developing as a whole or in part, due to defective workmanship, materials or defective arrangement of the various parts or materials damaged as a result of these defects or repairs. All defects shall be made good to the satisfaction of the Engineer at this Contractor's expense.
3. Replace, at no cost, all incandescent lamps burned out during a 30 (thirty) day period, all burned-out fluorescent and HID lamps for a period of 90 (ninety) days and all burned out LEDs based on a 70% lumen maintenance within a 5 year warranty period after date of issuance of certificate of Substantial Performance for the contract of this building.
4. Additional requirements as detailed in Section 26 05 00, paragraph 1.7, sentence 9.

1.4 Inquiries

1. All inquiries will be responded to in writing and will be distributed to all bidders.

1.5 Site Meeting

1. The site meeting will be scheduled during the tender period by the project manager.

1.6 Examination of Premises And Work

1. Visit and examine the site where the work is to be done. Become familiar with all features and characteristics of the site and/or any existing structure before submitting a bid. No allowances will be made by the Owner for any difficulties encountered by this Contractor due to any peculiarities of the site, surrounding public or private property that existed when the Tender was submitted.
2. This Contractor shall examine the structural, mechanical, architectural and electrical and any other drawings issued to satisfy himself that the work can be satisfactorily carried out. Before commencing work or prefabrication, examine the work of other trades and report at once any defect or interference affecting the work of the electrical trade.
3. Where variances occur between the drawings and the specifications, or within either document itself, the item or arrangement of better quality, greater quantity or higher cost shall be included in the contract sum. The Engineer will decide on the item and manner in which the work shall be installed.
4. All bidders shall familiarize themselves with and adhere to the owner's building standards and guidelines.

1.7 Terms And Conditions

1. DEFINITIONS

1. The term Owner shall be understood to refer to City of Pickering.
 2. The term consultant shall be understood to refer to Howard Cohen, P. Eng., RCDD/LAN, MBA.
 3. Not used.
 4. The term electrical contractor shall be understood to refer to the successful bidder to this specifications package.
 5. The term Contract shall be understood to refer to all items and conditions of this specification, Drawings, the complete tender package, the Contractor's tender submission and any other future contractual arrangements. All such items and conditions shall be binding unless agreed otherwise by the Contractor, Consultant and Owner.
 6. The term Project shall be understood to refer to the complete supply and installation of the Electrical System and components, as defined in this specification and Drawings.
 7. Wherever the words "equal", "equivalent", "approved", or "approved equal" are used, it shall be understood to mean, "equal", "equivalent", "approved", or "approved equal" in the opinion of the Consultant only.
 8. Wherever the words "install", "provide", or "supply and install", are used it shall be understood to mean "provide and install, inclusive of all labour, materials, installation, testing, and connections" for the item to which referred.
 9. "Concealed" is defined as "out of sight" in "normal" viewing conditions, and includes buried in concrete, above acoustic tile or gypsum board ceilings, within masonry or gypsum board constructed walls, within cable trays of below raised access floors.
2. These specifications or the drawings shall not be used alone. Any item or subject omitted from one, but mentioned or reasonably implied in the other, shall be provided. Misinterpretation of any requirements of either the specification or drawings shall not result in any additional charge after submission of Tender. This Contractor shall, by careful study of the total requirements, include all necessary components to make each system workable.
 3. This paragraph not used.
 4. The Contractor shall co-operate fully with the Owner, Consultant, landlord and landlord's agent and all contractors, sub-contractors and other persons working on the site.

General Conditions

-
5. The Contractor shall do the complete installation in accordance with the latest editions of the National Building Code, Ontario Building Code, Canadian Electrical Safety Code, C.S.A., or other Codes or governing authorities of competent jurisdiction. In case of discrepancies with this or the manufacturer's specifications, the Contractor shall notify the Consultant immediately.
 6. Obtain and pay for permits and ESA plans approvals (note: Building Permit obtained by owner) and inspections required for work performed. Provide Certificate (s) of Acceptance from the Authorities Inspection Department, upon completion of work.
 7. Submit required Documents and shop drawings to authorities having jurisdiction in order to obtain approval for the Work. Copies of Contract Drawings and Specifications may be used for this purpose. Prepare any additional information, details and drawings which these authorities may require.
 8. The Contractor must comply with all requirements of the Occupational Health & Safety Act.
 9. In order to meet the requirements of substantial completion the electrical contractor must complete the following:
 1. Installation and successful testing of all electrical system devices as per mutually agreed to tests and commissioning plan.
 2. Overall system test demonstrating system operation and coordination of the utility systems.
 3. Commissioning of all systems including access control systems, intrusion systems, CCTV systems and duress systems
 4. Client training for all systems including access control systems, intrusion systems, CCTV systems and duress systems.
 5. Submission of all coordination and permit documentation for the Consultant's review.
 6. Submission of all record and As-built documentation.
 7. Correction of any deficiencies in the electrical system.

1.8 Schedule

1. Include for all necessary overtime required to carry out the project. The successful contractor will not be permitted claims as a consequence of this requirement. Successful Contractor to submit a full construction schedule before starting any work.
2. Sufficient manpower, materials, equipment, appliances and services are to be kept on site at all times to maintain the scheduled completion of work.
3. All work required to be done after office hours and weekends (including x-raying, core drilling and power shutdowns), shall be included in the tender price. Note: All x-raying and core drilling shall be provided by the electrical contractor.
4. Work associated with power shutdowns and with testing and commissioning of electrical systems must be carried out on Sunday mornings from 1am to 4 am. All shut downs must be approved by Owner and by Landlord.
5. **Contractor must provide a dedicated on-site electrician for 8 hours on the Monday following each cutover.**

1.9 Contract Drawings

1. The Drawings for the electrical system work are diagrammatic performance Drawings, intended to convey the scope of work and indicate the approximate sizes and locations of equipment and outlets. The Drawings do not intend to show Designer's Architectural, Mechanical or Structural details.
2. Do not scale or measure Drawings, but obtain information regarding accurate dimensions, from the dimensions shown or by site measurements. Follow the Drawings for laying out the work.

General Conditions

-
3. Make, at no additional cost, any changes or additions to materials and equipment necessary to accommodate Structural conditions (offsets around beams, columns, etc.).
 4. Alter at no additional cost, the location of materials and/or equipment as directed, provided that the changes are made before installation, and do not necessitate additional materials.
 5. Change location of termination panels and devices at no extra cost providing cable length increase resulting from relocation does not exceed 3m (10 ft.) and information is given before installation.
 6. Confirm at the site, the exact location of equipment.
 7. Any miscellaneous materials, hardware, devices, wiring, etc., not specifically described, but required for the installation and operation of the electrical system, shall be provided and included as part of the Bid.

1.10 Materials And Equipment

1. All materials and equipment shall be completely new and unused products of only the most recent manufacturer model or version number, C.S.A. certified, and manufactured to the Standards specified.
2. Where there is no alternative to supplying equipment which is not C.S.A. certified, obtain special approval from the local Inspection Department.
3. No damaged, chipped or marked equipment or materials will be accepted and must not be installed.

1.11 Substitutes

1. Manufacturer's Basis of Design product part numbers and / or product photos have been included as part of this specifications package as the basis for the specification and tenders. and to clearly describe the quality of the product that is required for the work. A specific Manufacturer's name and model number also represents specific physical dimensions and operational requirements required on this project.
2. Substitutes will only be considered when submitted in sufficient time to review the proposal before tender closing. Proposals must be submitted at least two weeks prior to the deadline for Addenda Issues and for light fixtures must include detailed photometric plots for proposed light fixture substitutions. The photometric plots must be of the entire floor plan and must include all partitions and workstations (based on 5' high furniture panels). After reviewing the proposals, the Engineer will preliminarily accept or reject the proposed substitute(s). Addenda will be issued to confirm the preliminary acceptance of proposed substitutions. Preliminary acceptance of substitutes does not constitute approval for the use of those substitutes in the work.

General Conditions

-
4. It is the Contractor's responsibility to demonstrate in his proposal that the proposed substitutions are compatible with all related work and that the characteristics are equal to, or superior to the original specified items, including, but not limited to:
 - performance;
 - physical characteristics (i.e. dimensions, weights);
 - electrical characteristics (i.e. voltage, number of phases, rated load amperage);
 - availability;
 - noise characteristic (i.e. generated sound power, attenuation).
 - average max to min and average light levels (light fixtures).
 - lighting power density.
 - illuminated surface area.
 - lumen maintenance.
 5. This Contractor shall be responsible for any additional costs necessary to accommodate substitutes.
 6. All shop drawings submitted for approved substituted equipment shall be marked as such by the Contractor.

1.12 Operation And Maintenance Manuals

1. Provide five (5) hard copy sets of operation and maintenance manuals for equipment and products supplied.
2. Provide three (3) soft copy scanned sets of operation and maintenance manuals for equipment and products supplied. Media shall be USB sticks.
3. Include the following information in the Operation and Maintenance manuals:
 - Names and address of local suppliers for the items included.
 - Technical data, product data, supplemented by bulletins, component illustrations, exploded views, technical descriptions of items and parts lists. Advertising or sales literature is not acceptable.
 - Details of design elements, construction features, component function and maintenance requirements, to permit effective start-up, operation, maintenance, repair, modification, extension and expansion of any portion or feature of the installation.
4. Review information provided in the maintenance instructions and manuals with the Owners' operating personnel to ensure a complete understanding of the electrical equipment and systems and their operation.

1.13 Progress Payments

1. Submit a complete breakdown of the Contract with each progress billing, indicating percentage of work complete, in a form acceptable to the Owner/Consultant.
2. The amount of monies to be allocated for close out documents must be 3% of contract value. This does not include monies allocated for testing, measurement and verification, commissioning, training, etc.

1.14 Shop Drawings

General Conditions

-
1. Submitted Shop Drawings must indicate details of construction, dimensions, capacities, weights and electrical performance and flame spread characteristics of equipment or materials, as well as specification reference Section number and project name.
 2. Shop Drawings shall be provided with sufficient space on the front for all Consultant's and Contractor's "review" stamps.
 3. Work affected by submittal shall not proceed until review is complete.
 4. Review submittal prior to submission to Consultant. This review represents that necessary requirements have been determined and verified, or will be, and that each submittal has been checked and coordinated with requirements of the work and Contract Documents and bears the Stamp of Communications Contractor.
 5. Changes made to the Shop Drawings by the Consultant will not affect the Contract Price.
 6. Submit Shop Drawings for all material and equipment referred to in contract document.

1.15 Field Supervision

1. Throughout the duration of the Project, a properly qualified Electrical Field Supervisor must be available at all times. The Supervisor who starts the work must not be changed unless requested by the project manager, or written permission from the project manager is obtained.
2. In addition, provide proper office supervision of the work. The person responsible for office supervision must visit the site as often as necessary, to ensure work is properly performed, and attend weekly site meetings when so requested.

1.16 Site Responsibilities

1. Maintain work areas to be free of construction debris and waste. The disposal of all materials shall be the responsibility of the Contractor.
2. Make all necessary arrangements to transport materials and equipment to and within the site. The Contractor shall be responsible for arranging for the use of any hoists, lifts, pulleys, winches, cranes or service elevators.
3. The Contractor is responsible for complete storage, handling, delivery, and installation of all materials used in the performance of the work.
4. Obtain a copy of the Landlord's leasehold design manual and ensure that all requirements are complied with.

1.17 Deliveries / Access

1. Coordinate all deliveries to site with the Building Manager. Book loading dock and service elevators 72 hours in advance. Contractor must pre-arrange all site access and authorization for all site personnel and subcontractor personnel with the Building Project Manager or his representative

1.18 Testing And Commissioning

1. Provide testing and commissioning as per Testing and Commissioning Plan to be reviewed and approved by the Consultant and Project Manager for all items and their related components.
2. Supply all required equipment maintenance and operations manuals, for owner's staff use.
3. Provide all required software for monitoring, annunciation and control/dispatch applications

1.19 Other

1. It is the responsibility of the Contractor to perform all cutting, patching and repair related to the electrical system work.
2. Work by the electrical contractor shall be protected during erection against disfigurement, contamination or damage by mechanical abuse or harmful materials. Protective covers shall be installed where exposure to potential damage is likely. The contractor shall ensure that no eating, drinking or smoking is carried out in the finished areas. Damages resulting from a breach of these requirements shall be repaired at the cost of the electrical contractor.
3. Existing and adjacent finishes, work and structures shall be protected from damage resulting from work of this project.

1.20 Record and As-Built Drawings

1. The Contractor shall maintain two sets of drawings on site. Clearly mark on these drawings all changes and deviations from the contract drawings and in particular mark the actual location of all feeder conduit locations.
2. All deviations from the contract drawings shall be recorded on the "as-built" drawings, including those changes due to Addenda, Site Instructions or Change Orders.
3. After the date of Substantial Performance, obtain from the Consultant, a set of AutoCAD Version 2017 CD of the most recent Electrical System Drawings. These Drawings shall be marked up to record clearly, neatly, accurately and promptly all locations of Electrical System deviations as a result of Change Orders, Consultant's or Owner's Instruction, site conditions, etc. Utilize normal recognized CAD procedures that match the original drafting methodology. Submit the revised As-Built AutoCAD CD and Drawings (three sets) with changes clearly indicated to the Consultant for review and final presentation to the Owner.
4. For the disk drawing submission described above, the electrical contractor must include as part of the lump sum price \$375.00 plus HST to have HCC Engineering supply the AutoCAD floor plans denoted as 'Issued for Tender' on disks.

1.21 Drawings

1. For exact details and quantities, refer to the later sections of this document and to drawing E-1.1, E-1.2, E-1.3, E-2.1, E-3.1, E-5.1, E-6.1 and E-7.1 denoted as 'Issued For Tender March 20, 2020.'

1.22 Contract

1. Conform to the conditions stated in the Contract Form, Document CCDC-2.
2. A confidentiality agreement will form an integral part of the contract and will be provided to the successful contractor.

1.23 Cleaning

1. It is the responsibility of the Contractor to dispose of all waste related to this project.
2. Conduct cleaning and disposal operations to comply with local ordinances and anti-pollution laws.
3. On a daily basis, remove waste materials, rubbish, tools, equipment, machinery, surplus materials and clean all sight exposed surfaces.
4. All materials must be stacked neatly and safely.

General Conditions

-
5. Handle materials in a controlled manner with as few handlings as possible. Do not drop or throw materials from heights.
 6. Cleaning operations shall include those areas used for temporary site access or used on a temporary basis to facilitate work.
 7. The contractor will remove all garbage from site on a daily basis at his own expense.
 8. Failure to provide housekeeping and/or maintain a clean work area to the satisfaction of the project manager will result in the project manager providing the necessary housekeeping and/or maintenance service with all related costs, including mark-up's, being charged to the electrical contractor.

1.24 Demolition

1. Disconnect and remove existing conduit and wiring in partitions to be demolished and existing 'BX' cables, conduit and wire in ceiling where existing outlets, lighting fixtures, devices and mechanical equipment are to be removed.
2. Remove all branch circuit wiring and raceways originating from the existing receptacle panels. Wiring and raceways shall be removed back to the source panel. Circuits utilized to feed existing to remain mechanical equipment and other 120/208 volt sources to remain must be maintained.
3. Remove all existing electrical outlets and light switches as well as the associated wiring and raceways not being reused and/or not required for new layout (note: existing outlets and switches to be removed are not shown on the drawings). Provide blank coverplates at all locations where electrical and/or communications devices were removed in which partitions are not being demolished.

1.25 Digital Photos

1. Provide digital photos of all progress to date on a weekly basis. Each photo submission must be reviewed and approved by the consultant prior to continuing with the installation.

End of Section

SECTION 26 05 01: COMMON WORK RESULTS - ELECTRICAL.

PART I: GENERAL

1.1 Reference:

1. This section forms part of every section of Division 26.

1.2 Access Doors:

1. Not Required.

1.3 Cleaning:

1. Clean devices and other surfaces that have been exposed to construction dust and dirt. Clean the insides and outsides of panels and other electrical equipment and completely remove all debris and tools from the project.

1.4 Codes and Standards:

1. Complete the installation of the work in accordance with latest editions of the National Building Code, Canadian Electrical Safety Code, C.S.A., U.L.C., N.F.P.A, O.S.H.A. or other codes, as required.
2. Comply with CEC Electrical Bulletins in force at time of Bid submission. While not identified and specified by number in this Division, they are to be considered as forming part of related Standards.
3. Abbreviations for electrical terms are as per C.S.A. Z85.

1.5 Finishes:

1. All shop finished metal equipment and enclosure surfaces, must be prepared by removal of rust and scale from the raw metal, degreasing, cleaning, application of rust resistance primer inside and outside, and at least two coats of finish enamel paint. Use factory standard colours unless otherwise specified. Colour reference numbers are Sico.
2. Paint exterior surfaces of indoor electrical equipment to manufacturer's standard.
3. Clean and touch-up (to Consultant's acceptance) surfaces of shop-finished equipment that is scratched or marred during shipment or installation, so as to match original paint.
4. Leave with the Owner, 0.22 gal. of paint of each colour used, in the form of liquid or spray, to allow for future touch-up of damaged areas.

1.6 Inserts, Hangers and Sleeves:

1. Provide hangers, inserts, sleeves and supports as required.
2. Inserts are to be of lead shield type.
3. Hangers must not be welded to structural steel members and burning of holes in structural steel is prohibited.
4. Sleeves are to be of a type suitable for the application and be sealed and made watertight. Sleeves through concrete shall be sized for free passage of conduit, and installed flush with underside of concrete slab and extend 100mm (4") above finished floor unless otherwise shown.

Common Work Results – Electrical

1.7 Intent:

1. It is the intent of these drawings and specifications that the Contractor provide complete and operational systems as required.
2. Where differences occur, the maximum condition shall govern.
3. Any miscellaneous items, hardware, devices, wiring, etc., not specifically described, but required for the operation of the system, must be provided and included as part of the Bid.

1.8 Mounting Heights:

1. Mounting height of equipment is from finished floor to center line of equipment unless specified or indicated otherwise.
2. If mounting height of equipment is not indicated, verify with Consultant before proceeding with installation.

1.9 Owners Instruction and Trial Usage:

1. Instruct the Owner's operating personnel in the startup, operation, care and maintenance of all the equipment. All equipment to be tested, operational and commissioned before instruction. Provide sheets for signatures of Owner's representative and operating personnel present at each instruction period.
2. Arrange and pay for the service of the manufacturer's factory service Engineer/Technician to supervise the start-up of his equipment installation, and to check, adjust, balance and calibrate components.
3. Provide these services for such period and for as many visits as necessary to ensure that the Owner's operating personnel are conversant with all aspects of its care and operation.
 1. Prior to any instruction sessions, commissioning coordinator shall submit check lists of each system or equipment indicating their operation status for acceptance by the Owner.
 2. Coordinate all instruction sessions to suit Owner's operation personnel schedule. Submit proposed instruction session schedule c/w training agenda three weeks prior to session start date to Owner for review.
5. The Owner's operating personnel must be permitted to operate the systems under the contractor's supervision for a reasonable period of time prior to Substantial Completion of Contract. This use shall not be misconstrued as acceptance of the equipment.

1.10 Plywood Backboard:

1. Supply and install all plywood backboards required for the work of this Division. Plywood to be highest quality fire retardant fir. 1200 mm wide x 2400 mm high (4'-0" wide x 8'-0" high), 19mm (3/4") thick unless otherwise specified. Prime and paint backboards on both sides with fire retardant paint, equal to CGSB spec. #1-GP-151M, of a colour to match the equipment and services mounted thereon as defined in "Finishes" above. Do not paint over fire rated stamps.
2. Plywood backboards are to be provided for mounting the following surface wall mounted equipment:
 - Cabinets.

Common Work Results – Electrical

- Contactors.
- Control Panels
- Disconnect Switches.
- Junction Boxes 600mm (2 ft) square and larger.
- Pull Boxes.
- Panel Boards.
- Splitters
- Transient Voltage Surge Suppression Units.
- External Breakers

3. Where practical, group devices on a common backboard.

1.11 Protection:

1. Protect exposed live equipment during construction for personnel safety.
2. Shield and mark live parts "LIVE 600 VOLTS", or with appropriate voltage in English.

1.12 Sealing:

1. Where cables or conduits pass through non fire-rated floors, walls or roof, provide internal and external sealing thereto.
2. Retain the service of a specialty sealant contractor for the work required.
3. Comply with manufacturer's installation instructions for all sealant applications.
4. For non-fire rated locations, Sealant shall be silicone, that meets requirements of CGSB 19-GP-23, for the size of the joint required, and the types of materials being bonded.
5. For fire rated locations, the fire stop shall meet the requirements of ULC with regards to the type of assembly and the fire separation.
6. Provide architecturally approved air barrier seals and vapor barrier seals to electrical items passing through or terminating within walls, roofs and decks, humidity controlled areas and pressurized areas.
7. Engage the services of a third party architect to provide a sealed report for all fire stopping assemblies provided as part of this scope of work. Sealed report must detail compliance with the Ontario Building Code.

1.13 Sprinkler Proofing:

1. All areas of this building are protected by a wet sprinkler system. All electrical equipment to be configured for installation in such an environment.

1.14 Warning Signs:

1. Provide warning signs, as specified to meet requirements of Ministry of Labour Safety Inspection, Inspection Department, Authorities having jurisdiction and Consultant.
2. Use decal signs, in English minimum as required by Authorities.

Common Work Results – Electrical

1.15 Wire Pulling Lubricant:

1. Lubricant to be non-corrosive and CSA approved for the type of cable used.
2. Lubricants to be soap or wax based, depending upon application. Use soap based for short runs and for semi-conducting insulated wires, and wax based for long runs.

End of Section

SECTION 26 05 20: WIRE AND BOX CONNECTORS.

PART I - GENERAL

1.1 Work Included:

1. Provide all wire and box connectors required for a complete electrical system installation.

PART II - PRODUCTS

2.1 Materials:

1. Pressure type wire connectors are to be manufactured to CSA C22.2 No.65. Clamps and connectors are to be manufactured to CSA C22.2 No. 18.
2. Building Wire Connectors shall be:
 1. For wire sizes up to #6 AWG - Ideal "Wing Nut" or Gardner - Bender "Wing Gard".
 2. For Wire Sizes #4 AWG and larger:
 - End to end splices - Burndy YS.
 - Parallel splices - Burndy UC.
 - At studs and bus bars - Burndy QQA (CU / AL).
 - Two or three conductors in parallel - Burndy Q2A or Q3Q (CU / AL).
3. Cable connectors shall be:
 1. For armored TECK cables, watertight type, with open compounded head - T&B series "Spin-on 2" with corrosion resistant boot.
 2. For armored cables steel type with nylon insulated throat - T&B "TITE-Bite".
 3. Clamps or connectors for armored cable, flexible conduit, non-metallic sheathed cable shall be as required.

PART III - EXECUTION

3.1 Installation:

1. Remove insulation carefully from ends of conductors and:
 1. Install connectors and tighten as recommended by manufacturer.
Installation shall meet secureness tests in accordance with CSA C22.2 No.65.
 2. Install bushing stud connectors in accordance with EEMAC 1Y-2.

End of Section

SECTION 26 05 21: WIRES AND CABLES.

PART I - GENERAL

1.1 Work Included:

1. Provide building wire as detailed below and as required for a complete electrical installation.

PART II - PRODUCTS

2.1 Materials

1. Wire in Conduit:

1. Conductor material to be annealed commercial grade, copper, 98 percent conductivity, up to #10 AWG solid, with RW90 insulation, #8 and larger, stranded, with RW90 insulation, unless noted otherwise, 300V rating for fire alarm, security and other low voltage circuits, 600V rating for 120 / 208V circuits, 1000V rating for 240 / 416V circuits, 1000V rating for 277 / 480V circuits, 1000V rating for 347 / 600V circuits.

2. Colour Coding:

1. 120 / 208V, circuits:

- Two conductor, 1 phase: 1 black, 1 white
- Three conductor, 1 phase: 1 red, 1 black, 1 white
- Three conductor, 3 phase: 1 red, 1 black, 1 blue
- Four conductor, 3 phase: 1 red, 1 black, 1 blue, 1 white

2. 347 / 600V, circuits:

- Two conductor, 1 phase: 1 orange, 1 white
- Three conductor, 1 phase: 1 orange, 1 brown, 1 white
- Three conductor, 3 phase: 1 orange, 1 brown, 1 yellow
- Four conductor, 3 phase: 1 orange, 1 brown, 1 yellow, 1 white

3. Ground wires: green.

3. Low voltage Armored Cables Type AC-90:

1. Type to be AC-90, Multi-conductor, with solid, annealed commercial grade 98 percent conductivity tinned copper conductors and cross-linked polyethylene with R90 insulation, 600 volt rating, on #10 and #12 size only.

2. Colour Coding:

- Two conductor, 1 phase: 1 black, 1 white
- Three conductor, 1 phase: 1 black, 1 red, 1 white

3. Grounding to be uninsulated, solid copper, with impregnated paper separator.

-
4. Low voltage Armored Cables - TECK:
 1. Type to be TECK, single conductor with annealed. Class B, stranded copper conductors and cross linked polyethylene, RW90 insulation, 1000 volt rating for #8 AWG and larger.
 2. Grounding to be uninsulated tinned stranded copper, with non-hygroscopic filter material to maintain circular cross-section.
 3. The inner and outer jackets to be PVC "Flamenol" suitable for -40 degC, with mylar tape separator and aluminum strip, armour helically wound and interlocked.

PART III - EXECUTION

3.1 Installation:

1. General:

1. Wire shall be installed in conduit, and sized for the connected load (s) and protection as required, unless otherwise specified.
2. All single neutrals ran with Phase 'A', 'B', 'C' conductors to be minimum #10 AWG. #12 AWG neutrals may be used when run from final junction box to wiring devices.
3. Minimum power conductor wire size shall be #12 AWG. Use solid conductors for #10 and smaller and stranded conductors for #8 and larger. All wiring shall be copper conductors, RW90 (90degC ampacity).
4. Home runs in excess of 25 m (75 ft.) for circuits protected by a 15A over current device, shall be #10 AWG. Refer to drawings for additional requirements.
5. The current carrying capacity of the feeders, subfeeders and branch circuit conductors shall be sized to equal or better than shown on the drawings. If wire or cable sizes with equivalent current carrying capacity other than that specified is used, ensure that the voltage drop shall not be more than 2%.
6. The number of wires indicated for various systems is intended to show the general scheme only. The required number and type of wires shall be installed in accordance with the manufacturer's diagrams and with the requirements of the installation.

2. Wire in Conduit:

1. Provide pigtails at all outlets for wiring devices. All neutrals and branch circuits shall be connected in each outlet box to avoid a break in the neutral or the circuit wire when fixture or wiring device is disconnected.
2. At each junction, pull and outlet box make a 360 deg. loop of the stripped uncut ground conductor under the ground screws.

3. Low Voltage Armored Cables - (Feeders):
 1. Do not directly bury in or below concrete slabs or walls.
 2. Do not encircle single conductor cable with ferrous metal.
 3. No splices will be permitted.
 4. Single conductors of the three or four wire circuit shall be run with uniform spacing of not less than one cable diameter throughout the feeder length.
 5. Use wood throated cable clamps to ensure proper and uniform cable spacing.
 6. Where cables are installed on walls, provide mechanical protection over them up to 2.4m (8 ft.) above finished floor, using a 12 gauge U section aluminum cover.
 7. Cable connections to all enclosures, boxes and panels shall be by means of a watertight malleable aluminum connector.

End of Section

SECTION 26 05 27: GROUNDING.

PART I - GENERAL

1.1 Work Included:

1. Provide all grounding to conform with the Canadian Electrical Code and the latest instructions of the Inspection Authority, with any further requirements as noted herein.

PART II - PRODUCTS

2.1 Materials:

1. All grounding conductors stranded copper, bare or insulated as indicated on Drawings or in Specifications.
2. All ground wires are to be FT-4 rated factory green. Green tape, spray paint or any other means to alter the colour of the conductor is not permitted.
3. Use Cadweld or Burndy Thermoweld process for all weld connections. AMP of Canada Ltd. Wrench-Lok grounding connectors are an acceptable equivalent to welded connections.
4. All ground connectors to be designed and approved for grounding purposes.

PART III - EXECUTION

3.1 Installation:

1. Ground all conduit, and all non-current carrying metal parts, equipment cases, frames, bases, brackets, etc.
2. Grounding of all trays, AFCR's, racks, cabinets, etc. provided by the electrical contractor.
3. Ground each piece of fixed equipment back to the panel feeding that equipment, by one of the following methods:
 1. Conduit shall **not** be utilized for the ground return conductor.
 2. Where the conduit is flexible, install a separate bare soft drawn copper ground inside the conduit. At the switchboard or distribution panel, provide a grounding bushing, loop the ground conductor through the bushing, and connect to the switchboard ground bus. At the fixed equipment, connect to an internal ground bus, or connect to the inside of the metal enclosure utilizing approved screws and connectors (remove all paint). Run a separate (dedicated) insulated ground wire in all conduits to all devices and fixtures.
 4. Where equipment is fed by a multi-conductor power cable, provide a ground conductor in the cable. At the switchboard or panel, connect to the ground bus. Use a grounding connector on the cable for positive grounding of the metallic sheath. Loop the ground wire to the grounding connector.
 5. Run a separate ground wire in all flexible conduits. Connect each end to ground bus or lug or connector.
 6. Where mechanical protection is required for insulated grounding conductors install in rigid conduit.

7. Provide weld connection or wrench type grounding connectors for:
All connections between grounding conductors.
All connections to building steel.
All connections between grounding conductors and cable lugs.
8. Arrange grounding to provide the minimum impedance paths for ground fault currents.
Provide any additional grounding required for approval by the inspecting authorities.

3.2 Equipment Grounding

1. Install grounding connections to typical equipment including non-current carrying metal parts of transformers, generators, motors, circuit breakers, cable sheaths, raceways, pipe work, screen guards, switchboards, meter and relay cases, any exposed building metal and building structural steel.

End of Section

Hangers and Supports for Electrical Systems

SECTION 26 05 29: HANGERS AND SUPPORTS FOR ELECTRICAL SYSTEMS.

PART I - GENERAL

1.1 Work Included:

1. Provide fastenings and supports as required for a complete electrical system installation.

PART II - PRODUCTS

2.1 Support Channels:

1. U shape pre-galvanized steel, size 41 mm x 41 mm x 22 mm (1-5/8" x 1-5/8" x 7/8"), for surface mounting, suspending, or inserting into poured concrete walls and ceilings as required.
2. All channel fittings to suit channel type.
3. All other fittings to suit equipment weight, location and surface as required.

PART III - EXECUTION

3.1 Installation:

1. Secure plywood backboards, channels, luminaires, equipment and fittings to wood with wood screws, to solid masonry, tile and plaster surfaces with lead anchors, to poured concrete with self-drilling expandable inserts, and to hollow masonry walls with toggle bolts.
2. All ceiling mounted equipment shall be independently supported from the structure. Do not support equipment from ceiling support system.
3. Support equipment, conduit or cable using clips, spring loaded bolts, or cable clamps designed as accessories to basic channel members.
4. Fasten exposed conduit or cables to building using:
 1. Two-hole steel straps to secure surface conduits and cables 50 mm (2") and smaller.
 2. Two-hole steel straps for conduits and cables larger than 50 mm (2").
 3. Beam clamps to secure conduit to exposed steel work.
5. For suspended support system:
 1. Support individual cable or conduit runs with 6 mm (1/4") diameter threaded rods and spring clips.
 2. Support two or more cables or conduits on channels support by 6 mm (1/4") diameter threaded rod hangers where direct fastening to building construction is impractical.
 3. Support suspended luminaire using two or more lengths of Weldless "Single Jack", bright zinc plated steel chain, Canadian Standard #10 gauge, 13 links per foot.
6. Provide metal brackets, frames, hangers, clamps and related type of support structure where indicated or as required to support conduit and cable runs.
7. Ensure adequate support for raceways and cables dropped vertically to equipment where there is no wall support.

Hangers and Supports for Electrical Systems

8. Do not use wire lashing or perforated strap to support or secure raceways or cables.
9. Do not use supports or equipment installed for other trades for conduit or cable support.
10. Install fastenings and supports as required for each type of equipment, cable and conduits, and in accordance with manufacturer's installation recommendations.
11. Hangers shall be spaced such that there is a hanger within 610mm (24") of every bend and that the maximum spacing does not exceed the limits indicated in OESC code.
12. All conduit or cable shall be supported at equipment mounted on spring isolators, with spring hangers for at least 4572mm (15').

End of Section

Splitters, Junction, Pull Boxes and Cabinets

SECTION 26 05 31: SPLITTERS, JUNCTION, PULL BOXES AND CABINETS.

PART I - GENERAL

1.1 Work Included:

1. Provide splitters, junction boxes, pull boxes and cabinets as shown on the drawings and as required for a complete electrical installation.

PART II - PRODUCTS

2.1 Splitter Troughs:

1. Splitter trough construction is to be based on CSA C22.2 No. 76.
2. They shall have sheet steel enclosure, with welded corners and formed hinged cover suitable for locking in closed position.
3. Connection bars are to match required size and number of incoming and outgoing conductors as indicated.
4. Provide at least three spare terminals on each set of lugs in splitter troughs less than 400A and feed through lugs where required.
5. Provide double lugs for neutrals where required.
6. Enclosures shall be CSA/EEMAC Type 1 modified to sprinkler proof enclosure.

2.2 Junction and Pull boxes.

1. Junction and pull boxes construction is to be based on CSA C22.2 No. 40.
2. They shall be suitable for surface mounting and be of welded steel construction with screw-on flat covers.
3. For flush-mounted pull and junction boxes, provide covers with 25 mm (1") minimum extension all around.

2.3 General Cabinets:

1. Type D or E to be sheet steel, for surface mounting, complete with screw on cover (D) or hinged door (E), and return flange overlapping sides, handle and catch.

Splitters, Junction, Pull Boxes and Cabinets

PART III - EXECUTION

3.1 Splitter Installation:

1. Install splitter troughs where required. Mount plumb, true and square to the building lines.
2. Extend splitters for full length of equipment arrangement except where indicated otherwise.
3. Provide water tight connections for all services entering the top of the splitter trough.

3.2 Junction, Pull Boxes and Cabinet installation:

1. Install junction, pull boxes and cabinets in inconspicuous but accessible locations.
2. Only certain junction and pull boxes are indicated. Provide pull boxes so as not to exceed 30 m (100 ft) of conduit run between boxes, and after every 2 (two) 90 deg. bends.

3.3 Identification:

1. Install nameplates.

End of Section

Outlet Boxes, Conduit Boxes and Fittings

SECTION 26 05 32: OUTLET BOXES, CONDUIT BOXES AND FITTINGS.

PART I - GENERAL

1.1 Work Included:

1. Provide outlet and conduit boxes and fittings as required for a complete electrical system installation.

PART II - PRODUCTS

2.1 Outlet and Conduit boxes - General

1. The construction of outlet boxes, conduit boxes and fittings is to be based on CSA C22.2 No.18.
2. Boxes shall be suitable for the utilization voltage.
3. Combination boxes shall have barriers where outlets for more than one system are grouped.
4. Recessed 100 mm (4") square or larger outlet boxes shall be complete with single or ganged plaster rings to suit application.

2.2 Sheet Steel Outlet boxes:

1. Electro-galvanized steel single and multi-gang device boxes for flush installation, shall be minimum size 75 mm x 50 mm x 37 mm (3" x 2" x 1-1/2") unless otherwise specified or required. 100 mm (4") square outlet boxes shall be used when more than one conduit enters one side, with extension and plaster rings as required.
2. Boxes for door switches and push buttons shall be sized as required.
3. Utility boxes for connection to surface mounted EMT conduit, shall be minimum 100 x 54 x 48 mm (4" x 2-1/8" x 1-7/8") size.
4. Square or octagonal outlet boxes for lighting fixture outlets, shall be minimum 100 mm (4") size.
5. Square outlet boxes with extension and plaster rings for flush mounting devices in finished plaster or tile walls, shall be minimum 100 mm (4") size.

2.3 Masonry Boxes:

1. Electro-galvanized steel masonry single and multi-gang MBD boxes shall be used for flush mounted devices in exposed block walls.

2.4 Concrete boxes:

1. Electro-galvanized sheet steel concrete boxes shall be used for flush mounting in concrete, with matching extension and plaster rings as required.

2.5 Conduit Boxes:

1. Cast FS or FD ferrous boxes with factory-threaded hubs and mounting feet shall be used for outlets connected to surface mounted rigid conduit.

Outlet Boxes, Conduit Boxes and Fittings

2.6 PVC Boxes:

1. F series and octagon boxes shall be moulded type, with fastening ears and screwed secured covers as required.

2.7 Fittings - General:

2. Bushing and connectors shall be with nylon insulated throats.
3. Provide knock-out fillers to prevent entry of foreign materials.
4. Use conduit outlet bodies for conduit up to and including 32 mm (1-1/4") and pull boxes for larger conduits.
5. Provide double locknuts and insulated bushings on sheet metal boxes.

PART III - EXECUTION

3.1 Installation:

1. Support boxes independently of connecting conduits.
2. Fill boxes with paper, foam sponges or similar approved material to prevent entry of construction material.
3. Size box wiring chambers in accordance with Canadian Electrical Safety Code.
4. Gang boxes together where wiring devices are grouped.
5. Provide matching blank cover plates for boxes without wiring devices.
6. Use combination boxes where outlets for more than one system or voltage are grouped.
7. For flush installations, mount outlets flush with finished wall using plaster rings to permit wall finish to come within 5mm (1/4") of opening.
8. Provide correct size of openings in boxes for conduit and armored cable connections. Reducing washers are not allowed.

End of Section

Conduits, Conduit Fastenings and Conduit Fittings

SECTION 26 05 34: CONDUITS, CONDUIT FASTENINGS AND CONDUIT FITTINGS.

PART I - GENERAL

1.1 Work Included:

1. Provide conduits, conduit fastenings and conduit fittings as detailed below and as required for a complete electrical installation.

PART II - PRODUCTS

2.1 Conduits:

1. Rigid and epoxy coated conduit shall be threaded, galvanized steel and shall be manufactured to C.S.A C22.2 No. 45.
2. Electrical metallic tube (EMT) conduit and couplings shall be manufactured to C.S.A. C22.2 No. 83.
3. Flexible metal conduit and liquid tight - flexible metal conduit shall be manufactured to C.S.A. C22.2 No. 56.

2.2 Conduit Fastenings:

1. Conduit straps shall be steel, double hole for rigid or EMT conduit. Single hole straps are not acceptable.

2.3 Conduit Fittings:

1. Fittings for conduits shall be manufactured to C.S.A. C22.2 No.18. Provide coatings as per conduit.
2. Fittings for rigid conduit shall be steel threaded type, and for EMT conduit, to be steel set screw type.
3. Fittings for EMT conduit in wash bays to be steel compression fitting type.
4. Fittings for flexible conduit and exposed conduit outdoors to be liquid-tight type, straight or angled threaded for rigid and compression for EMT conduit.
5. Expansion fittings for rigid or EMT conduits shall be of the watertight type, with an integral bonding assembly, suitable for deflection in all directions.

2.4 Pulling Cables:

1. Pulling cables shall be polypropylene and of a strength suitable for tension to be pulled.

2.5 Waterproof Membrane:

1. Conduits penetrating waterproof membranes shall be PEM #6372.

Conduits, Conduit Fastenings and Conduit Fittings

PART III - EXECUTION

3.1 Installation (General):

1. The conduits for the following circuits and systems shall be run separately:
 - 120/208 volt utility power distribution.
 - 347/600 volt utility power distribution.
 - Normal power to luminaries.
 - Emergency power to luminaries and exit signs.
 - Fire alarm system multiplex loop devices.
 - Fire alarm system signaling devices.
 - Security, Duress, Intrusion and CCTV system devices.
 - Telephone and data systems.
 - Control wiring.
 - Paging System
2. All conduits to be surface mounted (exposed, EMT) in mechanical and electrical service spaces and rooms and concealed elsewhere unless otherwise shown.
3. Wiring in ceiling spaces and in all partitions shall be EMT.
4. Exposed conduits shall be installed to conserve headroom and cause minimum interference in spaces through which they pass.
5. Use rigid conduit up to 2.4 m (8' -0") above finished floor where exposed indoors
6. Use RGS conduit PVC coated galvanized rigid steel Robroy Permacote in all outdoor locations and in areas that are not environmentally controlled.
7. Use electrical metallic tubing (EMT) above grade, and above 2.4 m (8'-0") above finished floor where exposed indoors.
8. Use flexible liquid tight metal conduit for connection to motors, and transformers.
9. Bend conduit without heating. Replace conduit if kinked or flattened more than 1/10th of its original diameter.
10. Mechanically bend conduit over 20mm (3/4") diameter.
11. Field threads on rigid conduit must be of sufficient length to draw conduits tight.
12. Install pulling cables in all conduits that are to remain "empty".
13. A maximum of 2 (two), 90 deg. bends, or equivalent up to 180 deg., will be permitted without installation of a pull box. Radius of bends must be no less than 10 (ten) times the conduit diameter.
14. Conduits must be dry, before installing wires.
15. Support all branch conduits from building structure. Do not clip conduits to ceiling hangers, sprinkler pipes, plumbing or BAS wiring hangers.

Conduits, Conduit Fastenings and Conduit Fittings

3.2 Surface Conduits:

1. Surface conduits shall be run parallel or perpendicular to building lines.
2. Conduits located near any heat producing equipment shall have 1500 mm (5 ft.) clearance.
3. Conduits adjacent to structural steel, beams or columns shall be run within the flanged portion, unless otherwise shown.
4. Group exposed conduits on surface or suspended channels.
5. Do not pass conduits through structural members except where indicated and approved by Landlord.
6. Do not locate conduits less than 75 mm (3") parallel to steam or hot water lines. Provide a minimum clearance of 25 mm (1") at crossovers.

3.3 Conduit Size:

1. The minimum conduit size shall be 19 mm (3/4").
2. All undimensioned conduits in the drawings are 19 mm (3/4").

3.4 Expansion Fittings:

1. Conduit expansion fittings shall be provided on all conduits crossing expansion joints, and at maximum of 60 m (200 ft.) spacing.
2. Install expansion fittings perpendicular to expansion joint.
3. Refer to structural drawings for location of expansion joints.

End of Section

SECTION 26 27 26: WIRING DEVICES.

PART I - GENERAL

1.1 Work Included:

1. Provide all wiring devices indicated on drawings and described below.

PART II - PRODUCTS

2.1 Standards:

1. Construction of manually operated general purpose AC switches is to be based on CSA C22.2 No. 111, snap switches on CSA C22.2 No.55, and receptacles, plugs and similar wiring devices on CSA C22.2 No. 42.
2. Devices shall be Specification Grade and of one manufacturer throughout

2.2 Switches:

1. Switches shall be suitable for the voltage and load controlled and shall be single pole or three way as indicated.
2. They shall have terminal holes approved for No. 10 AWG wire, silver alloy contacts, and urea or melamine moldings for parts subject to carbon tracking.
3. They shall be suitable for back and side wiring, and rated for tungsten filament and fluorescent lamps, and up to 80% of rated capacity of motor loads.
4. White 'Decora' style switches shall be used for 120V circuits, in all finished areas.
5. White 'Decora' style switches shall be used for 347V circuits in all areas.

2.3 Receptacles:

1. Duplex receptacles shall be CSA Type 5-15R, 125 volt, 15 Amp, U ground and CSA Type 5-20RA, 125 volt, 15/20 Amp, U Ground.
2. They shall be colour, as specified on site by interior designer, 'Decora' style.
3. They shall be suitable for No. 10 AWG, back and side wiring, have break-off links for use as split receptacles and shall have eight (8) back wired entrances, four (4) side wiring screws and double wipe contacts with riveted grounding contacts.

2.4 Coverplates:

1. Coverplates shall be colour, as specified on site by interior designer in finished areas and stainless steel in unfinished areas.
2. Use die cast aluminum coverplates for wiring devices mounted for surface mounted FS or FD boxes, and pressed steel coverplates for utility surface boxes.
3. Use weatherproof spring-loaded, cast aluminum coverplates complete with gaskets for exterior mounted single receptacles and switches, or where indicated.

PART III - EXECUTION

3.1 Installation:

1. Switches:

1. Install single throw switches with lever in "UP" position when switch closed.
2. Install switches in gang type outlet box when more than one switch is required in one location.

2. Receptacles:

1. Install receptacles in gang type outlet box when more than one device is required in one location.

3. Coverplates:

1. Protect coverplate finish until painting and other work is finished, or install after painting is complete.
2. Do not use flush type coverplates on surface mounted boxes.

End of Section

SECTION 26 28 13.01: FUSES – LOW VOLTAGE.

PART I - GENERAL

1.2 Work Included:

1. Supply and install fuses in disconnect switches, etc. as required to complete this contract.

PART II - PRODUCTS

2.1 Fuses - General:

1. Plug and cartridge fuses shall be manufactured to CSA C22.2 No. 59.
2. HRC fuses shall be manufactured to CSA C22.2 No. 106 and to have interrupting capability of 200,000A symmetrical.
3. Fuses shall be the product of one manufacturer.
4. Fuse type reference L1, L2, J1, R1, etc. have been adopted for use in this specification.

2.2 Fuse Types:

1. HRCI - J fuses.
 1. Type J1, time delay, capable of carrying 500% of its rated current for 10 seconds minimum.
 2. Type J2, fast acting.
2. HRC - L.
 1. Type L1, time delay, capable of carrying 500% of its rated current for 10 seconds minimum.
 2. Type L2, fast acting.
3. HRC - R fuses (For UL Class RK1 fuses, peak let-through current and I^2t values not to exceed limits of UL 198E table 10.2.)
 1. Type R1, (UL Class RK1), time delay capable of carrying 500% of its rate current for 10 seconds minimum, to meet UL Class RK1 maximum let-through limits.
 2. Type R2, time delay, capable of carrying 500% of its rated current for 10 seconds minimum.
 3. Type R3, (UL Class RK1), fast acting Class R, to meet UL Class RK1 maximum let-through limits.
 4. HRCII - C fuses.

PART III - EXECUTION

3.1 Installation:

1. Install fuses in mounting devices immediately before energizing circuit.
2. Ensure circuit fuses fitted to physically matched mounting devices. Install Class R rejection clips for HRCI-R fuses.
3. Ensure correct fuses fitted to assigned electrical circuit.
4. Fuses protecting motor loads and transformers to be type J1 for up to and including 600A and L1 for ratings above 600A.
5. Fuses protecting feeder circuits to be type J2 for up to and including 600A and type L2 ratings above 600A.
6. Fuses protecting other services or equipment shall be of the type required for that purpose.

End of Section

Disconnect Switches – Fused and Non-Fused

SECTION 26 28 23: DISCONNECT SWITCHES - FUSED AND NON-FUSED.

PART I - GENERAL

1.1 Work Included:

1. Provide all disconnect switches shown on the drawings and as required for motors.

PART II - PRODUCTS

2.1 Equipment

1. Fuseholder assemblies to CSA C22.2 No. 39
2. Fusible and non-fusible disconnect switches shall be installed in CSA enclosures.
3. Provide for padlocking in "OFF" switch position by one lock.
4. Provide a mechanically interlocked door to prevent opening when handle in "ON" position.
5. Provide fuses sized as required.
6. Fuseholders in each switch shall be suitable without adapters, for type of fuse as specified.
7. Provide quick make, quick break action.
8. Provide ON-OFF switch position indication on switch enclosure cover.
9. Enclosures shall be CSA/EEMAC Type 1 modified to sprinkler proof enclosure.

PART III - EXECUTION

3.1 Installation:

1. Install disconnect switches with or without fuses as required.
2. Provide water tight connections for all services entering the top of the disconnect switches.

End of Section

SECTION 26 51 00: INTERIOR LIGHTING.

PART I - GENERAL

1.1 SUMMARY

1. Section Includes:

1. Interior lighting fixtures, lamps, ballasts, LEDs and drivers.
2. Emergency lighting units.
3. Exit signs.
4. Lighting fixture supports.
5. Retrofit kits for fluorescent lighting fixtures.

2. Related Sections:

1. Section 26 09 23 "Lighting Control Devices" for automatic control of lighting, including time switches, photoelectric relays, occupancy sensors, and multipole lighting relays and contactors.

1.2 REFERENCES

1. ANSI/NFPA 70, National Electrical Code
2. IESNA LM-79, Electrical and Photometric Measurements of Solid-State Lighting Products
3. IESNA LM-80, Approved Method for Measuring Lumen Maintenance of LED Light Sources
4. IESNA TM-21, Luminaire Classification System for Indoor Luminaires
5. UL1598, Standard for Safety of Luminaires

1.3 ACTION SUBMITTALS

1. Product Data: For each type of lighting fixture, arranged in order of fixture designation. Include data on features, accessories, and finishes.
2. Shop Drawings: Show details of nonstandard or custom lighting fixtures. Indicate dimensions, weights, methods of field assembly, components, features, and accessories.
Product Certificates: For each type of ballast for bi-level and dimmer-controlled fixtures, from manufacturer.

1.4 INFORMATIONAL SUBMITTALS

1. Field quality-control reports.

1.5 QUALITY ASSURANCE

1. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended location and application.
2. Comply with NFPA 70.
3. Luminaires shall be fully assembled and individually electrically tested prior to shipment.
4. Manufacturers of LED luminaires shall demonstrate a suitable testing program to ensure system reliability and to substantiate lifetime claims.
5. The sole use of IESNA LM-80 data to predict luminaire lifetime is not acceptable.
6. At time of manufacture, electrical and light technical properties shall be recorded for each luminaire. At a minimum, this should include lumen output, CCT, and CRI. Each luminaire shall utilize a unique serial numbering scheme. Technical properties must be made available for a minimum of 5 years after the date of manufacture.
7. Luminaires shall be provided with a minimum 5 year warranty covering, LEDs, drivers and paint finish.

PART 2 - PRODUCTS

2.1 MANUFACTURERS

1. Products: Subject to compliance with requirements, available products that may be incorporated into the Work include, but are not limited to, product(s) indicated on Drawings.
2. LED, fluorescent and HID lamps shall be of 1 (one) manufacturer, either in total, or in groups defined by lamp type.
3. Drivers / ballast and lamps provided under this contract must be an approved combination by both respective manufacturers

2.2 GENERAL REQUIREMENTS FOR LIGHTING FIXTURES AND COMPONENTS

1. Recessed Fixtures: Comply with NEMA LE 4 for ceiling compatibility for recessed fixtures.
2. Incandescent Fixtures: Comply with UL 1598. Where LER is specified, test according to NEMA LE 5A.
3. Fluorescent Fixtures: Comply with UL 1598. Where LER is specified, test according to NEMA LE 5 and NEMA LE 5A as applicable.
4. HID Fixtures: Comply with UL 1598. Where LER is specified, test according to NEMA LE 5B.
5. Metal Parts: Free of burrs and sharp corners and edges.

-
6. Sheet Metal Components: Steel unless otherwise indicated. Form and support to prevent warping and sagging.
 7. Doors, Frames, and Other Internal Access: Smooth operating, free of light leakage under operating conditions, and designed to permit relamping without use of tools. Designed to prevent doors, frames, lenses, diffusers, and other components from falling accidentally during relamping and when secured in operating position.
 8. Diffusers and Globes:
 1. Acrylic Lighting Diffusers: 100 percent virgin acrylic plastic. High resistance to yellowing and other changes due to aging, exposure to heat, and UV radiation.
 - a. Lens Thickness: At least [0.125 inch (3.175 mm)] minimum unless otherwise indicated.
 - b. UV stabilized.
 2. Glass: Annealed crystal glass unless otherwise indicated.
 9. Fixture Bodies:
 1. Lighting fixture bodies shall be of minimum 20 gauge cold rolled prime steel of rigid construction with knockouts as required.
 2. Fixtures shall be finished in baked white enamel with exposed surfaces matching the exposed t-bar ceiling specified in other sections and shall resist chipping, corrosion, and discoloration. Before finishing, all metal shall be chemically degreased and neutralized. Finish shall not be less than two coats of enamel, sprayed and baked on. Reflecting surfaces shall be white with an average reflectance of not less than 85%.

2.3 BALLASTS FOR LINEAR FLUORESCENT LAMPS

1. General Requirements for Electronic Ballasts:
 1. Comply with UL 935 and with ANSI C82.11.
 2. Designed for type and quantity of lamps served.
 3. Ballasts shall be designed for full light output unless another BF, dimmer, or bi-level control is indicated.
 4. Sound Rating: Class
 5. Total Harmonic Distortion Rating: Less than 10 percent.
 6. Transient Voltage Protection: IEEE C62.41.1 and IEEE C62.41.2, Category A or better.
 7. Power Factor: 0.95 or higher.
2. Luminaires controlled by occupancy sensors shall have programmed-start ballasts.
3. Electromagnetic Ballasts: Comply with ANSI C82.1; energy saving, high-power factor, Class P, and having automatic-reset thermal protection.
 1. Ballast Manufacturer Certification: Indicated by label.
4. Single Ballasts for Multiple Lighting Fixtures: Factory wired with ballast arrangements and bundled extension wiring to suit final installation conditions without modification or rewiring in the field.

2.4 BALLASTS FOR COMPACT FLUORESCENT LAMPS

1. Description: Electronic-programmed rapid-start type, complying with UL 935 and with ANSI C 82.11, designed for type and quantity of lamps indicated. Ballast shall be designed for full light output unless dimmer or bi-level control is indicated:
 1. Lamp end-of-life detection and shutdown circuit.
 2. Automatic lamp starting after lamp replacement.
 3. Sound Rating: Class A.
 4. Total Harmonic Distortion Rating: Less than 20 percent.
 5. Transient Voltage Protection: IEEE C62.41.1 and IEEE C62.41.2, Category A or better.
 6. Operating Frequency: 20 kHz or higher.
 7. Lamp Current Crest Factor: 1.7 or less.
 8. BF: 0.95 or higher unless otherwise indicated.
 9. Power Factor: 0.95 or higher.
 10. Interference: Comply with 47 CFR 18, Ch. 1, Subpart C, for limitations on electromagnetic and radio-frequency interference for nonconsumer equipment.

2.5 BALLASTS FOR HID LAMPS

1. Electromagnetic Ballast for Metal-Halide Lamps: Comply with ANSI C82.4 and UL 1029. Include the following features unless otherwise indicated:
 1. Ballast Circuit: Constant-wattage autotransformer or regulating high-power-factor type.
 2. Minimum Starting Temperature: Minus 22 deg F (Minus 30 deg C) for single-lamp ballasts.
 3. Rated Ambient Operating Temperature: 104 deg F (40 deg C).
 4. Open-circuit operation that will not reduce average life.
 5. Low-Noise Ballasts: Manufacturers' standard epoxy-encapsulated models designed to minimize audible fixture noise.

2.6 DRIVERS FOR LED FIXTURES

1. Electronic Driver for LED Fixtures: Comply with UL 1310 Class 2 requirements for dry and damp locations. EMI compliance with FCC Part 15 Class A. Include the following features unless otherwise indicated:
 1. Rated for 50,000 hours of life, unless otherwise noted.
 2. Type: Constant current
 3. Sound Rating: Class A.
 4. Total Harmonic Distortion Rating: 20 percent or less.
 5. Power factor at full load: >0.90
 6. Efficiency at full load: >85%
 7. Input Voltage: 120V - 277V (+/- 10%)
 8. Frequency Range: 50 – 60 Hz (+/- 10%)
 9. Transient Protection: NEMA SSL – 2010, Non-Roadway 2.5KV
 10. Over voltage and load protection: Yes, non-latching
 11. Ambient Operating Temperature: -30C to 50C
 12. Dimming Control: DALI
 13. Dimming Range: 10% - 100%

-
14. Source/Sink Current: 1mA max.

2.7 EXIT SIGNS

1. General Requirements for Exit Signs: Comply with UL 924; for sign colors, visibility, luminance, and lettering size, comply with authorities having jurisdiction.
2. Internally Lighted Signs:
 1. Lamps for AC Operation: Fluorescent, two for each fixture, 20,000 hours of rated lamp life.
 2. Lamps for AC Operation: LEDs, 50,000 hours minimum rated lamp life.
 3. Self-Powered Exit Signs (Battery Type): Integral automatic charger in a self-contained power pack.
 - a. Battery: Sealed, maintenance-free, nickel-cadmium type.
 - b. Charger: Fully automatic, solid-state type with sealed transfer relay.
 - c. Operation: Relay automatically energizes lamp from battery when circuit voltage drops to 80 percent of nominal voltage or below. When normal voltage is restored, relay disconnects lamps from battery, and battery is automatically recharged and floated on charger.
 - d. Test Push Button: Push-to-test type, in unit housing, simulates loss of normal power and demonstrates unit operability.
 - e. LED Indicator Light: Indicates normal power on. Normal glow indicates trickle charge; bright glow indicates charging at end of discharge cycle.

2.8 EMERGENCY LIGHTING UNITS

1. General Requirements for Emergency Lighting Units: Self-contained units complying with UL 924.
 1. Battery: Sealed, maintenance-free, lead-acid type.
 2. Charger: Fully automatic, solid-state type with sealed transfer relay.
 3. Operation: Relay automatically turns lamp on when power-supply circuit voltage drops to 80 percent of nominal voltage or below. Lamp automatically disconnects from battery when voltage approaches deep-discharge level. When normal voltage is restored, relay disconnects lamps from battery, and battery is automatically recharged and floated on charger.
 4. Test Push Button: Push-to-test type, in unit housing, simulates loss of normal power and demonstrates unit operability.
 5. LED Indicator Light: Indicates normal power on. Normal glow indicates trickle charge; bright glow indicates charging at end of discharge cycle.
 6. Wire Guard: Heavy-chrome-plated wire guard protects lamp heads or fixtures.
 7. Integral Time-Delay Relay: Holds unit on for fixed interval of 15 minutes when power is restored after an outage.

2.9 FLUORESCENT LAMPS

1. T8 rapid-start lamps, rated 32 W maximum, nominal length of 48 inches (1220 mm), 2800 initial lumens (minimum), CRI 85 (minimum), color temperature 4000K, and average rated life 40,000 hours unless otherwise indicated.
2. T8 rapid-start lamps, rated 17 W maximum, nominal length of 24 inches (610 mm), 1300 initial lumens (minimum), CRI 85 (minimum), color temperature 4000K, and average rated life of 40,000 hours unless otherwise indicated.
3. Compact Fluorescent Lamps: 4-Pin, CRI 85 (minimum), color temperature 4000K, average rated life of 12,000 hours at three hours operation per start, and suitable for use with dimming ballasts] unless otherwise indicated.
 1. 13 W: T4, double or triple tube, rated 900 initial lumens (minimum).
 2. 18 W: T4, double or triple tube, rated 1200 initial lumens (minimum).
 3. 26 W: T4, double or triple tube, rated 1800 initial lumens (minimum).
 4. 32 W: T4, triple tube, rated 2400 initial lumens (minimum).
 5. 42 W: T4, triple tube, rated 3200 initial lumens (minimum).
 6. 57 W: T4, triple tube, rated 4300 initial lumens (minimum).
 7. 70 W: T4, triple tube, rated 5200 initial lumens (minimum).

2.10 HID LAMPS

1. High-Pressure Sodium Lamps: ANSI C78.42, CRI 21 (minimum), color temperature 1900 K, and average rated life of 24,000 hours, minimum.
2. Metal-Halide Lamps: ANSI C78.43, with minimum CRI 70, and color temperature 4000 K.
3. Pulse-Start, Metal-Halide Lamps: Minimum CRI 70, and color temperature 4000 K.

2.11 LED FIXTURES

1. Except as otherwise indicated, provide LED luminaires, of types and sizes indicated on fixture schedules.
2. Include the following features unless otherwise indicated:
 1. Each Luminaire shall consist of an assembly that utilizes edge-lit LEDs as the light source. In addition, a complete luminaire shall consist of a housing, LED array, and electronic driver (power supply).
 2. Luminaire optics shall consist of precision formed optical assembly with positively retained high grade acrylic lenses using laser precise micro-prism patterns to provide directional distribution
 3. Each luminaire shall be rated for a minimum operational life of 100,000 hours utilizing a maximum ambient temperature of (25°C).
 4. Light Emitting Diodes tested under LM-80 Standards for a minimum of 10,000 hours.
 5. Color Rendering Index (CRI) of 85 at a minimum.
 6. Color temperature 4000K, unless otherwise indicated.

-
7. Rated lumen maintenance greater than 92% lumen output for 100,000 hours and theoretical L70 hours greater than 448,000 for recessed LED troffers.
 8. Fixture efficacy of 115 Lumens/Watt, minimum
 9. Fixture depth shall be no greater than 3.25"
 10. 5 year luminaire warranty, minimum.
 11. Photometry must comply with IESNA LM-79.
 12. Luminaires shall be Design Lights Consortium Premium Qualified
 13. The individual LEDs shall be constructed such that a catastrophic loss of the failure of one LED will not result in the loss of the entire luminaire.
 14. Luminaire shall be constructed such that driver may be replaced or repaired without the replacement of the whole fixture.

3. Technical Requirements

1. The luminaire shall not consume power in the off state.
2. Operation Voltage: The luminaire shall operate from a 50 HZ to 60 HZ AC line over a voltage ranging from 120 VAC to 277 VAC. The fluctuations of line voltage shall have no visible effect on the luminous output.
3. Power Factor: The luminaire shall have a power factor of 0.9 or greater.
4. THD: Total harmonic distortion (current and voltage) induced into an AC power line by a luminaire shall not exceed 20 percent.
5. Operational Performance: The LED circuitry shall prevent visible flicker to the unaided eye over the voltage range specified above.

4. Thermal Management

1. The thermal management (of the heat generated by the LEDs) shall be of sufficient capacity to assure proper operation of the luminaire over the expected useful life.
2. The LED manufacturer's maximum thermal pad temperature for the expected life shall not be exceeded.
3. Thermal management shall be passive by design. The use of fans or other mechanical devices shall not be allowed.
4. The luminaire shall have a minimum heat sink surface such that LED manufacturer's maximum junction temperature is not exceeded at maximum rated ambient temperature.

2.12 LIGHTING FIXTURE SUPPORT COMPONENTS

1. Comply with Section 260529 "Hangers and Supports for Electrical Systems" for channel- and angle-iron supports and nonmetallic channel and angle supports.
2. Single-Stem Hangers: 1/2-inch (13-mm) steel tubing with swivel ball fittings and ceiling canopy. Finish same as fixture.
3. Twin-Stem Hangers: Two, 1/2-inch (13-mm) steel tubes with single canopy designed to mount a single fixture. Finish same as fixture.
4. Rod Hangers: 3/16-inch (5-mm) minimum diameter, cadmium-plated, threaded steel rod.
5. Hook Hangers: Integrated assembly matched to fixture and line voltage and equipped with threaded attachment, cord, and locking-type plug.

2.13 RETROFIT KITS FOR FLUORESCENT LIGHTING FIXTURES

1. Ballast and Lamp Change Kit: UL 1598, Type II. Suitable for changing existing ballast, lamps, and sockets.

PART 3 - EXECUTION

3.1 INSTALLATION

1. Lighting fixtures: Set level, plumb, and square with ceilings and walls. Install lamps in each fixture.
2. Lamp and Driver / Ballast Installation:
 1. Refer to luminaire schedule and drawings, for lamp and driver / ballast requirements.
 2. Install lamps only when the luminaires are clean.
 3. Ensure that lamps are suitable for luminaires before energization and lamp length and colours are that as specified. Report any discrepancies to the consultant.
3. Luminaire Installation:
 1. Install luminaires accurately and carefully aligned complete with all mounting hardware. Ensure any suspension rods are vertical.
 2. All luminaires shall be supplied with accessory items such as yokes, plaster rings, frame adjusters, etc., where required for proper installation.
 3. At the time of date of "Substantial Completion" all luminaires, lenses, louvers and lamps must be clean and the lamps illuminated.
4. Luminaire Support:
 1. All fixtures in finished ceilings must be chained by 2 points directly to main structure such that they are supported independently of the ceiling system.

Interior Lighting

-
2. All fixtures in exposed ceiling areas (no T-bar or Drywall) shall be mounted on 1-5/8" unistrut, running the full length of the run of fixtures. The unistrut is to be suspended from the ceiling deck by 3/8" threaded rod from unistrut between the joists. Do not puncture ceiling deck.
 3. All lighting feeds for suspended fixtures shall be dropped from the deck or slab straight down into the fixture or raceway. Fixture to fixture conduits will not be permitted. Conduit must go to the deck then to the next fixture.

5. Cleaning:

1. All luminaires must be cleaned before lamping and installing lenses or louvres.
2. Use dry, clean, soft cloths if luminaires are dusty. Use mild solvents to clean soiled luminaires.

3.2 FIELD QUALITY CONTROL

1. Test for Emergency Lighting: Interrupt power supply to demonstrate proper operation. Verify transfer from normal power to battery and retransfer to normal.
2. Prepare a written report of tests, inspections, observations, and verifications indicating and interpreting results. If adjustments are made to lighting system, retest to demonstrate compliance with standards.

End of Section

SECTION 26 60 01: ELECTRICAL IDENTIFICATION.

PART I - GENERAL

1.1 Work Included:

1. Identify electrical equipment as specified herein.

1.2 Manufacturer's Nameplates:

1. Have the manufacturer's nameplates affixed to each item of all equipment showing the size, name of equipment, serial number and all information usually provided, including voltage, cycle, phase, horsepower, etc., and the name of the manufacturer and his address. Ensure that all stamped, etched or engraved lettering on plates is perfectly legible. Ensure that nameplates are not painted over. Where apparatus is to be concealed, attach the nameplate in an approved location on the equipment support or frame.
2. Ensure that panels and other apparatus which have exposed faces in finished areas do not have any visible trademarks or other identifying symbols. Mount nameplates behind doors.

PART II - PRODUCTS

2.1 Lamacoid Plates:

1. Refer to drawings for lamacoid background and text colour. Minimum size 75mm x 25mm (3" x 1") and 3.2mm (1/8") thick laminated plastic and 6.4mm (1/4") deep engraved lettering.

2.2 Conductor Markers:

1. Cable diameter less than 13 mm (1/2") - Electrovert type Z.
2. Cable diameter 13 mm (1/2") and larger - Electrovert #510 strap-on.
3. Colour - white with black markings except fire alarm and life safety system which shall be white with red markings.

PART III - EXECUTION

3.1 Conduit Services - Power:

1. Locate identification:
 - Behind each access door.
 - At each change of direction and at junction boxes.
 - At not more than 10 m (40') apart in straight runs of conduit behind removable enclosures such as lay-in type ceiling, but on both sides of sleeves through walls or floors.
 - Above each floor or platform for vertical exposed conduits, preferably 1500 mm (60") above floor or platform.
 - Use stencils and stencil paint or lamacoid plates on all conduit.
 - Use minimum 25 mm (1") high letters.

-
- The identification shall describe system voltage and service, i.e., "120 / 208 volt lighting to panel AA".

3.2 Conduits and outlet boxes:

1. Identify conduits and outlet boxes for the various systems by the use of the following distinctive colour paints. Apply a small area of paint to the inside of each outlet box, pull box and panel as it is being installed. Identify junction boxes in suspended ceiling areas with colour on both inside and outside.
 1. 120 / 208 volt system. -Black
 2. Fire Alarm systems. -Red
 3. 347/600 volt system. -Blue
 4. Security Alarm system -Orange
2. Use the colour coding as defined in CGSB Code 24-GP-3A and CSA Standard B53.
3. Where the existing colour coding differs from these Specifications, notify the Consultant of colours used and maintain existing colour coding.

3.3 Equipment Nameplates:

1. Identify all equipment listed below with lamacoid plates, letters 10 mm (0.4") high, unless otherwise noted.
 1. Lighting and Power Panels - Plates to be on outsides of door. Typical identification: "Lighting Panel C 120/208 v, 3 phase, 4 W MAINS 225 AMP 18KA RMS. Supplied from Panel BB".
 2. Disconnect switches and starters - Plates to be mounted externally on switch cover. Typical identification: "Fan S4, 208 v, 3 phase".
 3. Transformers - Plates to be mounted externally on case. Typical identification: "Transformer TR-UPSA 225 KVA/416/120/208 v, 3 PH / 4W fed from Panel UPS A".
2. Secure with mechanical fastening devices except on the inside of panel doors where gluing will be acceptable.

3.7 Wiring Colour Code:

1. Power and Lighting Conductors:
 1. Phase A - Red
 2. Phase B - Black
 3. Phase C - Blue
 4. Neutral - White
 5. Ground - Green
2. For sizes available in black only, use coloured tape markers at junction boxes and terminal points to match phase coding described above.
3. Band green isolated ground conductors with yellow tape.
4. Control conductors - Orange
5. Fire Alarm System Conductors.
 1. Alarm initiating devices and manual pull stations - red and blue.

2. Alarm signaling devices - black and white.

3.8 Conductor Markers:

1. For power feeders, install markers at either end of the conductors where terminated inside of equipment to match wiring diagram conductor identification or panelboard circuit numbers. Typical identification Panel AA circuits - 21; use "AA-21". For a three phase circuit provide identification on phase A conductor only. For a single phase circuit provide identification on the phase conductor.
2. For Branch circuits supplying single phase and three phase devices such as receptacles and connections to equipment identify conductors at panel and in device outlet box. Install marker on phase conductor inside outlet box. Typical identification if device is connected to Panel B - circuit 14, marker identification "B-14".

End of Section

Testing and Commissioning of Electrical Systems

SECTION 26 60 02: TESTING AND COMMISSIONING OF ELECTRICAL SYSTEMS.

PART I - GENERAL

1.1 Description:

1. Include in work of this section, the testing and commissioning of all new electrical and component systems.
2. Include any specific testing of equipment required by the Hydro Inspection or Supply Authorities.
3. The complete costs of the site, load bank and factory testing and commissioning witnessing of Electrical Equipment is to be included in the Bid price.
4. Inform manufacturers of all factory and site testing requirements and include all their costs in the Bid price.
5. At their own discretion, testing is to be witnessed by the Owner and the Electrical Consultant.

1.2 Scope:

1. Include factory testing and approved certification, where required.
2. Coordinate with the equipment manufacturer, notify the Electrical Consultant in writing, 10 (ten) days before any factory testing to confirm Consultant's desired presence, and be present for all site testing.

1.3 Completion of Work:

1. All electrical systems and equipment shall be totally commissioned and operating before date of "Substantial Completion".
2. Coordinate with other trades and the building operations staff for work which affects the operation of the electrical systems, before submitting request for testing and commissioning. Failing to comply, bear all costs including Consultant's time cost, incurred for re-testing and re-commissioning.

PART II - PRODUCTS

2.1 Materials:

1. Provide all tools, equipment, labour and materials required to perform electrical testing and commissioning as specified. Provide the test results report (s).

2.2 Temporary Load Bank:

1. For testing of the UPS systems, provide resistive variable load banks.
2. Load banks must be complete with breakers to protect generators and UPS systems from cable faults.

Testing and Commissioning of Electrical Systems

PART III - EXECUTION

3.1 Installation:

1. Perform site testing and commissioning only after all equipment is installed and operational.
2. Furnish manufacturer's certificate or letter confirming that entire installation as it pertains to each system has been installed to manufacturer's instructions.
3. Provide 4 (four) copies of certificates of all factory and site testing in complete detail bearing in each case, the seal of the engineer responsible for the tests.
4. Submit all test results for Consultant's review.
5. All equipment or system deficiencies identified by factory or site testing procedures, to be corrected by the Contractor prior to obtaining a "Certificate of Substantial Completion".
6. Submit report, at completion of measurements, listing phase and neutral currents on panelboards, dry-type transformers and motor control centres, operating under normal load. Include hour and date on which load was measured, and voltage at time of test.
7. General operations: energize and operate electrical circuit and item. Repair, alter, replace, test and adjust as necessary for a complete and operating electrical system.
8. Test systems and obtain written confirmation from manufacturers that components have been installed correctly and system functioning as intended. Submit certification for power distribution, communications systems and emergency power to Owner's Consultant.
9. Provide labour, instruments, apparatus and pay expenses required for testing. Owner's Consultant reserves right to demand proof of accuracy of instruments used.
10. Perform the following tests on completed power systems:
 1. Supply voltage: measure line voltage of each phase at load terminals of main breakers and report results in writing to Owner's Consultant. Perform test with majority of electrical equipment in use.
 2. Motor loading: measure line current of each phase of motors with motor operating under load, and report results in writing to Owner's Consultants.
 1. Upon indications of imbalances or overloads, thoroughly examine electrical connections and rectify defective parts or wiring.
 2. If electrical connections are correct, report overloads due to defects in driven machines in writing to Owner's Consultant.
 3. Insulation resistance tests:
 1. Megger circuits, feeders and equipment up to 350V with a 500V instrument for at least one (1) minute.
 2. Megger 350-600V circuits, feeders and equipment with a 1000V instrument for at least one (1) minute.
 3. Check resistance to ground before energizing.
 4. Coordinate and carry out motor testing at same time as driven equipment is being tested. In addition to motor loading tests, provide labour and instruments to read and record motor load readings required to supplement tests on driven equipment through various load sequences, as required by driven equipment tests.
11. Immediately prior to occupancy, test entire electrical system by performing loss and return of utility power test. Demonstrate operation of:
 1. Low voltage service equipment and metering
 2. Exit and emergency lighting
 3. restabilization of systems after power return. Attach report printouts as evidence of expected operation on systems.
 4. User equipment shut-down and auto-restart.

Testing and Commissioning of Electrical Systems

3.2 Field Tests

1. Provide advance notice to Owner's Consultant of proposed testing schedule.
2. Perform tests at time of acceptance of work.
3. Conduct and pay for field tests:
 1. Power distribution, including phase voltage, grounding and load balancing.
 2. Circuits originating from branch distribution panels.
 3. Lighting and lighting control. Motors, heaters and associated control equipment, including sequenced operation.
 4. Emergency Power Systems
4. Perform tests in presence of Owner's Representative.
 1. Provide instruments, meters, equipment and personnel required to conduct required tests.
 2. Test systems to verify operation as specified.
5. Conduct di-electric tests, hi-pot tests, insulation resistance tests and ground continuity tests as required by nature of various systems and equipment

3.3 General Testing:

1. With the system completely connected, perform the following tests:
 1. Control and Switching - all circuits shall be tested for the correct operation of devices, switches and controls.
 2. Polarity Tests - all sockets shall be tested for correct polarity.
 3. Voltage Test - a voltage test shall be made at the last outlet of each circuit. The maximum drop in potential permitted will be 2% on 120 and 208 volt branch circuits and on 208 volt feeder circuits. Any deficiency in this respect shall be corrected.
 4. Phase Balance - measure the load on each phase at each splitter, and lighting and power panelboard and report the results in writing to the Consultant. Rearrange phase connections as necessary to balance the load on each phase as instructed by the Consultant, with the re-arrangement being restricted to the exchanging of connections at the distribution points mentioned in this paragraph. After making any such changes, make available to the Consultant drawings or marked prints showing the modified connections.
 5. General Operations - energize and put into operation each and every electrical circuit and item. Necessary repairs, alterations, replacements, tests and adjustments required shall be made for complete and satisfactory operating systems.

3.4 Sealing:

1. Ensure and verify that all penetrations of electrical equipment have been properly sealed with appropriate material and to the manufacturers' requirements.

3.5 Noise and vibration:

1. Ensure and verify that all isolation equipment has been installed where required and to the manufacturers' recommendations. Include the locations of and measurements of static deflection of spring isolators.

Testing and Commissioning of Electrical Systems

3.6 Coordination Study

1. For the entire electrical distribution system provided as part of this contract and for the existing high voltage base building switchgear and low voltage base building switchgear, supply a report from an independent test agency of the short circuit, protection, co-ordination study of the electrical distribution system. **An existing coordination study is not available for contractor's use.**
2. Co-ordination of Protective Devices:
 - .1 Ensure circuit protective devices such as overcurrent trips, relays, circuit breakers and fuses are installed to values and settings so as to provide protection by means of opening the closest device to the fault.
 - .2 Submit a short circuit protection and co-ordination study as follows:
 1. Obtain and organize all electrical protection data for all the equipment. This will consist of obtaining the relay types and settings, transformer impedances, cable sizes, fuse sizes and types, motor data, etc., required to carry out the short circuit.
 2. Perform a short circuit analysis to determine short circuit current levels at all critical points in the distribution system, having obtained the available short circuit current available from the Hydro Supply Authority.
 3. Generate appropriate settings for all relays and protective devices from the level of the Hydro Supply Authority feeder protective devices to the largest downstream device on all the feeder secondary distribution levels.
 - .3 Provide a complete, comprehensive report at the conclusion of the short circuit, protection and co-ordination study consisting of the following:
 1. A set of time current curve characteristics of all protective devices in the system plotted on log/log graph paper with corresponding short circuit current levels.
 2. Time current damage curves for all transformers, large motors and cables are also to be plotted.
 3. Provide a complete schedule of all main protective relays, fuses and other protective device listing device locations, function number, manufacturer, model number, size, range, setting, etc.
 4. The complete study will illustrate and ensure that the settings and sizes of all protective devices for each voltage level have been chosen to ensure maximum or optional protection and co-ordination during electrical fault or overload conditions.
 5. These generated settings will then be applied by "in-field" testing methods to the respective devices.

3.7 Ground Fault Protection System

1. Inspect relays visually for condition and clean where necessary.
2. Check all connections for tightness.
3. Apply settings to each relay as specified in the short circuit, protection and co-ordination study and test operation by means of a relay test set.
4. Verify each protective system by means of a primary current injection through the zero phase sequence transformer. This will provide correct operation of both the transformer and relay as well as proper functioning of the circuitry through to the breaker tripping elements.

Testing and Commissioning of Electrical Systems

3.8 Arc Flash Analyses

1. For the entire electrical distribution system provided as part of this contract and the existing electrical distribution system shown on the drawings, conduct an electrical arc flash hazard analysis as prescribed under NFPA 70E (CSA Z462) dated 2008 and provide a written report summarizing the findings and recommended control measures to be taken. The arc flashing analysis results must be deemed acceptable prior to the equipment purchase.
2. Provide appropriate labels for all equipment.

3.9 Emergency Light Level Measurements

1. As part of this scope of work procure the services of a professional engineer to measure and record emergency lighting levels in foot candles throughout all scope of work areas with a calibrated light meter. Readings shall be taken based on a minimum of one reading for every 20' center in open office areas and corridors / hallways and one reading in each closed office, meeting room, boardroom and stairwell.
2. All light level readings are to be taken during non-daylight hours.
3. Provide a sealed letter identifying light level readings and stating that the emergency lighting levels meet the requirements of the National Building Code. Notify Owner and Consultant at least ten (10) days prior to proposed testing date and schedule testing at time and date acceptable to Owner and Consultant.

3.10 Test Results

1. Submit test results to Owner's Consultant for review.
2. Testing methods and test results: to CSA, CEC and authorities having jurisdiction.
3. Remove and replace conductors found damaged with new materials.
4. Provide required labour and tools, if during testing Owner's Representative requests equipment be opened and removed from their housings to examine equipment, terminations and connections.

End of Section

Project: 17264

Panelboard: Panel PPA

Voltage (V):

Phase/Wire:

Bus and Lugs Rating (A):

CCT NO	Load	Breaker		CCT NO	Load	Breaker	
		Amp	Pole			Amp	Pole
1	Existing CCT	15	1	2	Existing CCT	15	1
3	Existing CCT	15	1	4			
5	Existing CCT	15	1	6			
7	Existing CCT	15	1	8			
9	Existing CCT	15	1	10			
11	Existing CCT	15	1	12	Existing CCT	15	1
13	Existing CCT	15	1	14	Existing CCT	15	1
15	Existing CCT	30		16	Existing CCT	15	1
17	Existing CCT		2	18	Existing CCT	15	1
19	Existing CCT	15	1	20	Existing CCT	15	1
21	Existing CCT	15	1	22			
23	Existing CCT	15	1	24			
25	Existing CCT	20	1	26			
27	Existing CCT	15	1	28	PPD	100	
29	Existing CCT	15	1	30			2
31	Existing CCT	20	1	32			
33	Existing CCT	30		34	Existing CCT	15	1
35	Existing CCT		2	36	Existing CCT	15	1
37	Existing CCT	15	1	38	Existing CCT	15	1
39	Existing CCT	30		40	Existing CCT	30	
41	Existing CCT		2	42	Existing CCT		2

Project: 17264

Panelboard: Panel PPD

Voltage (V):

Phase/Wire:

Bus and Lugs Rating (A):

CCT NO	Load	Breaker		CCT NO	Load	Breaker	
		Amp	Pole			Amp	Pole
1	Lighting Circuit / Emergency Battery Unit	15	1	2	Washroom Sensors / EF	15	1
3	Dormitory Receptacles	20	1	4	Change Table	20	1
5	Study Area 108 Receptacle	20	1	6	Universal Washroom Receptacle	20	1
7	Lounge 114 TV Receptacle	20	1	8	Washroom 105 Receptacle	20	1
9	Locker Room	20	1	10	Duress System / Door Lock/ Door Operator	15	1
11				12	Exterior Lighting	20	1
13	Dish Washer	20		14	Parking Garage Lighting	15	1
15			2	16	Parking Garage Lighting	15	1
17	Range Hood	20	1	18	Parking Garage Lighting	15	1
19	Stove	20	1	20	HWT	15	1
21	Counter Receptacle	20	1	22	ERV-1	15	1
23	Counter Receptacle	20	1	24	EDH-1	20	1
25	Counter Receptacle	20	1	26			
27	Counter Receptacle	20	1	28			
29	Counter Receptacle	20	1	30	House Keeping	20	1
31	Counter Receptacle	20	1	32			
33	Counter Receptacle	20	1	34			
35				36			
37	Spare	20	1	38	Spare	15	1
39	Spare	20	1	40	Spare	15	1
41	Spare	20	1	42	Spare	15	1