

August 21, 2024

Via Ariba internet posting
(2 Pages)

ADDENDUM No. 2
REQUEST FOR TENDER ARIBA Doc4703911352
CLOSING DATE (REVISED): 12:00 NOON (LOCAL TIME), August 29, 2024

For: Request for Tenders for Generator Replacement at Fire Hall #212 EMS Station #25
Located at 8500 Sheppard Ave East, Toronto

Please refer to the above Tender Call document in your possession and be advised of the following information:

1. QUESTIONS

Q1 – Which points do we need to provide for the generator? It only says to tie in generator to existing fire panel spare zones but doesn't specify which or how many points are needed.

A1 – The generator shall have the following signals (generator common trouble, generator fuel valves closed, generator running) tied into the fire alarm panel as noted on E-100 Detail 3 per CSA C282.

Q2 – Qty how many bollards?

A2 – No Bollards installation is required currently. If Enbridge requests them to be installed, the total cost associated with bollards installation will be paid from the cash allowance.

Q3 – Length x Width x Height of Pad - assumed same structural requirements as generator pad?

A3 – Contractor to include the cost for concrete pad for the new/upgraded Enbridge meter station as follow:

Reinforced, 8" thick a "slab on grade" concrete pad, size 10'(L) x 4'(W)

Rebars are to be 10M at 300mm O/C in the middle.

Min. 8" depth, ¾ Crush stone well compacted is required.

28 days concrete compression strength to be 32MPa with 4% to 7% air entrainment.

Note: Contractor to confirm with Enbridge the size of the required concrete pad, prior to installation. Existing landscaping to be restored to existing conditions.

Please continue to monitor this procurement as further extensions or possible cancellation may occur. Should you have any questions regarding this addendum send via the event message board or contact Max Parker by email at Max.Parker@toronto.ca.

Bidders must acknowledge receipt of all addenda on the space provided on the submission form as per the Process Terms and Conditions, Part 1.7 - Addenda, of the RFT document. All other aspects of the RFT remain the same.

Sincerely,

Theodoros Maicantis

Theodoros Maicantis, Supervisor
Purchasing & Materials Management Division