



# Fire Alarm and Life Safety System Inspection Report

*For*

Communication, Traffic, &  
Computer Centre

703 Don Mills Rd

Toronto, Ontario M3C 3N3

Building Number: 903953

Tested to CAN/ULC S536-04 Standard

Smoke alarms are inspected to CAN ULC S552-02

*This report should be accompanied by the BRForm containing the contents of CAN/ULC S536-04 Appendix E*

*This Inspection was performed in accordance with applicable ULC Standards. The subsequent pages of this report provide performance measurements, listed ranges of acceptable results, and complete documentation of the inspection. Whenever discrepancies exist between acceptable performance standards and actual test results, notes and/or recommended solutions have been proposed or provided for immediate review and approval.*

*The devices in this report are 100% tested and 92% passed*

*Annual Inspection*

*Start Date: Jan 4, 2023*

*End Date: Jan 16, 2023*

*Service - Annual*

Building: Communication, Traffic, & Computer Centre

Contact: . .


Company: Greater Toronto Fire Protection

Contact: Joseph Bryant

To obtain further details about this inspection please utilize your login and password to view online.  
This FireScan report should be accompanied with the associated BRForm.

# Executive Summary

Generated by: BuildingReports.com

Building Information		
<b>Building:</b> Communication, Traffic, & Computer Centre	<b>Contact:</b> . .	
<b>Address:</b> 703 Don Mills Rd	<b>Phone:</b> 1111111111	
<b>Address:</b>	<b>City/Province/Postal Code:</b> Toronto, Ontario M3C 3N3	
<b>Email:</b>		
Inspection Performed By		
<b>Company:</b> Greater Toronto Fire Protection	<b>Inspector:</b> Joseph Bryant	
<b>Address:</b> 111 Warren Road	<b>Phone:</b> 647-256-3473	
<b>Address:</b>	<b>City/Province/Postal Code:</b> Whitby, ON L1N 2C4	
<b>Email:</b> fatech1@gtfp.ca		
System Control Unit		
<b>Manufacturer:</b> SimplexGrinnell	<b>Inspection Date:</b> 01/16/2023	<b>IDC Style:</b> A
<b>Model Number:</b> 4100	<b>Install Date:</b> 03/11/1992	<b>SLC Style:</b> 7
<b>Software Version:</b> 11.10, R	<b>Version Date:</b> 09/03/2015	<b>NAC Style:</b> Y
<b>Location:</b> 1st security deck at front entrance	<b>Current Protection:</b> Fuse	<b>Auto Evac Time:</b>
Central Station Signal Verification		
<b>Type:</b>	<b>Mfg:</b>	<b>Model #:</b>
<b>Test Time/Date:</b>	<b>Restore Time:</b>	
Type of Signal	Signal Confirmation	Notes
Type: Alarm/Trouble/Supervisory	Confirmed Time:	
Certification		
<b>Company:</b> Greater Toronto Fire Protection	<b>Building:</b> Communication, Traffic, & Computer Centre	
<b>Inspector:</b> Joseph Bryant	<b>Contact:</b> . .	
		
<b>Signed:</b> Jan 16, 2023	<b>Signed:</b>	
Joseph Bryant Certifications		
Certification Type	Number	
CFAA Registered Technician	19-999060	

# Discrepancy Report with Proposed Solutions

Generated by: BuildingReports.com

## Building: Communication, Traffic, & Computer Centre

This report consolidates all discrepancies and provides proposed solutions to these issues. Discrepancies are listed by Category, and grouped by device type. The description of the problem is provided and where appropriate, code references are listed for your convenience. Any devices that have been corrected and passed the retest are checkmarked under the Fixed column and details regarding the individual who completed the fix are noted in the last column. Any item that was inspected that is subject to a recall or part of a manufacturer's replacement/upgrade program is included.

Device Type	Manufacturer	Model Number	Date	Qty
-------------	--------------	--------------	------	-----

### Items listed for Recall or Replacement/Upgrade

No items found during this inspection.

Scan Number	Model	Type/Size	Discrepancy	Solution	Cost	A P P R O V E D	F I X E D	Date Corrected and Passed Retest
-------------	-------	-----------	-------------	----------	------	--------------------------------------	-----------------------	---

### Annunciator

57019683	n/a	LED List	Special Note CAN/ULC S536 5.4.1	See note	T/M	<input type="checkbox"/>	<input type="checkbox"/>	
----------	-----	----------	---------------------------------------	----------	-----	--------------------------	--------------------------	--

**Location:** 1st security deck at front entrance

**Note:** Evac Switch operates as alert tone - alert switch operates as evac tone Improper led lights - alarm LED should be red

### Battery

62118586	ELA-12V-34AH	Sealed Lead Acid	Failed Test CAN/ULC S536 5.3.2	Replace	T/M	<input type="checkbox"/>	<input type="checkbox"/>	
----------	--------------	------------------	--------------------------------------	---------	-----	--------------------------	--------------------------	--

**Location:** 1st electrical room door plaque 111

**Note:** Requires bigger batteries

62118731	ELA-12V-34AH	Sealed Lead Acid	Failed Test CAN/ULC S536 5.3.2	Replace	T/M	<input type="checkbox"/>	<input type="checkbox"/>	
----------	--------------	------------------	--------------------------------------	---------	-----	--------------------------	--------------------------	--

**Location:** 4th electrical room Node -3

**Note:** Requires Bigger Batteries

58610050	ELA-12V-34AH	Sealed Lead Acid	Date Expired CAN/ULC S536 5.3.2	Replace Battery	T/M	<input type="checkbox"/>	<input type="checkbox"/>	
----------	--------------	------------------	---------------------------------------	--------------------	-----	--------------------------	--------------------------	--

**Location:** 7th Electrical/Fire Alarm Panel Room door plaque 704 Left tub

58610049	ELA-12V-34AH	Sealed Lead Acid	Failed Test CAN/ULC S536 5.3.2	Replace	T/M	<input type="checkbox"/>	<input type="checkbox"/>	
----------	--------------	------------------	--------------------------------------	---------	-----	--------------------------	--------------------------	--

Scan Number	Model	Type/Size	Discrepancy	Solution	Cost	A P P R O V E D	F I X E D	Date Corrected and Passed Retest
<b>Battery</b>								
<b>Location:</b> 7th Electrical/Fire Alarm Panel Room door plaque <b>Note:</b> 704 Main tub								
57019735	F4P12V35Ah	Sealed Lead Acid	Failed Test CAN/ULC S536 5.3.2	Replace 2x 12V35Ah Batteries	T/M	<input type="checkbox"/>	<input type="checkbox"/>	
<b>Location:</b> 9th Electrical Room Fire Alarm Panel Room Left <b>Note:</b> tub								
57019734	F4P12V35Ah	Sealed Lead Acid	Failed Test CAN/ULC S536 5.3.2	Replace 2x 12V35Ah Batteries	T/M	<input type="checkbox"/>	<input type="checkbox"/>	
<b>Location:</b> 9th Electrical Room Fire Alarm Panel Room Main <b>Note:</b> Panel died during Full load testing - batteries failed - Toronto FLS supplying batteries for a further date - requires bigger batteries								
<b>Control Panel</b>								
57019680	4100	Addressable	Defective CAN/ULC S536 5.2.2	See notes /recommendations	T/M	<input type="checkbox"/>	<input type="checkbox"/>	
<b>Location:</b> 1st security deck at front entrance <b>Note:</b>								
57019733	4100	Addressable	Defective CAN/ULC S536 5.2.2	Replace	T/M	<input type="checkbox"/>	<input type="checkbox"/>	
<b>Location:</b> 9th Electrical Room Fire Alarm Panel Room <b>Note:</b> Disconnected battery leads - panel died - panel failed during full load test								
<b>Duct Detector</b>								
57019730	2098-9131 (Housing)	Photoelectric	Special Note CAN/ULC S536 5.7.4.1.2	Retest	T/M	<input type="checkbox"/>	<input type="checkbox"/>	
<b>Location:</b> Penthouse mechanical/fan room RF1 standing <b>Note:</b> height								
57019732	2098-9131 (Housing)	Photoelectric	Special Note CAN/ULC S536 5.7.4.1.2	Retest	T/M	<input type="checkbox"/>	<input type="checkbox"/>	
<b>Location:</b> Penthouse mechanical/fan room SF1 Overhead, <b>Note:</b> 12'								
57019731	2098-9131 (Housing)	Photoelectric	Special Note CAN/ULC S536 5.7.4.1.2	Retest	T/M	<input type="checkbox"/>	<input type="checkbox"/>	

Scan Number	Model	Type/Size	Discrepancy	Solution	Cost	A P P R O V E D	F I X E D	Date Corrected and Passed Retest
<b>Duct Detector</b>								

**Location:** Penthouse mechanical/fan room SF2 standing height  
**Note:**

<b>End Of Line</b>								
57019868	EOL 2081-9018		Failed to Report	No Ground Reported	T/M	<input type="checkbox"/>	<input type="checkbox"/>	

**Location:** 7th mid stairwell north  
**Note:**

57019821	EOL 2081-9018		Damaged/Worn	Replace	T/M	<input type="checkbox"/>	<input type="checkbox"/>	
----------	---------------	--	--------------	---------	-----	--------------------------	--------------------------	--

**Location:** 8th corridor by men's washroom door plaque 806  
**Note:**

<b>Generator Running</b>								
58610083	n/a		Special Note CAN/ULC S536 5.3.3	Reschedule	T/M	<input type="checkbox"/>	<input type="checkbox"/>	

**Location:** Penthouse Electrical Room by Generator room  
Generator 1 Running  
**Note:**

58610081	n/a		Special Note CAN/ULC S536 5.3.3	Reschedule	T/M	<input type="checkbox"/>	<input type="checkbox"/>	
----------	-----	--	---------------------------------------	------------	-----	--------------------------	--------------------------	--

**Location:** Penthouse Electrical Room by Generator room  
Generator 2 Running  
**Note:**

<b>Generator Trouble</b>								
58610084	n/a		Special Note CAN/ULC S536 5.3.3	Reschedule	T/M	<input type="checkbox"/>	<input type="checkbox"/>	

**Location:** Penthouse Electrical Room by Generator room  
Generator 1 Trouble  
**Note:**

58610082	n/a		Special Note CAN/ULC S536 5.3.3	Reschedule	T/M	<input type="checkbox"/>	<input type="checkbox"/>	
----------	-----	--	---------------------------------------	------------	-----	--------------------------	--------------------------	--

**Location:** Penthouse Electrical Room by Generator room  
Generator 2 Trouble  
**Note:**

<b>Heat Detector</b>								
64248500	CR-135	Rate-of-Rise	Access Denied CAN/ULC S536 5.7.1.3	Reschedule	T/M	<input type="checkbox"/>	<input type="checkbox"/>	

**Location:** Basement elevator 1&2 pit door plaque 006  
barcode on exterior doorframe  
**Note:**

64248501	CR-135	Rate-of-Rise	Access Denied	Reschedule	T/M			
----------	--------	--------------	---------------	------------	-----	--	--	--

Scan Number	Model	Type/Size	Discrepancy	Solution	Cost	A P P R O V E D	F I X E D	Date Corrected and Passed Retest
<b>Heat Detector</b>								
			CAN/ULC S536 5.7.1.3			<input type="checkbox"/>	<input type="checkbox"/>	
<b>Location:</b> Basement elevator 3 pit barcode on exterior doorframe <b>Note:</b>								
64248502	CR-135	Rate-of-Rise	Access Denied CAN/ULC S536 5.7.1.3	Reschedule	T/M	<input type="checkbox"/>	<input type="checkbox"/>	
<b>Location:</b> Penthouse top of elevator shaft accessed through centre elev. barcode on 9th floor elev. doorframe <b>Note:</b>								
<b>Initiating Device</b>								
59582754	2099-9288C	Supporting Field Device	Door Locked CAN/ULC S536 5.7.7.1	Reschedule	T/M	<input type="checkbox"/>	<input type="checkbox"/>	
<b>Location:</b> Basement fitness room woman's locker room GA key door plaque 026 <b>Note:</b>								
57019860	2099-9288C	Supporting Field Device	Failed Test CAN/ULC S536 5.7.7.1		T/M	<input type="checkbox"/>	<input type="checkbox"/>	
<b>Location:</b> 7th elevator lobby right side GA key <b>Note:</b>								
57019855	2099-9288C	Supporting Field Device	Failed Test CAN/ULC S536 5.7.7.1		T/M	<input type="checkbox"/>	<input type="checkbox"/>	
<b>Location:</b> 7th stairwell north GA key door plaque 7ST1A <b>Note:</b>								
58610015	2099-9288C	Supporting Field Device	Defective CAN/ULC S536 5.7.7.1	Replace	T/M	<input type="checkbox"/>	<input type="checkbox"/>	
<b>Location:</b> 8th corridor by south stair GA key <b>Note:</b>								
57019729	2099-9288C	Supporting Field Device	Failed Operation CAN/ULC S536 5.7.7.1	Replace	T/M	<input type="checkbox"/>	<input type="checkbox"/>	
<b>Location:</b> Penthouse mechanical/fan room GA key <b>Note:</b>								
<b>Phone Station</b>								
59582763	2084-9103-C		Inaccessible	Phone Station Door DNO	T/M	<input type="checkbox"/>	<input type="checkbox"/>	
<b>Location:</b> Basement corridor by stair 1 door plaque 0ST1 <b>Note:</b>								
59582735	2084-9103-C		Inaccessible	Phone Station Door DNO	T/M	<input type="checkbox"/>	<input type="checkbox"/>	

Scan Number	Model	Type/Size	Discrepancy	Solution	Cost	A P P R O V E D	F I X E D	Date Corrected and Passed Retest
<b>Phone Station</b>								
<b>Location:</b> Basement corridor by stair 2 door plaque 0ST2 <b>Note:</b>								
62118590	2084-9103-C		Inaccessible	Phone Station Door DNO	T/M	<input type="checkbox"/>	<input type="checkbox"/>	
<b>Location:</b> 1st corridor south exit east <b>Note:</b>								
62118609	2084-9103-C		Inaccessible	Phone Station Door DNO	T/M	<input type="checkbox"/>	<input type="checkbox"/>	
<b>Location:</b> 1st front lobby <b>Note:</b>								
62118596	2084-9103-C		Inaccessible	Phone Station Door DNO	T/M	<input type="checkbox"/>	<input type="checkbox"/>	
<b>Location:</b> 1st rear turnstile lobby <b>Note:</b>								
62118639	2084-9103-C		Inaccessible	Phone Station Door DNO	T/M	<input type="checkbox"/>	<input type="checkbox"/>	
<b>Location:</b> 2nd common corridor by men's washroom door plaque 206 <b>Note:</b>								
62118650	2084-9103-C		Inaccessible	Phone Station Door DNO	T/M	<input type="checkbox"/>	<input type="checkbox"/>	
<b>Location:</b> 2nd common corridor by women's washroom door plaque 209 <b>Note:</b>								
62118664	2084-9103-C		Inaccessible	Phone Station Door DNO	T/M	<input type="checkbox"/>	<input type="checkbox"/>	
<b>Location:</b> 3rd common corridor by men's washroom door plaque 306 <b>Note:</b>								
62118684	2084-9103-C		Inaccessible	Phone Station Door DNO	T/M	<input type="checkbox"/>	<input type="checkbox"/>	
<b>Location:</b> 3rd common corridor by women's washroom door plaque 309 <b>Note:</b>								
62118723	2084-9103-C		Inaccessible	Phone Station Door DNO	T/M	<input type="checkbox"/>	<input type="checkbox"/>	
<b>Location:</b> 4th common corridor by men's washroom door plaque 406 <b>Note:</b>								
62118736	2084-9103-C		Inaccessible	Phone Station Door DNO	T/M	<input type="checkbox"/>	<input type="checkbox"/>	
<b>Location:</b> 4th common corridor by women's washroom door plaque 409 <b>Note:</b>								
62118771	2084-9103-C		Inaccessible	Phone Station Door DNO	T/M	<input type="checkbox"/>	<input type="checkbox"/>	

Scan Number	Model	Type/Size	Discrepancy	Solution	Cost	A P P R O V E D	F I X E D	Date Corrected and Passed Retest
<b>Phone Station</b>								
<b>Location:</b> 5th common corridor by men's washroom door <b>Note:</b> plaque 506								
62118781	2084-9103-C		Inaccessible	Phone Station Door DNO	T/M	<input type="checkbox"/>	<input type="checkbox"/>	
<b>Location:</b> 5th common corridor by women's washroom door <b>Note:</b> plaque 509								
62118799	2084-9103-C		Inaccessible	Phone Station Door DNO	T/M	<input type="checkbox"/>	<input type="checkbox"/>	
<b>Location:</b> 6th common corridor by men's washroom door <b>Note:</b> plaque 607								
62118787	2084-9103-C		Damaged/Worn CAN/ULC S536 5.7.1.1		T/M	<input type="checkbox"/>	<input type="checkbox"/>	
<b>Location:</b> 6th common corridor by women's washroom door <b>Note:</b> Glass broken on phone station plaque 609								
57019850	2084-9103-C		Defective CAN/ULC S536 5.7.10.1	Phone Station Door DNO	T/M	<input type="checkbox"/>	<input type="checkbox"/>	
<b>Location:</b> 7th corridor by men's washroom door plaque 706 <b>Note:</b>								
57019834	2084-9103-C		Inaccessible	Phone Station Door DNO	T/M	<input type="checkbox"/>	<input type="checkbox"/>	
<b>Location:</b> 7th corridor by women's washroom door plaque 709 <b>Note:</b>								
57019770	2084-9103-C		Inaccessible	Phone Station Door DNO	T/M	<input type="checkbox"/>	<input type="checkbox"/>	
<b>Location:</b> 9th corridor by men's washroom <b>Note:</b>								
57019744	2084-9103-C		Inaccessible	Phone Station Door DNO	T/M	<input type="checkbox"/>	<input type="checkbox"/>	
<b>Location:</b> 9th corridor by women's washroom <b>Note:</b>								
57019691	2084-9103-C		Door Locked CAN/ULC S536 5.7.10.1	Investigate	T/M	<input type="checkbox"/>	<input type="checkbox"/>	
<b>Location:</b> Penthouse corridor by north stairwell <b>Note:</b>								
<b>Pull Station</b>								
59582755	2099-9288C	Dual Action	Inaccessible CAN/ULC S536 5.7.1.3		T/M	<input type="checkbox"/>	<input type="checkbox"/>	



Scan Number	Model	Type/Size	Discrepancy	Solution	Cost	A P P R O V E D	F I X E D	Date Corrected and Passed Retest
<b>Pull Station</b>								
<b>Location:</b> Basement fitness room women's locker room door <b>Note:</b> plaque 026								
62118652	2099-9288C	Dual Action	Failed Annunciation CAN/ULC S536 5.7.2.1		T/M	<input type="checkbox"/>	<input type="checkbox"/>	
<b>Location:</b> 2nd corridor exit south door plaque 2ST2 <b>Note:</b> Comes in as trouble on the panel. Pull station goes into alarm when reset.								
62118613	2099-9288C	Dual Action	Failed Test CAN/ULC S536 5.7.2.1		T/M	<input type="checkbox"/>	<input type="checkbox"/>	
<b>Location:</b> 2nd office south door plaque 203 <b>Note:</b> Comes in as trouble. Goes into alarm when pull station is reset.								
57019854	2099-9288C	Dual Action	Failed Annunciation CAN/ULC S536 5.7.2.1		T/M	<input type="checkbox"/>	<input type="checkbox"/>	
<b>Location:</b> 7th stairwell north door plaque 7ST1A <b>Note:</b> Comes in as smoke detector.								
57019831	2099-9288C	Dual Action	Failed Annunciation CAN/ULC S536 5.7.2.1		T/M	<input type="checkbox"/>	<input type="checkbox"/>	
<b>Location:</b> 7th stairwell south door plaque 7ST2A <b>Note:</b> Comes in as smoke detector.								
57019869	2099-9288C	Dual Action	Failed Annunciation CAN/ULC S536 5.7.2.1		T/M	<input type="checkbox"/>	<input type="checkbox"/>	
<b>Location:</b> 7th top of mid stairwell north <b>Note:</b> Pull station comes in as smoke detector.								
57019865	2099-9288C	Dual Action	Failed Annunciation CAN/ULC S536 5.7.2.1		T/M	<input type="checkbox"/>	<input type="checkbox"/>	
<b>Location:</b> 7th top of mid stairwell south <b>Note:</b> Comes in as smoke detector								
<b>Smoke Detector</b>								
58612466	4098-9601	Photoelectric	Failed Test CAN/ULC S536 5.7.4.1.2	Replace	T/M	<input type="checkbox"/>	<input type="checkbox"/>	
<b>Location:</b> 4th comp. & comm. room ceiling, s/w by tanks Z-1 <b>Note:</b>								

Scan Number	Model	Type/Size	Discrepancy	Solution	Cost	A P P R O V E D	F I X E D	Date Corrected and Passed Retest
<b>Speaker</b>								
58610031	2902-9312		Special Note CAN/ULC S536 5.7.9.1	Not Connected	T/M	<input type="checkbox"/>	<input type="checkbox"/>	
<b>Location:</b> 8th Toronto paramedic room S/E			<b>Note:</b> Not connected to system - x written on device					
58610023	2902-9312		Special Note CAN/ULC S536 5.7.9.1	Not Connected	T/M	<input type="checkbox"/>	<input type="checkbox"/>	
<b>Location:</b> 8th fitness room south			<b>Note:</b> Not connected to system - x written on device					
58610043	2902-9312		Special Note CAN/ULC S536 5.7.9.1	Not Connected	T/M	<input type="checkbox"/>	<input type="checkbox"/>	
<b>Location:</b> 8th inside women locker room north			<b>Note:</b> Not connected to system - x written on device					
58610044	2902-9312		Special Note CAN/ULC S536 5.7.9.1	Not Connected	T/M	<input type="checkbox"/>	<input type="checkbox"/>	
<b>Location:</b> 8th inside women locker room south			<b>Note:</b>					
58610026	2902-9312		Special Note CAN/ULC S536 5.7.9.1	Not Connected	T/M	<input type="checkbox"/>	<input type="checkbox"/>	
<b>Location:</b> 8th lunch room south			<b>Note:</b> Not connected to system - x written on device					
58610020	2902-9312		Special Note CAN/ULC S536 5.7.9.1	Not Connected	T/M	<input type="checkbox"/>	<input type="checkbox"/>	
<b>Location:</b> 8th male locker rm north			<b>Note:</b> Not connected to system - x written on device					
58610021	2902-9312		Special Note CAN/ULC S536 5.7.9.1	Not Connected	T/M	<input type="checkbox"/>	<input type="checkbox"/>	
<b>Location:</b> 8th male locker rm south			<b>Note:</b> Not connected to system - x written on device					

Total Cost (excluding taxes): T/M

PO #: (none)

# Notes & Recommendations

Generated by: *BuildingReports.com*

## Building: Communication, Traffic, & Computer Centre

*The Notes & Recommendations Report details notes made by the technician during the course of the building inspection for passed devices and the inspection as a whole.*

### General Note

#### ANNUAL 2023

- Elevators not scheduled for testing devices in shaft / pit and for testing elevator recall
- Generator Tech not scheduled for testing
- Recommend Replacing fire alarm system
- full investigation required
- COT FLS replacing batteries throughout annual - batteries subject to change on report - battery testing required
- Each Node Main panels require bigger batteries - failed battery calculations
- Unable to test phone stations - doors locked - return required
- Recommend Replacing Node 5 Panel
- Removing battery leads from node 5 with AC power on shut down node 5 panel - did not annunciate to main panel that it was shut down and not operating
- node 5 panel died / failed during full load test
- node 5 charger issues (not charging) when batteries were replaced
- replaced node 5 main panel 2x 12v34ah batteries during annual
- Node 5 system pseudo status Trouble on main panel after speaker testing
- node 5 VTG Supervision Tone Not Active after speaker testing - warm start to clear panel
- investigation required for node 5
- throughout annual "common trouble point for node 3" latching on main panel LED Showing "Normal", trouble visual indicator stays on - warm start to clear LED
- Node 1 Main panel FM bypass trouble "normal" latches on LED and keeps reinitiating trouble signals - warm start to clear panel
- pull stations in stairwells annunciate as "smoke detector"
- when testing pull stations on 2nd floor - activating pull stations caused a trouble on the panel - resetting pull stations caused an alarm on panel
- Alert switch operates as evac tone and evac switch operates as alert tone - investigation / programming required
- 9th floor speakers disconnected and replaced with strobes per COT FLS and confirmed during full load - removed from fire scan
- Recommend Simplex technicians Investigate issues and reprogram

Building: Communication, Traffic, & Computer Centre			Control Panel: 4 - SimplexGrinnell 4100	
Note	Device Type	Location	Comment	ScanID
<b>Initiating</b>				
2	Smoke Detector	7th main computer room 724D under, middle row, centre	Passed	59582814
	Unable to test for sensitivity, smoke installed facing floor			
3	Smoke Detector	7th main computer room 724D under, middle row, centre	Passed	59582815
	Unable to test for sensitivity, smoke installed facing floor			
4	Smoke Detector	7th main computer room 724D under, middle row, east	Passed	59582816
	Unable to test for sensitivity, smoke installed facing floor			
5	Smoke Detector	7th main computer room 724D under, middle row, east	Passed	59582817
	Unable to test for sensitivity, smoke installed facing floor			
6	Smoke Detector	7th main computer room 724D under, middle row, east	Passed	59582818
	Unable to test for sensitivity, smoke installed facing floor			
7	Smoke Detector	7th main computer room 724D under, middle row, west	Passed	59582811
	Unable to test for sensitivity, smoke installed facing floor			
8	Smoke Detector	7th main computer room 724D under, middle row, west	Passed	59582812
	Unable to test for sensitivity, smoke installed facing floor			
9	Smoke Detector	7th main computer room 724D under, middle row, west	Passed	59582813
	Unable to test for sensitivity, smoke installed facing floor			
10	Smoke Detector	7th main computer room 724D under, north row, centre	Passed	59582822
	Unable to test for sensitivity, smoke installed facing floor			
11	Smoke Detector	7th main computer room 724D under, north row, centre	Passed	59582823
	Unable to test for sensitivity, smoke installed facing floor			
12	Smoke Detector	7th main computer room 724D under, north row, east	Passed	59582819
	Unable to test for sensitivity, smoke installed facing floor			
13	Smoke Detector	7th main computer room 724D under, north row, east	Passed	59582820
	Unable to test for sensitivity, smoke installed facing floor			
14	Smoke Detector	7th main computer room 724D under, north row, east	Passed	59582821
	Unable to test for sensitivity, smoke installed facing floor			
15	Smoke Detector	7th main computer room 724D under, north row, west	Passed	59582824
	Unable to test for sensitivity, smoke installed facing floor			
16	Smoke Detector	7th main computer room 724D under, north row, west	Passed	59582825

Note	Device Type	Location	Comment	ScanID
	Unable to test for sensitivity, smoke installed facing floor			
17	Smoke Detector	7th main computer room 724D under, north row, west	Passed	59582826
	Unable to test for sensitivity, smoke installed facing floor			
18	Smoke Detector	7th main computer room 724D under, south row, centre	Passed	59582808
	Unable to test for sensitivity, smoke installed facing floor			
19	Smoke Detector	7th main computer room 724D under, south row, centre	Passed	59582809
	Unable to test for sensitivity, smoke installed facing floor			
20	Smoke Detector	7th main computer room 724D under, south row, east	Passed	59582805
	Unable to test for sensitivity, smoke installed facing floor			
21	Smoke Detector	7th main computer room 724D under, south row, east	Passed	59582806
	Unable to test for sensitivity, smoke installed facing floor			
22	Smoke Detector	7th main computer room 724D under, south row, east	Passed	59582807
	Unable to test for sensitivity, smoke installed facing floor			
23	Smoke Detector	7th main computer room 724D under, south row, west	Passed	59582810
	Unable to test for sensitivity, smoke installed facing floor			

# Individual Device Record

Generated by: BuildingReports.com

**Type of Inspection:** Fire Alarm System Annual Inspection and Test (ULC S536-04) and Smoke Alarms Inspection and Test(CAN/ULC-S552-02)

**Building Name:** Communication, Traffic, & Computer Centre

**Inspection Date and Time:** 1/16/23 8:14:47 AM

**Inspector:** Joseph Bryant

**Note:** The Location Column includes the location, time and date of the inspection and barcode number.

Remarks Column: Detector sensitivity in percentage and Waterflow Switch time delay in seconds.

For specific output circuit operation confirmation see associated BRForm section - "Ancillary Function Testing"

Location	Device Type	Correctly Installed	Requires Service, Repairs, Cleaning or Missing	Alarm Operation Confirmed	Annunciation Indication Confirmed	Zone Circuit Number or Address	Supervision of Wiring Device Confirmed	Ground Circuit Confirmed	Remarks/ Readings
<i>Tested</i>									
Basement Elevator Lobby, 9:09:38AM 01/13/2023 (67060227)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-19-2634	<input type="checkbox"/>	<input type="checkbox"/>	2.5%, LTD 01/13/2023
Basement Electrical Room, 10:04:04AM 01/13/2023 (67060228)	Fault Isolation Module	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1-Basement Floor out	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/13/2023
Basement Electrical Room, 10:04:08AM 01/13/2023 (67060229)	Fault Isolation Module	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1-Basement Floor in	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/13/2023
Basement Inside Telephone Room 021, 8:06:57PM 01/11/2023 (67060226)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11/2023
Basement corridor by stair 1 GA key, 9:14:30AM 01/13/2023 (59582764)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-GA 19-3020	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/13/2023
Basement corridor by stair 2 GA key, 9:10:51AM 01/13/2023 (59582736)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-GA 19-3020	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/13/2023
Basement outside Telephone Room 021, 8:06:51PM 01/11/2023 (67060225)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11/2023
Basement women's washroom, 8:04:35PM 01/11/2023 (59582734)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11/2023
Basement Network Comm. room 34/35 Zone 1, first stage FM-200 system, 9:10:03AM 01/06/2023 (57019968)	Programmable Relay	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/06/2023
Basement Network Comm. room 34/35 Zone 2, second stage FM-200 system, 9:09:59AM 01/06/2023 (57019969)	Programmable Relay	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/06/2023

Location	Device Type	Correctly Installed	Requires Service, Repairs, Cleaning or Missing	Alarm Operation Confirmed	Annunciation Indication Confirmed	Zone Circuit Number or Address	Supervision of Wiring Device Confirmed	Ground Circuit Confirmed	Remarks/ Readings
Basement Telephone room 33 Damper FM-200 system, 9:57:58AM 01/06/2023 (57019989)	Programmable Relay	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/06 /2023
Basement Telephone room 33 Zone 1, first stage FM-200 system, 9:09:44AM 01/06/2023 (57019987)	Programmable Relay	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/06 /2023
Basement Telephone room 33 Zone 2, second stage FM-200 system, 9:09:41AM 01/06/2023 (57019988)	Programmable Relay	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/06 /2023
Basement corridor Network Comm. room 34/35 Alarm FM-200 system, 9:10:07AM 01/06/2023 (57019965)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/06 /2023
Basement Network Communication Room 1 Novec System Panel , Zone 1 Active, 9:48:10AM 01/13/2023 (68832582)	Programmable Relay	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-M32 19-2650	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/13 /2023
Basement Network Communication Room 1 Novec System Panel , Zone 2 Active, 9:48:07AM 01/13/2023 (68832581)	Programmable Relay	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-M33 19-2650	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/13 /2023
Basement Network Communication Room 2 Novec System Panel Alarm, 9:48:13AM 01/13/2023 (68832583)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-M34 19-2650	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/13 /2023
Basement Network Communication Room 2 Novec System Panel trouble, 9:48:15AM 01/13/2023 (68832588)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-M35 19-2649	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/13 /2023
Basement corridor mechanical room 032 Zone 1 Pre action zone 1 Active alarm, 10:00:29AM 01/06/2023 (64248326)	Programmable Relay	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-M24	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/06 /2023
Basement corridor mechanical room 032 Pre action zone 2 Active alarm, 10:00:17AM 01/06/2023 (64248323)	Programmable Relay	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-M27	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/06 /2023
Basement corridor mechanical room 032 Trouble Pre action 1/2/33 system, 10:00:12AM 01/06/2023 (64248322)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-2 19-2651	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/06 /2023
Basement corridor mechanical room 032 Alarm Pre action 21 system, 10:00:22AM 01/06/2023 (64248324)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-19-2655	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/06 /2023
Basement corridor mechanical room 032 Trouble Pre action 21 system, 10:00:25AM 01/06/2023 (64248325)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-1 19-2654	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/06 /2023
Basement Custodial Services Storage Room Tel Room #21 , Novec System Panel Alarm, 10:29:09AM 01/06/2023 (68832575)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-M22 19-2658	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/06 /2023
Basement Custodial Services Storage Room Tel Room #21 , Novec System Panel Trouble, 10:29:04AM 01/06/2023 (68832577)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-M23 19-2657	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/06 /2023
Basement Custodial Services Storage Room Telephone Room #21 , Novec System Panel , Zone 1 Active, 10:28:55AM 01/06/2023 ( 68832574)	Programmable Relay	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-M20	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/06 /2023
Basement Custodial Services Storage Room Telephone Room #21 , Novec System Panel , Zone 2 Active, 10:28:59AM 01/06/2023 ( 68832576)	Programmable Relay	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-M21	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/06 /2023
Basement electrical room door plaque 005, 10:04:16AM 01/13/2023 (59582731)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-SIG CCT B 19-3040	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/13 /2023
Basement electrical room door plaque 005, 10:04:20AM 01/13/2023 (59582732)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-SIG CCT A 19-3041	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/13 /2023
Basement electrical room 020 034 door plaque 005 , Smoke Rm	End Of Line					1-57 19-			LTD 01/13

Location	Device Type	Correctly Installed	Requires Service, Repairs, Cleaning or Missing	Alarm Operation Confirmed	Annunciation Indication Confirmed	Zone Circuit Number or Address	Supervision of Wiring Device Confirmed	Ground Circuit Confirmed	Remarks/ Readings
20, N32, 10:04:23AM 01/13/2023 (59582733)		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2975	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	/2023
Basement electrical room door plaque 005 , rm Elevator Pit Zone, 10:04:12AM 01/13/2023 (59582730)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-17 19-3015	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/13 /2023
Basement corridor by elevator pit door plaque 006, 8:00:42PM 01/11 /2023 (59582775)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
Basement corridor by janitor room door plaque 007, 8:01:29PM 01 /11/2023 (59582769)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
Basement corridor by men's washroom door plaque 008, 8:01: 53PM 01/11/2023 (59582761)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
Basement men's washroom door plaque 008, 8:01:42PM 01/11 /2023 (59582762)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
Basement corridor by facility mgmt men's locker room door plaque 012, 8:04:25PM 01/11/2023 (59582739)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
Basement facility mgmt men's locker room door plaque 012, 8:04: 17PM 01/11/2023 (59582738)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
Basement corridor by facility mgmt women's locker room door plaque 013, 8:04:56PM 01/11/2023 (59582729)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
Basement corridor by facility mgmt women's locker room door plaque 013, 8:05:03PM 01/11/2023 (59582728)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
Basement building operations workshop door plaque 018, 8:06: 54PM 01/11/2023 (59582773)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
Basement corridor by mechanical room door plaque 020, 8:01: 08PM 01/11/2023 (59582774)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
Basement hydro vault door plaque 021, 8:06:48PM 01/11/2023 ( 59582772)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
Basement building storage column far side door plaque 023, 8:06: 41PM 01/11/2023 (59582770)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
Basement building storage column near side door plaque 023, 8:06: 44PM 01/11/2023 (59582771)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
Basement fitness room door plaque 024, 8:05:44PM 01/11/2023 ( 59582758)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
Basement fitness room door plaque 024, 9:12:31AM 01/13/2023 ( 59582760)	Pull Station	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-9 19-3023	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/13 /2023
Basement fitness room GA key door plaque 024, 9:12:39AM 01/13 /2023 (59582759)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-GA 19-3020	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/13 /2023
Basement fitness room women's change room door plaque 026, 8: 06:23PM 01/11/2023 (59582756)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
Basement fitness room men's change room door plaque 027, 8:05: 54PM 01/11/2023 (59582757)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
Basement Mechanical Room door plaque 032, 8:07:01PM 01/11 /2023 (67060230)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023



Location	Device Type	Correctly Installed	Requires Service, Repairs, Cleaning or Missing	Alarm Operation Confirmed	Annunciation Indication Confirmed	Zone Circuit Number or Address	Supervision of Wiring Device Confirmed	Ground Circuit Confirmed	Remarks/ Readings
Basement corridor by telephone room 33 door plaque 033, 8:02:14PM 01/11/2023 (59582752)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
Basement corridor by network comm. room 1 door plaque 034, 8:02:07PM 01/11/2023 (59582753)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
Basement corridor by network comm. room 2 door plaque 035, 8:02:31PM 01/11/2023 (59582751)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
Basement corridor by mech/fire pump room door plaque 037, 8:02:39PM 01/11/2023 (59582750)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
Basement mech/fire pump room door plaque 037, 8:06:38PM 01/11 /2023 (59582749)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
Basement transportation storage door plaque 040, 8:06:34PM 01/11 /2023 (59582746)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
Basement transportation storage inner door plaque 041, 8:06:31PM 01/11/2023 (59582745)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
Basement corridor by custodial lunch room door plaque 043, 8:02:50PM 01/11/2023 (59582748)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
Basement custodial lunch room door plaque 043, 8:02:57PM 01/11 /2023 (59582747)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
Basement shipping & receiving far side door plaque 044, 8:03:32PM 01/11/2023 (59582743)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
Basement shipping & receiving near side door plaque 044, 8:03:29PM 01/11/2023 (59582744)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
Basement shipping & receiving ramp door plaque 047, 8:03:51PM 01/11/2023 (59582742)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
Basement shipping & receiving ramp door plaque 047, 9:11:26AM 01/13/2023 (59582741)	Pull Station	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-9 19-3023	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/13 /2023
Basement shipping & receiving ramp GA key door plaque 047, 9:11:43AM 01/13/2023 (59582740)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-GA 19-3020	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/13 /2023
Basement corridor by stair 1 door plaque OST1, 10:19:18AM 01/13 /2023 (59582766)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-9 19-3023	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/13 /2023
Basement corridor by stair 1 door plaque OST1, 10:19:11AM 01/13 /2023 (59582768)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-12 19-3020	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/13 /2023
Basement corridor by stair 1 door plaque OST1, 10:19:15AM 01/13 /2023 (59582767)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-19-3034	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/13 /2023
Basement corridor exit to stair 1 door plaque OST1, 9:14:25AM 01 /13/2023 (59582765)	Pull Station	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-9 19-3023	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/13 /2023
Basement corridor exit to stair 2 door plaque OST2, 9:10:24AM 01 /13/2023 (59582737)	Pull Station	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-9 19-3023	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/13 /2023
1st Elevator Lobby, 9:15:30AM 01/13/2023 (67060231)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-10 19-2633	<input type="checkbox"/>	<input type="checkbox"/>	2.5%, LTD 01/13/2023
1st corridor north, 9:27:17AM 01/13/2023 (62118602)	Pull Station					1-10 19-			LTD 01/13

Location	Device Type	Correctly Installed	Requires Service, Repairs, Cleaning or Missing	Alarm Operation Confirmed	Annunciation Indication Confirmed	Zone Circuit Number or Address	Supervision of Wiring Device Confirmed	Ground Circuit Confirmed	Remarks/ Readings
1st corridor north GA key, 9:27:23AM 01/13/2023 (62118601)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	3028	<input type="checkbox"/>	<input type="checkbox"/>	/2023
1st corridor south GA key, 9:18:24AM 01/13/2023 (62118591)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-GA 19-3024	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/13 /2023
1st corridor south exit east, 9:17:59AM 01/13/2023 (62118592)	Pull Station	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-10 19-3028	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/13 /2023
1st elevator lobby, 9:28:41AM 01/13/2023 (62118608)	Pull Station	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-10 19-3028	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/13 /2023
1st elevator lobby GA key, 9:28:47AM 01/13/2023 (62118607)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-GA 19-3024	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/13 /2023
1st elevator lobby north, 7:59:00PM 01/11/2023 (62118605)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
1st elevator lobby south, 7:55:29PM 01/11/2023 (62118578)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
1st front lobby, 9:29:15AM 01/13/2023 (62118611)	Pull Station	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-10 19-3028	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/13 /2023
1st front lobby GA key, 9:29:20AM 01/13/2023 (62118610)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-GA 19-3024	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/13 /2023
1st men's washroom, 7:58:00PM 01/11/2023 (62118576)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
1st north office GA key, 9:28:01AM 01/13/2023 (59582776)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-GA 19-3024	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/13 /2023
1st north office paper copy room, 7:59:12PM 01/11/2023 (59582778)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
1st north office paper copy room exit, 9:27:49AM 01/13/2023 (59582777)	Pull Station	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-10 19-3028	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/13 /2023
1st north/west board room, 8:00:01PM 01/11/2023 (62118606)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
1st rear lobby, 7:57:50PM 01/11/2023 (62118600)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
1st rear turnstile lobby, 9:18:53AM 01/13/2023 (62118598)	Pull Station	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-10 19-3028	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/13 /2023
1st rear turnstile lobby GA key, 9:18:58AM 01/13/2023 (62118597)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-GA 19-3024	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/13 /2023
1st rear vestibule, 9:19:52AM 01/13/2023 (62118595)	Pull Station	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-10 19-3028	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/13 /2023
1st rear vestibule GA key, 9:19:58AM 01/13/2023 (62118594)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-GA 19-3024	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/13 /2023
1st security control office, 9:44:51AM 01/13/2023 (62118553)	Strobe	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/13 /2023

Location	Device Type	Correctly Installed	Requires Service, Repairs, Cleaning or Missing	Alarm Operation Confirmed	Annunciation Indication Confirmed	Zone Circuit Number or Address	Supervision of Wiring Device Confirmed	Ground Circuit Confirmed	Remarks/ Readings
1st security control office GA key, 9:22:03AM 01/13/2023 (62118560 )	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-GA 19-3024	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/13 /2023
1st security control office GA key, 9:23:01AM 01/13/2023 (62118555 )	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-GA 19-3024	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/13 /2023
1st security control office GA key, 9:23:50AM 01/13/2023 (62118557 )	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-GA 19-3024	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/13 /2023
1st security control office centre, 9:34:14AM 01/13/2023 (62118554)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-10 2973	<input type="checkbox"/>	<input type="checkbox"/>	2.5%, LTD 01/13/2023
1st security control office exit to lobby, 9:22:53AM 01/13/2023 ( 62118556)	Pull Station	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-10 19-2974	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/13 /2023
1st security control office exit to vestibule, 9:23:42AM 01/13/2023 ( 62118558)	Pull Station	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-10 19-2974	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/13 /2023
1st security control office lobby, 9:24:48AM 01/13/2023 (62118562)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-10	<input type="checkbox"/>	<input type="checkbox"/>	2.5%, LTD 01/13/2023
1st security control office manager office, 7:59:42PM 01/11/2023 ( 62118564)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
1st security control office vestibule, 9:21:55AM 01/13/2023 ( 62118561)	Pull Station	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-10 19-2974	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/13 /2023
1st security control office vestibule, 9:34:17AM 01/13/2023 ( 62118559)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-10	<input type="checkbox"/>	<input type="checkbox"/>	2.5%, LTD 01/13/2023
1st security control office washroom, 9:42:36AM 01/13/2023 ( 62118551)	Heat Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-10 19-2974	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/13 /2023
1st security deck at front entrance, 10:30:49AM 01/13/2023 ( 73397730)	Battery	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	1	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/13 /2023
1st security deck at front entrance, 6:27:52PM 01/10/2023 ( 57019684)	Handset	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/10 /2023
1st security deck at front entrance, 6:28:16PM 01/10/2023 ( 57019682)	Monitoring	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/10 /2023
1st security deck at front entrance, 6:27:57PM 01/10/2023 ( 57019685)	Phone Station	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/10 /2023
1st security deck at front entrance, 9:25:27AM 01/13/2023 ( 73397732)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/13 /2023
1st south office GA key, 9:16:57AM 01/13/2023 (62118571)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-GA 19-3024	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/13 /2023
1st south office centre aisle east, 7:59:45PM 01/11/2023 (62118567)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
1st south office centre aisle west, 7:59:48PM 01/11/2023 (62118568 )	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
1st south office exit to lobby, 9:17:09AM 01/13/2023 (62118572)	Pull Station	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-10 19-3028	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/13 /2023
1st stairwell north, 7:59:58PM 01/11/2023 (62118599)	Speaker					1-SIG			LTD 01/11

Location	Device Type	Correctly Installed	Requires Service, Repairs, Cleaning or Missing	Alarm Operation Confirmed	Annunciation Indication Confirmed	Zone Circuit Number or Address	Supervision of Wiring Device Confirmed	Ground Circuit Confirmed	Remarks/ Readings
1st stairwell south, 7:59:52PM 01/11/2023 (62118577)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	/2023
1st women's washroom, 7:58:18PM 01/11/2023 (62118575)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
1st security control office By Lockers, 7:59:38PM 01/11/2023 (62118563)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
1st north office N/E, 7:59:19PM 01/11/2023 (59582780)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
1st north office N/W, 7:59:29PM 01/11/2023 (59582783)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
1st north office N/centre, 7:59:26PM 01/11/2023 (59582782)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
1st north office S/E, 7:59:15PM 01/11/2023 (59582779)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
1st north office S/W, 7:59:32PM 01/11/2023 (59582784)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
1st north office S/centre, 7:59:22PM 01/11/2023 (59582781)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
1st corridor south by door plaque 108B, 7:57:38PM 01/11/2023 (62118593)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
1st corridor south by door plaque 111, 7:59:55PM 01/11/2023 (62118588)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
1st corridor north by door plaque 112, 7:58:52PM 01/11/2023 (62118604)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
1st south office by door plaque 139, 7:56:55PM 01/11/2023 (62118565)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
1st south office by door plaque 141, 7:56:47PM 01/11/2023 (62118566)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
1st south office by door plaque 143, 7:55:57PM 01/11/2023 (62118569)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
1st south office by door plaque 146, 7:55:48PM 01/11/2023 (62118570)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
1st corridor south by door plaque 1ST2, 7:57:27PM 01/11/2023 (62118589)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
1st corridor north by panel RP-1-B, 7:58:43PM 01/11/2023 (62118603)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
1st electrical room door plaque 111, 11:45:51AM 01/12/2023 (62118579)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-Stair#2 SIG B 19 /2800	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/12 /2023
1st electrical room door plaque 111, 11:45:54AM 01/12/2023 (	End Of Line					1-Stair#1			LTD 01/12

Location	Device Type	Correctly Installed	Requires Service, Repairs, Cleaning or Missing	Alarm Operation Confirmed	Annunciation Indication Confirmed	Zone Circuit Number or Address	Supervision of Wiring Device Confirmed	Ground Circuit Confirmed	Remarks/ Readings
62118580)		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	SIG B 19 /2801	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	/2023
1st electrical room RP-1-EA CCT#19 door plaque 111, 5:53:42PM 01/10/2023 (62118584)	Disconnect	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/10 /2023
1st janitor room door plaque 112, 11:35:02AM 01/12/2023 ( 62118574)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-Stair#2 SIG A 19 /2802	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/12 /2023
1st janitor room door plaque 112, 11:35:06AM 01/12/2023 ( 62118573)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-Stair#1 SIG A 19 /2803	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/12 /2023
1st north office door plaque 127, 7:59:34PM 01/11/2023 (59582785)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
2nd office east, 7:50:18PM 01/11/2023 (62118631)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
2nd office east cubicles, 7:50:40PM 01/11/2023 (62118632)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
2nd office north/east corner, 7:54:34PM 01/11/2023 (62118630)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
2nd office south cubicles, 7:51:44PM 01/11/2023 (62118617)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
2nd office south cubicles, 7:51:52PM 01/11/2023 (62118616)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
2nd office south cubicles, 7:52:12PM 01/11/2023 (62118619)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
2nd office south cubicles, 7:52:23PM 01/11/2023 (62118618)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
2nd office south/east corner, 7:51:16PM 01/11/2023 (62118615)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
2nd office south/east cubicles, 7:51:01PM 01/11/2023 (62118614)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
2nd office south/west corner, 7:52:45PM 01/11/2023 (62118620)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
2nd office south/west cubicles, 7:53:08PM 01/11/2023 (62118621)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
2nd corridor north by door plaque 202, 11:22:38AM 01/12/2023 ( 62118643)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-GA 19 /3008	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/12 /2023
2nd corridor north by door plaque 202, 11:22:36AM 01/12/2023 ( 62118642)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-9 19/3037	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/12 /2023
2nd corridor north by door plaque 202, 11:25:09AM 01/12/2023 ( 62118638)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-2nd floor phon 19 /3033	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/12 /2023

Location	Device Type	Correctly Installed	Requires Service, Repairs, Cleaning or Missing	Alarm Operation Confirmed	Annunciation Indication Confirmed	Zone Circuit Number or Address	Supervision of Wiring Device Confirmed	Ground Circuit Confirmed	Remarks/ Readings
2nd office north by door plaque 202, 7:50:08PM 01/11/2023 ( 62118633)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
2nd corridor south by door plaque 203, 7:54:15PM 01/11/2023 ( 62118653)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
2nd elevator lobby north by door plaque 210A, 7:54:38PM 01/11 /2023 (62118644)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
2nd office north/west corner by door plaque 213, 7:54:22PM 01/11 /2023 (62118624)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
2nd office north/west corner by door plaque 218B, 7:54:25PM 01/11 /2023 (62118625)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
2nd office north by door plaque 221, 7:54:28PM 01/11/2023 ( 62118628)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
2nd office north by door plaque 224, 7:54:31PM 01/11/2023 ( 62118629)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
2nd elevator lobby south by door plaque 240, 7:53:39PM 01/11 /2023 (62118645)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
2nd corridor north by door plaque 2ST1, 7:49:44PM 01/11/2023 ( 62118637)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
2nd corridor south by door plaque 2ST2, 7:53:49PM 01/11/2023 ( 62118649)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
2nd office north door plaque 202, 9:32:08AM 01/13/2023 (62118635 )	Pull Station	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-1 19-3037	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/13 /2023
2nd office north GA key door plaque 202, 9:32:03AM 01/13/2023 ( 62118634)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-GA 19-3008	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/13 /2023
2nd office south GA key door plaque 203, 1:08:14PM 01/09/2023 ( 62118612)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-GA 19-3008	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09 /2023
2nd electrical room door plaque 204, 11:25:53AM 01/12/2023 ( 62118647)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-SIG B 19 /3048	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/12 /2023
2nd electrical room door plaque 204, 11:25:56AM 01/12/2023 ( 62118646)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-SIG A 19 /3049	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/12 /2023
2nd men's washroom door plaque 206, 7:49:51PM 01/11/2023 ( 62118636)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
2nd women's washroom door plaque 209, 7:54:02PM 01/11/2023 ( 62118648)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
2nd office north door plaque 210A, 9:33:12AM 01/13/2023 ( 62118627)	Pull Station	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-9 19-3037	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/13 /2023
2nd office north GA key door plaque 210A, 9:33:17AM 01/13/2023 ( 62118626)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-GA 19-3008	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/13 /2023
2nd office south door plaque 240, 1:06:57PM 01/09/2023 (62118623 )	Pull Station	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-9 19-3037	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09 /2023
2nd office south GA key door plaque 240, 1:07:04PM 01/09/2023 (	Initiating Device					1-GA 19-			LTD 01/09

Location	Device Type	Correctly Installed	Requires Service, Repairs, Cleaning or Missing	Alarm Operation Confirmed	Annunciation Indication Confirmed	Zone Circuit Number or Address	Supervision of Wiring Device Confirmed	Ground Circuit Confirmed	Remarks/ Readings
62118622)		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	3008	<input type="checkbox"/>	<input type="checkbox"/>	/2023
2nd corridor exit north door plaque 2ST1, 9:31:08AM 01/13/2023 ( 62118641)	Pull Station	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-9 19-3037	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/13 /2023
2nd exit north GA key door plaque 2ST1, 9:31:01AM 01/13/2023 ( 62118640)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-GA 19-3008	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/13 /2023
2nd exit south GA key door plaque 2ST2, 1:05:45PM 01/09/2023 ( 62118651)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-GA 19-3008	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09 /2023
3rd elevator lobby, 7:49:00PM 01/11/2023 (62118659)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
3rd elevator lobby north, 1:03:30PM 01/09/2023 (62118656)	Pull Station	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-8 19-2957 /2943	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09 /2023
3rd elevator lobby south, 1:02:32PM 01/09/2023 (62118658)	Pull Station	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-8 19-2957 /2943	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09 /2023
3rd north office west corner cubicles, 7:45:25PM 01/11/2023 ( 62118669)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
3rd south office centre cubicles, 7:46:27PM 01/11/2023 (62118675)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
3rd south office centre cubicles, 7:46:34PM 01/11/2023 (62118674)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
3rd south office centre cubicles, 7:46:59PM 01/11/2023 (62118677)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
3rd south office centre cubicles, 7:48:53PM 01/11/2023 (62118676)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
3rd south office east corner cubicles, 7:47:38PM 01/11/2023 ( 62118679)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
3rd south office east corner cubicles, 7:48:50PM 01/11/2023 ( 62118678)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
3rd south office west corner cubicles, 7:46:08PM 01/11/2023 ( 62118672)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
3rd south office west corner cubicles, 7:46:16PM 01/11/2023 ( 62118673)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
3rd west office, 7:45:39PM 01/11/2023 (62118670)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
3rd west office, 7:45:54PM 01/11/2023 (62118671)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
3rd Computer Room Centre Exit, 12:25:09PM 01/12/2023 ( 67060242)	Pull Station	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-10 19-2957/2943	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/12 /2023
3rd Computer Room Above D3AB-C04, 7:48:37PM 01/11/2023 ( 67060238)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
3rd Computer Room Above D3AE-C04, 7:48:40PM 01/11/2023 ( 67060237)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023



Location	Device Type	Correctly Installed	Requires Service, Repairs, Cleaning or Missing	Alarm Operation Confirmed	Annunciation Indication Confirmed	Zone Circuit Number or Address	Supervision of Wiring Device Confirmed	Ground Circuit Confirmed	Remarks/ Readings
3rd Computer Room Above D3AX-C05, 7:48:34PM 01/11/2023 ( 73397733)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
3rd Computer Room North Exit, 12:25:05PM 01/12/2023 (67060239)	Pull Station	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-10 19-2957/2943	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/12 /2023
3rd Computer Room South Exit, 12:25:13PM 01/12/2023 (67060243 )	Pull Station	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-10 19-2957/2943	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/12 /2023
3rd south office east by door plaque 303, 7:48:43PM 01/11/2023 ( 62118688)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
3rd north corridor by door plaque 306, 7:45:02PM 01/11/2023 ( 62118667)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
3rd north office corridor by door plaque 321, 7:44:33PM 01/11/2023 (62118668)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
3rd north corridor exit to stairs by door plaque 3ST1, 1:03:52PM 01 /09/2023 (62118666)	Pull Station	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-8 19-2957 /2943	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09 /2023
3rd south office by door plaque 3ST2, 7:48:25PM 01/11/2023 ( 62118687)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
3rd south office exit to stairs by door plaque 3ST2, 1:01:36PM 01/09 /2023 (62118686)	Pull Station	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-8 19-2957 /2943	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09 /2023
3rd electrical room door plaque 304, 11:15:25AM 01/12/2023 ( 62118680)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-SIG B 19 /2969	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/12 /2023
3rd electrical room door plaque 304, 11:15:28AM 01/12/2023 ( 62118681)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-SIG A 19 /2900	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/12 /2023
3rd common corridor by men's washroom door plaque 306, 11:04: 24AM 01/12/2023 (62118662)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-GA 19- 2943	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/12 /2023
3rd common corridor by men's washroom door plaque 306, 11:04: 21AM 01/12/2023 (62118663)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-8 19-2957	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/12 /2023
3rd common corridor by men's washroom door plaque 306, 11:04: 28AM 01/12/2023 (62118661)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-3rd floor phon 19- 2914	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/12 /2023
3rd men's washroom door plaque 306, 7:44:47PM 01/11/2023 ( 62118660)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
3rd women's washroom door plaque 309, 7:48:18PM 01/11/2023 ( 62118682)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
3rd north stairwell door plaque 3ST1, 7:49:03PM 01/11/2023 ( 62118654)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
3rd south stairwell door plaque 3ST2, 7:48:47PM 01/11/2023 ( 62118683)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
4th computer & communications room Door plaque 402, 12:24: 47PM 01/12/2023 (62118718)	Pull Station	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-5 19-2962	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/12 /2023
4th common hall by men's washroom Door plaque 406, 10:58:01AM 01/12/2023 (62118721)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-GA 19- 2942	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/12 /2023



Location	Device Type	Correctly Installed	Requires Service, Repairs, Cleaning or Missing	Alarm Operation Confirmed	Annunciation Indication Confirmed	Zone Circuit Number or Address	Supervision of Wiring Device Confirmed	Ground Circuit Confirmed	Remarks/ Readings
4th common hall by men's washroom Door plaque 406, 10:58:06AM 01/12/2023 (62118720)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-7 19-2962	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/12 /2023
4th common hall by men's washroom Door plaque 406, 1:00:41PM 01/09/2023 (62118725)	Pull Station	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-5 19-2962	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09 /2023
4th common hall by men's washroom Door plaque 406, 10:57:55AM 01/12/2023 (62118722)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-4th phone CCT 19-2913	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/12 /2023
4th common hall by women's washroom Door plaque 409, 12:56:42PM 01/09/2023 (62118738)	Pull Station	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-5 19-2962	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09 /2023
4th north office Door plaque 431A, 12:59:15PM 01/09/2023 (62118691)	Pull Station	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-5 19-2962	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09 /2023
4th computer & communications room Door plaque 444B, 12:24:43PM 01/12/2023 (62118716)	Pull Station	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-7 19-2962	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/12 /2023
4th maintenance & testing lab Door plaque 448, 12:24:41PM 01/12/2023 (62118706)	Pull Station	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-5 19-2962	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/12 /2023
4th computers & communication room GA key by door plaque 402, 9:44:28AM 01/13/2023 (62118717)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-25 19-2942	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/13 /2023
4th electrical room by door plaque 404, 11:03:31AM 01/12/2023 (62118733)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-SIG B 19-2903	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/12 /2023
4th electrical room by door plaque 404, 11:03:28AM 01/12/2023 (62118734)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-SIG A 19-2904	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/12 /2023
4th common hall GA key by door plaque 406, 1:00:48PM 01/09/2023 (62118724)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-25 19-2942	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09 /2023
4th common hall GA key by door plaque 409, 9:44:24AM 01/13/2023 (62118737)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-25 19-2942	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/13 /2023
4th women's washroom by door plaque 409, 7:37:47PM 01/11/2023 (62118735)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
4th corridor by elev, south by door plaque 410A, 7:43:30PM 01/11/2023 (62118728)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
4th south office GA key by door plaque 410A, 12:58:17PM 01/09/2023 (62118698)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-25 19-2942	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09 /2023
4th south office west by door plaque 418, 7:42:45PM 01/11/2023 (62118697)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
4th west office by door plaque 425, 7:42:35PM 01/11/2023 (62118696)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
4th west office by door plaque 428, 7:42:21PM 01/11/2023 (62118695)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
4th corridor by elev, north by door plaque 431A, 7:40:57PM 01/11/2023 (62118727)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
4th north office south by door plaque 431A, 7:41:08PM 01/11/2023 (62118692)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023

Location	Device Type	Correctly Installed	Requires Service, Repairs, Cleaning or Missing	Alarm Operation Confirmed	Annunciation Indication Confirmed	Zone Circuit Number or Address	Supervision of Wiring Device Confirmed	Ground Circuit Confirmed	Remarks/ Readings
4th north office west by door plaque 431B, 7:41:57PM 01/11/2023 ( 64247948)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
4th north office west by door plaque 436, 7:41:44PM 01/11/2023 ( 62118694)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
4th north office north by door plaque 440, 7:41:33PM 01/11/2023 ( 62118693)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
4th north office east by door plaque 442, 7:41:23PM 01/11/2023 ( 62118689)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
4th computers & communication room GA key by door plaque 444B, 9:44:34AM 01/13/2023 (62118715)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-25 19-2942	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/13 /2023
4th maintenance & testing lab GA key by door plaque 448, 9:44:39AM 01/13/2023 (62118705)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-25 19-2942	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/13 /2023
4th south corridor by door plaque 448, 7:37:31PM 01/11/2023 ( 62118739)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
4th corridor north by door plaque 4ST1, 7:40:49PM 01/11/2023 ( 62118726)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
4th south corridor by door plaque 4ST2, 7:37:57PM 01/11/2023 ( 62118729)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
4th computer & communication room door plaque 402, 7:43:21PM 01/11/2023 (62118708)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
4th computer & communication room door plaque 402, 7:43:24PM 01/11/2023 (62118709)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
4th men's washroom door plaque 406, 7:40:41PM 01/11/2023 ( 62118719)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
4th south office door plaque 410A, 7:42:57PM 01/11/2023 ( 62118700)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
4th south office east cubicles door plaque 412, 7:38:37PM 01/11 /2023 (62118702)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
4th south office south cubicles door plaque 412, 7:43:09PM 01/11 /2023 (62118701)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
4th north office GA key door plaque 431A, 1:00:15PM 01/09/2023 ( 62118690)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-25 19-2942	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09 /2023
4th computer & communication room door plaque 444B, 7:43:45PM 01/11/2023 (73397740)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
4th computer & communication room door plaque 444B, 7:43:48PM 01/11/2023 (73397739)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
4th computer & communication room door plaque 444D, 7:43:18PM 01/11/2023 (62118707)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
4th computer & communication room door plaque 445D, 7:43:35PM 01/11/2023 (73397735)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
4th computer & communication room door plaque 445D, 7:43:38PM	Speaker					1-SIG			LTD 01/11

Location	Device Type	Correctly Installed	Requires Service, Repairs, Cleaning or Missing	Alarm Operation Confirmed	Annunciation Indication Confirmed	Zone Circuit Number or Address	Supervision of Wiring Device Confirmed	Ground Circuit Confirmed	Remarks/ Readings
01/11/2023 (73397737)		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	/2023
4th computer & communication room door plaque 445D, 7:43:41PM 01/11/2023 (73397738)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
4th maintenance & testing lab door plaque 448, 7:43:12PM 01/11 /2023 (62118703)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
4th maintenance & testing lab door plaque 448, 7:43:15PM 01/11 /2023 (62118704)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
5th RESCU & Active Traffic mgmt, 12:24:53PM 01/12/2023 ( 62118762)	Pull Station	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-6 19-2966	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/12 /2023
5th RESCU & Active Traffic mgmt, at ramp by Kitchen, 7:29:12PM 01/11/2023 (73397734)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
5th Traffic Signal Operations, 12:54:58PM 01/09/2023 (62118746)	Pull Station	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-6 19-2966	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09 /2023
5th Traffic, south/east office s/e cubicles, 9:48:49AM 01/13/2023 ( 62118753)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-Strobe B 19/2664	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/13 /2023
5th Traffic, south/east office s/e cubicles, 7:31:17PM 01/11/2023 ( 62118755)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
5th Traffic, south/east office s/e cubicles, 7:31:21PM 01/11/2023 ( 62118754)	Strobe	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
5th Traffic, south/west office s/w cubicles, 7:35:49PM 01/11/2023 ( 62118750)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
5th Traffic, west office south cubicles, 7:32:22PM 01/11/2023 ( 62118749)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
5th Traffic, west/north office n/w cubicles, 7:32:56PM 01/11/2023 ( 62118744)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
5th common corridor by elev, north, 7:35:03PM 01/11/2023 ( 62118775)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
5th common corridor by elev, south, 7:35:18PM 01/11/2023 ( 62118776)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
5th Transportation Operations Centre Door plaque 502, 7:29:39PM 01/11/2023 (62118764)	Pull Station	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-6 19-2966	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
5th common hall by men's washroom Door plaque 506, 12:44:26PM 01/09/2023 (62118773)	Pull Station	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-6 19-2966	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09 /2023
5th common hall by women's washroom Door plaque 509, 12:45: 12PM 01/09/2023 (62118783)	Pull Station	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-6 19-2966	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09 /2023
5th computer room FM-200 system, 10:37:42AM 01/12/2023 ( 68832501)	Annunciator	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	1	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/12 /2023
5th RESCU & Active Traffic mgmt GA, 9:44:13AM 01/13/2023 ( 62118761)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-25 19-2964	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/13 /2023
5th Traffic Signal Operations GA, 9:44:19AM 01/13/2023 (62118745 )	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-25 19-2964	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/13 /2023

Location	Device Type	Correctly Installed	Requires Service, Repairs, Cleaning or Missing	Alarm Operation Confirmed	Annunciation Indication Confirmed	Zone Circuit Number or Address	Supervision of Wiring Device Confirmed	Ground Circuit Confirmed	Remarks/ Readings
5th common corridor north by door plaque 506, 7:34:53PM 01/11/2023 (62118774)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11/2023
5th common hall GA key by door plaque 506, 9:44:00AM 01/13/2023 (62118772)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-25 19-2964	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/13/2023
5th men's washroom by door plaque 506, 7:34:40PM 01/11/2023 (62118767)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11/2023
5th common hall GA key by door plaque 509, 9:43:56AM 01/13/2023 (62118782)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-3 19-2964	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/13/2023
5th women's washroom by door plaque 509, 7:35:40PM 01/11/2023 (62118779)	Strobe	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG Strobe 19/2665	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11/2023
5th women's washroom by door plaque 509, 7:35:36PM 01/11/2023 (62118780)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11/2023
5th Traffic, south/west office by door plaque 514, 7:31:44PM 01/11/2023 (62118751)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11/2023
5th Traffic, west office centre cubicles by door plaque 521, 7:32:32PM 01/11/2023 (62118748)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11/2023
5th Traffic, west/north office west cubicles by door plaque 523, 7:32:44PM 01/11/2023 (62118747)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11/2023
5th Traffic, west/north office north cubicles by door plaque 531, 7:33:13PM 01/11/2023 (62118743)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11/2023
5th TOC corridor by door plaque 543, 7:35:53PM 01/11/2023 (62118758)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11/2023
5th Traffic, south office s/centre cubicles by door plaque 551, 7:31:33PM 01/11/2023 (62118752)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11/2023
5th Traffic, south/east office s/e by door plaque 555, 7:31:02PM 01/11/2023 (62118756)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11/2023
5th Traffic, south/east office s/e corner by door plaque 555, 7:30:51PM 01/11/2023 (62118757)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11/2023
5th common corridor south by door plaque 5ST2, 7:36:03PM 01/11/2023 (62118784)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11/2023
5th TOC GA key door plaque 502, 9:44:05AM 01/13/2023 (62118763)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-25 19-2964	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/13/2023
5th TOC in front of screens door plaque 502, 7:35:56PM 01/11/2023 (62118760)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11/2023
5th Transportation Operations Centre door plaque 502, 7:29:43PM 01/11/2023 (62118765)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11/2023
5th electrical room door plaque 504, 10:50:27AM 01/12/2023 (62118777)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-SIG B 19/2907	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/12/2023
5th electrical room door plaque 504, 10:50:24AM 01/12/2023 (62118778)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-SIG A 19/2908	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/12/2023

Location	Device Type	Correctly Installed	Requires Service, Repairs, Cleaning or Missing	Alarm Operation Confirmed	Annunciation Indication Confirmed	Zone Circuit Number or Address	Supervision of Wiring Device Confirmed	Ground Circuit Confirmed	Remarks/ Readings
5th common corridor by janitor room door plaque 505, 10:45:01AM 01/12/2023 (62118768)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-GA 19 /2964	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/12 /2023
5th common corridor by janitor room door plaque 505, 10:45:04AM 01/12/2023 (62118769)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-6 19/2966	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/12 /2023
5th common corridor by janitor room door plaque 505, 10:45:08AM 01/12/2023 (62118770)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-5th floor phon 19 /2912	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/12 /2023
5th meeting room & DOC door plaque 535, 7:33:57PM 01/11/2023 ( 62118740)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
5th meeting room & DOC door plaque 535, 12:52:27PM 01/09/2023 (62118742)	Pull Station	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-6 19-2966	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09 /2023
5th meeting room & DOC door plaque 535 GA, 12:53:01PM 01/09 /2023 (62118741)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-25 19- 2964	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09 /2023
5th stairwell north door plaque 5ST1, 7:35:59PM 01/11/2023 ( 62118766)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
5th stairwell south door plaque 5ST2, 7:36:05PM 01/11/2023 ( 62118785)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
6th OEM corridor by door plaque 637-A, 7:24:19PM 01/11/2023 ( 62118817)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
6th OEM lunch room exit GA key, 9:43:52AM 01/13/2023 (62118804 )	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-25 19- 2871	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/13 /2023
6th OEM meeting room A east, 7:21:00PM 01/11/2023 (64248336)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
6th OEM meeting room A west, 7:20:51PM 01/11/2023 (64248337)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
6th OEM north corridor by TFS, 7:21:22PM 01/11/2023 (62118824)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
6th OEM north corridor by disaster recovery, 7:23:10PM 01/11/2023 (62118823)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
6th OEM north/east corridor, 7:23:55PM 01/11/2023 (62118818)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
6th OEM office lunch room by corridor, 7:25:44PM 01/11/2023 ( 62118813)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
6th OEM office lunch room by kitchen, 7:25:11PM 01/11/2023 ( 62118814)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
6th OEM office lunch room by washroom, 7:24:57PM 01/11/2023 ( 62118815)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
6th OEM office lunch room exit, 12:39:51PM 01/09/2023 (62118805)	Pull Station	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-5 19-2886	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09 /2023
6th OEM office meeting room, 7:28:25PM 01/11/2023 (62118816)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023

Location	Device Type	Correctly Installed	Requires Service, Repairs, Cleaning or Missing	Alarm Operation Confirmed	Annunciation Indication Confirmed	Zone Circuit Number or Address	Supervision of Wiring Device Confirmed	Ground Circuit Confirmed	Remarks/ Readings
6th common corridor by 6ST2 stairwell, 7:27:49PM 01/11/2023 ( 62118790)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
6th common corridor by elev lobby, north, 7:20:43PM 01/11/2023 ( 62118794)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
6th common corridor by elev lobby, south, 7:27:38PM 01/11/2023 ( 62118793)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
6th OEM north/east office north Door plaque 128, 7:23:32PM 01/11 /2023 (62118822)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
6th OEM north/east office north/centre Door plaque 128, 7:24:07PM 01/11/2023 (62118821)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
6th OEM north/east office south Door plaque 128, 7:24:45PM 01/11 /2023 (62118819)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
6th OEM north/east office south/centre Door plaque 128, 7:24:31PM 01/11/2023 (62118820)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
6th common hall by men's washroom Door plaque 607, 10:32:20AM 01/12/2023 (62118797)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-5 19-2886	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/12 /2023
6th common hall by men's washroom Door plaque 607, 12:36:04PM 01/09/2023 (62118801)	Pull Station	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-5 19-2886	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09 /2023
6th common hall by women's washroom Door plaque 609, 12:37:34PM 01/09/2023 (62118789)	Pull Station	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-5 19-2886	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09 /2023
6th OEM office board room Door plaque 645, 7:25:31PM 01/11 /2023 (62118812)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
6th common corridor by men's washroom by door plaque 607, 7:28:44PM 01/11/2023 (62118802)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
6th common hall GA key by door plaque 607, 10:32:23AM 01/12 /2023 (62118798)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-25 19-2871	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/12 /2023
6th common hall GA key by door plaque 607, 12:36:10PM 01/09 /2023 (62118800)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-25 19-2871	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09 /2023
6th common hall GA key by door plaque 609, 12:38:02PM 01/09 /2023 (62118788)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-25 19-2871	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09 /2023
6th OEM office south corridor by door plaque 646, 7:25:55PM 01/11 /2023 (62118811)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
6th OEM office south corridor by door plaque 649, 7:26:09PM 01/11 /2023 (62118810)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
6th OEM office south corridor by door plaque 652, 7:26:23PM 01/11 /2023 (62118809)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
6th OEM office south corridor by door plaque 656, 7:26:34PM 01/11 /2023 (62118808)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
6th OEM office vestibule to common hall by door plaque 659A, 7:27:31PM 01/11/2023 (62118803)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
6th electrical room door plaque 604, 10:37:30AM 01/12/2023 (	End Of Line					1-SIG B 19			LTD 01/12

Location	Device Type	Correctly Installed	Requires Service, Repairs, Cleaning or Missing	Alarm Operation Confirmed	Annunciation Indication Confirmed	Zone Circuit Number or Address	Supervision of Wiring Device Confirmed	Ground Circuit Confirmed	Remarks/ Readings
62118791)		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	/2897	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	/2023
6th electrical room door plaque 604, 10:37:26AM 01/12/2023 (62118792)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-SIG A 19 /2828	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/12 /2023
6th common corridor by men's washroom door plaque 607, 10:32:14AM 01/12/2023 (62118796)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-6th floor phone CCT	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/12 /2023
6th men's washroom door plaque 607, 7:28:54PM 01/11/2023 (62118795)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
6th women's washroom door plaque 609, 7:28:02PM 01/11/2023 (62118786)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
6th TFS Office space centre/east door plaque 654, 7:22:01PM 01/11/2023 (62118827)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
6th TFS Office space centre/west door plaque 654, 7:22:10PM 01/11/2023 (62118828)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
6th TFS Office space north/east door plaque 654, 7:21:32PM 01/11/2023 (62118826)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
6th TFS Office space north/west door plaque 654, 7:21:49PM 01/11/2023 (62118825)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
6th TFS Office space south/east door plaque 654, 7:22:37PM 01/11/2023 (62118830)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
6th TFS Office space south/west door plaque 654, 7:22:28PM 01/11/2023 (62118829)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
6th OEM south corridor GA key door plaque 655, 10:31:18AM 01/13/2023 (62118806)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-25 19-2871	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/13 /2023
6th OEM south corridor exit to common hall door plaque 655, 12:42:04PM 01/09/2023 (62118807)	Pull Station	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-5 19-2886	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09 /2023
7th CAD support left side, 7:19:37PM 01/11/2023 (57019841)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
7th CAD support right side, 7:19:34PM 01/11/2023 (57019840)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
7th Elevator Lobby, 7:14:57PM 01/11/2023 (57019873)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
7th TPS Computer room N/E, 7:20:12PM 01/11/2023 (59582802)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
7th TPS Computer room N/E/E, 7:20:09PM 01/11/2023 (59582801)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
7th TPS Computer room N/W, 7:20:15PM 01/11/2023 (59582803)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
7th TPS Computer room N/W/W, 7:20:18PM 01/11/2023 (59582804)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
7th TPS Computer room S/E, 7:20:06PM 01/11/2023 (59582800)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023



Location	Device Type	Correctly Installed	Requires Service, Repairs, Cleaning or Missing	Alarm Operation Confirmed	Annunciation Indication Confirmed	Zone Circuit Number or Address	Supervision of Wiring Device Confirmed	Ground Circuit Confirmed	Remarks/ Readings
7th TPS Computer room S/W, 7:19:59PM 01/11/2023 (59582798)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
7th TPS Computer room S/centre, 7:20:03PM 01/11/2023 (59582799)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
7th corridor by CAD support, 7:17:22PM 01/11/2023 (57019839)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
7th corridor by elec. panel RP-7A, 7:17:13PM 01/11/2023 (57019837)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
7th elevator lobby by door to Computer room side, 12:05:41PM 01/09/2023 (57019859)	Pull Station	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-4 19-2891	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09 /2023
7th mid stairwell north, 9:38:37AM 01/13/2023 (57019867)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-13 19-2882	<input type="checkbox"/>	<input type="checkbox"/>	2.5%, LTD 01/13/2023
7th mid stairwell south, 9:37:23AM 01/13/2023 (57019864)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-12 19-2883	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/13 /2023
7th mid stairwell south, 9:37:29AM 01/13/2023 (57019863)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-12 19-2883	<input type="checkbox"/>	<input type="checkbox"/>	2.5%, LTD 01/13/2023
7th office at end of hall Sandra Lewis, 7:17:31PM 01/11/2023 (57019838)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
7th top of mid stairwell north GA key, 12:16:02PM 01/09/2023 (57019870)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-25 19-2870	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09 /2023
7th top of mid stairwell south GA key, 12:33:27PM 01/09/2023 (57019866)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-25 19-2870	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09 /2023
7th TPS Computer room N/W closet End of line relay, 9:55:15AM 01/12/2023 (59582796)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-Z2 19-2867	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/12 /2023
7th TPS Computer room N/W closet End of line relay, 9:55:18AM 01/12/2023 (59582797)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-Z1 19-2889	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/12 /2023
7th T.R.I.P room Alarm FM-200 system, 7:16:04PM 01/11/2023 (57019845)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-29 19-2866	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
7th T.R.I.P room supervisory FM-200 system, 7:15:59PM 01/11/2023 (57019844)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-30 19-2865	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
7th computer room FM-200 system, 9:18:13AM 01/04/2023 (59582837)	Annunciator	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	1	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04 /2023
7th computer room FM-200 system, 3:17:36PM 01/10/2023 (68832502)	Annunciator	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	1	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/10 /2023
7th corridor by Electrical room door plaque 704, 7:18:18PM 01/11/2023 (57019829)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
7th corridor by men's washroom door plaque 706, 7:20:30PM 01/11/2023 (64248335)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
7th men's washroom door plaque 706, 7:15:41PM 01/11/2023 (57019849)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
7th corridor by men's washroom door plaque 706 , 7th FI GA, 10:11:	End Of Line					1-25 19-			LTD 01/12



Location	Device Type	Correctly Installed	Requires Service, Repairs, Cleaning or Missing	Alarm Operation Confirmed	Annunciation Indication Confirmed	Zone Circuit Number or Address	Supervision of Wiring Device Confirmed	Ground Circuit Confirmed	Remarks/ Readings
03AM 01/12/2023 (57019848)		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2870	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	/2023
7th corridor by men's washroom door plaque 706 , 7th Fl. Pull Stations, 10:10:59AM 01/12/2023 (57019847)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-4 19-2891	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/12 /2023
7th women's washroom door plaque 709, 7:17:50PM 01/11/2023 (57019833)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
7th TPS Comms Admin lunch room door plaque 712B, 7:20:36PM 01/11/2023 (68832504)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
7th Audio & Data systems by entrance door plaque 713, 7:19:20PM 01/11/2023 (57019826)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
7th Audio & Data systems rear door plaque 713, 7:19:24PM 01/11 /2023 (57019827)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
7th TPS Comms Admin above reception desk door plaque 713.1A, 7:19:11PM 01/11/2023 (57019823)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
7th Restricted Access Area door plaque 714, 7:19:27PM 01/11 /2023 (57019828)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
7th TPS Comms Admin by offices door plaque 717, 7:19:15PM 01 /11/2023 (57019824)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
7th Information Technology Services door plaque 723, 7:15:09PM 01/11/2023 (57019871)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
7th Information Technology Services outer room door plaque 723, 7: 20:27PM 01/11/2023 (64248334)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
7th Information Technology Services inner room door plaque 723A, 7:19:51PM 01/11/2023 (57019872)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
7th TPS Computer room main entrance door plaque 724C, 10:05: 47AM 01/04/2023 (59582792)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-4 19-2870	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04 /2023
7th TPS Computer room main entrance door plaque 724C, 10:06: 00AM 01/04/2023 (59582793)	Pull Station	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-4 19-2891	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04 /2023
7th TPS Computer room main entrance door plaque 724C , Computer Room Damper, 9:41:28AM 01/04/2023 (59582788)	Programmable Relay	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-DMP	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04 /2023
7th TPS Computer room main entrance door plaque 724C , FM-200 Panel Low Press Switch, 9:41:32AM 01/04/2023 (59582791)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-19-2700	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04 /2023
7th TPS Computer room main entrance door plaque 724C . Zone 2 Detectors, 9:41:21AM 01/04/2023 (59582786)	Programmable Relay	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-DZ2	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04 /2023
7th TPS Computer room main entrance door plaque 724C, FM-200 Panel Alarm, 9:41:36AM 01/04/2023 (59582790)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-19-2704	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04 /2023
7th TPS Computer room main entrance door plaque 724C, FM-200 Panel Trouble, 9:41:40AM 01/04/2023 (59582789)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-19-2703	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04 /2023
7th TPS Computer room main entrance door plaque 724C. Zone 1 Detectors, 9:41:24AM 01/04/2023 (59582787)	Programmable Relay	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-DZ1	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04 /2023
7th TPS Computer room main entrance door plaque 724D, 10:03: 08AM 01/04/2023 (59582794)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-4 19-2870	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04 /2023

Location	Device Type	Correctly Installed	Requires Service, Repairs, Cleaning or Missing	Alarm Operation Confirmed	Annunciation Indication Confirmed	Zone Circuit Number or Address	Supervision of Wiring Device Confirmed	Ground Circuit Confirmed	Remarks/ Readings
7th TPS Computer room main entrance door plaque 724D, 10:04:10AM 01/04/2023 (59582795)	Pull Station	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-4 19-2891	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04 /2023
7th corridor by Computer room door plaque 724D, 7:19:43PM 01/11 /2023 (57019858)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
7th by handicap washroom door plaque 726A, 7:15:56PM 01/11 /2023 (57019843)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
7th corridor by handicap washroom door plaque 732, 7:16:51PM 01 /11/2023 (57019842)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
7th corridor by north stairs door plaque 7ST1A, 12:10:28PM 01/09 /2023 (57019851)	Pull Station	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-4 19-2891	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09 /2023
7th corridor by north stairs GA key door plaque 7ST1A, 12:10:44PM 01/09/2023 (57019852)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-25 19-2870	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09 /2023
7th stairwell north door plaque 7ST1A, 7:15:34PM 01/11/2023 ( 57019853)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
7th corridor by south stairs door plaque 7ST2A, 12:01:28PM 01/09 /2023 (57019835)	Pull Station	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-4 19-2891	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09 /2023
7th corridor by south stairs GA key door plaque 7ST2A, 12:02:14PM 01/09/2023 (57019836)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-25 19-2870	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09 /2023
7th stairwell south door plaque 7ST2A, 7:17:56PM 01/11/2023 ( 57019830)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
7th stairwell south GA key door plaque 7ST2A, 12:31:36PM 01/09 /2023 (57019832)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-25 19-2870	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09 /2023
8th Elevator Lobby, 11:07:33AM 01/09/2023 (67060261)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-19 19-2613	<input type="checkbox"/>	<input type="checkbox"/>	2.5%, LTD 01/09/2023
8th Toronto paramedic room N/E, 7:12:27PM 01/11/2023 (58610028 )	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
8th Toronto paramedic room N/W, 7:12:34PM 01/11/2023 ( 58610030)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
8th Toronto paramedic room S/E, 7:12:22PM 01/11/2023 (58610029 )	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
8th Toronto paramedic room S/W, 7:12:38PM 01/11/2023 ( 58610032)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
8th by communication services, 7:04:28PM 01/11/2023 (58610006)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
8th by communication support room, 7:04:57PM 01/11/2023 ( 58610038)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
8th by elevator, 7:03:03PM 01/11/2023 (58610005)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
8th classroom N/E, 7:04:49PM 01/11/2023 (58610009)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
8th classroom N/W, 7:04:52PM 01/11/2023 (58610010)	Speaker					1-SIG			LTD 01/11

Location	Device Type	Correctly Installed	Requires Service, Repairs, Cleaning or Missing	Alarm Operation Confirmed	Annunciation Indication Confirmed	Zone Circuit Number or Address	Supervision of Wiring Device Confirmed	Ground Circuit Confirmed	Remarks/ Readings
8th classroom center, 7:03:30PM 01/11/2023 (58610008)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	/2023
8th classroom south, 7:03:27PM 01/11/2023 (58610007)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
8th communication services by front desk, 7:13:50PM 01/11/2023 (58610011)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
8th communication services common area west, 7:13:59PM 01/11/2023 (58610013)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
8th communication services inside alarms section, 7:13:54PM 01/11/2023 (58610012)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
8th corridor by male locker room, 7:11:05PM 01/11/2023 (58610018)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
8th corridor by north stair, 7:05:17PM 01/11/2023 (58610033)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
8th corridor by north stair, 11:26:20AM 01/09/2023 (58610036)	Phone Station	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-8	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09 /2023
8th corridor by north stair, 11:26:10AM 01/09/2023 (58610034)	Pull Station	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-1 19-2894	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09 /2023
8th corridor by south stair, 7:10:07PM 01/11/2023 (58610017)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
8th corridor by south stair, 11:14:40AM 01/09/2023 (58610014)	Pull Station	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-1 19-2894	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09 /2023
8th corridor elevator lobby north, 11:06:40AM 01/09/2023 (58610004)	Pull Station	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-1 19-2894	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09 /2023
8th corridor elevator lobby south, 11:06:04AM 01/09/2023 (58610003)	Pull Station	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-1 19-2894	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09 /2023
8th corridor by north stair GA key, 11:26:14AM 01/09/2023 (58610035)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-26 19-2869	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09 /2023
8th corridor by south stairwell, 11:15:05AM 01/09/2023 (58610016)	Phone Station	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-8	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09 /2023
8th elevator lobby north GA key, 11:06:35AM 01/09/2023 (58610047)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-26 19-2869	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09 /2023
8th elevator lobby south GA key, 11:05:59AM 01/09/2023 (58610046)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-26 19-2869	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09 /2023
8th fitness room center, 7:06:07PM 01/11/2023 (58610024)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
8th fitness room north, 7:06:11PM 01/11/2023 (58610025)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
8th inside communication support by phone support, 7:05:02PM 01/11/2023 (58610039)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023

Location	Device Type	Correctly Installed	Requires Service, Repairs, Cleaning or Missing	Alarm Operation Confirmed	Annunciation Indication Confirmed	Zone Circuit Number or Address	Supervision of Wiring Device Confirmed	Ground Circuit Confirmed	Remarks/ Readings
8th inside communication support by radio support, 7:05:06PM 01/11/2023 (58610040)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11/2023
8th inside male washroom, 7:05:20PM 01/11/2023 (58610037)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11/2023
8th inside women locker room north, 7:08:57PM 01/11/2023 (58610042)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11/2023
8th inside women locker room south, 7:09:11PM 01/11/2023 (58610045)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11/2023
8th inside women washroom, 7:10:10PM 01/11/2023 (58610041)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11/2023
8th lunch room north, 7:11:32PM 01/11/2023 (58610027)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11/2023
8th male locker rm north, 7:07:32PM 01/11/2023 (58610019)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11/2023
8th male locker rm south, 7:07:40PM 01/11/2023 (58610022)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11/2023
9th Elevator Lobby, 10:46:45AM 01/09/2023 (67037882)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-6 19-2611	<input type="checkbox"/>	<input type="checkbox"/>	2.5%, LTD 01/09/2023
9th Electrical Room Fire Alarm Panel Room Elevator Shaft, 11:00:57AM 01/09/2023 (57019738)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-12 19-2768	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/09/2023
9th corridor by Electrical Room, 9:47:31AM 01/12/2023 (57019742)	Strobe	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/12/2023
9th corridor exit to stairwell north, 10:33:41AM 01/09/2023 (57019771)	Pull Station	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-6 19-2774	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09/2023
9th corridor exit to stairwell south, 10:47:56AM 01/09/2023 (57019745)	Pull Station	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-6 19-2774	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09/2023
9th corridor exit to stairwell north GA key, 10:34:03AM 01/09/2023 (57019772)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-8 19-2772	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09/2023
9th corridor exit to stairwell south GA key, 10:47:51AM 01/09/2023 (57019746)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-8 19-2772	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09/2023
9th elevator lobby, 9:48:13AM 01/12/2023 (57019780)	Strobe	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/12/2023
9th elevator lobby north, 10:43:53AM 01/09/2023 (57019781)	Pull Station	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-6 19-2774	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09/2023
9th elevator lobby south, 10:44:40AM 01/09/2023 (57019783)	Pull Station	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-6 19-2774	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09/2023
9th elevator lobby north GA key, 10:44:20AM 01/09/2023 (57019782)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-8 19-2772	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09/2023
9th elevator lobby south GA key, 10:44:53AM 01/09/2023 (57019784)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-8 19-2772	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09/2023
9th handicap washroom, 9:47:37AM 01/12/2023 (57019749)	Strobe					1-SIG			LTD 01/12

Location	Device Type	Correctly Installed	Requires Service, Repairs, Cleaning or Missing	Alarm Operation Confirmed	Annunciation Indication Confirmed	Zone Circuit Number or Address	Supervision of Wiring Device Confirmed	Ground Circuit Confirmed	Remarks/ Readings
9th inside stairwell north side, 9:21:06AM 01/12/2023 (57019773)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	/2023
9th inside stairwell south side, 9:21:53AM 01/12/2023 (57019743)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/12 /2023
9th lunch room refrigerator area, 9:47:40AM 01/12/2023 (57019751)	Strobe	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/12 /2023
9th lunch room seating area, 9:47:44AM 01/12/2023 (57019753)	Strobe	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/12 /2023
9th south call centre, 9:48:16AM 01/12/2023 (57019785)	Strobe	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/12 /2023
9th south call centre, 9:48:20AM 01/12/2023 (57019791)	Strobe	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/12 /2023
9th west call centre, 9:48:23AM 01/12/2023 (57019877)	Strobe	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/12 /2023
9th west call centre, 9:48:26AM 01/12/2023 (57019881)	Strobe	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/12 /2023
9th west call centre, 9:48:29AM 01/12/2023 (57019886)	Strobe	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/12 /2023
9th west call centre, 9:48:32AM 01/12/2023 (57019889)	Strobe	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/12 /2023
9th west call centre, 9:48:35AM 01/12/2023 (57019896)	Strobe	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/12 /2023
9th west call centre, 9:48:38AM 01/12/2023 (57019903)	Strobe	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/12 /2023
9th women's washroom, 9:47:34AM 01/12/2023 (57019748)	Strobe	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/12 /2023
9th men's washroom Door plaque 906, 9:48:07AM 01/12/2023 (57019769)	Strobe	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/12 /2023
9th Mail room Door plaque 921, 9:48:03AM 01/12/2023 (57019765)	Strobe	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/12 /2023
9th office Door plaque 922, 9:48:01AM 01/12/2023 (57019763)	Strobe	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/12 /2023
9th storage/supply room restricted access Door plaque 924, 9:47:58AM 01/12/2023 (57019762)	Strobe	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/12 /2023
9th OHS Door plaque 925, 9:47:55AM 01/12/2023 (57019760)	Strobe	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/12 /2023
9th training office smaller Door plaque 926, 9:47:52AM 01/12/2023 (57019759)	Strobe	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/12 /2023
9th corridor by kitchenette Door plaque 931B, 9:47:47AM 01/12/2023 (57019757)	Strobe	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/12 /2023

Location	Device Type	Correctly Installed	Requires Service, Repairs, Cleaning or Missing	Alarm Operation Confirmed	Annunciation Indication Confirmed	Zone Circuit Number or Address	Supervision of Wiring Device Confirmed	Ground Circuit Confirmed	Remarks/ Readings
9th training office larger Door plaque 931B, 9:47:50AM 01/12/2023 (57019758)	Strobe	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/12 /2023
9th corridor by stairwell north Door plaque 9ST1, 9:20:59AM 01/12 /2023 (57019774)	Strobe	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/12 /2023
9th corridor by stairwell north Door plaque 9ST1 , 9th FI Zone, 10: 40:13AM 01/09/2023 (57019777)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-6 19-2774	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/09 /2023
9th corridor by stairwell north Door plaque 9ST1 , 9th fl GA, 10:37: 52AM 01/09/2023 (57019776)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-8 19-2772	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/09 /2023
9th computer room FM-200 system, 8:15:23AM 01/04/2023 (57019935)	Annunciator	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	1	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04 /2023
9th computer room Damper FM-200 system, 7:46:32AM 01/04/2023 (57019939)	Programmable Relay	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04 /2023
9th computer room Zone 1, first stage FM-200 system, 7:46:59AM 01/04/2023 (57019941)	Programmable Relay	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04 /2023
9th computer room Zone 2, second stage FM-200 system, 7:46: 50AM 01/04/2023 (57019940)	Programmable Relay	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04 /2023
Penthouse Top of North Stair 1, 10:13:44AM 01/09/2023 (67037879)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-9 19-2771	<input type="checkbox"/>	<input type="checkbox"/>	2.5%, LTD 01/09/2023
Penthouse Battery room, 7:49:11AM 01/16/2023 (57019712)	Horn	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/16 /2023
Penthouse Electrical/UPS room, 7:49:15AM 01/16/2023 (57019711)	Horn	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/16 /2023
Penthouse Transformer Room By N/W Roof Exit, 9:05:57AM 01/13 /2023 (67037880)	Horn	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/13 /2023
Penthouse boiler room far side, 7:48:44AM 01/16/2023 (57019722)	Horn	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/16 /2023
Penthouse boiler room near side, 7:48:48AM 01/16/2023 (57019721 )	Horn	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/16 /2023
Penthouse corridor outside of emergency generator room, 7:49: 25AM 01/16/2023 (57019701)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/16 /2023
Penthouse corridor outside of fan room, 7:49:32AM 01/16/2023 (57019692)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/16 /2023
Penthouse corridor outside of mechanical room, 7:49:29AM 01/16 /2023 (57019693)	Speaker	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/16 /2023
Penthouse corridor by south stairwell, 9:36:22AM 01/09/2023 (57019694)	Phone Station	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-PH	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09 /2023
Penthouse emergency generator room by gen 1, 7:49:22AM 01/16 /2023 (57019702)	Horn	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/16 /2023
Penthouse emergency generator room by gen 2, 7:49:19AM 01/16 /2023 (57019703)	Horn	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/16 /2023
Penthouse exit to north stairwell, 10:04:10AM 01/09/2023 (	Pull Station					1-1 19-2779			LTD 01/09

Location	Device Type	Correctly Installed	Requires Service, Repairs, Cleaning or Missing	Alarm Operation Confirmed	Annunciation Indication Confirmed	Zone Circuit Number or Address	Supervision of Wiring Device Confirmed	Ground Circuit Confirmed	Remarks/ Readings
57019689)		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	/2023
Penthouse exit to north stairwell GA key, 10:04:49AM 01/09/2023 ( 57019690)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-22 19-2758	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09 /2023
Penthouse exit to south stairwell, 9:34:54AM 01/09/2023 (57019695)	Pull Station	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-1 19-2779	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09 /2023
Penthouse exit to south stairwell GA key, 9:35:27AM 01/09/2023 ( 57019696)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-22 19-2758	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09 /2023
Penthouse inside south stairwell GA key, 10:22:53AM 01/09/2023 ( 57019698)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-22 19-2758	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09 /2023
Penthouse inside south stairwell stair 2, 10:21:55AM 01/09/2023 ( 57019699)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-10 19-2770	<input type="checkbox"/>	<input type="checkbox"/>	2.5%, LTD 01/09/2023
Penthouse inside south stairwell stair 2, 10:22:30AM 01/09/2023 ( 57019697)	Pull Station	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-1 19-2779	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09 /2023
Penthouse mechanical/chiller room GA key, 9:53:58AM 01/09/2023 (57019720)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-22 19-2758	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09 /2023
Penthouse mechanical/chiller room by battery room, 7:49:09AM 01 /16/2023 (57019713)	Horn	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/16 /2023
Penthouse mechanical/chiller room by boiler room, 7:48:56AM 01/16 /2023 (57019717)	Horn	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/16 /2023
Penthouse mechanical/chiller room by elec. control MCC-1EA, 7:49: 02AM 01/16/2023 (57019715)	Horn	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/16 /2023
Penthouse mechanical/chiller room by elec. control MCC-1N, 7:49: 06AM 01/16/2023 (57019714)	Horn	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/16 /2023
Penthouse mechanical/chiller room by exit to corridor, 7:48:51AM 01 /16/2023 (57019718)	Horn	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/16 /2023
Penthouse mechanical/chiller room column by chiller 2, 7:48:59AM 01/16/2023 (57019716)	Horn	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/16 /2023
Penthouse mechanical/chiller room exit to corridor, 10:23:44AM 01 /09/2023 (57019719)	Pull Station	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-1 19-2779	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09 /2023
Penthouse mechanical/fan room, 10:30:12AM 01/09/2023 ( 57019728)	Pull Station	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-1 19-2779	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09 /2023
Penthouse mechanical/fan room by entrance, 7:48:41AM 01/16 /2023 (57019723)	Horn	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/16 /2023
Penthouse mechanical/fan room left side/SF2, 7:48:35AM 01/16 /2023 (57019725)	Horn	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/16 /2023
Penthouse mechanical/fan room right side/SF1, 7:48:38AM 01/16 /2023 (57019724)	Horn	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/16 /2023
Penthouse top of north stairwell GA key, 10:07:31AM 01/09/2023 ( 57019688)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-22 19-2758	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09 /2023
Penthouse top of north stairwell stair 1, 10:07:11AM 01/09/2023 ( 57019686)	Pull Station	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-1 19-2779	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09 /2023



Location	Device Type	Correctly Installed	Requires Service, Repairs, Cleaning or Missing	Alarm Operation Confirmed	Annunciation Indication Confirmed	Zone Circuit Number or Address	Supervision of Wiring Device Confirmed	Ground Circuit Confirmed	Remarks/ Readings
Penthouse Transformer Room By LBS#1 Transformer, 9:05:51AM 01/13/2023 (67037878)	Horn	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/13 /2023
Penthouse Transformer Room By Electrical Room, 9:05:54AM 01/13 /2023 (67037877)	Horn	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/13 /2023
Penthouse Electrical/Transformer room by elec. room Flow Switch P1, 9:46:44AM 01/09/2023 (57019875)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-2 19-2778	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/09 /2023
Penthouse Electrical/Transformer room by elec. room Flow switch P2, 9:49:09AM 01/09/2023 (57019876)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-3 19-2777	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/09 /2023
Penthouse mechanical/fan room by entrance GA zone, 10:27:19AM 01/09/2023 (57019726)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-22 19-2758	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/09 /2023
Penthouse Electrical/Transformer room by gen room Generator 1 trouble, 10:03:10AM 01/09/2023 (57019709)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-26 19-2786	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/09 /2023
Penthouse mechanical/fan room by entrance PH Zone, 10:26:30AM 01/09/2023 (57019727)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-1 19-2779	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/09 /2023
Roof top of south stairwell stair 3, 10:15:03AM 01/09/2023 (57019700)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1-11 19-2769	<input type="checkbox"/>	<input type="checkbox"/>	2.5%, LTD 01/09/2023
Basement ceiling Network Comm. room 34/35 by entrance, 9:10:30AM 01/06/2023 (57019971)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2-57 19-2975	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/06 /2023
Basement corridor above ceiling by electrical room Door plaque 005, 9:50:32AM 01/13/2023 (57019803)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2-Z48/SV south s 19-2984	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/13 /2023
Basement corridor above ceiling by janitor closet Door plaque 007, 9:50:28AM 01/13/2023 (57019856)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2-Z47/SV north s 19-2985	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/13 /2023
Basement mech/fire pump room Door plaque 037, 8:36:10AM 01/06 /2023 (57019506)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2-Z39/SV main in 19-2993	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/06 /2023
Basement mech/fire pump room Door plaque 037, 8:37:30AM 01/06 /2023 (57018848)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2-Z10/FS basemen 19-3022	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/06 /2023
Basement ceiling Network Comm. room 34/35 by entrance FM-200 system, 9:10:24AM 01/06/2023 (57019970)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2-62 19-3068	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/06 /2023
Basement ceiling Network Comm. room 34/35 middle FM-200 system, 9:10:33AM 01/06/2023 (57019972)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2-62 19-3069	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/06 /2023
Basement ceiling Network Comm. room 34/35 rear FM-200 system, 9:10:37AM 01/06/2023 (64248327)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2-62 19-3068	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/06 /2023
Basement corridor Network Comm. room 34/35 Pressure FM-200 system, 9:10:11AM 01/06/2023 (57019967)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2-5 19-2688	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/06 /2023
Basement corridor Network Comm. room 34/35 Trouble FM-200 system, 9:10:09AM 01/06/2023 (57019966)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2-2 19-2691	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/06 /2023
Basement corridor Telephone room 33 Alarm FM-200 system, 9:09:	Initiating Device					2-11 19-			LTD 01/06



Location	Device Type	Correctly Installed	Requires Service, Repairs, Cleaning or Missing	Alarm Operation Confirmed	Annunciation Indication Confirmed	Zone Circuit Number or Address	Supervision of Wiring Device Confirmed	Ground Circuit Confirmed	Remarks/ Readings
55AM 01/06/2023 (57019984)		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2686	<input type="checkbox"/>	<input type="checkbox"/>	/2023
Basement corridor Telephone room 33 Pressure FM-200 system, 9:09:48AM 01/06/2023 (57019986)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2-15 19-2682	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/06 /2023
Basement corridor Telephone room 33 Trouble FM-200 system, 9:09:51AM 01/06/2023 (57019985)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2-12 19-2685	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/06 /2023
Basement ceiling Telephone room 33 east FM-200 system, Z-2, 9:58:20AM 01/06/2023 (57019983)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2-64 19-3066	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/06 /2023
Basement ceiling Telephone room 33 by entrance west FM-200 system, Zone -1, 9:58:16AM 01/06/2023 (57019982)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2-63 19-3067	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/06 /2023
Basement mech/fire pump room FS Ground Floor Sprinkler, 8:51:33AM 01/06/2023 (57018846)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2-Z5/FS ground F 19-3027	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/06 /2023
Basement mech/fire pump room FS Main Sprinkler, 8:46:23AM 01/06/2023 (57019523)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2-Z14/FS main sp 19-3018	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/06 /2023
Basement mech/fire pump room FS Refuse, 8:50:35AM 01/06/2023 (57018842)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2-Z30/FS refuse 19-3019	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/06 /2023
Basement mech/fire pump room Low Pressure, 9:16:13AM 01/06/2023 (57019520)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2-Z56/LP main sp 19-2976	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/06 /2023
Basement corridor mechanical room 032 Alarm Pre action 1/2/33 system, 10:00:08AM 01/06/2023 (64248321)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2-19-2652	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/06 /2023
Basement mech/fire pump room SV07 Bypass Valve For Fire Pump 2, 8:54:08AM 01/06/2023 (57019517)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2-Z45/SV pump by 19-2987	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/06 /2023
Basement mech/fire pump room SV08 Bypass Valve For Fire Pump 2, 8:53:27AM 01/06/2023 (57019518)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2-Z46/SV pump by 19-2986	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/06 /2023
Basement mech/fire pump room SV1 Main Water Supply To Building, 8:44:01AM 01/06/2023 (57019505)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2-Z39/SV main in 19-2993	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/06 /2023
Basement mech/fire pump room SV11 Supply Valve To Sprinkler System, 8:53:38AM 01/06/2023 (57019516)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2-Z49/SV Sprinkl 19-2983	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/06 /2023
Basement mech/fire pump room SV12 Alarm Valve Control, 8:48:17AM 01/06/2023 (57019519)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2-Z50/SV main sp 19-2982	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/06 /2023
Basement mech/fire pump room SV13 Ground Floor Sprinkler, 8:51:05AM 01/06/2023 (57018843)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2-Z37/SV ground 19-3005	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/06 /2023
Basement mech/fire pump room SV14 Refuse Compactor	End Of Line					2-Z29/SV			LTD 01/06

Location	Device Type	Correctly Installed	Requires Service, Repairs, Cleaning or Missing	Alarm Operation Confirmed	Annunciation Indication Confirmed	Zone Circuit Number or Address	Supervision of Wiring Device Confirmed	Ground Circuit Confirmed	Remarks/ Readings
Sprinklers, 8:45:39AM 01/06/2023 (57019551)		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	refuse 19-3003	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	/2023
Basement mech/fire pump room SV15 Basement Sprinklers, 8:41:01AM 01/06/2023 (57018847)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2-Z28/SV basemen 19-3004	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/06 /2023
Basement mech/fire pump room SV16 Sprinkler Pump Suction, 8:49:54AM 01/06/2023 (57019529)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2-Z51/SV Fire pu 19-2981	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/06 /2023
Basement mech/fire pump room SV17 Sprinkler Pump Discharge, 9:13:05AM 01/06/2023 (57019533)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2-Z52/SV Fire pu 19-2980	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/06 /2023
Basement mech/fire pump room SV18 Sprinkler Pump Bypass, 8:48:23AM 01/06/2023 (57019527)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2-Z53/SV pump by 19-2979	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/06 /2023
Basement mech/fire pump room SV19 Sprinkler Pump Bypass, 8:48:51AM 01/06/2023 (57019528)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2-Z54/SV pump by 19-2978	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/06 /2023
Basement mech/fire pump room SV2, 8:43:14AM 01/06/2023 (57019507)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2-Z40/SV back fl 19-2992	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/06 /2023
Basement mech/fire pump room SV20 Pump Test Header, 9:12:28AM 01/06/2023 (57019806)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2-Z55/SV Fire pu 19-2977	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/06 /2023
Basement mech/fire pump room SV3 ISO Valve For Back-flow Preventor, 8:42:31AM 01/06/2023 (57019508)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2-Z41/SV back fl 19-2991	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/06 /2023
Basement mech/fire pump room SV5 ISO Valve For Fire Pump 2, 8:44:42AM 01/06/2023 (57019509)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2-Z43/SV Fire pu 19-2989	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/06 /2023
Basement mech/fire pump room SV6 ISO Valve For Fire Pump 2, 8:47:26AM 01/06/2023 (57019514)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2-Z44/SV Fire pu 19-2988	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/06 /2023
1st electrical room Node -2, 10:30:43AM 01/13/2023 (62118587)	Control Panel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2	<input type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/13 /2023
1st electrical room door plaque 111, 11:40:53AM 01/12/2023 (62118582)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2-SIG B 19 /3044	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/12 /2023
1st electrical room door plaque 111, 11:40:50AM 01/12/2023 (62118583)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2-SIG A 19 /3045	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/12 /2023
1st electrical room door plaque 111, 11:40:57AM 01/12/2023 (62118581)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2-SIG 19 /3031	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/12 /2023
1st electrical room amplifier door plaque 111, 10:30:39AM 01/13 /2023 (62118585)	Battery	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/13 /2023

Location	Device Type	Correctly Installed	Requires Service, Repairs, Cleaning or Missing	Alarm Operation Confirmed	Annunciation Indication Confirmed	Zone Circuit Number or Address	Supervision of Wiring Device Confirmed	Ground Circuit Confirmed	Remarks/ Readings
2nd Electrical Room, 11:25:43AM 01/12/2023 (67060233)	Fault Isolation Module	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	2-2nd Floor in	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/12 /2023
2nd Electrical Room, 11:25:46AM 01/12/2023 (67060234)	Fault Isolation Module	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	2-2nd Floor out	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/12 /2023
2nd janitor room FS 2nd Floor Door plaque 205, 10:47:32AM 01/06 /2023 (57019801)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2-Z2/FS 2nd Flr 19-3036	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/06 /2023
2nd janitor room SV2.1 2nd Flr Sprinkler Door plaque 205, 10:47:17AM 01/06/2023 (57019800)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2-Z25/SV-2-1 19-3007	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/06 /2023
2nd Elevator Lobby, 9:34:49AM 01/13/2023 (67060235)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2-19-2632	<input type="checkbox"/>	<input type="checkbox"/>	2.5%, LTD 01/13/2023
7th Electrical/Fire Alarm Panel Room door plaque 704 FM200, 5:49:32PM 01/10/2023 (58610051)	Disconnect	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/10 /2023
8th Electrical room door plaque 804 RP-8-UA, CCT#39 , Node 2 1st Floor, 4:39:53PM 01/10/2023 (58610060)	Disconnect	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2-1st floor FACP 19-302	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/10 /2023
3rd Electrical Room, 11:11:33AM 01/12/2023 (67060245)	Fault Isolation Module	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	3-3Rd Floor	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/12 /2023
3rd Electrical Room, 11:11:36AM 01/12/2023 (67060246)	Fault Isolation Module	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	3-3Rd Floor	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/12 /2023
3rd Computer Room Ceiling Smoke Z-1, 8:11:58PM 01/11/2023 ( 62125509)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	3-12 2955	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/11 /2023
3rd janitor room FS 3rd Floor Door plaque 305, 10:45:14AM 01/06 /2023 (57019798)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	3-Z11/FS 3rd Flr 19-2956	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/06 /2023
3rd janitor room SV3.1 3rd Flr Sprinkler Door plaque 305, 10:45:03AM 01/06/2023 (57019797)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	3-Z21/SV-3-1 19-2946	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/06 /2023
3rd Elevator Lobby, 9:42:00AM 01/13/2023 (67060244)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	3-19-2625	<input type="checkbox"/>	<input type="checkbox"/>	2.5%, LTD 01/13/2023
3rd Computer Room , Under Floor N/C Area Z-1, 8:13:02PM 01/11 /2023 (62125489)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	3-13 19-2954	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
3rd Computer Room , Under Floor N/C Area Z-1, 8:13:13PM 01/11 /2023 (62125487)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	3-13 19-2954	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
3rd Computer Room , Under Floor N/E Area Z-1, 8:12:09PM 01/11 /2023 (62125505)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	3-13 19-2954	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
3rd Computer Room , Under Floor N/E Area Z-1, 8:12:42PM 01/11 /2023 (62125495)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	3-13 19-2951	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
3rd Computer Room , Under Floor N/W Area Z-1, 8:13:10PM 01/11 /2023 (62125486)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	3-13 19-2954	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
3rd Computer Room , Under Floor N/W Area Z-1, 8:13:26PM 01/11 /2023 (62125484)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	3-13 19-2954	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023

Location	Device Type	Correctly Installed	Requires Service, Repairs, Cleaning or Missing	Alarm Operation Confirmed	Annunciation Indication Confirmed	Zone Circuit Number or Address	Supervision of Wiring Device Confirmed	Ground Circuit Confirmed	Remarks/ Readings
3rd Computer Room , Under Floor S/E Area Z-1, 8:12:16PM 01/11/2023 (62125503)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	3-13 19-2954	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11/2023
3rd Computer Room Ceiling Centre Above D3AX -CO5 Z-1, 8:11:40PM 01/11/2023 (62125530)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	3-12 19-2625	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11/2023
3rd Computer Room Ceiling N/C Above D3AL-CO3 Z-1, 8:11:47PM 01/11/2023 (62125525)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	3-19-2955	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11/2023
3rd Computer Room Ceiling N/E By D3AS-C03 Z-1, 8:11:36PM 01/11/2023 (62125531)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	3-19-2955	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11/2023
3rd Computer Room Ceiling N/W Above FM -200 Tanks Z-1, 8:11:51PM 01/11/2023 (62125521)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	3-19-2955	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11/2023
3rd Computer Room Ceiling North Above D3AB-CO3 Z-1, 8:12:02PM 01/11/2023 (62125510)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	3-19-2955	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11/2023
3rd Computer Room Ceiling S/E By D3BA-C04 Z-1, 8:11:29PM 01/11/2023 (62125535)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	3-12 19-2625	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11/2023
3rd Computer Room Ceiling S/w Above D3BB-CO3 Z-1, 8:11:24PM 01/11/2023 (62125536)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	3-12 19-2625	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11/2023
3rd Computer Room , Under Floor N/E Area Z-1 , by D3AS-C01, 8:12:22PM 01/11/2023 (62125501)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	3-13 19-2954	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11/2023
3rd Computer Room , Under Floor N/C Area Z-1 , by FM -200 Tanks, 8:12:57PM 01/11/2023 (62125491)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	3-13 19-2954	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11/2023
3rd Computer Room , Under Floor N/E Area Z-1 by D3AP-C01, 8:12:36PM 01/11/2023 (62125497)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	3-13 19-2955	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11/2023
3rd Computer Room , Under Floor N/E Area Z-1 by D3AU-C01, 8:12:49PM 01/11/2023 (62125493)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	3-13 19-2954	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11/2023
3rd Computer Room , Under Floor N/E Area Z-1 by D3AZ-CO6, 8:12:29PM 01/11/2023 (62125499)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	3-13 19-2954	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11/2023
3rd Computer Room , Under Floor N/C Area Z-2, 8:12:53PM 01/11/2023 (62125492)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	3-14 19-2953	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11/2023
3rd Computer Room , Under Floor N/C Area Z-2, 8:13:00PM 01/11/2023 (62125490)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	3-14 19-2953	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11/2023
3rd Computer Room , Under Floor N/C Area Z-2, 8:13:07PM 01/11/2023 (62125488)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	3-14 19-2953	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11/2023
3rd Computer Room , Under Floor N/E Area Z-2, 8:12:32PM 01/11/2023 (62125498)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	3-14 19-2953	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11/2023
3rd Computer Room , Under Floor N/E Area Z-2, 8:12:39PM 01/11/2023 (62125496)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	3-14 19-2953	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11/2023
3rd Computer Room , Under Floor N/E Area Z-2, 8:12:45PM 01/11/2023 (62125494)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	3-14 19-2953	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11/2023
3rd Computer Room , Under Floor N/W Area Z-2, 8:13:17PM 01/11/2023 (62125485)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	3-14 19-2953	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11/2023
3rd Computer Room , Under Floor N/W Area Z-2, 8:13:20PM 01/11/2023 (62125485)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	3-14 19-			LTD 01/11/2023

Location	Device Type	Correctly Installed	Requires Service, Repairs, Cleaning or Missing	Alarm Operation Confirmed	Annunciation Indication Confirmed	Zone Circuit Number or Address	Supervision of Wiring Device Confirmed	Ground Circuit Confirmed	Remarks/ Readings
/2023 (62125482)		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	2953	<input type="checkbox"/>	<input type="checkbox"/>	/2023
3rd Computer Room , Under Floor N/W Area Z-2, 8:13:23PM 01/11/2023 (62125481)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	3-14 19-2953	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11/2023
3rd Computer Room , Under Floor S/E Area Z-2, 8:12:05PM 01/11/2023 (62125506)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	3-14 19-2953	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11/2023
3rd Computer Room , Under Floor S/E Area Z-2, 8:12:12PM 01/11/2023 (62125504)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	3-14 19-2953	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11/2023
3rd Computer Room , Under Floor S/E Area Z-2, 8:12:19PM 01/11/2023 (62125502)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	3-14 19-2953	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11/2023
3rd Computer Room Ceiling N/W Above D3AD-CO3 Z-2, 8:11:55PM 01/11/2023 (62125511)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	3-19-2940	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11/2023
3rd Computer Room Ceiling N/W Above D3AG-CO2 Z-2, 8:11:43PM 01/11/2023 (62125526)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	3-19-2940	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11/2023
3rd Computer Room Ceiling S/E By D3AZ-C03 Z-2, 8:11:32PM 01/11/2023 (62125532)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	3-19-2940	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11/2023
3rd Computer Room Ceiling S/E By D3BC-C05 Z-2, 8:11:21PM 01/11/2023 (62125537)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	3-19-2940	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11/2023
3rd Computer Room , Under Floor N/E Area Z-2, By D3AM-C01, 8:12:25PM 01/11/2023 (62125500)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	3-14 19-2953	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11/2023
4th Elevator Lobby, 9:41:10AM 01/13/2023 (67060247)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	3-19-2624	<input type="checkbox"/>	<input type="checkbox"/>	2.5%, LTD 01/13/2023
4th Electrical Room, 10:31:04AM 01/13/2023 (67060248)	Fault Isolation Module	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	3-4th Floor	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/13/2023
4th Electrical Room, 10:31:07AM 01/13/2023 (67060249)	Fault Isolation Module	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	3-4th Floor	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/13/2023
4th electrical room Amplifier Cabinet, 10:59:04AM 01/12/2023 (62118730)	Battery	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/12/2023
4th janitor room FS 4th Floor Door plaque 405, 10:44:02AM 01/06/2023 (57019559)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	3-Z6/FS 4th Flr 19-2961	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/06/2023
4th janitor room SV4.1 4th Flr Sprinkler Door plaque 405, 10:43:48AM 01/06/2023 (57019558)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	3-Z19/SV-4-1 19-2948	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/06/2023
4th south office Door plaque 410A, 12:57:30PM 01/09/2023 (62118699)	Pull Station	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	3-5 19-2962	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09/2023
4th electrical room by door plaque 404, 10:58:53AM 01/12/2023 (62118732)	Control Panel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3	<input type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/12/2023
5th Elevator Lobby, 9:40:12AM 01/13/2023 (67060250)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	3-19-2623	<input type="checkbox"/>	<input type="checkbox"/>	2.5%, LTD 01/13/2023
5th janitor room FS 5th Floor Door plaque 505, 10:41:41AM 01/06/2023 (57019555)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	3-Z2/FS 5th Flr 19-2965	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/06/2023
5th janitor room SV5.1 5th Flr Sprinkler Door plaque 505, 10:42:03AM 01/06/2023 (57019554)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	3-Z17/SV-5-1 19-2950	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/06/2023

Location	Device Type	Correctly Installed	Requires Service, Repairs, Cleaning or Missing	Alarm Operation Confirmed	Annunciation Indication Confirmed	Zone Circuit Number or Address	Supervision of Wiring Device Confirmed	Ground Circuit Confirmed	Remarks/ Readings
8th Electrical room door plaque 804 RP-8-UA, CCT#37 4th FI to Panel, 4:39:40PM 01/10/2023 (58610059)	Disconnect	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	3-4th floor FACP 19-303	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/10 /2023
4th comp. & comm. room n/w at release panel Zone-1, 1:03:50PM 01/04/2023 (58612478)	Programmable Relay	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	4-1	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04 /2023
5th Electrical Room, 10:45:42AM 01/12/2023 (67060252)	Fault Isolation Module	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	4-5th Floor Out	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/12 /2023
5th Electrical Room, 10:45:46AM 01/12/2023 (67060251)	Fault Isolation Module	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	4-5th Floor In	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/12 /2023
6th Electrical Room, 10:33:08AM 01/12/2023 (67060254)	Fault Isolation Module	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	4-6th Floor	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/12 /2023
6th Electrical Room, 10:33:14AM 01/12/2023 (67060253)	Fault Isolation Module	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	4-6th Floor	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/12 /2023
6th janitor room FS 6th Floor Door plaque 605, 10:40:17AM 01/06 /2023 (57019552)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	4-Z10/FS 6th Flr 19-2885	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/06 /2023
6th janitor room SV6.1 6th Flr Sprinkler Door plaque 605, 10:40:05AM 01/06/2023 (57019550)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	4-Z20/SV-6-1 19-2875	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/06 /2023
6th Elevator Lobby, 9:39:26AM 01/13/2023 (67060240)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	4-19-2615	<input type="checkbox"/>	<input type="checkbox"/>	2.5%, LTD 01/13/2023
7th Electrical Room, 7:46:51AM 01/16/2023 (67060257)	Fault Isolation Module	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	4-7th Floor	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/16 /2023
7th Electrical Room, 7:46:55AM 01/16/2023 (67060256)	Fault Isolation Module	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	4-7th Floor	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/16 /2023
7th Electrical/Fire Alarm Panel Room door plaque 704, 9:55:31AM 01/12/2023 (58610053)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	4-SIG9 4-1-0	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/12 /2023
7th Electrical/Fire Alarm Panel Room door plaque 704, 9:55:36AM 01/12/2023 (58610054)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	4-SIG10 4-2-0	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/12 /2023
7th elevator lobby by door to Comms centre side, 12:04:45PM 01/09 /2023 (57019861)	Pull Station	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	4-4 19-2891	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09 /2023
7th elevator lobby left side GA key, 12:05:06PM 01/09/2023 (57019862)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	4-25 19-2870	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09 /2023
7th main computer room 724D under, middle row, centre, 10:28:27AM 01/04/2023 (59582814)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	4-4 19-2888	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04 /2023
7th main computer room 724D under, middle row, centre, 10:28:23AM 01/04/2023 (59582815)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	4-3 19-2887	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04 /2023
7th main computer room 724D under, middle row, east, 10:28:10AM 01/04/2023 (59582818)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	4-4 19-2888	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04 /2023
7th main computer room 724D under, middle row, east, 10:28:18AM 01/04/2023 (59582816)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	4-4 19-2888	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04 /2023
7th main computer room 724D under, middle row, east, 10:28:	Smoke Detector					4-3 19-2887			LTD 01/04

Location	Device Type	Correctly Installed	Requires Service, Repairs, Cleaning or Missing	Alarm Operation Confirmed	Annunciation Indication Confirmed	Zone Circuit Number or Address	Supervision of Wiring Device Confirmed	Ground Circuit Confirmed	Remarks/ Readings
13AM 01/04/2023 (59582817)		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	/2023
7th main computer room 724D under, middle row, west, 10:28:34AM 01/04/2023 (59582812)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	4-4 19-2888	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04 /2023
7th main computer room 724D under, middle row, west, 10:28:30AM 01/04/2023 (59582813)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	4-3 19-2887	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04 /2023
7th main computer room 724D under, middle row, west, 10:28:44AM 01/04/2023 (59582811)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	4-3 19-2887	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04 /2023
7th main computer room 724D under, north row, centre, 10:27:56AM 01/04/2023 (59582822)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	4-4 19-2888	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04 /2023
7th main computer room 724D under, north row, centre, 10:27:52AM 01/04/2023 (59582823)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	4-3 19-2887	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04 /2023
7th main computer room 724D under, north row, east, 10:28:03AM 01/04/2023 (59582820)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	4-4 19-2888	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04 /2023
7th main computer room 724D under, north row, east, 10:27:59AM 01/04/2023 (59582821)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	4-3 19-2887	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04 /2023
7th main computer room 724D under, north row, east, 10:28:07AM 01/04/2023 (59582819)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	4-3 19-2887	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04 /2023
7th main computer room 724D under, north row, west, 10:27:43AM 01/04/2023 (59582826)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	4-4 19-2888	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04 /2023
7th main computer room 724D under, north row, west, 10:27:49AM 01/04/2023 (59582824)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	4-4 19-2888	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04 /2023
7th main computer room 724D under, north row, west, 10:27:45AM 01/04/2023 (59582825)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	4-3 19-2887	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04 /2023
7th main computer room 724D under, south row, centre, 10:28:55AM 01/04/2023 (59582808)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	4-4 19-2888	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04 /2023
7th main computer room 724D under, south row, centre, 10:28:51AM 01/04/2023 (59582809)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	4-3 19-2887	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04 /2023
7th main computer room 724D under, south row, east, 10:29:13AM 01/04/2023 (59582806)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	4-4 19-2888	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04 /2023
7th main computer room 724D under, south row, east, 10:29:02AM 01/04/2023 (59582807)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	4-3 19-2887	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04 /2023
7th main computer room 724D under, south row, east, 10:29:22AM 01/04/2023 (59582805)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	4-3 19-2887	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04 /2023
7th main computer room 724D under, south row, west, 10:28:47AM 01/04/2023 (59582810)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	4-4 19-2888	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04 /2023
7th janitor room FS 7th Floor Door plaque 705, 10:37:40AM 01/06 /2023 (57019548)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	4-Z5/FS 7th Fir 19-2890	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/06 /2023
7th janitor room SV7.1 7th Flr Sprinkler Door plaque 705, 10:36:44AM 01/06/2023 (57019547)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	4-Z19/SV-7-1 19-2876	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/06 /2023
7th Elevator Lobby, 9:36:35AM 01/13/2023 (67060255)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	4-19-2614	<input type="checkbox"/>	<input type="checkbox"/>	2.5%, LTD 01/13/2023



Location	Device Type	Correctly Installed	Requires Service, Repairs, Cleaning or Missing	Alarm Operation Confirmed	Annunciation Indication Confirmed	Zone Circuit Number or Address	Supervision of Wiring Device Confirmed	Ground Circuit Confirmed	Remarks/ Readings
7th Electrical/Fire Alarm Panel Room door plaque 704 FM200 supervisory, 7:46:48AM 01/16/2023 (58610052)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	4-4/M1-7 19-2659	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/16 /2023
7th Electrical/Fire Alarm Panel Room door plaque 704 Node -4, 7:53:46AM 01/16/2023 (58610048)	Control Panel	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	4	<input type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/16 /2023
7th main computer room 724D ceiling, north row, centre Z-1, 9:57:12AM 01/04/2023 (59582842)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	4-1 19-2889	<input type="checkbox"/>	<input type="checkbox"/>	1.26%, LTD 01/04/2023
7th main computer room 724D ceiling, north row, east Z-1, 9:50:48AM 01/04/2023 (59582840)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	4-1 19-2889	<input type="checkbox"/>	<input type="checkbox"/>	1.31%, LTD 01/04/2023
7th main computer room 724D ceiling, north row, west Z-1, 8:40:32AM 01/09/2023 (59582844)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	4-1 19-2889	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09 /2023
7th main computer room 724D ceiling, south row, centre Z-1, 10:00:55AM 01/04/2023 (59582836)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	4-1 19-2889	<input type="checkbox"/>	<input type="checkbox"/>	2.5%, LTD 01/04/2023
7th main computer room 724D ceiling, south row, east Z-1, 9:51:10AM 01/04/2023 (59582834)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	4-1 19-2889	<input type="checkbox"/>	<input type="checkbox"/>	1.11%, LTD 01/04/2023
7th main computer room 724D ceiling, north row, centre Z-2, 9:53:40AM 01/04/2023 (59582841)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	4-2 19-2867	<input type="checkbox"/>	<input type="checkbox"/>	1.21%, LTD 01/04/2023
7th main computer room 724D ceiling, north row, east Z-2, 9:50:23AM 01/04/2023 (59582839)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	4-2 19-2867	<input type="checkbox"/>	<input type="checkbox"/>	1.38%, LTD 01/04/2023
7th main computer room 724D ceiling, north row, west Z-2, 9:57:36AM 01/04/2023 (59582843)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	4-2 19-2867	<input type="checkbox"/>	<input type="checkbox"/>	2.5%, LTD 01/04/2023
7th main computer room 724D ceiling, south row, centre Z-2, 9:53:00AM 01/04/2023 (59582835)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	4-2 19-2867	<input type="checkbox"/>	<input type="checkbox"/>	1.14%, LTD 01/04/2023
7th main computer room 724D ceiling, south row, east Z-2, 9:49:58AM 01/04/2023 (59582833)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	4-2 19-2867	<input type="checkbox"/>	<input type="checkbox"/>	2.5%, LTD 01/04/2023
7th corridor by janitor door plaque 705, 7th FI Hand Sets, 10:17:56AM 01/12/2023 (57019857)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	4-SIG22 19-2853	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/12 /2023
7th main computer room 724D n/e corner for under floor smokes, 9:08:34AM 01/04/2023 (64248328)	Programmable Relay	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	4-19-2887	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04 /2023
7th main computer room 724D n/e corner for under floor smokes, 9:35:39AM 01/04/2023 (64248329)	Programmable Relay	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	4-19-2888	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04 /2023
8th Electrical room door plaque 804, 11:12:41AM 01/09/2023 (57019819)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	4-SIG4 19-2835	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/09 /2023
8th corridor by men's washroom door plaque 806, 11:21:57AM 01/09/2023 (57019820)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	4-1 19-2894	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/09 /2023
8th corridor by janitor door plaque 805 8th fl handset, 11:22:46AM 01/09/2023 (57019822)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	4-SIG23 19-2852	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/09 /2023
8th Electrical room door plaque 804 Circuit A, 11:12:36AM 01/09/2023 (58610062)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	4-SIG3 19-2836	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/09 /2023
8th janitor room FS 8th Floor Door plaque 805, 10:34:10AM 01/06/2023 (57019545)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	4-Z2/FS 8th Flr 19-2893	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/06 /2023
8th janitor room SV8.1 8th Flr Sprinkler Door plaque 805, 10:34:	End Of Line					4-Z17/SV-8-			LTD 01/06



Location	Device Type	Correctly Installed	Requires Service, Repairs, Cleaning or Missing	Alarm Operation Confirmed	Annunciation Indication Confirmed	Zone Circuit Number or Address	Supervision of Wiring Device Confirmed	Ground Circuit Confirmed	Remarks/ Readings
00AM 01/06/2023 (57019544)		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	1 19-2878	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	/2023
8th Electrical room door plaque 804 RP-8-UA, CCT#32 7th FL. Node 4, Tub, 4:40:00PM 01/10/2023 (58610055)	Disconnect	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	4-7th floor FACP	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/10 /2023
8th Electrical room door plaque 804 RP-8-UA, CCT#34, 7th FI panel Node 4, 4:40:05PM 01/10/2023 (58610056)	Disconnect	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	4-7th floor FACP 19-304	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/10 /2023
8th Electrical Room, 11:08:18AM 01/09/2023 (67060260)	Fault Isolation Module	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	5-8th floor	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09 /2023
8th Electrical Room, 11:08:23AM 01/09/2023 (67060259)	Fault Isolation Module	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	5-8th floor	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09 /2023
8th Electrical room door plaque 804 RP-8-UA, CCT#31 , Node 5 Tub 1, 4:39:17PM 01/10/2023 (58610057)	Disconnect	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	5-9th floor FACP	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/10 /2023
8th Electrical room door plaque 804 RP-8-UA, CCT#33 , Node 5, 4:39:30PM 01/10/2023 (58610058)	Disconnect	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	5-9th floor FACP 19-305	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/10 /2023
9th Electrical Room, 10:49:37AM 01/09/2023 (57019874)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	5	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09 /2023
9th Electrical Room Fire Alarm Panel Room Speaker Circuit, 11:01:21AM 01/09/2023 (57019740)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	5-SIG4 19-2806	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/09 /2023
9th Electrical Room Fire Alarm Panel Room Speaker Circuit, 11:01:07AM 01/09/2023 (57019739)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	5-SIG3 19-2807	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/09 /2023
9th Electrical Room Fire Alarm Panel Room Strobe Circuit, 10:55:14AM 01/09/2023 (57019737)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	5-SIG28 19-2812	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/09 /2023
9th janitor room Door plaque 905, 10:32:20AM 01/06/2023 (57019542)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	5-Z7/FS-9th flr 19-2773	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/06 /2023
9th janitor room Door plaque 905, 10:32:00AM 01/06/2023 (57019541)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	5-Z23/SV-9-1 19-2757	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/06 /2023
9th corridor by stairwell north Door plaque 9ST1, phone Circuit, 10:41:37AM 01/09/2023 (57019778)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	5-SIG21 19-2827	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/09 /2023
9th computer room Pressure FM-200 system, 7:47:23AM 01/04/2023 (57019936)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	5-19-2681	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04 /2023
9th computer room Trouble FM-200 system, 7:47:19AM 01/04/2023 (57019937)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	5-19-2681	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04 /2023
9th ceiling computer room north/east FM-200 system, 8:03:27AM 01/04/2023 (57019928)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	5-19-2668	<input type="checkbox"/>	<input type="checkbox"/>	2.5%, LTD 01/04/2023
9th ceiling computer room north/west FM-200 system, 7:56:41AM 01/04/2023 (57019929)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	5-19-2669	<input type="checkbox"/>	<input type="checkbox"/>	1.3%, LTD 01/04/2023
9th ceiling computer room south/east FM-200 system, 7:56:23AM 01/04/2023 (57019927)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	5-19-2667	<input type="checkbox"/>	<input type="checkbox"/>	2.5%, LTD 01/04/2023
9th ceiling computer room south/west FM-200 system, 7:56:49AM 01/04/2023 (57019930)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	5-19-2666	<input type="checkbox"/>	<input type="checkbox"/>	2.5%, LTD 01/04/2023

Location	Device Type	Correctly Installed	Requires Service, Repairs, Cleaning or Missing	Alarm Operation Confirmed	Annunciation Indication Confirmed	Zone Circuit Number or Address	Supervision of Wiring Device Confirmed	Ground Circuit Confirmed	Remarks/ Readings
9th under tile computer room north/east FM-200 system, 8:06:41AM 01/04/2023 (57019932)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	5-19-2674	<input type="checkbox"/>	<input type="checkbox"/>	2.5%, LTD 01/04/2023
9th under tile computer room north/west FM-200 system, 8:06:38AM 01/04/2023 (57019933)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	5-19-2675	<input type="checkbox"/>	<input type="checkbox"/>	1.3%, LTD 01/04/2023
9th under tile computer room south/east FM-200 system, 8:06:45AM 01/04/2023 (57019931)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	5-19-2673	<input type="checkbox"/>	<input type="checkbox"/>	1.3%, LTD 01/04/2023
9th under tile computer room south/west FM-200 system, 8:06:34AM 01/04/2023 (57019934)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	5-19-2672	<input type="checkbox"/>	<input type="checkbox"/>	2.5%, LTD 01/04/2023
9th computer room FM-200 system Alarm, 7:47:27AM 01/04/2023 (57019938)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	5-19-2681	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04/2023
9th Electrical Room Fire Alarm Panel Room Strobe Circuit, 10:55:00AM 01/09/2023 (57019736)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	5-SIG27 19-2813	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/09/2023
Penthouse Electrical Room, 10:32:15AM 01/09/2023 (67037876)	Fault Isolation Module	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	5-19-305	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09/2023
Penthouse Electrical/Transformer room by gen room Generator 1 Running, 9:58:40AM 01/09/2023 (57019710)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	5-24 19-2756	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/09/2023
Penthouse Electrical/Transformer room by gen room Generator 2 Running, 9:43:10AM 01/09/2023 (57019708)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	5-17 19-2671	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/09/2023
Penthouse Electrical/Transformer room by gen room Generator 2 Trouble, 9:43:18AM 01/09/2023 (57019707)	End Of Line	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	5-18 19-2670	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	LTD 01/09/2023
4th comp. & comm. room ceiling, north area, 2:33:40PM 01/04/2023 (58612473)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	6-7 19-2960	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04/2023
4th comp. & comm. room ceiling, north area, 2:33:57PM 01/04/2023 (58612477)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	6-2 19-2939	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04/2023
4th comp. & comm. room under, comm. room c/e, 1:55:15PM 01/04/2023 (58612431)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	6-19-2958	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04/2023
4th comp. & comm. room under, comm. room c/w, 1:57:01PM 01/04/2023 (58612434)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	6-19-2959	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04/2023
4th comp. & comm. room under, comm. room n/e, 1:56:54PM 01/04/2023 (58612432)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	6-19-2959	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04/2023
4th comp. & comm. room under, comm. room n/w, 1:56:58PM 01/04/2023 (58612433)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	6-19-2958	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04/2023
4th comp. & comm. room under, comm. room s/e, 1:55:10PM 01/04/2023 (58612430)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	6-19-2959	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04/2023
4th comp. & comm. room under, comm. room s/w, 1:57:08PM 01/04/2023 (58612435)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	6-19-2958	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04/2023
4th comp. & comm. room under, north area c/c, 1:57:31PM 01/04/2023 (58612440)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	6-19-2959	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04/2023
4th comp. & comm. room under, north area c/e, 1:57:34PM 01/04/2023 (58612441)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	6-19-2958	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04/2023
4th comp. & comm. room under, north area c/w, 1:57:28PM 01/04	Smoke Detector					6-19-2958			LTD 01/04

Location	Device Type	Correctly Installed	Requires Service, Repairs, Cleaning or Missing	Alarm Operation Confirmed	Annunciation Indication Confirmed	Zone Circuit Number or Address	Supervision of Wiring Device Confirmed	Ground Circuit Confirmed	Remarks/ Readings
/2023 (58612439)		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	/2023
4th comp. & comm. room under, north area n/e, 1:57:39PM 01/04/2023 (58612442)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	6-19-2959	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04/2023
4th comp. & comm. room under, north area s/c, 1:57:18PM 01/04/2023 (58612437)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	6-19-2958	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04/2023
4th comp. & comm. room under, north area s/e, 1:57:12PM 01/04/2023 (58612436)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	6-19-2959	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04/2023
4th comp. & comm. room under, north area s/w, 1:57:23PM 01/04/2023 (58612438)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	6-19-2959	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04/2023
4th comp. & comm. room under, south area c/c, 1:54:48PM 01/04/2023 (58612425)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	6-19-2958	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04/2023
4th comp. & comm. room under, south area c/e, 1:54:54PM 01/04/2023 (58612426)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	6-19-2959	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04/2023
4th comp. & comm. room under, south area n/c, 1:55:02PM 01/04/2023 (58612428)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	6-19-2959	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04/2023
4th comp. & comm. room under, south area n/e, 1:54:58PM 01/04/2023 (58612427)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	6-19-2958	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04/2023
4th comp. & comm. room under, south area n/w, 1:55:06PM 01/04/2023 (58612429)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	6-19-2958	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04/2023
4th comp. & comm. room under, south area s/c, 1:04:13PM 01/04/2023 (58612424)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	6-19-2958	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04/2023
4th comp. & comm. room under, south area s/e, 1:04:19PM 01/04/2023 (58612423)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	6-19-2959	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04/2023
4th maintenance/test lab under, n/c, 1:04:29PM 01/04/2023 (58612421)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	6-19-2958	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04/2023
4th maintenance/test lab under, n/e, 1:04:35PM 01/04/2023 (58612420)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	6-19-2959	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04/2023
4th maintenance/test lab under, n/w, 1:04:25PM 01/04/2023 (58612422)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	6-19-2959	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04/2023
4th maintenance/test lab under, s/c, 1:04:47PM 01/04/2023 (58612498)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	6-19-2959	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04/2023
4th maintenance/test lab under, s/e, 1:04:42PM 01/04/2023 (58612499)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	6-19-2958	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04/2023
4th maintenance/test lab under, s/w, 1:04:54PM 01/04/2023 (58612497)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	6-19-2958	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04/2023
4th comp. & comm. room n/w at release panel Alarm, 1:03:45PM 01/04/2023 (58612483)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	6-13 19-2709	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04/2023
4th comp. & comm. room n/w at release panel Damper, 1:04:01PM 01/04/2023 (58612480)	Programmable Relay	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	6-1 19-2960	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04/2023
4th comp. & comm. room n/w release panel Tanks Low Pressure, 12:59:43PM 01/04/2023 (58612481)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	6-13 19-2706	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04/2023

Location	Device Type	Correctly Installed	Requires Service, Repairs, Cleaning or Missing	Alarm Operation Confirmed	Annunciation Indication Confirmed	Zone Circuit Number or Address	Supervision of Wiring Device Confirmed	Ground Circuit Confirmed	Remarks/ Readings
4th comp. & comm. room n/w at release panel Trouble, 12:57:10PM 01/04/2023 (58612482)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	6-13 19-2998	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04 /2023
4th comp. & comm. room ceiling, comm. room c/e Z-1, 2:32:33PM 01/04/2023 (58612459)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	6-1 19-2960	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04 /2023
4th comp. & comm. room ceiling, comm. room c/e Z-1, 2:32:42PM 01/04/2023 (58612461)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	6-1 19-2960	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04 /2023
4th comp. & comm. room ceiling, comm. room c/w Z-1, 2:32:30PM 01/04/2023 (58612458)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	6-2 19-2960	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04 /2023
4th comp. & comm. room ceiling, comm. room s/w Z-1, 2:32:50PM 01/04/2023 (58612463)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	6-1 19-2960	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04 /2023
4th comp. & comm. room ceiling, north area Z-1, 2:33:48PM 01/04 /2023 (58612475)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	6-1 19-2960	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04 /2023
4th comp. & comm. room ceiling, north area Z-1, 2:33:53PM 01/04 /2023 (58612476)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	6-1 19-2960	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04 /2023
4th comp. & comm. room ceiling, s/e area Z-1, 2:33:26PM 01/04 /2023 (58612470)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	6-1 19-2960	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04 /2023
4th comp. & comm. room ceiling, south area Z-1, 2:33:31PM 01/04 /2023 (58612471)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	6-2 19-2960	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04 /2023
4th comp. & comm. room ceiling, south area Z-1, 2:33:15PM 01/04 /2023 (58612468)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	6-1 19-2960	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04 /2023
4th comp. & comm. room ceiling, comm. room n/e Z-2, 2:32:39PM 01/04/2023 (58612460)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	6-2 19-2939	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04 /2023
4th comp. & comm. room ceiling, comm. room s/e Z-2, 2:32:46PM 01/04/2023 (58612462)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	6-2 19-2939	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04 /2023
4th comp. & comm. room ceiling, north area Z-2, 2:33:45PM 01/04 /2023 (58612474)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	6-28 19-2939	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04 /2023
4th comp. & comm. room ceiling, s/e area Z-2, 2:33:20PM 01/04 /2023 (58612469)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	6-2 19-2939	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04 /2023
4th comp. & comm. room ceiling, s/w area Z-2, 2:33:36PM 01/04 /2023 (58612472)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	6-1 19-2939	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04 /2023
4th comp. & comm. room ceiling, s/w by maintenance lab Z-2, 2:33:12PM 01/04/2023 (58612467)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	6-2 19-2939	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04 /2023
4th comp. & comm. room n/w at release panel Zone -2, 1:03:55PM 01/04/2023 (58612479)	Programmable Relay	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	6-2 19-2939	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04 /2023
4th maintenance lab E ceiling Z-2 barcode on doorframe, 7:39:24PM 01/11/2023 (58612465)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	6-2 19-2939	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
4th maintenance lab W ceiling Z-1 barcode on doorframe, 7:39:21PM 01/11/2023 (58612464)	Smoke Detector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	6-1 19-2960	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
3rd Southeast Corner outside computer room by Suppression panel DMP(Damper), 11:16:27AM 01/12/2023 (62118540)	Programmable Relay	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	7	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/12 /2023
3rd Southeast Corner outside computer room by Suppression panel	Programmable Relay					7			LTD 01/12

Location	Device Type	Correctly Installed	Requires Service, Repairs, Cleaning or Missing	Alarm Operation Confirmed	Annunciation Indication Confirmed	Zone Circuit Number or Address	Supervision of Wiring Device Confirmed	Ground Circuit Confirmed	Remarks/ Readings
DZ1, 11:16:20AM 01/12/2023 (62118542)		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	/2023
3rd Southeast Corner outside computer room by Suppression panel DZ2, 11:16:23AM 01/12/2023 (62118541)	Programmable Relay	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	7	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/12 /2023
3rd Southeast Corner outside computer room by Suppression panel Low Pressure, 11:16:40AM 01/12/2023 (62118543)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	7	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/12 /2023
3rd Southeast Corner outside computer room by Suppression panel Panel Alarm, 11:16:32AM 01/12/2023 (62118546)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	7-19-2698	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/12 /2023
3rd Southeast Corner outside computer room Suppression panel Trouble, 11:16:36AM 01/12/2023 (62118545)	Initiating Device	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	7-28 19-2697	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/12 /2023
Basement elevator 1&2 pit door plaque 006 barcode on exterior doorframe, 9:15:03AM 01/06/2023 (64248500)	Heat Detector	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	1-17 19-3015	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/06 /2023
Basement elevator 3 pit barcode on exterior doorframe, 9:09:32AM 01/13/2023 (64248501)	Heat Detector	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	1-17 19-3015	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/13 /2023
Basement fitness room women's locker room door plaque 026, 9:30:11AM 01/13/2023 (59582755)	Pull Station	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	1-9 19-3023	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/13 /2023
Basement fitness room woman's locker room GA key door plaque 026, 9:47:54AM 01/13/2023 (59582754)	Initiating Device	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	1-GA 19-3020	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/13 /2023
Basement corridor by stair 1 door plaque 0ST1, 7:50:42AM 01/16 /2023 (59582763)	Phone Station	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	1-Basement	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/16 /2023
Basement corridor by stair 2 door plaque 0ST2, 7:50:29AM 01/16 /2023 (59582735)	Phone Station	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	1-Basement	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/16 /2023
1st corridor south exit east, 7:50:52AM 01/16/2023 (62118590)	Phone Station	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	1-Ground floor	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/16 /2023
1st front lobby, 7:51:11AM 01/16/2023 (62118609)	Phone Station	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	1-Ground floor	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/16 /2023
1st rear turnstile lobby, 7:51:02AM 01/16/2023 (62118596)	Phone Station	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	1-Ground floor	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/16 /2023
1st security deck at front entrance, 9:01:43AM 01/13/2023 (57019683)	Annunciator	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	1	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/13 /2023
1st security deck at front entrance, 8:14:47AM 01/16/2023 (57019680)	Control Panel	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	1	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/16 /2023
2nd office south door plaque 203, 9:32:51AM 01/13/2023 (62118613 )	Pull Station	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	1-9 19-3037	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/13 /2023
2nd common corridor by men's washroom door plaque 206, 7:51:24AM 01/16/2023 (62118639)	Phone Station	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	1-2nd floor	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/16 /2023
2nd common corridor by women's washroom door plaque 209, 7:51:32AM 01/16/2023 (62118650)	Phone Station	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	1-2nd floor	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/16 /2023
2nd corridor exit south door plaque 2ST2, 1:06:23PM 01/09/2023 (62118652)	Pull Station	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	1-9 19-3037	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09 /2023
3rd common corridor by men's washroom door plaque 306, 7:51:42AM 01/16/2023 (62118664)	Phone Station	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	1-3rd floor	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/16 /2023

Location	Device Type	Correctly Installed	Requires Service, Repairs, Cleaning or Missing	Alarm Operation Confirmed	Annunciation Indication Confirmed	Zone Circuit Number or Address	Supervision of Wiring Device Confirmed	Ground Circuit Confirmed	Remarks/ Readings
3rd common corridor by women's washroom door plaque 309, 7:51:50AM 01/16/2023 (62118684)	Phone Station	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	1-3rd floor	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/16 /2023
4th common corridor by men's washroom door plaque 406, 7:52:06AM 01/16/2023 (62118723)	Phone Station	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	1-4th floor	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/16 /2023
4th common corridor by women's washroom door plaque 409, 7:52:16AM 01/16/2023 (62118736)	Phone Station	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	1-4th floor	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/16 /2023
5th common corridor by men's washroom door plaque 506, 7:52:26AM 01/16/2023 (62118771)	Phone Station	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	1-5th floor	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/16 /2023
5th common corridor by women's washroom door plaque 509, 7:52:35AM 01/16/2023 (62118781)	Phone Station	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	1-5th floor	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/16 /2023
6th common corridor by men's washroom door plaque 607, 7:52:44AM 01/16/2023 (62118799)	Phone Station	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	1-6th floor	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/16 /2023
6th common corridor by women's washroom door plaque 609, 12:20:15PM 01/09/2023 (62118787)	Phone Station	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	1-6th floor	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09 /2023
7th elevator lobby right side GA key, 12:06:52PM 01/09/2023 (57019860)	Initiating Device	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	1-25 19-2870	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09 /2023
7th mid stairwell north, 10:22:24AM 01/12/2023 (57019868)	End Of Line	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	1-13 19-2882	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/12 /2023
7th top of mid stairwell north, 12:30:14PM 01/09/2023 (57019869)	Pull Station	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	1-13 19-2882	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09 /2023
7th top of mid stairwell south, 12:32:59PM 01/09/2023 (57019865)	Pull Station	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	1-12 19-2883	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09 /2023
7th corridor by men's washroom door plaque 706, 7:53:11AM 01/16 /2023 (57019850)	Phone Station	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	1-7th floor	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/16 /2023
7th corridor by women's washroom door plaque 709, 7:52:56AM 01 /16/2023 (57019834)	Phone Station	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	1-7th floor	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/16 /2023
7th stairwell north door plaque 7ST1A, 12:28:54PM 01/09/2023 (57019854)	Pull Station	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	1-30 19-2882	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09 /2023
7th stairwell north GA key door plaque 7ST1A, 12:29:38PM 01/09 /2023 (57019855)	Initiating Device	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	1-25 19-2870	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09 /2023
7th stairwell south door plaque 7ST2A, 12:33:47PM 01/09/2023 (57019831)	Pull Station	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	1-4 19-2883	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09 /2023
8th Toronto paramedic room S/E, 7:13:25PM 01/11/2023 (58610031 )	Speaker	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
8th corridor by south stair GA key, 11:14:56AM 01/09/2023 (58610015)	Initiating Device	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	1-26 19-2869	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09 /2023
8th fitness room south, 7:07:08PM 01/11/2023 (58610023)	Speaker	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
8th inside women locker room north, 7:09:50PM 01/11/2023 (58610043)	Speaker	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
8th inside women locker room south, 7:09:37PM 01/11/2023 (	Speaker					1-SIG			LTD 01/11

Location	Device Type	Correctly Installed	Requires Service, Repairs, Cleaning or Missing	Alarm Operation Confirmed	Annunciation Indication Confirmed	Zone Circuit Number or Address	Supervision of Wiring Device Confirmed	Ground Circuit Confirmed	Remarks/ Readings
58610044)		<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	/2023
8th lunch room south, 7:11:57PM 01/11/2023 (58610026)	Speaker	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
8th male locker rm north, 7:08:18PM 01/11/2023 (58610020)	Speaker	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
8th male locker rm south, 7:08:29PM 01/11/2023 (58610021)	Speaker	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	1-SIG	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/11 /2023
9th corridor by men's washroom, 7:53:32AM 01/16/2023 (57019770)	Phone Station	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	1-9th floor	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/16 /2023
9th corridor by women's washroom, 7:53:21AM 01/16/2023 (57019744)	Phone Station	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	1-9th floor	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/16 /2023
Penthouse corridor by north stairwell, 10:06:42AM 01/09/2023 (57019691)	Phone Station	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	1-PH	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09 /2023
Penthouse mechanical/fan room GA key, 10:31:23AM 01/09/2023 (57019729)	Initiating Device	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	1-22 19-2758	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09 /2023
Penthouse Electrical Room by Generator room Generator 1 Running, 10:50:37AM 01/04/2023 (58610083)	Generator Running	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	1-24 19-2756	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04 /2023
Penthouse Electrical Room by Generator room Generator 1 Trouble, 10:50:26AM 01/04/2023 (58610084)	Generator Trouble	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	1-26 19-2786	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04 /2023
Penthouse mechanical/fan room SF1 Overhead, 12', 9:07:22AM 01/13/2023 (57019732)	Duct Detector	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	1-9-17 19-2763	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/13 /2023
Penthouse top of elevator shaft accessed through centre elev. barcode on 9th floor elev. doorframe, 9:57:04AM 01/09/2023 (64248502)	Heat Detector	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	1-12 19-2768	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/09 /2023
Penthouse mechanical/fan room RF1 standing height, 9:06:23AM 01/13/2023 (57019730)	Duct Detector	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	1-10-18 19-2762	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/13 /2023
Penthouse mechanical/fan room SF2 standing height, 9:06:39AM 01/13/2023 (57019731)	Duct Detector	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	1-19 19-2761	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/13 /2023
1st electrical room door plaque 111, 7:54:00AM 01/16/2023 (62118586)	Battery	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/16 /2023
4th electrical room Node -3, 7:54:24AM 01/16/2023 (62118731)	Battery	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/16 /2023
7th Electrical/Fire Alarm Panel Room door plaque 704 Left tub, 5:50:23PM 01/10/2023 (58610050)	Battery	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	4	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/10 /2023
7th Electrical/Fire Alarm Panel Room door plaque 704 Main tub, 7:56:31AM 01/16/2023 (58610049)	Battery	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	4	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/16 /2023
8th corridor by men's washroom door plaque 806, 3:17:46PM 01/10/2023 (57019821)	End Of Line	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	4-26 19-2869	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/10 /2023
9th Electrical Room Fire Alarm Panel Room, 9:39:04PM 01/10/2023 (57019733)	Control Panel	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	5	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/10 /2023
9th Electrical Room Fire Alarm Panel Room Left tub, 4:55:05PM 01	Battery					5			LTD 01/10



Location	Device Type	Correctly Installed	Requires Service, Repairs, Cleaning or Missing	Alarm Operation Confirmed	Annunciation Indication Confirmed	Zone Circuit Number or Address	Supervision of Wiring Device Confirmed	Ground Circuit Confirmed	Remarks/ Readings
/10/2023 (57019735)		<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	/2023
9th Electrical Room Fire Alarm Panel Room Main tub, 4:54:43PM 01 /10/2023 (57019734)	Battery	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	5	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/10 /2023
Penthouse Electrical Room by Generator room Generator 2 Running, 10:51:01AM 01/04/2023 (58610081)	Generator Running	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	5-17 19-2671	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04 /2023
Penthouse Electrical Room by Generator room Generator 2 Trouble, 10:50:48AM 01/04/2023 (58610082)	Generator Trouble	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	5-18 19-2670	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04 /2023
4th comp. & comm. room ceiling, s/w by tanks Z-1, 2:13:17PM 01/04 /2023 (58612466)	Smoke Detector	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	6-1 19-2960	<input type="checkbox"/>	<input type="checkbox"/>	LTD 01/04 /2023



# Inspection & Testing

Generated by: BuildingReports.com

Building: Communication, Traffic, & Computer Centre	Control Panel: 1 - SimplexGrinnell 4100
---	---

The Inspection & Testing section lists all of the items inspected in your building. Items are grouped by Passed or Failed/Other. Items are listed by Category. Each item includes the services performed, and the time & date at which testing occurred.

Device Type	Location	Service	Time	Date
<b>Passed</b>				
<b>Auxiliary</b>				
Programmable Relay	Basement Custodial Services Storage Room Telephone Room #21 , Novec System Panel , Zone 1 Active	Annual	10:28:55 AM	01/06/2023
Programmable Relay	Basement Custodial Services Storage Room Telephone Room #21 , Novec System Panel , Zone 2 Active	Annual	10:28:59 AM	01/06/2023
Programmable Relay	Basement Network Comm. room 34/35 Zone 1, first stage FM-200 system	Annual	9:10:03 AM	01/06/2023
Programmable Relay	Basement Network Comm. room 34/35 Zone 2, second stage FM-200 system	Annual	9:09:59 AM	01/06/2023
Programmable Relay	Basement Network Communication Room 1 Novec System Panel , Zone 1 Active	Annual	9:48:10 AM	01/13/2023
Programmable Relay	Basement Network Communication Room 1 Novec System Panel , Zone 2 Active	Annual	9:48:07 AM	01/13/2023
Programmable Relay	Basement Telephone room 33 Damper FM-200 system	Annual	9:57:58 AM	01/06/2023
Programmable Relay	Basement Telephone room 33 Zone 1, first stage FM-200 system	Annual	9:09:44 AM	01/06/2023
Programmable Relay	Basement Telephone room 33 Zone 2, second stage FM-200 system	Annual	9:09:41 AM	01/06/2023
Programmable Relay	Basement corridor mechanical room 032 Pre action zone 2 Active alarm	Annual	10:00:17 AM	01/06/2023
Programmable Relay	Basement corridor mechanical room 032 Zone 1 Pre action zone 1 Active alarm	Annual	10:00:29 AM	01/06/2023
Programmable Relay	7th TPS Computer room main entrance door plaque 724C , Computer Room Damper	Annual	9:41:28 AM	01/04/2023
Programmable Relay	7th TPS Computer room main entrance door plaque 724C . Zone 2 Detectors	Annual	9:41:21 AM	01/04/2023
Programmable Relay	7th TPS Computer room main entrance door plaque 724C. Zone 1 Detectors	Annual	9:41:24 AM	01/04/2023
Programmable Relay	9th computer room Damper FM-200 system	Annual	7:46:32 AM	01/04/2023

Device Type	Location	Service	Time	Date
<b><i>Passed</i></b>				
Programmable Relay	9th computer room Zone 1, first stage FM-200 system	Annual	7:46:59 AM	01/04/2023
Programmable Relay	9th computer room Zone 2, second stage FM-200 system	Annual	7:46:50 AM	01/04/2023
<b>Control</b>				
Annunciator	5th computer room FM-200 system	Annual	10:37:42 AM	01/12/2023
Annunciator	7th computer room FM-200 system	Annual	9:18:13 AM	01/04/2023
Annunciator	7th computer room FM-200 system	Annual	3:17:36 PM	01/10/2023
Annunciator	9th computer room FM-200 system	Annual	8:15:23 AM	01/04/2023
Battery	1st security deck at front entrance	Annual	10:30:49 AM	01/13/2023
Disconnect	1st electrical room RP-1-EA CCT#19 door plaque 111	Annual	5:53:42 PM	01/10/2023
Handset	1st security deck at front entrance	Annual	6:27:52 PM	01/10/2023
Phone Station	1st security deck at front entrance	Annual	6:27:57 PM	01/10/2023
Phone Station	8th corridor by north stair	Annual	11:26:20 AM	01/09/2023
Phone Station	8th corridor by south stairwell	Annual	11:15:05 AM	01/09/2023
Phone Station	Penthouse corridor by south stairwell	Annual	9:36:22 AM	01/09/2023
<b>Indicating</b>				
Horn	Penthouse Battery room	Annual	7:49:11 AM	01/16/2023
Horn	Penthouse Electrical/UPS room	Annual	7:49:15 AM	01/16/2023
Horn	Penthouse Transformer Room By By LBS#1 Transformer	Annual	9:05:51 AM	01/13/2023
Horn	Penthouse Transformer Room By Electrical Room	Annual	9:05:54 AM	01/13/2023
Horn	Penthouse Transformer Room By N/W Roof Exit	Annual	9:05:57 AM	01/13/2023
Horn	Penthouse boiler room far side	Annual	7:48:44 AM	01/16/2023
Horn	Penthouse boiler room near side	Annual	7:48:48 AM	01/16/2023
Horn	Penthouse emergency generator room by gen 1	Annual	7:49:22 AM	01/16/2023
Horn	Penthouse emergency generator room by gen 2	Annual	7:49:19 AM	01/16/2023
Horn	Penthouse mechanical/chiller room by battery room	Annual	7:49:09 AM	01/16/2023
Horn	Penthouse mechanical/chiller room by boiler room	Annual	7:48:56 AM	01/16/2023
Horn	Penthouse mechanical/chiller room by elec. control MCC-1EA	Annual	7:49:02 AM	01/16/2023
Horn	Penthouse mechanical/chiller room by elec. control MCC-1N	Annual	7:49:06 AM	01/16/2023
Horn	Penthouse mechanical/chiller room by exit to corridor	Annual	7:48:51 AM	01/16/2023

Device Type	Location	Service	Time	Date
<b><i>Passed</i></b>				
Horn	Penthouse mechanical/chiller room column by chiller 2	Annual	7:48:59 AM	01/16/2023
Horn	Penthouse mechanical/fan room by entrance	Annual	7:48:41 AM	01/16/2023
Horn	Penthouse mechanical/fan room left side /SF2	Annual	7:48:35 AM	01/16/2023
Horn	Penthouse mechanical/fan room right side /SF1	Annual	7:48:38 AM	01/16/2023
Speaker	Basement Inside Telephone Room 021	Annual	8:06:57 PM	01/11/2023
Speaker	Basement Mechanical Room door plaque 032	Annual	8:07:01 PM	01/11/2023
Speaker	Basement building operations workshop door plaque 018	Annual	8:06:54 PM	01/11/2023
Speaker	Basement building storage column far side door plaque 023	Annual	8:06:41 PM	01/11/2023
Speaker	Basement building storage column near side door plaque 023	Annual	8:06:44 PM	01/11/2023
Speaker	Basement corridor by custodial lunch room door plaque 043	Annual	8:02:50 PM	01/11/2023
Speaker	Basement corridor by elevator pit door plaque 006	Annual	8:00:42 PM	01/11/2023
Speaker	Basement corridor by facility mgmt men's locker room door plaque 012	Annual	8:04:25 PM	01/11/2023
Speaker	Basement corridor by facility mgmt women's locker room door plaque 013	Annual	8:04:56 PM	01/11/2023
Speaker	Basement corridor by facility mgmt women's locker room door plaque 013	Annual	8:05:03 PM	01/11/2023
Speaker	Basement corridor by janitor room door plaque 007	Annual	8:01:29 PM	01/11/2023
Speaker	Basement corridor by mech/fire pump room door plaque 037	Annual	8:02:39 PM	01/11/2023
Speaker	Basement corridor by mechanical room door plaque 020	Annual	8:01:08 PM	01/11/2023
Speaker	Basement corridor by men's washroom door plaque 008	Annual	8:01:53 PM	01/11/2023
Speaker	Basement corridor by network comm. room 1 door plaque 034	Annual	8:02:07 PM	01/11/2023
Speaker	Basement corridor by network comm. room 2 door plaque 035	Annual	8:02:31 PM	01/11/2023
Speaker	Basement corridor by telephone room 33 door plaque 033	Annual	8:02:14 PM	01/11/2023
Speaker	Basement custodial lunch room door plaque 043	Annual	8:02:57 PM	01/11/2023
Speaker	Basement facility mgmt men's locker room door plaque 012	Annual	8:04:17 PM	01/11/2023
Speaker	Basement fitness room door plaque 024	Annual	8:05:44 PM	01/11/2023

Device Type	Location	Service	Time	Date
<b><i>Passed</i></b>				
Speaker	Basement fitness room men's change room door plaque 027	Annual	8:05:54 PM	01/11/2023
Speaker	Basement fitness room women's change room door plaque 026	Annual	8:06:23 PM	01/11/2023
Speaker	Basement hydro vault door plaque 021	Annual	8:06:48 PM	01/11/2023
Speaker	Basement mech/fire pump room door plaque 037	Annual	8:06:38 PM	01/11/2023
Speaker	Basement men's washroom door plaque 008	Annual	8:01:42 PM	01/11/2023
Speaker	Basement outside Telephone Room 021	Annual	8:06:51 PM	01/11/2023
Speaker	Basement shipping & receiving far side door plaque 044	Annual	8:03:32 PM	01/11/2023
Speaker	Basement shipping & receiving near side door plaque 044	Annual	8:03:29 PM	01/11/2023
Speaker	Basement shipping & receiving ramp door plaque 047	Annual	8:03:51 PM	01/11/2023
Speaker	Basement transportation storage door plaque 040	Annual	8:06:34 PM	01/11/2023
Speaker	Basement transportation storage inner door plaque 041	Annual	8:06:31 PM	01/11/2023
Speaker	Basement women's washroom	Annual	8:04:35 PM	01/11/2023
Speaker	1st corridor north by door plaque 112	Annual	7:58:52 PM	01/11/2023
Speaker	1st corridor north by panel RP-1-B	Annual	7:58:43 PM	01/11/2023
Speaker	1st corridor south by door plaque 108B	Annual	7:57:38 PM	01/11/2023
Speaker	1st corridor south by door plaque 111	Annual	7:59:55 PM	01/11/2023
Speaker	1st corridor south by door plaque 1ST2	Annual	7:57:27 PM	01/11/2023
Speaker	1st elevator lobby north	Annual	7:59:00 PM	01/11/2023
Speaker	1st elevator lobby south	Annual	7:55:29 PM	01/11/2023
Speaker	1st men's washroom	Annual	7:58:00 PM	01/11/2023
Speaker	1st north office N/E	Annual	7:59:19 PM	01/11/2023
Speaker	1st north office N/W	Annual	7:59:29 PM	01/11/2023
Speaker	1st north office N/centre	Annual	7:59:26 PM	01/11/2023
Speaker	1st north office S/E	Annual	7:59:15 PM	01/11/2023
Speaker	1st north office S/W	Annual	7:59:32 PM	01/11/2023
Speaker	1st north office S/centre	Annual	7:59:22 PM	01/11/2023
Speaker	1st north office door plaque 127	Annual	7:59:34 PM	01/11/2023
Speaker	1st north office paper copy room	Annual	7:59:12 PM	01/11/2023
Speaker	1st north/west board room	Annual	8:00:01 PM	01/11/2023
Speaker	1st rear lobby	Annual	7:57:50 PM	01/11/2023
Speaker	1st security control office By Lockers	Annual	7:59:38 PM	01/11/2023
Speaker	1st security control office manager office	Annual	7:59:42 PM	01/11/2023

Device Type	Location	Service	Time	Date
<i>Passed</i>				
Speaker	1st security deck at front entrance	Annual	9:25:27 AM	01/13/2023
Speaker	1st south office by door plaque 139	Annual	7:56:55 PM	01/11/2023
Speaker	1st south office by door plaque 141	Annual	7:56:47 PM	01/11/2023
Speaker	1st south office by door plaque 143	Annual	7:55:57 PM	01/11/2023
Speaker	1st south office by door plaque 146	Annual	7:55:48 PM	01/11/2023
Speaker	1st south office centre aisle east	Annual	7:59:45 PM	01/11/2023
Speaker	1st south office centre aisle west	Annual	7:59:48 PM	01/11/2023
Speaker	1st stairwell north	Annual	7:59:58 PM	01/11/2023
Speaker	1st stairwell south	Annual	7:59:52 PM	01/11/2023
Speaker	1st women's washroom	Annual	7:58:18 PM	01/11/2023
Speaker	2nd corridor north by door plaque 2ST1	Annual	7:49:44 PM	01/11/2023
Speaker	2nd corridor south by door plaque 203	Annual	7:54:15 PM	01/11/2023
Speaker	2nd corridor south by door plaque 2ST2	Annual	7:53:49 PM	01/11/2023
Speaker	2nd elevator lobby north by door plaque 210A	Annual	7:54:38 PM	01/11/2023
Speaker	2nd elevator lobby south by door plaque 240	Annual	7:53:39 PM	01/11/2023
Speaker	2nd men's washroom door plaque 206	Annual	7:49:51 PM	01/11/2023
Speaker	2nd office east	Annual	7:50:18 PM	01/11/2023
Speaker	2nd office east cubicles	Annual	7:50:40 PM	01/11/2023
Speaker	2nd office north by door plaque 202	Annual	7:50:08 PM	01/11/2023
Speaker	2nd office north by door plaque 221	Annual	7:54:28 PM	01/11/2023
Speaker	2nd office north by door plaque 224	Annual	7:54:31 PM	01/11/2023
Speaker	2nd office north/east corner	Annual	7:54:34 PM	01/11/2023
Speaker	2nd office north/west corner by door plaque 213	Annual	7:54:22 PM	01/11/2023
Speaker	2nd office north/west corner by door plaque 218B	Annual	7:54:25 PM	01/11/2023
Speaker	2nd office south cubicles	Annual	7:51:44 PM	01/11/2023
Speaker	2nd office south cubicles	Annual	7:51:52 PM	01/11/2023
Speaker	2nd office south cubicles	Annual	7:52:12 PM	01/11/2023
Speaker	2nd office south cubicles	Annual	7:52:23 PM	01/11/2023
Speaker	2nd office south/east corner	Annual	7:51:16 PM	01/11/2023
Speaker	2nd office south/east cubicles	Annual	7:51:01 PM	01/11/2023
Speaker	2nd office south/west corner	Annual	7:52:45 PM	01/11/2023
Speaker	2nd office south/west cubicles	Annual	7:53:08 PM	01/11/2023
Speaker	2nd women's washroom door plaque 209	Annual	7:54:02 PM	01/11/2023
Speaker	3rd Computer Room Above D3AB-C04	Annual	7:48:37 PM	01/11/2023
Speaker	3rd Computer Room Above D3AE-C04	Annual	7:48:40 PM	01/11/2023

Device Type	Location	Service	Time	Date
<i>Passed</i>				
Speaker				
Speaker	3rd Computer Room Above D3AX-C05	Annual	7:48:34 PM	01/11/2023
Speaker	3rd elevator lobby	Annual	7:49:00 PM	01/11/2023
Speaker	3rd men's washroom door plaque 306	Annual	7:44:47 PM	01/11/2023
Speaker	3rd north corridor by door plaque 306	Annual	7:45:02 PM	01/11/2023
Speaker	3rd north office corridor by door plaque 321	Annual	7:44:33 PM	01/11/2023
Speaker	3rd north office west corner cubicles	Annual	7:45:25 PM	01/11/2023
Speaker	3rd north stairwell door plaque 3ST1	Annual	7:49:03 PM	01/11/2023
Speaker	3rd south office by door plaque 3ST2	Annual	7:48:25 PM	01/11/2023
Speaker	3rd south office centre cubicles	Annual	7:46:27 PM	01/11/2023
Speaker	3rd south office centre cubicles	Annual	7:46:34 PM	01/11/2023
Speaker	3rd south office centre cubicles	Annual	7:46:59 PM	01/11/2023
Speaker	3rd south office centre cubicles	Annual	7:48:53 PM	01/11/2023
Speaker	3rd south office east by door plaque 303	Annual	7:48:43 PM	01/11/2023
Speaker	3rd south office east corner cubicles	Annual	7:47:38 PM	01/11/2023
Speaker	3rd south office east corner cubicles	Annual	7:48:50 PM	01/11/2023
Speaker	3rd south office west corner cubicles	Annual	7:46:08 PM	01/11/2023
Speaker	3rd south office west corner cubicles	Annual	7:46:16 PM	01/11/2023
Speaker	3rd south stairwell door plaque 3ST2	Annual	7:48:47 PM	01/11/2023
Speaker	3rd west office	Annual	7:45:39 PM	01/11/2023
Speaker	3rd west office	Annual	7:45:54 PM	01/11/2023
Speaker	3rd women's washroom door plaque 309	Annual	7:48:18 PM	01/11/2023
Speaker	4th computer & communication room door plaque 402	Annual	7:43:21 PM	01/11/2023
Speaker	4th computer & communication room door plaque 402	Annual	7:43:24 PM	01/11/2023
Speaker	4th computer & communication room door plaque 444B	Annual	7:43:45 PM	01/11/2023
Speaker	4th computer & communication room door plaque 444B	Annual	7:43:48 PM	01/11/2023
Speaker	4th computer & communication room door plaque 444D	Annual	7:43:18 PM	01/11/2023
Speaker	4th computer & communication room door plaque 445D	Annual	7:43:35 PM	01/11/2023
Speaker	4th computer & communication room door plaque 445D	Annual	7:43:38 PM	01/11/2023
Speaker	4th computer & communication room door plaque 445D	Annual	7:43:41 PM	01/11/2023
Speaker	4th corridor by elev, north by door plaque 431A	Annual	7:40:57 PM	01/11/2023
Speaker	4th corridor by elev, south by door plaque	Annual	7:43:30 PM	01/11/2023

Device Type	Location	Service	Time	Date
<i>Passed</i>				
	410A			
Speaker	4th corridor north by door plaque 4ST1	Annual	7:40:49 PM	01/11/2023
Speaker	4th maintenance & testing lab door plaque 448	Annual	7:43:12 PM	01/11/2023
Speaker	4th maintenance & testing lab door plaque 448	Annual	7:43:15 PM	01/11/2023
Speaker	4th men's washroom door plaque 406	Annual	7:40:41 PM	01/11/2023
Speaker	4th north office east by door plaque 442	Annual	7:41:23 PM	01/11/2023
Speaker	4th north office north by door plaque 440	Annual	7:41:33 PM	01/11/2023
Speaker	4th north office south by door plaque 431A	Annual	7:41:08 PM	01/11/2023
Speaker	4th north office west by door plaque 431B	Annual	7:41:57 PM	01/11/2023
Speaker	4th north office west by door plaque 436	Annual	7:41:44 PM	01/11/2023
Speaker	4th south corridor by door plaque 448	Annual	7:37:31 PM	01/11/2023
Speaker	4th south corridor by door plaque 4ST2	Annual	7:37:57 PM	01/11/2023
Speaker	4th south office door plaque 410A	Annual	7:42:57 PM	01/11/2023
Speaker	4th south office east cubicles door plaque 412	Annual	7:38:37 PM	01/11/2023
Speaker	4th south office south cubicles door plaque 412	Annual	7:43:09 PM	01/11/2023
Speaker	4th south office west by door plaque 418	Annual	7:42:45 PM	01/11/2023
Speaker	4th west office by door plaque 425	Annual	7:42:35 PM	01/11/2023
Speaker	4th west office by door plaque 428	Annual	7:42:21 PM	01/11/2023
Speaker	4th women's washroom by door plaque 409	Annual	7:37:47 PM	01/11/2023
Speaker	5th RESCU & Active Traffic mgmt, at ramp by Kitchen	Annual	7:29:12 PM	01/11/2023
Speaker	5th TOC corridor by door plaque 543	Annual	7:35:53 PM	01/11/2023
Speaker	5th TOC in front of screens door plaque 502	Annual	7:35:56 PM	01/11/2023
Speaker	5th Traffic, south office s/centre cubicles by door plaque 551	Annual	7:31:33 PM	01/11/2023
Speaker	5th Traffic, south/east office s/e by door plaque 555	Annual	7:31:02 PM	01/11/2023
Speaker	5th Traffic, south/east office s/e corner by door plaque 555	Annual	7:30:51 PM	01/11/2023
Speaker	5th Traffic, south/east office s/e cubicles	Annual	7:31:17 PM	01/11/2023
Speaker	5th Traffic, south/west office by door plaque 514	Annual	7:31:44 PM	01/11/2023
Speaker	5th Traffic, south/west office s/w cubicles	Annual	7:35:49 PM	01/11/2023
Speaker	5th Traffic, west office centre cubicles by door plaque 521	Annual	7:32:32 PM	01/11/2023
Speaker	5th Traffic, west office south cubicles	Annual	7:32:22 PM	01/11/2023
Speaker	5th Traffic, west/north office n/w cubicles	Annual	7:32:56 PM	01/11/2023



Device Type	Location	Service	Time	Date
<b><i>Passed</i></b>				
Speaker	5th Traffic, west/north office north cubicles by door plaque 531	Annual	7:33:13 PM	01/11/2023
Speaker	5th Traffic, west/north office west cubicles by door plaque 523	Annual	7:32:44 PM	01/11/2023
Speaker	5th Transportation Operations Centre door plaque 502	Annual	7:29:43 PM	01/11/2023
Speaker	5th common corridor by elev, north	Annual	7:35:03 PM	01/11/2023
Speaker	5th common corridor by elev, south	Annual	7:35:18 PM	01/11/2023
Speaker	5th common corridor north by door plaque 506	Annual	7:34:53 PM	01/11/2023
Speaker	5th common corridor south by door plaque 5ST2	Annual	7:36:03 PM	01/11/2023
Speaker	5th meeting room & DOC door plaque 535	Annual	7:33:57 PM	01/11/2023
Speaker	5th men's washroom by door plaque 506	Annual	7:34:40 PM	01/11/2023
Speaker	5th stairwell north door plaque 5ST1	Annual	7:35:59 PM	01/11/2023
Speaker	5th stairwell south door plaque 5ST2	Annual	7:36:05 PM	01/11/2023
Speaker	5th women's washroom by door plaque 509	Annual	7:35:36 PM	01/11/2023
Speaker	6th OEM corridor by door plaque 637-A	Annual	7:24:19 PM	01/11/2023
Speaker	6th OEM meeting room A east	Annual	7:21:00 PM	01/11/2023
Speaker	6th OEM meeting room A west	Annual	7:20:51 PM	01/11/2023
Speaker	6th OEM north corridor by TFS	Annual	7:21:22 PM	01/11/2023
Speaker	6th OEM north corridor by disaster recovery	Annual	7:23:10 PM	01/11/2023
Speaker	6th OEM north/east corridor	Annual	7:23:55 PM	01/11/2023
Speaker	6th OEM north/east office north Door plaque 128	Annual	7:23:32 PM	01/11/2023
Speaker	6th OEM north/east office north/centre Door plaque 128	Annual	7:24:07 PM	01/11/2023
Speaker	6th OEM north/east office south Door plaque 128	Annual	7:24:45 PM	01/11/2023
Speaker	6th OEM north/east office south/centre Door plaque 128	Annual	7:24:31 PM	01/11/2023
Speaker	6th OEM office board room Door plaque 645	Annual	7:25:31 PM	01/11/2023
Speaker	6th OEM office lunch room by corridor	Annual	7:25:44 PM	01/11/2023
Speaker	6th OEM office lunch room by kitchen	Annual	7:25:11 PM	01/11/2023
Speaker	6th OEM office lunch room by washroom	Annual	7:24:57 PM	01/11/2023
Speaker	6th OEM office meeting room	Annual	7:28:25 PM	01/11/2023
Speaker	6th OEM office south corridor by door plaque 646	Annual	7:25:55 PM	01/11/2023
Speaker	6th OEM office south corridor by door plaque 649	Annual	7:26:09 PM	01/11/2023
Speaker	6th OEM office south corridor by door	Annual	7:26:23 PM	01/11/2023



Device Type	Location	Service	Time	Date
<i>Passed</i>				
Speaker	plaque 652 6th OEM office south corridor by door plaque 656	Annual	7:26:34 PM	01/11/2023
Speaker	6th OEM office vestibule to common hall by door plaque 659A	Annual	7:27:31 PM	01/11/2023
Speaker	6th TFS Office space centre/east door plaque 654	Annual	7:22:01 PM	01/11/2023
Speaker	6th TFS Office space centre/west door plaque 654	Annual	7:22:10 PM	01/11/2023
Speaker	6th TFS Office space north/east door plaque 654	Annual	7:21:32 PM	01/11/2023
Speaker	6th TFS Office space north/west door plaque 654	Annual	7:21:49 PM	01/11/2023
Speaker	6th TFS Office space south/east door plaque 654	Annual	7:22:37 PM	01/11/2023
Speaker	6th TFS Office space south/west door plaque 654	Annual	7:22:28 PM	01/11/2023
Speaker	6th common corridor by 6ST2 stairwell	Annual	7:27:49 PM	01/11/2023
Speaker	6th common corridor by elev lobby, north	Annual	7:20:43 PM	01/11/2023
Speaker	6th common corridor by elev lobby, south	Annual	7:27:38 PM	01/11/2023
Speaker	6th common corridor by men's washroom by door plaque 607	Annual	7:28:44 PM	01/11/2023
Speaker	6th men's washroom door plaque 607	Annual	7:28:54 PM	01/11/2023
Speaker	6th women's washroom door plaque 609	Annual	7:28:02 PM	01/11/2023
Speaker	7th by handicap washroom door plaque 726A	Annual	7:15:56 PM	01/11/2023
Speaker	7th Audio & Data systems by entrance door plaque 713	Annual	7:19:20 PM	01/11/2023
Speaker	7th Audio & Data systems rear door plaque 713	Annual	7:19:24 PM	01/11/2023
Speaker	7th CAD support left side	Annual	7:19:37 PM	01/11/2023
Speaker	7th CAD support right side	Annual	7:19:34 PM	01/11/2023
Speaker	7th Elevator Lobby	Annual	7:14:57 PM	01/11/2023
Speaker	7th Information Technology Services door plaque 723	Annual	7:15:09 PM	01/11/2023
Speaker	7th Information Technology Services inner room door plaque 723A	Annual	7:19:51 PM	01/11/2023
Speaker	7th Information Technology Services outer room door plaque 723	Annual	7:20:27 PM	01/11/2023
Speaker	7th Restricted Access Area door plaque 714	Annual	7:19:27 PM	01/11/2023
Speaker	7th TPS Comms Admin above reception desk door plaque 713.1A	Annual	7:19:11 PM	01/11/2023
Speaker	7th TPS Comms Admin by offices door plaque 717	Annual	7:19:15 PM	01/11/2023

Device Type	Location	Service	Time	Date
<b><i>Passed</i></b>				
Speaker	7th TPS Comms Admin lunch room door plaque 712B	Annual	7:20:36 PM	01/11/2023
Speaker	7th TPS Computer room N/E	Annual	7:20:12 PM	01/11/2023
Speaker	7th TPS Computer room N/E/E	Annual	7:20:09 PM	01/11/2023
Speaker	7th TPS Computer room N/W	Annual	7:20:15 PM	01/11/2023
Speaker	7th TPS Computer room N/W/W	Annual	7:20:18 PM	01/11/2023
Speaker	7th TPS Computer room S/E	Annual	7:20:06 PM	01/11/2023
Speaker	7th TPS Computer room S/W	Annual	7:19:59 PM	01/11/2023
Speaker	7th TPS Computer room S/centre	Annual	7:20:03 PM	01/11/2023
Speaker	7th corridor by CAD support	Annual	7:17:22 PM	01/11/2023
Speaker	7th corridor by Computer room door plaque 724D	Annual	7:19:43 PM	01/11/2023
Speaker	7th corridor by Electrical room door plaque 704	Annual	7:18:18 PM	01/11/2023
Speaker	7th corridor by elec. panel RP-7A	Annual	7:17:13 PM	01/11/2023
Speaker	7th corridor by handicap washroom door plaque 732	Annual	7:16:51 PM	01/11/2023
Speaker	7th corridor by men's washroom door plaque 706	Annual	7:20:30 PM	01/11/2023
Speaker	7th men's washroom door plaque 706	Annual	7:15:41 PM	01/11/2023
Speaker	7th office at end of hall Sandra Lewis	Annual	7:17:31 PM	01/11/2023
Speaker	7th stairwell north door plaque 7ST1A	Annual	7:15:34 PM	01/11/2023
Speaker	7th stairwell south door plaque 7ST2A	Annual	7:17:56 PM	01/11/2023
Speaker	7th women's washroom door plaque 709	Annual	7:17:50 PM	01/11/2023
Speaker	8th Toronto paramedic room N/E	Annual	7:12:27 PM	01/11/2023
Speaker	8th Toronto paramedic room N/W	Annual	7:12:34 PM	01/11/2023
Speaker	8th Toronto paramedic room S/E	Annual	7:12:22 PM	01/11/2023
Speaker	8th Toronto paramedic room S/W	Annual	7:12:38 PM	01/11/2023
Speaker	8th by communication services	Annual	7:04:28 PM	01/11/2023
Speaker	8th by communication support room	Annual	7:04:57 PM	01/11/2023
Speaker	8th by elevator	Annual	7:03:03 PM	01/11/2023
Speaker	8th classroom N/E	Annual	7:04:49 PM	01/11/2023
Speaker	8th classroom N/W	Annual	7:04:52 PM	01/11/2023
Speaker	8th classroom center	Annual	7:03:30 PM	01/11/2023
Speaker	8th classroom south	Annual	7:03:27 PM	01/11/2023
Speaker	8th communication services by front desk	Annual	7:13:50 PM	01/11/2023
Speaker	8th communication services common area west	Annual	7:13:59 PM	01/11/2023
Speaker	8th communication services inside alarms section	Annual	7:13:54 PM	01/11/2023

Device Type	Location	Service	Time	Date
<b><i>Passed</i></b>				
Speaker	8th corridor by male locker room	Annual	7:11:05 PM	01/11/2023
Speaker	8th corridor by north stair	Annual	7:05:17 PM	01/11/2023
Speaker	8th corridor by south stair	Annual	7:10:07 PM	01/11/2023
Speaker	8th fitness room center	Annual	7:06:07 PM	01/11/2023
Speaker	8th fitness room north	Annual	7:06:11 PM	01/11/2023
Speaker	8th inside communication support by phone support	Annual	7:05:02 PM	01/11/2023
Speaker	8th inside communication support by radio support	Annual	7:05:06 PM	01/11/2023
Speaker	8th inside male washroom	Annual	7:05:20 PM	01/11/2023
Speaker	8th inside women locker room north	Annual	7:08:57 PM	01/11/2023
Speaker	8th inside women locker room south	Annual	7:09:11 PM	01/11/2023
Speaker	8th inside women washroom	Annual	7:10:10 PM	01/11/2023
Speaker	8th lunch room north	Annual	7:11:32 PM	01/11/2023
Speaker	8th male locker rm north	Annual	7:07:32 PM	01/11/2023
Speaker	8th male locker rm south	Annual	7:07:40 PM	01/11/2023
Speaker	9th inside stairwell north side	Annual	9:21:06 AM	01/12/2023
Speaker	9th inside stairwell south side	Annual	9:21:53 AM	01/12/2023
Speaker	Penthouse corridor outside of emergency generator room	Annual	7:49:25 AM	01/16/2023
Speaker	Penthouse corridor outside of fan room	Annual	7:49:32 AM	01/16/2023
Speaker	Penthouse corridor outside of mechanical room	Annual	7:49:29 AM	01/16/2023
Strobe	1st security control office	Tested	9:44:51 AM	01/13/2023
Strobe	5th Traffic, south/east office s/e cubicles	Annual	7:31:21 PM	01/11/2023
Strobe	5th women's washroom by door plaque 509	Annual	7:35:40 PM	01/11/2023
Strobe	9th Mail room Door plaque 921	Annual	9:48:03 AM	01/12/2023
Strobe	9th OHS Door plaque 925	Annual	9:47:55 AM	01/12/2023
Strobe	9th corridor by Electrical Room	Annual	9:47:31 AM	01/12/2023
Strobe	9th corridor by kitchenette Door plaque 931B	Annual	9:47:47 AM	01/12/2023
Strobe	9th corridor by stairwell north Door plaque 9ST1	Annual	9:20:59 AM	01/12/2023
Strobe	9th elevator lobby	Annual	9:48:13 AM	01/12/2023
Strobe	9th handicap washroom	Annual	9:47:37 AM	01/12/2023
Strobe	9th lunch room refrigerator area	Annual	9:47:40 AM	01/12/2023
Strobe	9th lunch room seating area	Annual	9:47:44 AM	01/12/2023
Strobe	9th men's washroom Door plaque 906	Annual	9:48:07 AM	01/12/2023
Strobe	9th office Door plaque 922	Annual	9:48:01 AM	01/12/2023

Device Type	Location	Service	Time	Date
<b><i>Passed</i></b>				
Strobe	9th south call centre	Annual	9:48:16 AM	01/12/2023
Strobe	9th south call centre	Annual	9:48:20 AM	01/12/2023
Strobe	9th storage/supply room restricted access Door plaque 924	Annual	9:47:58 AM	01/12/2023
Strobe	9th training office larger Door plaque 931B	Annual	9:47:50 AM	01/12/2023
Strobe	9th training office smaller Door plaque 926	Annual	9:47:52 AM	01/12/2023
Strobe	9th west call centre	Annual	9:48:23 AM	01/12/2023
Strobe	9th west call centre	Annual	9:48:26 AM	01/12/2023
Strobe	9th west call centre	Annual	9:48:29 AM	01/12/2023
Strobe	9th west call centre	Annual	9:48:32 AM	01/12/2023
Strobe	9th west call centre	Annual	9:48:35 AM	01/12/2023
Strobe	9th west call centre	Annual	9:48:38 AM	01/12/2023
Strobe	9th women's washroom	Annual	9:47:34 AM	01/12/2023
<b>Initiating</b>				
Heat Detector	1st security control office washroom	Tested	9:42:36 AM	01/13/2023
Initiating Device	Basement Custodial Services Storage Room Tel Room #21 , Novec System Panel Alarm	Annual	10:29:09 AM	01/06/2023
Initiating Device	Basement Custodial Services Storage Room Tel Room #21 , Novec System Panel Trouble	Annual	10:29:04 AM	01/06/2023
Initiating Device	Basement Network Communication Room 2 Novec System Panel Alarm	Annual	9:48:13 AM	01/13/2023
Initiating Device	Basement Network Communication Room 2 Novec System Panel trouble	Annual	9:48:15 AM	01/13/2023
Initiating Device	Basement corridor by stair 1 GA key	Tested	9:14:30 AM	01/13/2023
Initiating Device	Basement corridor by stair 2 GA key	Tested	9:10:51 AM	01/13/2023
Initiating Device	Basement fitness room GA key door plaque 024	Tested	9:12:39 AM	01/13/2023
Initiating Device	Basement shipping & receiving ramp GA key door plaque 047	Tested	9:11:43 AM	01/13/2023
Initiating Device	Basement corridor Network Comm. room 34 /35 Alarm FM-200 system	Annual	9:10:07 AM	01/06/2023
Initiating Device	Basement corridor mechanical room 032 Alarm Pre action 21 system	Annual	10:00:22 AM	01/06/2023
Initiating Device	Basement corridor mechanical room 032 Trouble Pre action 1/2/33 system	Annual	10:00:12 AM	01/06/2023
Initiating Device	Basement corridor mechanical room 032 Trouble Pre action 21 system	Annual	10:00:25 AM	01/06/2023
Initiating Device	1st corridor north GA key	Tested	9:27:23 AM	01/13/2023
Initiating Device	1st corridor south GA key	Tested	9:18:24 AM	01/13/2023
Initiating Device	1st elevator lobby GA key	Tested	9:28:47 AM	01/13/2023

Device Type	Location	Service	Time	Date
<i>Passed</i>				
Initiating Device	1st front lobby GA key	Tested	9:29:20 AM	01/13/2023
Initiating Device	1st north office GA key	Tested	9:28:01 AM	01/13/2023
Initiating Device	1st rear turnstile lobby GA key	Tested	9:18:58 AM	01/13/2023
Initiating Device	1st rear vestibule GA key	Tested	9:19:58 AM	01/13/2023
Initiating Device	1st security control office GA key	Tested	9:22:03 AM	01/13/2023
Initiating Device	1st security control office GA key	Tested	9:23:01 AM	01/13/2023
Initiating Device	1st security control office GA key	Tested	9:23:50 AM	01/13/2023
Initiating Device	1st south office GA key	Tested	9:16:57 AM	01/13/2023
Initiating Device	2nd exit north GA key door plaque 2ST1	Tested	9:31:01 AM	01/13/2023
Initiating Device	2nd exit south GA key door plaque 2ST2	Tested	1:05:45 PM	01/09/2023
Initiating Device	2nd office north GA key door plaque 202	Tested	9:32:03 AM	01/13/2023
Initiating Device	2nd office north GA key door plaque 210A	Tested	9:33:17 AM	01/13/2023
Initiating Device	2nd office south GA key door plaque 203	Tested	1:08:14 PM	01/09/2023
Initiating Device	2nd office south GA key door plaque 240	Tested	1:07:04 PM	01/09/2023
Initiating Device	4th common hall GA key by door plaque 406	Tested	1:00:48 PM	01/09/2023
Initiating Device	4th common hall GA key by door plaque 409	Tested	9:44:24 AM	01/13/2023
Initiating Device	4th computers & communication room GA key by door plaque 402	Tested	9:44:28 AM	01/13/2023
Initiating Device	4th computers & communication room GA key by door plaque 444B	Tested	9:44:34 AM	01/13/2023
Initiating Device	4th maintenance & testing lab GA key by door plaque 448	Tested	9:44:39 AM	01/13/2023
Initiating Device	4th north office GA key door plaque 431A	Tested	1:00:15 PM	01/09/2023
Initiating Device	4th south office GA key by door plaque 410A	Tested	12:58:17 PM	01/09/2023
Initiating Device	5th RESCU & Active Traffic mgmt GA	Tested	9:44:13 AM	01/13/2023
Initiating Device	5th TOC GA key door plaque 502	Tested	9:44:05 AM	01/13/2023
Initiating Device	5th Traffic Signal Operations GA	Tested	9:44:19 AM	01/13/2023
Initiating Device	5th common hall GA key by door plaque 506	Tested	9:44:00 AM	01/13/2023
Initiating Device	5th common hall GA key by door plaque 509	Tested	9:43:56 AM	01/13/2023
Initiating Device	5th meeting room & DOC door plaque 535 GA	Tested	12:53:01 PM	01/09/2023
Initiating Device	6th OEM lunch room exit GA key	Tested	9:43:52 AM	01/13/2023
Initiating Device	6th OEM south corridor GA key door plaque 655	Annual	10:31:18 AM	01/13/2023
Initiating Device	6th common hall GA key by door plaque 607	Tested	12:36:10 PM	01/09/2023
	6th common hall GA key by door plaque	Tested	12:38:02 PM	01/09/2023

Device Type	Location	Service	Time	Date
<b><i>Passed</i></b>				
Initiating Device	609			
Initiating Device	7th T.R.I.P room Alarm FM-200 system	Annual	7:16:04 PM	01/11/2023
Initiating Device	7th T.R.I.P room supervisory FM-200 system	Annual	7:15:59 PM	01/11/2023
Initiating Device	7th TPS Computer room main entrance door plaque 724C	Annual	10:05:47 AM	01/04/2023
Initiating Device	7th TPS Computer room main entrance door plaque 724C , FM-200 Panel Low Press Switch	Annual	9:41:32 AM	01/04/2023
Initiating Device	7th TPS Computer room main entrance door plaque 724C, FM-200 Panel Alarm	Annual	9:41:36 AM	01/04/2023
Initiating Device	7th TPS Computer room main entrance door plaque 724C, FM-200 Panel Trouble	Annual	9:41:40 AM	01/04/2023
Initiating Device	7th TPS Computer room main entrance door plaque 724D	Annual	10:03:08 AM	01/04/2023
Initiating Device	7th corridor by north stairs GA key door plaque 7ST1A	Tested	12:10:44 PM	01/09/2023
Initiating Device	7th corridor by south stairs GA key door plaque 7ST2A	Tested	12:02:14 PM	01/09/2023
Initiating Device	7th stairwell south GA key door plaque 7ST2A	Tested	12:31:36 PM	01/09/2023
Initiating Device	7th top of mid stairwell north GA key	Tested	12:16:02 PM	01/09/2023
Initiating Device	7th top of mid stairwell south GA key	Tested	12:33:27 PM	01/09/2023
Initiating Device	8th corridor by north stair GA key	Annual	11:26:14 AM	01/09/2023
Initiating Device	8th elevator lobby north GA key	Annual	11:06:35 AM	01/09/2023
Initiating Device	8th elevator lobby south GA key	Annual	11:05:59 AM	01/09/2023
Initiating Device	9th corridor exit to stairwell north GA key	Annual	10:34:03 AM	01/09/2023
Initiating Device	9th corridor exit to stairwell south GA key	Annual	10:47:51 AM	01/09/2023
Initiating Device	9th elevator lobby north GA key	Annual	10:44:20 AM	01/09/2023
Initiating Device	9th elevator lobby south GA key	Annual	10:44:53 AM	01/09/2023
Initiating Device	Penthouse exit to north stairwell GA key	Annual	10:04:49 AM	01/09/2023
Initiating Device	Penthouse exit to south stairwell GA key	Annual	9:35:27 AM	01/09/2023
Initiating Device	Penthouse inside south stairwell GA key	Annual	10:22:53 AM	01/09/2023
Initiating Device	Penthouse mechanical/chiller room GA key	Annual	9:53:58 AM	01/09/2023
Initiating Device	Penthouse top of north stairwell GA key	Annual	10:07:31 AM	01/09/2023
Pull Station	Basement corridor exit to stair 1 door plaque 0ST1	Tested	9:14:25 AM	01/13/2023
Pull Station	Basement corridor exit to stair 2 door plaque 0ST2	Tested	9:10:24 AM	01/13/2023
Pull Station	Basement fitness room door plaque 024	Tested	9:12:31 AM	01/13/2023
Pull Station	Basement shipping & receiving ramp door plaque 047	Tested	9:11:26 AM	01/13/2023



Device Type	Location	Service	Time	Date
<b><i>Passed</i></b>				
Pull Station	1st corridor north	Tested	9:27:17 AM	01/13/2023
Pull Station	1st corridor south exit east	Tested	9:17:59 AM	01/13/2023
Pull Station	1st elevator lobby	Tested	9:28:41 AM	01/13/2023
Pull Station	1st front lobby	Tested	9:29:15 AM	01/13/2023
Pull Station	1st north office paper copy room exit	Tested	9:27:49 AM	01/13/2023
Pull Station	1st rear turnstile lobby	Tested	9:18:53 AM	01/13/2023
Pull Station	1st rear vestibule	Tested	9:19:52 AM	01/13/2023
Pull Station	1st security control office exit to lobby	Tested	9:22:53 AM	01/13/2023
Pull Station	1st security control office exit to vestibule	Tested	9:23:42 AM	01/13/2023
Pull Station	1st security control office vestibule	Tested	9:21:55 AM	01/13/2023
Pull Station	1st south office exit to lobby	Tested	9:17:09 AM	01/13/2023
Pull Station	2nd corridor exit north door plaque 2ST1	Tested	9:31:08 AM	01/13/2023
Pull Station	2nd office north door plaque 202	Tested	9:32:08 AM	01/13/2023
Pull Station	2nd office north door plaque 210A	Tested	9:33:12 AM	01/13/2023
Pull Station	2nd office south door plaque 240	Tested	1:06:57 PM	01/09/2023
Pull Station	3rd Computer Room Centre Exit	Tested	12:25:09 PM	01/12/2023
Pull Station	3rd Computer Room North Exit	Tested	12:25:05 PM	01/12/2023
Pull Station	3rd Computer Room South Exit	Tested	12:25:13 PM	01/12/2023
Pull Station	3rd elevator lobby north	Tested	1:03:30 PM	01/09/2023
Pull Station	3rd elevator lobby south	Tested	1:02:32 PM	01/09/2023
Pull Station	3rd north corridor exit to stairs by door plaque 3ST1	Tested	1:03:52 PM	01/09/2023
Pull Station	3rd south office exit to stairs by door plaque 3ST2	Tested	1:01:36 PM	01/09/2023
Pull Station	4th common hall by men's washroom Door plaque 406	Tested	1:00:41 PM	01/09/2023
Pull Station	4th common hall by women's washroom Door plaque 409	Tested	12:56:42 PM	01/09/2023
Pull Station	4th computer & communications room Door plaque 402	Tested	12:24:47 PM	01/12/2023
Pull Station	4th computer & communications room Door plaque 444B	Tested	12:24:43 PM	01/12/2023
Pull Station	4th maintenance & testing lab Door plaque 448	Tested	12:24:41 PM	01/12/2023
Pull Station	4th north office Door plaque 431A	Tested	12:59:15 PM	01/09/2023
Pull Station	5th RESCU & Active Traffic mgmt	Tested	12:24:53 PM	01/12/2023
Pull Station	5th Traffic Signal Operations	Tested	12:54:58 PM	01/09/2023
Pull Station	5th Transportation Operations Centre Door plaque 502	Annual	7:29:39 PM	01/11/2023
Pull Station	5th common hall by men's washroom Door plaque 506	Tested	12:44:26 PM	01/09/2023

Device Type	Location	Service	Time	Date
<b><i>Passed</i></b>				
Pull Station	5th common hall by women's washroom Door plaque 509	Tested	12:45:12 PM	01/09/2023
Pull Station	5th meeting room & DOC door plaque 535	Tested	12:52:27 PM	01/09/2023
Pull Station	6th OEM office lunch room exit	Tested	12:39:51 PM	01/09/2023
Pull Station	6th OEM south corridor exit to common hall door plaque 655	Tested	12:42:04 PM	01/09/2023
Pull Station	6th common hall by men's washroom Door plaque 607	Tested	12:36:04 PM	01/09/2023
Pull Station	6th common hall by women's washroom Door plaque 609	Tested	12:37:34 PM	01/09/2023
Pull Station	7th TPS Computer room main entrance door plaque 724C	Annual	10:06:00 AM	01/04/2023
Pull Station	7th TPS Computer room main entrance door plaque 724D	Annual	10:04:10 AM	01/04/2023
Pull Station	7th corridor by north stairs door plaque 7ST1A	Tested	12:10:28 PM	01/09/2023
Pull Station	7th corridor by south stairs door plaque 7ST2A	Tested	12:01:28 PM	01/09/2023
Pull Station	7th elevator lobby by door to Computer room side	Tested	12:05:41 PM	01/09/2023
Pull Station	8th corridor by north stair	Annual	11:26:10 AM	01/09/2023
Pull Station	8th corridor by south stair	Annual	11:14:40 AM	01/09/2023
Pull Station	8th corridor elevator lobby north	Annual	11:06:40 AM	01/09/2023
Pull Station	8th corridor elevator lobby south	Annual	11:06:04 AM	01/09/2023
Pull Station	9th corridor exit to stairwell north	Annual	10:33:41 AM	01/09/2023
Pull Station	9th corridor exit to stairwell south	Annual	10:47:56 AM	01/09/2023
Pull Station	9th elevator lobby north	Annual	10:43:53 AM	01/09/2023
Pull Station	9th elevator lobby south	Annual	10:44:40 AM	01/09/2023
Pull Station	Penthouse exit to north stairwell	Annual	10:04:10 AM	01/09/2023
Pull Station	Penthouse exit to south stairwell	Annual	9:34:54 AM	01/09/2023
Pull Station	Penthouse inside south stairwell stair 2	Annual	10:22:30 AM	01/09/2023
Pull Station	Penthouse mechanical/chiller room exit to corridor	Annual	10:23:44 AM	01/09/2023
Pull Station	Penthouse mechanical/fan room	Annual	10:30:12 AM	01/09/2023
Pull Station	Penthouse top of north stairwell stair 1	Annual	10:07:11 AM	01/09/2023
Smoke Detector	Basement Elevator Lobby	Tested/Cleaned	9:09:38 AM	01/13/2023
Smoke Detector	1st Elevator Lobby	Tested/Cleaned	9:15:30 AM	01/13/2023
Smoke Detector	1st security control office centre	Tested/Cleaned	9:34:14 AM	01/13/2023
Smoke Detector	1st security control office lobby	Tested/Cleaned	9:24:48 AM	01/13/2023
Smoke Detector	1st security control office vestibule	Tested/Cleaned	9:34:17 AM	01/13/2023
Smoke Detector	7th mid stairwell north	Tested/Cleaned	9:38:37 AM	01/13/2023



Device Type	Location	Service	Time	Date
<b><i>Passed</i></b>				
Smoke Detector	7th mid stairwell south	Tested/Cleaned	9:37:29 AM	01/13/2023
Smoke Detector	8th Elevator Lobby	Annual	11:07:33 AM	01/09/2023
Smoke Detector	9th Elevator Lobby	Annual	10:46:45 AM	01/09/2023
Smoke Detector	Penthouse Top of North Stair 1	Annual	10:13:44 AM	01/09/2023
Smoke Detector	Penthouse inside south stairwell stair 2	Annual	10:21:55 AM	01/09/2023
Smoke Detector	Roof top of south stairwell stair 3	Annual	10:15:03 AM	01/09/2023
<b>Monitor</b>				
Monitoring	1st security deck at front entrance	Annual	6:28:16 PM	01/10/2023
<b>Supervisory</b>				
End Of Line	Basement corridor by stair 1 door plaque 0ST1	Annual	10:19:11 AM	01/13/2023
End Of Line	Basement corridor by stair 1 door plaque 0ST1	Annual	10:19:15 AM	01/13/2023
End Of Line	Basement corridor by stair 1 door plaque 0ST1	Annual	10:19:18 AM	01/13/2023
End Of Line	Basement electrical room door plaque 005	Annual	10:04:16 AM	01/13/2023
End Of Line	Basement electrical room door plaque 005	Annual	10:04:20 AM	01/13/2023
End Of Line	Basement electrical room door plaque 005 , rm Elevator Pit Zone	Annual	10:04:12 AM	01/13/2023
End Of Line	Basement electrical room 020 034 door plaque 005 , Smoke Rm 20, N32	Annual	10:04:23 AM	01/13/2023
End Of Line	1st electrical room door plaque 111	Annual	11:45:51 AM	01/12/2023
End Of Line	1st electrical room door plaque 111	Annual	11:45:54 AM	01/12/2023
End Of Line	1st janitor room door plaque 112	Annual	11:35:02 AM	01/12/2023
End Of Line	1st janitor room door plaque 112	Annual	11:35:06 AM	01/12/2023
End Of Line	2nd corridor north by door plaque 202	Annual	11:22:36 AM	01/12/2023
End Of Line	2nd corridor north by door plaque 202	Annual	11:22:38 AM	01/12/2023
End Of Line	2nd corridor north by door plaque 202	Annual	11:25:09 AM	01/12/2023
End Of Line	2nd electrical room door plaque 204	Annual	11:25:53 AM	01/12/2023
End Of Line	2nd electrical room door plaque 204	Annual	11:25:56 AM	01/12/2023
End Of Line	3rd common corridor by men's washroom door plaque 306	Annual	11:04:21 AM	01/12/2023
End Of Line	3rd common corridor by men's washroom door plaque 306	Annual	11:04:24 AM	01/12/2023
End Of Line	3rd common corridor by men's washroom door plaque 306	Annual	11:04:28 AM	01/12/2023
End Of Line	3rd electrical room door plaque 304	Annual	11:15:25 AM	01/12/2023
End Of Line	3rd electrical room door plaque 304	Annual	11:15:28 AM	01/12/2023
End Of Line	4th common hall by men's washroom Door plaque 406	Annual	10:57:55 AM	01/12/2023
End Of Line	4th common hall by men's washroom Door	Annual	10:58:01 AM	01/12/2023

Device Type	Location	Service	Time	Date
<i>Passed</i>				
	plaque 406			
End Of Line	4th common hall by men's washroom Door plaque 406	Annual	10:58:06 AM	01/12/2023
End Of Line	4th electrical room by door plaque 404	Annual	11:03:28 AM	01/12/2023
End Of Line	4th electrical room by door plaque 404	Annual	11:03:31 AM	01/12/2023
End Of Line	5th Traffic, south/east office s/e cubicles	Annual	9:48:49 AM	01/13/2023
End Of Line	5th common corridor by janitor room door plaque 505	Annual	10:45:01 AM	01/12/2023
End Of Line	5th common corridor by janitor room door plaque 505	Annual	10:45:04 AM	01/12/2023
End Of Line	5th common corridor by janitor room door plaque 505	Annual	10:45:08 AM	01/12/2023
End Of Line	5th electrical room door plaque 504	Annual	10:50:24 AM	01/12/2023
End Of Line	5th electrical room door plaque 504	Annual	10:50:27 AM	01/12/2023
End Of Line	6th common corridor by men's washroom door plaque 607	Annual	10:32:14 AM	01/12/2023
End Of Line	6th common hall GA key by door plaque 607	Annual	10:32:23 AM	01/12/2023
End Of Line	6th common hall by men's washroom Door plaque 607	Annual	10:32:20 AM	01/12/2023
End Of Line	6th electrical room door plaque 604	Annual	10:37:26 AM	01/12/2023
End Of Line	6th electrical room door plaque 604	Annual	10:37:30 AM	01/12/2023
End Of Line	7th TPS Computer room N/W closet End of line relay	Annual	9:55:15 AM	01/12/2023
End Of Line	7th TPS Computer room N/W closet End of line relay	Annual	9:55:18 AM	01/12/2023
End Of Line	7th corridor by men's washroom door plaque 706 , 7th FI GA	Annual	10:11:03 AM	01/12/2023
End Of Line	7th corridor by men's washroom door plaque 706 , 7th FI. Pull Stations	Annual	10:10:59 AM	01/12/2023
End Of Line	7th mid stairwell south	Annual	9:37:23 AM	01/13/2023
End Of Line	9th Electrical Room Fire Alarm Panel Room Elevator Shaft	Annual	11:00:57 AM	01/09/2023
End Of Line	9th corridor by stairwell north Door plaque 9ST1 , 9th FI Zone	Annual	10:40:13 AM	01/09/2023
End Of Line	9th corridor by stairwell north Door plaque 9ST1 , 9th FI GA	Annual	10:37:52 AM	01/09/2023
End Of Line	Penthouse Electrical/Transformer room by elec. room Flow Switch P1	Annual	9:46:44 AM	01/09/2023
End Of Line	Penthouse Electrical/Transformer room by elec. room Flow switch P2	Annual	9:49:09 AM	01/09/2023
End Of Line	Penthouse Electrical/Transformer room by gen room Generator 1 trouble	Annual	10:03:10 AM	01/09/2023
End Of Line	Penthouse mechanical/fan room by entrance GA zone	Annual	10:27:19 AM	01/09/2023

Device Type	Location	Service	Time	Date
<b><i>Passed</i></b>				
End Of Line	Penthouse mechanical/fan room by entrance PH Zone	Annual	10:26:30 AM	01/09/2023
Fault Isolation Module	Basement Electrical Room	Annual	10:04:04 AM	01/13/2023
Fault Isolation Module	Basement Electrical Room	Annual	10:04:08 AM	01/13/2023
Device Type	Location	Service	Time	Date
<b><i>Failed/Other</i></b>				
<b>Control</b>				
Annunciator	1st security deck at front entrance	Annual	9:01:43 AM	01/13/2023
Control Panel	1st security deck at front entrance	Annual	8:14:47 AM	01/16/2023
Phone Station	Basement corridor by stair 1 door plaque 0ST1	Annual	7:50:42 AM	01/16/2023
Phone Station	Basement corridor by stair 2 door plaque 0ST2	Annual	7:50:29 AM	01/16/2023
Phone Station	1st corridor south exit east	Annual	7:50:52 AM	01/16/2023
Phone Station	1st front lobby	Annual	7:51:11 AM	01/16/2023
Phone Station	1st rear turnstile lobby	Annual	7:51:02 AM	01/16/2023
Phone Station	2nd common corridor by men's washroom door plaque 206	Annual	7:51:24 AM	01/16/2023
Phone Station	2nd common corridor by women's washroom door plaque 209	Annual	7:51:32 AM	01/16/2023
Phone Station	3rd common corridor by men's washroom door plaque 306	Annual	7:51:42 AM	01/16/2023
Phone Station	3rd common corridor by women's washroom door plaque 309	Annual	7:51:50 AM	01/16/2023
Phone Station	4th common corridor by men's washroom door plaque 406	Annual	7:52:06 AM	01/16/2023
Phone Station	4th common corridor by women's washroom door plaque 409	Annual	7:52:16 AM	01/16/2023
Phone Station	5th common corridor by men's washroom door plaque 506	Annual	7:52:26 AM	01/16/2023
Phone Station	5th common corridor by women's washroom door plaque 509	Annual	7:52:35 AM	01/16/2023
Phone Station	6th common corridor by men's washroom door plaque 607	Annual	7:52:44 AM	01/16/2023
Phone Station	6th common corridor by women's washroom door plaque 609	Tested	12:20:15 PM	01/09/2023
Phone Station	7th corridor by men's washroom door plaque 706	Annual	7:53:11 AM	01/16/2023
Phone Station	7th corridor by women's washroom door plaque 709	Annual	7:52:56 AM	01/16/2023
Phone Station	9th corridor by men's washroom	Annual	7:53:32 AM	01/16/2023
Phone Station	9th corridor by women's washroom	Annual	7:53:21 AM	01/16/2023

Device Type	Location	Service	Time	Date
<b><i>Failed/Other</i></b>				
Phone Station	Penthouse corridor by north stairwell	Annual	10:06:42 AM	01/09/2023
<b>Indicating</b>				
Speaker	8th Toronto paramedic room S/E	Annual	7:13:25 PM	01/11/2023
Speaker	8th fitness room south	Annual	7:07:08 PM	01/11/2023
Speaker	8th inside women locker room north	Annual	7:09:50 PM	01/11/2023
Speaker	8th inside women locker room south	Annual	7:09:37 PM	01/11/2023
Speaker	8th lunch room south	Annual	7:11:57 PM	01/11/2023
Speaker	8th male locker rm north	Annual	7:08:18 PM	01/11/2023
Speaker	8th male locker rm south	Annual	7:08:29 PM	01/11/2023
<b>Initiating</b>				
Duct Detector	Penthouse mechanical/fan room RF1 standing height	Annual	9:06:23 AM	01/13/2023
Duct Detector	Penthouse mechanical/fan room SF1 Overhead, 12'	Annual	9:07:22 AM	01/13/2023
Duct Detector	Penthouse mechanical/fan room SF2 standing height	Annual	9:06:39 AM	01/13/2023
Heat Detector	Basement elevator 1&2 pit door plaque 006 barcode on exterior doorframe	Annual	9:15:03 AM	01/06/2023
Heat Detector	Basement elevator 3 pit barcode on exterior doorframe	Annual	9:09:32 AM	01/13/2023
Heat Detector	Penthouse top of elevator shaft accessed through centre elev. barcode on 9th floor elev. doorframe	Annual	9:57:04 AM	01/09/2023
Initiating Device	Basement fitness room woman's locker room GA key door plaque 026	Annual	9:47:54 AM	01/13/2023
Initiating Device	7th elevator lobby right side GA key	Tested	12:06:52 PM	01/09/2023
Initiating Device	7th stairwell north GA key door plaque 7ST1A	Tested	12:29:38 PM	01/09/2023
Initiating Device	8th corridor by south stair GA key	Annual	11:14:56 AM	01/09/2023
Initiating Device	Penthouse mechanical/fan room GA key	Annual	10:31:23 AM	01/09/2023
Pull Station	Basement fitness room women's locker room door plaque 026	Tested	9:30:11 AM	01/13/2023
Pull Station	2nd corridor exit south door plaque 2ST2	Tested	1:06:23 PM	01/09/2023
Pull Station	2nd office south door plaque 203	Tested	9:32:51 AM	01/13/2023
Pull Station	7th stairwell north door plaque 7ST1A	Tested	12:28:54 PM	01/09/2023
Pull Station	7th stairwell south door plaque 7ST2A	Tested	12:33:47 PM	01/09/2023
Pull Station	7th top of mid stairwell north	Tested	12:30:14 PM	01/09/2023
Pull Station	7th top of mid stairwell south	Tested	12:32:59 PM	01/09/2023
<b>Supervisory</b>				
End Of Line	7th mid stairwell north	Annual	10:22:24 AM	01/12/2023
Generator Running	Penthouse Electrical Room by Generator	Annual	10:50:37 AM	01/04/2023

Device Type	Location	Service	Time	Date
<i>Failed/Other</i>				
Generator Trouble	room Generator 1 Running Penthouse Electrical Room by Generator room Generator 1 Trouble	Annual	10:50:26 AM	01/04/2023

<b>Building: Communication, Traffic, &amp; Computer Centre</b>	<b>Control Panel: 2 - SimplexGrinnell 4100</b>
--	--

*The Inspection & Testing section lists all of the items inspected in your building. Items are grouped by Passed or Failed/Other. Items are listed by Category. Each item includes the services performed, and the time & date at which testing occurred.*

Device Type	Location	Service	Time	Date
<b>Passed</b>				
<b>Control</b>				
Battery	1st electrical room amplifier door plaque 111	Annual	10:30:39 AM	01/13/2023
Control Panel	1st electrical room Node -2	Annual	10:30:43 AM	01/13/2023
Disconnect	7th Electrical/Fire Alarm Panel Room door plaque 704 FM200	Annual	5:49:32 PM	01/10/2023
Disconnect	8th Electrical room door plaque 804 RP-8-UA, CCT#39 , Node 2 1st Floor	Annual	4:39:53 PM	01/10/2023
<b>Initiating</b>				
Initiating Device	Basement corridor Network Comm. room 34 /35 Pressure FM-200 system	Annual	9:10:11 AM	01/06/2023
Initiating Device	Basement corridor Network Comm. room 34 /35 Trouble FM-200 system	Annual	9:10:09 AM	01/06/2023
Initiating Device	Basement corridor Telephone room 33 Alarm FM-200 system	Annual	9:09:55 AM	01/06/2023
Initiating Device	Basement corridor Telephone room 33 Pressure FM-200 system	Annual	9:09:48 AM	01/06/2023
Initiating Device	Basement corridor Telephone room 33 Trouble FM-200 system	Annual	9:09:51 AM	01/06/2023
Initiating Device	Basement corridor mechanical room 032 Alarm Pre action 1/2/33 system	Annual	10:00:08 AM	01/06/2023
Smoke Detector	Basement ceiling Network Comm. room 34 /35 by entrance	Annual	9:10:30 AM	01/06/2023
Smoke Detector	Basement ceiling Network Comm. room 34 /35 by entrance FM-200 system	Annual	9:10:24 AM	01/06/2023
Smoke Detector	Basement ceiling Network Comm. room 34 /35 middle FM-200 system	Annual	9:10:33 AM	01/06/2023
Smoke Detector	Basement ceiling Network Comm. room 34 /35 rear FM-200 system	Annual	9:10:37 AM	01/06/2023
Smoke Detector	Basement ceiling Telephone room 33 by entrance west FM-200 system, Zone -1	Annual	9:58:16 AM	01/06/2023
Smoke Detector	Basement ceiling Telephone room 33 east FM-200 system, Z-2	Annual	9:58:20 AM	01/06/2023
Smoke Detector	2nd Elevator Lobby	Tested/Cleaned	9:34:49 AM	01/13/2023
<b>Supervisory</b>				
End Of Line	Basement corridor above ceiling by electrical room Door plaque 005	Annual	9:50:32 AM	01/13/2023
End Of Line	Basement corridor above ceiling by janitor closet Door plaque 007	Annual	9:50:28 AM	01/13/2023
End Of Line	Basement mech/fire pump room Door	Annual	8:36:10 AM	01/06/2023

Device Type	Location	Service	Time	Date
<i>Passed</i>				
	plaque 037			
End Of Line	Basement mech/fire pump room Door	Annual	8:37:30 AM	01/06/2023
	plaque 037			
End Of Line	Basement mech/fire pump room FS Ground Floor Sprinkler	Annual	8:51:33 AM	01/06/2023
End Of Line	Basement mech/fire pump room FS Main Sprinkler	Annual	8:46:23 AM	01/06/2023
End Of Line	Basement mech/fire pump room FS Refuse	Annual	8:50:35 AM	01/06/2023
End Of Line	Basement mech/fire pump room Low Pressure	Annual	9:16:13 AM	01/06/2023
End Of Line	Basement mech/fire pump room SV07 Bypass Valve For Fire Pump 2	Annual	8:54:08 AM	01/06/2023
End Of Line	Basement mech/fire pump room SV08 Bypass Valve For Fire Pump 2	Annual	8:53:27 AM	01/06/2023
End Of Line	Basement mech/fire pump room SV1 Main Water Supply To Building	Annual	8:44:01 AM	01/06/2023
End Of Line	Basement mech/fire pump room SV11 Supply Valve To Sprinkler System	Annual	8:53:38 AM	01/06/2023
End Of Line	Basement mech/fire pump room SV12 Alarm Valve Control	Annual	8:48:17 AM	01/06/2023
End Of Line	Basement mech/fire pump room SV13 Ground Floor Sprinkler	Annual	8:51:05 AM	01/06/2023
End Of Line	Basement mech/fire pump room SV14 Refuse Compactor Sprinklers	Annual	8:45:39 AM	01/06/2023
End Of Line	Basement mech/fire pump room SV15 Basement Sprinklers	Annual	8:41:01 AM	01/06/2023
End Of Line	Basement mech/fire pump room SV16 Sprinkler Pump Suction	Annual	8:49:54 AM	01/06/2023
End Of Line	Basement mech/fire pump room SV17 Sprinkler Pump Discharge	Annual	9:13:05 AM	01/06/2023
End Of Line	Basement mech/fire pump room SV18 Sprinkler Pump Bypass	Annual	8:48:23 AM	01/06/2023
End Of Line	Basement mech/fire pump room SV19 Sprinkler Pump Bypass	Annual	8:48:51 AM	01/06/2023
End Of Line	Basement mech/fire pump room SV2	Annual	8:43:14 AM	01/06/2023
End Of Line	Basement mech/fire pump room SV20 Pump Test Header	Annual	9:12:28 AM	01/06/2023
End Of Line	Basement mech/fire pump room SV3 ISO Valve For Back-flow Preventor	Annual	8:42:31 AM	01/06/2023
End Of Line	Basement mech/fire pump room SV5 ISO Valve For Fire Pump 2	Annual	8:44:42 AM	01/06/2023
End Of Line	Basement mech/fire pump room SV6 ISO Valve For Fire Pump 2	Annual	8:47:26 AM	01/06/2023
End Of Line	1st electrical room door plaque 111	Annual	11:40:50 AM	01/12/2023
End Of Line	1st electrical room door plaque 111	Annual	11:40:53 AM	01/12/2023
End Of Line	1st electrical room door plaque 111	Annual	11:40:57 AM	01/12/2023



Device Type	Location	Service	Time	Date
<b><i>Passed</i></b>				
End Of Line	2nd janitor room FS 2nd Floor Door plaque 205	Annual	10:47:32 AM	01/06/2023
End Of Line	2nd janitor room SV2.1 2nd Flr Sprinkler Door plaque 205	Annual	10:47:17 AM	01/06/2023
Fault Isolation Module	2nd Electrical Room	Annual	11:25:43 AM	01/12/2023
Fault Isolation Module	2nd Electrical Room	Annual	11:25:46 AM	01/12/2023
Device Type	Location	Service	Time	Date
<b><i>Failed/Other</i></b>				
<b>Control</b>				
Battery	1st electrical room door plaque 111	Annual	7:54:00 AM	01/16/2023

<b>Building: Communication, Traffic, &amp; Computer Centre</b>	<b>Control Panel: 3 - SimplexGrinnell 4100</b>
--	--

*The Inspection & Testing section lists all of the items inspected in your building. Items are grouped by Passed or Failed/Other. Items are listed by Category. Each item includes the services performed, and the time & date at which testing occurred.*

Device Type	Location	Service	Time	Date
<b>Passed</b>				
<b>Control</b>				
Battery	4th electrical room Amplifier Cabinet	Annual	10:59:04 AM	01/12/2023
Control Panel	4th electrical room by door plaque 404	Annual	10:58:53 AM	01/12/2023
Disconnect	8th Electrical room door plaque 804 RP-8-UA, CCT#37 4th FI to Panel	Annual	4:39:40 PM	01/10/2023
<b>Initiating</b>				
Pull Station	4th south office Door plaque 410A	Tested	12:57:30 PM	01/09/2023
Smoke Detector	3rd Elevator Lobby	Tested/Cleaned	9:42:00 AM	01/13/2023
Smoke Detector	3rd Computer Room , Under Floor N/C Area Z-1	Annual	8:13:02 PM	01/11/2023
Smoke Detector	3rd Computer Room , Under Floor N/C Area Z-1	Annual	8:13:13 PM	01/11/2023
Smoke Detector	3rd Computer Room , Under Floor N/C Area Z-1 , by FM -200 Tanks	Annual	8:12:57 PM	01/11/2023
Smoke Detector	3rd Computer Room , Under Floor N/C Area Z-2	Annual	8:12:53 PM	01/11/2023
Smoke Detector	3rd Computer Room , Under Floor N/C Area Z-2	Annual	8:13:00 PM	01/11/2023
Smoke Detector	3rd Computer Room , Under Floor N/C Area Z-2	Annual	8:13:07 PM	01/11/2023
Smoke Detector	3rd Computer Room , Under Floor N/E Area Z-1	Annual	8:12:09 PM	01/11/2023
Smoke Detector	3rd Computer Room , Under Floor N/E Area Z-1	Annual	8:12:42 PM	01/11/2023
Smoke Detector	3rd Computer Room , Under Floor N/E Area Z-1 , by D3AS-C01	Annual	8:12:22 PM	01/11/2023
Smoke Detector	3rd Computer Room , Under Floor N/E Area Z-1 by D3AP-C01	Annual	8:12:36 PM	01/11/2023
Smoke Detector	3rd Computer Room , Under Floor N/E Area Z-1 by D3AU-C01	Annual	8:12:49 PM	01/11/2023
Smoke Detector	3rd Computer Room , Under Floor N/E Area Z-1 by D3AZ-CO6	Annual	8:12:29 PM	01/11/2023
Smoke Detector	3rd Computer Room , Under Floor N/E Area Z-2	Annual	8:12:32 PM	01/11/2023
Smoke Detector	3rd Computer Room , Under Floor N/E Area Z-2	Annual	8:12:39 PM	01/11/2023
Smoke Detector	3rd Computer Room , Under Floor N/E Area Z-2	Annual	8:12:45 PM	01/11/2023
Smoke Detector	3rd Computer Room , Under Floor N/E Area Z-2, By D3AM-C01	Annual	8:12:25 PM	01/11/2023

Device Type	Location	Service	Time	Date
<b><i>Passed</i></b>				
Smoke Detector	3rd Computer Room , Under Floor N/W Area Z-1	Annual	8:13:10 PM	01/11/2023
Smoke Detector	3rd Computer Room , Under Floor N/W Area Z-1	Annual	8:13:26 PM	01/11/2023
Smoke Detector	3rd Computer Room , Under Floor N/W Area Z-2	Annual	8:13:17 PM	01/11/2023
Smoke Detector	3rd Computer Room , Under Floor N/W Area Z-2	Annual	8:13:20 PM	01/11/2023
Smoke Detector	3rd Computer Room , Under Floor N/W Area Z-2	Annual	8:13:23 PM	01/11/2023
Smoke Detector	3rd Computer Room , Under Floor S/E Area Z-1	Annual	8:12:16 PM	01/11/2023
Smoke Detector	3rd Computer Room , Under Floor S/E Area Z-2	Annual	8:12:05 PM	01/11/2023
Smoke Detector	3rd Computer Room , Under Floor S/E Area Z-2	Annual	8:12:12 PM	01/11/2023
Smoke Detector	3rd Computer Room , Under Floor S/E Area Z-2	Annual	8:12:19 PM	01/11/2023
Smoke Detector	3rd Computer Room Ceiling Centre Above D3AX -CO5 Z-1	Annual	8:11:40 PM	01/11/2023
Smoke Detector	3rd Computer Room Ceiling N/C Above D3AL-CO3 Z-1	Annual	8:11:47 PM	01/11/2023
Smoke Detector	3rd Computer Room Ceiling N/E By D3AS-CO3 Z-1	Annual	8:11:36 PM	01/11/2023
Smoke Detector	3rd Computer Room Ceiling N/W Above D3AD-CO3 Z-2	Annual	8:11:55 PM	01/11/2023
Smoke Detector	3rd Computer Room Ceiling N/W Above D3AG-CO2 Z-2	Annual	8:11:43 PM	01/11/2023
Smoke Detector	3rd Computer Room Ceiling N/W Above FM -200 Tanks Z-1	Annual	8:11:51 PM	01/11/2023
Smoke Detector	3rd Computer Room Ceiling North Above D3AB-CO3 Z-1	Annual	8:12:02 PM	01/11/2023
Smoke Detector	3rd Computer Room Ceiling S/E By D3AZ-CO3 Z-2	Annual	8:11:32 PM	01/11/2023
Smoke Detector	3rd Computer Room Ceiling S/E By D3BA-CO4 Z-1	Annual	8:11:29 PM	01/11/2023
Smoke Detector	3rd Computer Room Ceiling S/E By D3BC-CO5 Z-2	Annual	8:11:21 PM	01/11/2023
Smoke Detector	3rd Computer Room Ceiling S/w Above D3BB-CO3 Z-1	Annual	8:11:24 PM	01/11/2023
Smoke Detector	4th Elevator Lobby	Tested/Cleaned	9:41:10 AM	01/13/2023
Smoke Detector	5th Elevator Lobby	Tested/Cleaned	9:40:12 AM	01/13/2023
<b>Supervisory</b>				
End Of Line	3rd Computer Room Ceiling Smoke Z-1	Annual	8:11:58 PM	01/11/2023
End Of Line	3rd janitor room FS 3rd Floor Door plaque 305	Annual	10:45:14 AM	01/06/2023

Device Type	Location	Service	Time	Date
<b><i>Passed</i></b>				
End Of Line	3rd janitor room SV3.1 3rd Flr Sprinkler Door plaque 305	Annual	10:45:03 AM	01/06/2023
End Of Line	4th janitor room FS 4th Floor Door plaque 405	Annual	10:44:02 AM	01/06/2023
End Of Line	4th janitor room SV4.1 4th Flr Sprinkler Door plaque 405	Annual	10:43:48 AM	01/06/2023
End Of Line	5th janitor room FS 5th Floor Door plaque 505	Annual	10:41:41 AM	01/06/2023
End Of Line	5th janitor room SV5.1 5th Flr Sprinkler Door plaque 505	Annual	10:42:03 AM	01/06/2023
Fault Isolation Module	3rd Electrical Room	Annual	11:11:33 AM	01/12/2023
Fault Isolation Module	3rd Electrical Room	Annual	11:11:36 AM	01/12/2023
Fault Isolation Module	4th Electrical Room	Annual	10:31:04 AM	01/13/2023
Fault Isolation Module	4th Electrical Room	Annual	10:31:07 AM	01/13/2023
Device Type	Location	Service	Time	Date
<b><i>Failed/Other</i></b>				
<b>Control</b>				
Battery	4th electrical room Node -3	Annual	7:54:24 AM	01/16/2023

<b>Building: Communication, Traffic, &amp; Computer Centre</b>	<b>Control Panel: 4 - SimplexGrinnell 4100</b>
--	--

*The Inspection & Testing section lists all of the items inspected in your building. Items are grouped by Passed or Failed/Other. Items are listed by Category. Each item includes the services performed, and the time & date at which testing occurred.*

Device Type	Location	Service	Time	Date
<b>Passed</b>				
<b>Auxiliary</b>				
Programmable Relay	4th comp. & comm. room n/w at release panel Zone-1	Tested	1:03:50 PM	01/04/2023
Programmable Relay	7th main computer room 724D n/e corner for under floor smokes	Annual	9:08:34 AM	01/04/2023
Programmable Relay	7th main computer room 724D n/e corner for under floor smokes	Annual	9:35:39 AM	01/04/2023
<b>Control</b>				
Control Panel	7th Electrical/Fire Alarm Panel Room door plaque 704 Node -4	Annual	7:53:46 AM	01/16/2023
Disconnect	8th Electrical room door plaque 804 RP-8-UA, CCT#32 7th FL. Node 4, Tub	Annual	4:40:00 PM	01/10/2023
Disconnect	8th Electrical room door plaque 804 RP-8-UA, CCT#34, 7th FI panel Node 4	Annual	4:40:05 PM	01/10/2023
<b>Initiating</b>				
Initiating Device	7th Electrical/Fire Alarm Panel Room door plaque 704 FM200 supervisory	Annual	7:46:48 AM	01/16/2023
Initiating Device	7th elevator lobby left side GA key	Tested	12:05:06 PM	01/09/2023
Pull Station	7th elevator lobby by door to Comms centre side	Tested	12:04:45 PM	01/09/2023
Smoke Detector	6th Elevator Lobby	Tested/Cleaned	9:39:26 AM	01/13/2023
Smoke Detector	7th Elevator Lobby	Tested/Cleaned	9:36:35 AM	01/13/2023
Smoke Detector	7th main computer room 724D ceiling, north row, centre Z-1	Annual	9:57:12 AM	01/04/2023
Smoke Detector	7th main computer room 724D ceiling, north row, centre Z-2	Annual	9:53:40 AM	01/04/2023
Smoke Detector	7th main computer room 724D ceiling, north row, east Z-1	Annual	9:50:48 AM	01/04/2023
Smoke Detector	7th main computer room 724D ceiling, north row, east Z-2	Annual	9:50:23 AM	01/04/2023
Smoke Detector	7th main computer room 724D ceiling, north row, west Z-1	Annual	8:40:32 AM	01/09/2023
Smoke Detector	7th main computer room 724D ceiling, north row, west Z-2	Annual	9:57:36 AM	01/04/2023
Smoke Detector	7th main computer room 724D ceiling, south row, centre Z-1	Annual	10:00:55 AM	01/04/2023
Smoke Detector	7th main computer room 724D ceiling, south row, centre Z-2	Annual	9:53:00 AM	01/04/2023
Smoke Detector	7th main computer room 724D ceiling,	Annual	9:51:10 AM	01/04/2023

Device Type	Location	Service	Time	Date
<b><i>Passed</i></b>				
	south row, east Z-1			
Smoke Detector	7th main computer room 724D ceiling, south row, east Z-2	Annual	9:49:58 AM	01/04/2023
Smoke Detector	7th main computer room 724D under, middle row, centre	Annual	10:28:23 AM	01/04/2023
Smoke Detector	7th main computer room 724D under, middle row, centre	Annual	10:28:27 AM	01/04/2023
Smoke Detector	7th main computer room 724D under, middle row, east	Annual	10:28:10 AM	01/04/2023
Smoke Detector	7th main computer room 724D under, middle row, east	Annual	10:28:13 AM	01/04/2023
Smoke Detector	7th main computer room 724D under, middle row, east	Annual	10:28:18 AM	01/04/2023
Smoke Detector	7th main computer room 724D under, middle row, west	Annual	10:28:30 AM	01/04/2023
Smoke Detector	7th main computer room 724D under, middle row, west	Annual	10:28:34 AM	01/04/2023
Smoke Detector	7th main computer room 724D under, middle row, west	Annual	10:28:44 AM	01/04/2023
Smoke Detector	7th main computer room 724D under, north row, centre	Annual	10:27:52 AM	01/04/2023
Smoke Detector	7th main computer room 724D under, north row, centre	Annual	10:27:56 AM	01/04/2023
Smoke Detector	7th main computer room 724D under, north row, east	Annual	10:27:59 AM	01/04/2023
Smoke Detector	7th main computer room 724D under, north row, east	Annual	10:28:03 AM	01/04/2023
Smoke Detector	7th main computer room 724D under, north row, east	Annual	10:28:07 AM	01/04/2023
Smoke Detector	7th main computer room 724D under, north row, west	Annual	10:27:43 AM	01/04/2023
Smoke Detector	7th main computer room 724D under, north row, west	Annual	10:27:45 AM	01/04/2023
Smoke Detector	7th main computer room 724D under, north row, west	Annual	10:27:49 AM	01/04/2023
Smoke Detector	7th main computer room 724D under, south row, centre	Annual	10:28:51 AM	01/04/2023
Smoke Detector	7th main computer room 724D under, south row, centre	Annual	10:28:55 AM	01/04/2023
Smoke Detector	7th main computer room 724D under, south row, east	Annual	10:29:02 AM	01/04/2023
Smoke Detector	7th main computer room 724D under, south row, east	Annual	10:29:13 AM	01/04/2023
Smoke Detector	7th main computer room 724D under, south row, east	Annual	10:29:22 AM	01/04/2023
Smoke Detector	7th main computer room 724D under, south row, west	Annual	10:28:47 AM	01/04/2023

Device Type	Location	Service	Time	Date
<b><i>Passed</i></b>				
<b>Supervisory</b>				
End Of Line	6th janitor room FS 6th Floor Door plaque 605	Annual	10:40:17 AM	01/06/2023
End Of Line	6th janitor room SV6.1 6th Flr Sprinkler Door plaque 605	Annual	10:40:05 AM	01/06/2023
End Of Line	7th Electrical/Fire Alarm Panel Room door plaque 704	Tested	9:55:31 AM	01/12/2023
End Of Line	7th Electrical/Fire Alarm Panel Room door plaque 704	Tested	9:55:36 AM	01/12/2023
End Of Line	7th corridor by janitor door plaque 705, 7th FI Hand Sets	Tested	10:17:56 AM	01/12/2023
End Of Line	7th janitor room FS 7th Floor Door plaque 705	Annual	10:37:40 AM	01/06/2023
End Of Line	7th janitor room SV7.1 7th Flr Sprinkler Door plaque 705	Annual	10:36:44 AM	01/06/2023
End Of Line	8th Electrical room door plaque 804	Annual	11:12:41 AM	01/09/2023
End Of Line	8th Electrical room door plaque 804 Circuit A	Annual	11:12:36 AM	01/09/2023
End Of Line	8th corridor by janitor door plaque 805 8th fl handset	Annual	11:22:46 AM	01/09/2023
End Of Line	8th corridor by men's washroom door plaque 806	Annual	11:21:57 AM	01/09/2023
End Of Line	8th janitor room FS 8th Floor Door plaque 805	Annual	10:34:10 AM	01/06/2023
End Of Line	8th janitor room SV8.1 8th Flr Sprinkler Door plaque 805	Annual	10:34:00 AM	01/06/2023
Fault Isolation Module	5th Electrical Room	Annual	10:45:42 AM	01/12/2023
Fault Isolation Module	5th Electrical Room	Annual	10:45:46 AM	01/12/2023
Fault Isolation Module	6th Electrical Room	Annual	10:33:08 AM	01/12/2023
Fault Isolation Module	6th Electrical Room	Annual	10:33:14 AM	01/12/2023
Fault Isolation Module	7th Electrical Room	Annual	7:46:51 AM	01/16/2023
Fault Isolation Module	7th Electrical Room	Annual	7:46:55 AM	01/16/2023
Device Type	Location	Service	Time	Date
<b><i>Failed/Other</i></b>				
<b>Control</b>				
Battery	7th Electrical/Fire Alarm Panel Room door plaque 704 Left tub	Annual	5:50:23 PM	01/10/2023
Battery	7th Electrical/Fire Alarm Panel Room door plaque 704 Main tub	Annual	7:56:31 AM	01/16/2023



Device Type	Location	Service	Time	Date
<i>Failed/Other</i>				
<b>Supervisory</b>				
End Of Line	8th corridor by men's washroom door plaque 806	Annual	3:17:46 PM	01/10/2023

<b>Building: Communication, Traffic, &amp; Computer Centre</b>	<b>Control Panel: 5 - SimplexGrinnell 4100</b>
--	--

*The Inspection & Testing section lists all of the items inspected in your building. Items are grouped by Passed or Failed/Other. Items are listed by Category. Each item includes the services performed, and the time & date at which testing occurred.*

Device Type	Location	Service	Time	Date
<b><i>Passed</i></b>				
<b>Control</b>				
Disconnect	8th Electrical room door plaque 804 RP-8-UA, CCT#31 , Node 5 Tub 1	Annual	4:39:17 PM	01/10/2023
Disconnect	8th Electrical room door plaque 804 RP-8-UA, CCT#33 , Node 5	Annual	4:39:30 PM	01/10/2023
<b>Initiating</b>				
Initiating Device	9th Electrical Room	Annual	10:49:37 AM	01/09/2023
Initiating Device	9th computer room FM-200 system Alarm	Annual	7:47:27 AM	01/04/2023
Initiating Device	9th computer room Pressure FM-200 system	Annual	7:47:23 AM	01/04/2023
Initiating Device	9th computer room Trouble FM-200 system	Annual	7:47:19 AM	01/04/2023
Smoke Detector	9th ceiling computer room north/east FM-200 system	Annual	8:03:27 AM	01/04/2023
Smoke Detector	9th ceiling computer room north/west FM-200 system	Annual	7:56:41 AM	01/04/2023
Smoke Detector	9th ceiling computer room south/east FM-200 system	Annual	7:56:23 AM	01/04/2023
Smoke Detector	9th ceiling computer room south/west FM-200 system	Annual	7:56:49 AM	01/04/2023
Smoke Detector	9th under tile computer room north/east FM-200 system	Annual	8:06:41 AM	01/04/2023
Smoke Detector	9th under tile computer room north/west FM-200 system	Annual	8:06:38 AM	01/04/2023
Smoke Detector	9th under tile computer room south/east FM-200 system	Annual	8:06:45 AM	01/04/2023
Smoke Detector	9th under tile computer room south/west FM-200 system	Annual	8:06:34 AM	01/04/2023
<b>Supervisory</b>				
End Of Line	9th Electrical Room Fire Alarm Panel Room Strobe Circuit	Annual	10:55:00 AM	01/09/2023
End Of Line	9th Electrical Room Fire Alarm Panel Room Speaker Circuit	Annual	11:01:07 AM	01/09/2023
End Of Line	9th Electrical Room Fire Alarm Panel Room Speaker Circuit	Annual	11:01:21 AM	01/09/2023
End Of Line	9th Electrical Room Fire Alarm Panel Room Strobe Circuit	Annual	10:55:14 AM	01/09/2023
End Of Line	9th corridor by stairwell north Door plaque 9ST1, phone Circuit	Annual	10:41:37 AM	01/09/2023
End Of Line	9th janitor room Door plaque 905	Annual	10:32:00 AM	01/06/2023

Device Type	Location	Service	Time	Date
<b><i>Passed</i></b>				
End Of Line	9th janitor room Door plaque 905	Annual	10:32:20 AM	01/06/2023
End Of Line	Penthouse Electrical/Transformer room by gen room Generator 1 Running	Annual	9:58:40 AM	01/09/2023
End Of Line	Penthouse Electrical/Transformer room by gen room Generator 2 Running	Annual	9:43:10 AM	01/09/2023
End Of Line	Penthouse Electrical/Transformer room by gen room Generator 2 Trouble	Annual	9:43:18 AM	01/09/2023
Fault Isolation Module	8th Electrical Room	Annual	11:08:18 AM	01/09/2023
Fault Isolation Module	8th Electrical Room	Annual	11:08:23 AM	01/09/2023
Fault Isolation Module	Penthouse Electrical Room	Annual	10:32:15 AM	01/09/2023
Device Type	Location	Service	Time	Date
<b><i>Failed/Other</i></b>				
<b>Control</b>				
Battery	9th Electrical Room Fire Alarm Panel Room Left tub	Annual	4:55:05 PM	01/10/2023
Battery	9th Electrical Room Fire Alarm Panel Room Main tub	Annual	4:54:43 PM	01/10/2023
Control Panel	9th Electrical Room Fire Alarm Panel Room	Annual	9:39:04 PM	01/10/2023
<b>Supervisory</b>				
Generator Running	Penthouse Electrical Room by Generator room Generator 2 Running	Annual	10:51:01 AM	01/04/2023
Generator Trouble	Penthouse Electrical Room by Generator room Generator 2 Trouble	Annual	10:50:48 AM	01/04/2023

<b>Building: Communication, Traffic, &amp; Computer Centre</b>	<b>Control Panel: 6</b>
--	-------------------------

*The Inspection & Testing section lists all of the items inspected in your building. Items are grouped by Passed or Failed/Other. Items are listed by Category. Each item includes the services performed, and the time & date at which testing occurred.*

Device Type	Location	Service	Time	Date
<b>Passed</b>				
<b>Auxiliary</b>				
Programmable Relay	4th comp. & comm. room n/w at release panel Damper	Tested	1:04:01 PM	01/04/2023
Programmable Relay	4th comp. & comm. room n/w at release panel Zone -2	Tested	1:03:55 PM	01/04/2023
<b>Initiating</b>				
Initiating Device	4th comp. & comm. room n/w at release panel Alarm	Tested	1:03:45 PM	01/04/2023
Initiating Device	4th comp. & comm. room n/w at release panel Trouble	Tested	12:57:10 PM	01/04/2023
Initiating Device	4th comp. & comm. room n/w release panel Tanks Low Pressure	Tested	12:59:43 PM	01/04/2023
Smoke Detector	4th comp. & comm. room ceiling, comm. room c/e Z-1	Tested/Cleaned	2:32:33 PM	01/04/2023
Smoke Detector	4th comp. & comm. room ceiling, comm. room c/e Z-1	Tested/Cleaned	2:32:42 PM	01/04/2023
Smoke Detector	4th comp. & comm. room ceiling, comm. room c/w Z-1	Tested/Cleaned	2:32:30 PM	01/04/2023
Smoke Detector	4th comp. & comm. room ceiling, comm. room n/e Z-2	Tested/Cleaned	2:32:39 PM	01/04/2023
Smoke Detector	4th comp. & comm. room ceiling, comm. room s/e Z-2	Tested/Cleaned	2:32:46 PM	01/04/2023
Smoke Detector	4th comp. & comm. room ceiling, comm. room s/w Z-1	Tested/Cleaned	2:32:50 PM	01/04/2023
Smoke Detector	4th comp. & comm. room ceiling, north area	Tested/Cleaned	2:33:40 PM	01/04/2023
Smoke Detector	4th comp. & comm. room ceiling, north area	Tested/Cleaned	2:33:57 PM	01/04/2023
Smoke Detector	4th comp. & comm. room ceiling, north area Z-1	Tested/Cleaned	2:33:48 PM	01/04/2023
Smoke Detector	4th comp. & comm. room ceiling, north area Z-1	Tested/Cleaned	2:33:53 PM	01/04/2023
Smoke Detector	4th comp. & comm. room ceiling, north area Z-2	Tested/Cleaned	2:33:45 PM	01/04/2023
Smoke Detector	4th comp. & comm. room ceiling, s/e area Z-1	Tested/Cleaned	2:33:26 PM	01/04/2023
Smoke Detector	4th comp. & comm. room ceiling, s/e area Z-2	Tested/Cleaned	2:33:20 PM	01/04/2023
Smoke Detector	4th comp. & comm. room ceiling, s/w area Z-2	Tested/Cleaned	2:33:36 PM	01/04/2023
Smoke Detector	4th comp. & comm. room ceiling, s/w by maintenance lab Z-2	Tested/Cleaned	2:33:12 PM	01/04/2023

Device Type	Location	Service	Time	Date
<b><i>Passed</i></b>				
Smoke Detector	4th comp. & comm. room ceiling, south area Z-1	Tested/Cleaned	2:33:15 PM	01/04/2023
Smoke Detector	4th comp. & comm. room ceiling, south area Z-1	Tested/Cleaned	2:33:31 PM	01/04/2023
Smoke Detector	4th comp. & comm. room under, comm. room c/e	Tested/Cleaned	1:55:15 PM	01/04/2023
Smoke Detector	4th comp. & comm. room under, comm. room c/w	Tested/Cleaned	1:57:01 PM	01/04/2023
Smoke Detector	4th comp. & comm. room under, comm. room n/e	Tested/Cleaned	1:56:54 PM	01/04/2023
Smoke Detector	4th comp. & comm. room under, comm. room n/w	Tested/Cleaned	1:56:58 PM	01/04/2023
Smoke Detector	4th comp. & comm. room under, comm. room s/e	Tested/Cleaned	1:55:10 PM	01/04/2023
Smoke Detector	4th comp. & comm. room under, comm. room s/w	Tested/Cleaned	1:57:08 PM	01/04/2023
Smoke Detector	4th comp. & comm. room under, north area c/c	Tested/Cleaned	1:57:31 PM	01/04/2023
Smoke Detector	4th comp. & comm. room under, north area c/e	Tested/Cleaned	1:57:34 PM	01/04/2023
Smoke Detector	4th comp. & comm. room under, north area c/w	Tested/Cleaned	1:57:28 PM	01/04/2023
Smoke Detector	4th comp. & comm. room under, north area n/e	Tested/Cleaned	1:57:39 PM	01/04/2023
Smoke Detector	4th comp. & comm. room under, north area s/c	Tested/Cleaned	1:57:18 PM	01/04/2023
Smoke Detector	4th comp. & comm. room under, north area s/e	Tested/Cleaned	1:57:12 PM	01/04/2023
Smoke Detector	4th comp. & comm. room under, north area s/w	Tested/Cleaned	1:57:23 PM	01/04/2023
Smoke Detector	4th comp. & comm. room under, south area c/c	Tested/Cleaned	1:54:48 PM	01/04/2023
Smoke Detector	4th comp. & comm. room under, south area c/e	Tested/Cleaned	1:54:54 PM	01/04/2023
Smoke Detector	4th comp. & comm. room under, south area n/c	Tested/Cleaned	1:55:02 PM	01/04/2023
Smoke Detector	4th comp. & comm. room under, south area n/e	Tested/Cleaned	1:54:58 PM	01/04/2023
Smoke Detector	4th comp. & comm. room under, south area n/w	Tested/Cleaned	1:55:06 PM	01/04/2023
Smoke Detector	4th comp. & comm. room under, south area s/c	Tested/Cleaned	1:04:13 PM	01/04/2023
Smoke Detector	4th comp. & comm. room under, south area s/e	Tested/Cleaned	1:04:19 PM	01/04/2023
Smoke Detector	4th maintenance lab E ceiling Z-2 barcode on doorframe	Annual	7:39:24 PM	01/11/2023
Smoke Detector	4th maintenance lab W ceiling Z-1 barcode	Annual	7:39:21 PM	01/11/2023

Device Type	Location	Service	Time	Date
<b><i>Passed</i></b>				
	on doorframe			
Smoke Detector	4th maintenance/test lab under, n/c	Tested/Cleaned	1:04:29 PM	01/04/2023
Smoke Detector	4th maintenance/test lab under, n/e	Tested/Cleaned	1:04:35 PM	01/04/2023
Smoke Detector	4th maintenance/test lab under, n/w	Tested/Cleaned	1:04:25 PM	01/04/2023
Smoke Detector	4th maintenance/test lab under, s/c	Tested/Cleaned	1:04:47 PM	01/04/2023
Smoke Detector	4th maintenance/test lab under, s/e	Tested/Cleaned	1:04:42 PM	01/04/2023
Smoke Detector	4th maintenance/test lab under, s/w	Tested/Cleaned	1:04:54 PM	01/04/2023
Device Type	Location	Service	Time	Date
<b><i>Failed/Other</i></b>				
<b>Initiating</b>				
Smoke Detector	4th comp. & comm. room ceiling, s/w by tanks Z-1	Tested/Cleaned	2:13:17 PM	01/04/2023

Building: Communication, Traffic, & Computer Centre			Control Panel: 7	
<i>The Inspection &amp; Testing section lists all of the items inspected in your building. Items are grouped by Passed or Failed/Other. Items are listed by Category. Each item includes the services performed, and the time &amp; date at which testing occurred.</i>				
Device Type	Location	Service	Time	Date
<i>Passed</i>				
Auxiliary				
Programmable Relay	3rd Southeast Corner outside computer room by Suppression panel DMP(Damper)	Annual	11:16:27 AM	01/12/2023
Programmable Relay	3rd Southeast Corner outside computer room by Suppression panel DZ1	Annual	11:16:20 AM	01/12/2023
Programmable Relay	3rd Southeast Corner outside computer room by Suppression panel DZ2	Annual	11:16:23 AM	01/12/2023
Initiating				
Initiating Device	3rd Southeast Corner outside computer room Suppression panel Trouble	Annual	11:16:36 AM	01/12/2023
Initiating Device	3rd Southeast Corner outside computer room by Suppression panel Low Pressure	Annual	11:16:40 AM	01/12/2023
Initiating Device	3rd Southeast Corner outside computer room by Suppression panel Panel Alarm	Annual	11:16:32 AM	01/12/2023



# Auxiliary Functions Testing

Generated by: BuildingReports.com

Building: Communication, Traffic, & Computer Centre	Control Panel: 1 - SimplexGrinnell 4100
---	---

The Auxiliary Functions Testing section lists each of the ancillary items, systems, and emergency equipment that are controlled by the system control unit. Items are grouped by Passed or Failed/Other. The items are listed by device type, and a check box is provided to indicate if the test conducted was simulated.

Type	Location	Comment	ScanID	Simulated
<b>Passed</b>				
<b>Programmable Relay</b>				
Releasing	Basement Custodial Services Storage Room Telephone Room #21 , Novec System Panel , Zone 1 Active	Passed	68832574	<input type="checkbox"/>
Releasing	Basement Custodial Services Storage Room Telephone Room #21 , Novec System Panel , Zone 2 Active	Passed	68832576	<input type="checkbox"/>
Relay	Basement Network Comm. room 34/35 Zone 1, first stage FM-200 system	Passed	57019968	<input type="checkbox"/>
Relay	Basement Network Comm. room 34/35 Zone 2, second stage FM-200 system	Passed	57019969	<input type="checkbox"/>
Releasing	Basement Network Communication Room 1 Novec System Panel , Zone 1 Active	Passed	68832582	<input type="checkbox"/>
Releasing	Basement Network Communication Room 1 Novec System Panel , Zone 2 Active	Passed	68832581	<input type="checkbox"/>
Relay	Basement Telephone room 33 Damper FM-200 system	Passed	57019989	<input type="checkbox"/>
Relay	Basement Telephone room 33 Zone 1, first stage FM-200 system	Passed	57019987	<input type="checkbox"/>
Relay	Basement Telephone room 33 Zone 2, second stage FM-200 system	Passed	57019988	<input type="checkbox"/>
Releasing	Basement corridor mechanical room 032 Pre action zone 2 Active alarm	Passed	64248323	<input type="checkbox"/>
	Basement corridor mechanical room 032 Zone 1 Pre action zone 1 Active alarm	Passed	64248326	<input type="checkbox"/>
Damper	7th TPS Computer room main entrance door plaque 724C , Computer Room Damper	Passed	59582788	<input type="checkbox"/>
control relay	7th TPS Computer room main entrance door plaque 724C . Zone 2 Detectors	Passed	59582786	<input type="checkbox"/>
control relay	7th TPS Computer room main entrance door plaque 724C. Zone 1 Detectors	Passed	59582787	<input type="checkbox"/>
Relay	9th computer room Damper FM-200 system	Passed	57019939	<input type="checkbox"/>
Relay	9th computer room Zone 1, first stage FM-200 system	Passed	57019941	<input type="checkbox"/>
Relay	9th computer room Zone 2, second stage FM-	Passed	57019940	<input type="checkbox"/>

Building: Communication, Traffic, & Computer Centre		Control Panel: 1 - SimplexGrinnell 4100		
<i>The Auxiliary Functions Testing section lists each of the ancillary items, systems, and emergency equipment that are controlled by the system control unit. Items are grouped by Passed or Failed/Other. The items are listed by device type, and a check box is provided to indicate if the test conducted was simulated.</i>				
Type	Location	Comment	ScanID	Simulated
Passed				
Programmable Relay				
	200 system			
Heat Detector				
Alarm	1st security control office washroom	Passed	62118551	
Smoke Detector				
Alarm	Basement Elevator Lobby	Passed	67060227	
Alarm	1st Elevator Lobby	Passed	67060231	
Alarm	1st security control office centre	Passed	62118554	
Alarm	1st security control office lobby	Passed	62118562	
Alarm	1st security control office vestibule	Passed	62118559	
Alarm	7th mid stairwell north	Passed	57019867	
Alarm	7th mid stairwell south	Passed	57019863	
Alarm	8th Elevator Lobby	Passed	67060261	
Alarm	9th Elevator Lobby	Passed	67037882	
Alarm	Penthouse Top of North Stair 1	Passed	67037879	
Alarm	Penthouse inside south stairwell stair 2	Passed	57019699	
Alarm	Roof top of south stairwell stair 3	Passed	57019700	
Failed/Other				
Duct Detector				
Alarm	Penthouse mechanical/fan room RF1 standing height	Special Note	57019730	
Alarm	Penthouse mechanical/fan room SF1 Overhead, 12'	Special Note	57019732	
Alarm	Penthouse mechanical/fan room SF2 standing height	Special Note	57019731	
Heat Detector				
Alarm	Basement elevator 1&2 pit door plaque 006 barcode on exterior doorframe	Access Denied	64248500	
Alarm	Basement elevator 3 pit barcode on exterior doorframe	Access Denied	64248501	
Alarm	Penthouse top of elevator shaft accessed through centre elev. barcode on 9th floor elev. doorframe	Access Denied	64248502	

<b>Building: Communication, Traffic, &amp; Computer Centre</b>	<b>Control Panel: 2 - SimplexGrinnell 4100</b>
--	--

*The Auxiliary Functions Testing section lists each of the ancillary items, systems, and emergency equipment that are controlled by the system control unit. Items are grouped by Passed or Failed/Other. The items are listed by device type, and a check box is provided to indicate if the test conducted was simulated.*

Type	Location	Comment	ScanID	Simulated
<b><i>Passed</i></b>				
<b>Smoke Detector</b>				
Alarm	Basement ceiling Network Comm. room 34/35 by entrance	Passed	57019971	
Alarm	Basement ceiling Network Comm. room 34/35 by entrance FM-200 system	Passed	57019970	
Alarm	Basement ceiling Network Comm. room 34/35 middle FM-200 system	Passed	57019972	
Alarm	Basement ceiling Network Comm. room 34/35 rear FM-200 system	Passed	64248327	
Alarm	Basement ceiling Telephone room 33 by entrance west FM-200 system, Zone -1	Passed	57019982	
Alarm	Basement ceiling Telephone room 33 east FM-200 system, Z-2	Passed	57019983	
Alarm	2nd Elevator Lobby	Passed	67060235	

<b>Building: Communication, Traffic, &amp; Computer Centre</b>	<b>Control Panel: 3 - SimplexGrinnell 4100</b>
--	--

*The Auxiliary Functions Testing section lists each of the ancillary items, systems, and emergency equipment that are controlled by the system control unit. Items are grouped by Passed or Failed/Other. The items are listed by device type, and a check box is provided to indicate if the test conducted was simulated.*

Type	Location	Comment	ScanID	Simulated
<b><i>Passed</i></b>				
<b>Smoke Detector</b>				
Alarm	3rd Elevator Lobby	Passed	67060244	
Alarm	3rd Computer Room , Under Floor N/C Area Z-1	Passed	62125489	
Alarm	3rd Computer Room , Under Floor N/C Area Z-1	Passed	62125487	
Alarm	3rd Computer Room , Under Floor N/C Area Z-1 , by FM -200 Tanks	Passed	62125491	
Alarm	3rd Computer Room , Under Floor N/C Area Z-2	Passed	62125492	
Alarm	3rd Computer Room , Under Floor N/C Area Z-2	Passed	62125490	
Alarm	3rd Computer Room , Under Floor N/C Area Z-2	Passed	62125488	
Alarm	3rd Computer Room , Under Floor N/E Area Z-1	Passed	62125505	
Alarm	3rd Computer Room , Under Floor N/E Area Z-	Passed	62125495	

<b>Building: Communication, Traffic, &amp; Computer Centre</b>	<b>Control Panel: 3 - SimplexGrinnell 4100</b>
--	--

*The Auxiliary Functions Testing section lists each of the ancillary items, systems, and emergency equipment that are controlled by the system control unit. Items are grouped by Passed or Failed/Other. The items are listed by device type, and a check box is provided to indicate if the test conducted was simulated.*

Type	Location	Comment	ScanID	Simulated
<b><i>Passed</i></b>				
<b>Smoke Detector</b>				
	1			
Alarm	3rd Computer Room , Under Floor N/E Area Z-1 , by D3AS-C01	Passed	62125501	
Alarm	3rd Computer Room , Under Floor N/E Area Z-1 by D3AP-C01	Passed	62125497	
Alarm	3rd Computer Room , Under Floor N/E Area Z-1 by D3AU-C01	Passed	62125493	
Alarm	3rd Computer Room , Under Floor N/E Area Z-1 by D3AZ-CO6	Passed	62125499	
Alarm	3rd Computer Room , Under Floor N/E Area Z-2	Passed	62125498	
Alarm	3rd Computer Room , Under Floor N/E Area Z-2	Passed	62125496	
Alarm	3rd Computer Room , Under Floor N/E Area Z-2	Passed	62125494	
Alarm	3rd Computer Room , Under Floor N/E Area Z-2, By D3AM-C01	Passed	62125500	
Alarm	3rd Computer Room , Under Floor N/W Area Z-1	Passed	62125486	
Alarm	3rd Computer Room , Under Floor N/W Area Z-1	Passed	62125484	
Alarm	3rd Computer Room , Under Floor N/W Area Z-2	Passed	62125485	
Alarm	3rd Computer Room , Under Floor N/W Area Z-2	Passed	62125482	
Alarm	3rd Computer Room , Under Floor N/W Area Z-2	Passed	62125481	
Alarm	3rd Computer Room , Under Floor S/E Area Z-1	Passed	62125503	
Alarm	3rd Computer Room , Under Floor S/E Area Z-2	Passed	62125506	
Alarm	3rd Computer Room , Under Floor S/E Area Z-2	Passed	62125504	
Alarm	3rd Computer Room , Under Floor S/E Area Z-2	Passed	62125502	
Alarm	3rd Computer Room Ceiling Centre Above D3AX -CO5 Z-1	Passed	62125530	
Alarm	3rd Computer Room Ceiling N/C Above D3AL-	Passed	62125525	

<b>Building: Communication, Traffic, &amp; Computer Centre</b>	<b>Control Panel: 3 - SimplexGrinnell 4100</b>
--	--

*The Auxiliary Functions Testing section lists each of the ancillary items, systems, and emergency equipment that are controlled by the system control unit. Items are grouped by Passed or Failed/Other. The items are listed by device type, and a check box is provided to indicate if the test conducted was simulated.*

Type	Location	Comment	ScanID	Simulated
<b><i>Passed</i></b>				
<b>Smoke Detector</b>				
	CO3 Z-1			
Alarm	3rd Computer Room Ceiling N/E By D3AS-C03 Z-1	Passed	62125531	
Alarm	3rd Computer Room Ceiling N/W Above D3AD-CO3 Z-2	Passed	62125511	
Alarm	3rd Computer Room Ceiling N/W Above D3AG-CO2 Z-2	Passed	62125526	
Alarm	3rd Computer Room Ceiling N/W Above FM -200 Tanks Z-1	Passed	62125521	
Alarm	3rd Computer Room Ceiling North Above D3AB-CO3 Z-1	Passed	62125510	
Alarm	3rd Computer Room Ceiling S/E By D3AZ-C03 Z-2	Passed	62125532	
Alarm	3rd Computer Room Ceiling S/E By D3BA-C04 Z-1	Passed	62125535	
Alarm	3rd Computer Room Ceiling S/E By D3BC-C05 Z-2	Passed	62125537	
Alarm	3rd Computer Room Ceiling S/w Above D3BB-CO3 Z-1	Passed	62125536	
Alarm	4th Elevator Lobby	Passed	67060247	
Alarm	5th Elevator Lobby	Passed	67060250	

<b>Building: Communication, Traffic, &amp; Computer Centre</b>	<b>Control Panel: 4 - SimplexGrinnell 4100</b>
--	--

*The Auxiliary Functions Testing section lists each of the ancillary items, systems, and emergency equipment that are controlled by the system control unit. Items are grouped by Passed or Failed/Other. The items are listed by device type, and a check box is provided to indicate if the test conducted was simulated.*

Type	Location	Comment	ScanID	Simulated
<b><i>Passed</i></b>				
<b>Programmable Relay</b>				
alarm activation	4th comp. & comm. room n/w at release panel Zone-1	Passed	58612478	<input type="checkbox"/>
Control Relay	7th main computer room 724D n/e corner for under floor smokes	Passed	64248328	<input type="checkbox"/>
Control Relay	7th main computer room 724D n/e corner for under floor smokes	Passed	64248329	<input type="checkbox"/>

<b>Building: Communication, Traffic, &amp; Computer Centre</b>	<b>Control Panel: 4 - SimplexGrinnell 4100</b>
--	--

*The Auxiliary Functions Testing section lists each of the ancillary items, systems, and emergency equipment that are controlled by the system control unit. Items are grouped by Passed or Failed/Other. The items are listed by device type, and a check box is provided to indicate if the test conducted was simulated.*

Type	Location	Comment	ScanID	Simulated
<b><i>Passed</i></b>				
<b>Smoke Detector</b>				
Alarm	6th Elevator Lobby	Passed	67060240	
Alarm	7th Elevator Lobby	Passed	67060255	
alarm	7th main computer room 724D ceiling, north row, centre Z-1	Passed	59582842	
alarm	7th main computer room 724D ceiling, north row, centre Z-2	Passed	59582841	
alarm	7th main computer room 724D ceiling, north row, east Z-1	Passed	59582840	
alarm	7th main computer room 724D ceiling, north row, east Z-2	Passed	59582839	
alarm	7th main computer room 724D ceiling, north row, west Z-1	Passed	59582844	
alarm	7th main computer room 724D ceiling, north row, west Z-2	Passed	59582843	
alarm	7th main computer room 724D ceiling, south row, centre Z-1	Passed	59582836	
alarm	7th main computer room 724D ceiling, south row, centre Z-2	Passed	59582835	
alarm	7th main computer room 724D ceiling, south row, east Z-1	Passed	59582834	
alarm	7th main computer room 724D ceiling, south row, east Z-2	Passed	59582833	
alarm	7th main computer room 724D under, middle row, centre	Passed	59582815	
alarm	7th main computer room 724D under, middle row, centre	Passed	59582814	
alarm	7th main computer room 724D under, middle row, east	Passed	59582818	
alarm	7th main computer room 724D under, middle row, east	Passed	59582817	
alarm	7th main computer room 724D under, middle row, east	Passed	59582816	
alarm	7th main computer room 724D under, middle row, west	Passed	59582813	
alarm	7th main computer room 724D under, middle row, west	Passed	59582812	
alarm	7th main computer room 724D under, middle row, west	Passed	59582811	

<b>Building: Communication, Traffic, &amp; Computer Centre</b>	<b>Control Panel: 4 - SimplexGrinnell 4100</b>
--	--

*The Auxiliary Functions Testing section lists each of the ancillary items, systems, and emergency equipment that are controlled by the system control unit. Items are grouped by Passed or Failed/Other. The items are listed by device type, and a check box is provided to indicate if the test conducted was simulated.*

Type	Location	Comment	ScanID	Simulated
<b><i>Passed</i></b>				
<b>Smoke Detector</b>				
alarm	7th main computer room 724D under, north row, centre	Passed	59582823	
alarm	7th main computer room 724D under, north row, centre	Passed	59582822	
alarm	7th main computer room 724D under, north row, east	Passed	59582821	
alarm	7th main computer room 724D under, north row, east	Passed	59582820	
alarm	7th main computer room 724D under, north row, east	Passed	59582819	
alarm	7th main computer room 724D under, north row, west	Passed	59582826	
alarm	7th main computer room 724D under, north row, west	Passed	59582825	
alarm	7th main computer room 724D under, north row, west	Passed	59582824	
alarm	7th main computer room 724D under, south row, centre	Passed	59582809	
alarm	7th main computer room 724D under, south row, centre	Passed	59582808	
alarm	7th main computer room 724D under, south row, east	Passed	59582807	
alarm	7th main computer room 724D under, south row, east	Passed	59582806	
alarm	7th main computer room 724D under, south row, east	Passed	59582805	
alarm	7th main computer room 724D under, south row, west	Passed	59582810	

<b>Building: Communication, Traffic, &amp; Computer Centre</b>	<b>Control Panel: 5 - SimplexGrinnell 4100</b>
--	--

*The Auxiliary Functions Testing section lists each of the ancillary items, systems, and emergency equipment that are controlled by the system control unit. Items are grouped by Passed or Failed/Other. The items are listed by device type, and a check box is provided to indicate if the test conducted was simulated.*

Type	Location	Comment	ScanID	Simulated
<b><i>Passed</i></b>				
<b>Smoke Detector</b>				
Alarm	9th ceiling computer room north/east FM-200	Passed	57019928	



<b>Building: Communication, Traffic, &amp; Computer Centre</b>	<b>Control Panel: 5 - SimplexGrinnell 4100</b>
--	--

*The Auxiliary Functions Testing section lists each of the ancillary items, systems, and emergency equipment that are controlled by the system control unit. Items are grouped by Passed or Failed/Other. The items are listed by device type, and a check box is provided to indicate if the test conducted was simulated.*

Type	Location	Comment	ScanID	Simulated
<b><i>Passed</i></b>				
<b>Smoke Detector</b>				
	system			
Alarm	9th ceiling computer room north/west FM-200 system	Passed	57019929	
Alarm	9th ceiling computer room south/east FM-200 system	Passed	57019927	
Alarm	9th ceiling computer room south/west FM-200 system	Passed	57019930	
Alarm	9th under tile computer room north/east FM-200 system	Passed	57019932	
Alarm	9th under tile computer room north/west FM-200 system	Passed	57019933	
Alarm	9th under tile computer room south/east FM-200 system	Passed	57019931	
Alarm	9th under tile computer room south/west FM-200 system	Passed	57019934	

<b>Building: Communication, Traffic, &amp; Computer Centre</b>	<b>Control Panel: 6</b>
--	-------------------------

*The Auxiliary Functions Testing section lists each of the ancillary items, systems, and emergency equipment that are controlled by the system control unit. Items are grouped by Passed or Failed/Other. The items are listed by device type, and a check box is provided to indicate if the test conducted was simulated.*

Type	Location	Comment	ScanID	Simulated
<b><i>Passed</i></b>				
<b>Programmable Relay</b>				
alarm activation	4th comp. & comm. room n/w at release panel Damper	Passed	58612480	<input type="checkbox"/>
alarm activation	4th comp. & comm. room n/w at release panel Zone -2	Passed	58612479	<input type="checkbox"/>
<b>Smoke Detector</b>				
alarm	4th comp. & comm. room ceiling, comm. room c/e Z-1	Passed	58612459	
alarm	4th comp. & comm. room ceiling, comm. room c/e Z-1	Passed	58612461	
alarm	4th comp. & comm. room ceiling, comm. room c/w Z-1	Passed	58612458	
alarm	4th comp. & comm. room ceiling, comm. room n/e Z-2	Passed	58612460	
alarm	4th comp. & comm. room ceiling, comm. room	Passed	58612462	

# Building: Communication, Traffic, & Computer Centre

Control Panel: 6

*The Auxiliary Functions Testing section lists each of the ancillary items, systems, and emergency equipment that are controlled by the system control unit. Items are grouped by Passed or Failed/Other. The items are listed by device type, and a check box is provided to indicate if the test conducted was simulated.*

Type	Location	Comment	ScanID	Simulated
<b><i>Passed</i></b>				
<b>Smoke Detector</b>				
	s/e Z-2			
alarm	4th comp. & comm. room ceiling, comm. room s/w Z-1	Passed	58612463	
alarm	4th comp. & comm. room ceiling, north area	Passed	58612473	
alarm	4th comp. & comm. room ceiling, north area	Passed	58612477	
alarm	4th comp. & comm. room ceiling, north area Z-1	Passed	58612475	
alarm	4th comp. & comm. room ceiling, north area Z-1	Passed	58612476	
alarm	4th comp. & comm. room ceiling, north area Z-2	Passed	58612474	
alarm	4th comp. & comm. room ceiling, s/e area Z-1	Passed	58612470	
alarm	4th comp. & comm. room ceiling, s/e area Z-2	Passed	58612469	
alarm	4th comp. & comm. room ceiling, s/w area Z-2	Passed	58612472	
alarm	4th comp. & comm. room ceiling, s/w by maintenance lab Z-2	Passed	58612467	
alarm	4th comp. & comm. room ceiling, south area Z-1	Passed	58612468	
alarm	4th comp. & comm. room ceiling, south area Z-1	Passed	58612471	
alarm	4th comp. & comm. room under, comm. room c/e	Passed	58612431	
alarm	4th comp. & comm. room under, comm. room c/w	Passed	58612434	
alarm	4th comp. & comm. room under, comm. room n/e	Passed	58612432	
alarm	4th comp. & comm. room under, comm. room n/w	Passed	58612433	
alarm	4th comp. & comm. room under, comm. room s/e	Passed	58612430	
alarm	4th comp. & comm. room under, comm. room s/w	Passed	58612435	
alarm	4th comp. & comm. room under, north area c/c	Passed	58612440	
alarm	4th comp. & comm. room under, north area c/e	Passed	58612441	
alarm	4th comp. & comm. room under, north area c/w	Passed	58612439	
alarm	4th comp. & comm. room under, north area n/e	Passed	58612442	

<b>Building: Communication, Traffic, &amp; Computer Centre</b>	<b>Control Panel: 6</b>
--	-------------------------

*The Auxiliary Functions Testing section lists each of the ancillary items, systems, and emergency equipment that are controlled by the system control unit. Items are grouped by Passed or Failed/Other. The items are listed by device type, and a check box is provided to indicate if the test conducted was simulated.*

Type	Location	Comment	ScanID	Simulated
<b><i>Passed</i></b>				
<b>Smoke Detector</b>				
alarm	4th comp. & comm. room under, north area s/c	Passed	58612437	
alarm	4th comp. & comm. room under, north area s/e	Passed	58612436	
alarm	4th comp. & comm. room under, north area s /w	Passed	58612438	
alarm	4th comp. & comm. room under, south area c /c	Passed	58612425	
alarm	4th comp. & comm. room under, south area c /e	Passed	58612426	
alarm	4th comp. & comm. room under, south area n /c	Passed	58612428	
alarm	4th comp. & comm. room under, south area n /e	Passed	58612427	
alarm	4th comp. & comm. room under, south area n /w	Passed	58612429	
alarm	4th comp. & comm. room under, south area s /c	Passed	58612424	
alarm	4th comp. & comm. room under, south area s /e	Passed	58612423	
alarm	4th maintenance lab E ceiling Z-2 barcode on doorframe	Passed	58612465	
alarm	4th maintenance lab W ceiling Z-1 barcode on doorframe	Passed	58612464	
alarm	4th maintenance/test lab under, n/c	Passed	58612421	
alarm	4th maintenance/test lab under, n/e	Passed	58612420	
alarm	4th maintenance/test lab under, n/w	Passed	58612422	
alarm	4th maintenance/test lab under, s/c	Passed	58612498	
alarm	4th maintenance/test lab under, s/e	Passed	58612499	
alarm	4th maintenance/test lab under, s/w	Passed	58612497	
<b><i>Failed/Other</i></b>				
<b>Smoke Detector</b>				
alarm	4th comp. & comm. room ceiling, s/w by tanks Z-1	Failed Test	58612466	

# Building: Communication, Traffic, & Computer Centre

Control Panel: 7

*The Auxiliary Functions Testing section lists each of the ancillary items, systems, and emergency equipment that are controlled by the system control unit. Items are grouped by Passed or Failed/Other. The items are listed by device type, and a check box is provided to indicate if the test conducted was simulated.*

Type	Location	Comment	ScanID	Simulated
<b><i>Passed</i></b>				
<b>Programmable Relay</b>				
Relay	3rd Southeast Corner outside computer room by Suppression panel DMP(Damper)	Passed	62118540	<input type="checkbox"/>
Relay	3rd Southeast Corner outside computer room by Suppression panel DZ1	Passed	62118542	<input type="checkbox"/>
Relay	3rd Southeast Corner outside computer room by Suppression panel DZ2	Passed	62118541	<input type="checkbox"/>

# Sensitivity Testing

Generated by: BuildingReports.com

Building: Communication, Traffic, & Computer Centre			Control Panel: 1 - SimplexGrinnell 4100		
<i>The Sensitivity Testing section details the sensitivity test ranges and acceptable readings for each type of device. Items are grouped by Passed or Failed/Other. Normally, Devices that perform outside the acceptable range of sensitivity are listed in Failed/Other.</i>					
Location	Address	Model #	Range	Value	ScanID
Passed					
Smoke Detector					
Basement Elevator Lobby	1-19-2634	4098-9714	0.2 - 3.7	2.5%	67060227
1st Elevator Lobby	1-10 19-2633	4098-9601	1.27 - 3.6	2.5%	67060231
1st security control office centre	1-10 2973	4098-9601	1.27 - 3.6	2.5%	62118554
1st security control office lobby	1-10	4098-9601	1.27 - 3.6	2.5%	62118562
1st security control office vestibule	1-10	4098-9601	1.27 - 3.6	2.5%	62118559
7th mid stairwell north	1-13 19-2882	2098-9131		2.5%	57019867
7th mid stairwell south	1-12 19-2883	2098-9131		2.5%	57019863
8th Elevator Lobby	1-19 19-2613	4098-9601	1.27 - 3.6	2.5%	67060261
9th Elevator Lobby	1-6 19-2611	4098-9601	1.27 - 3.6	2.5%	67037882
Penthouse Top of North Stair 1	1-9 19-2771	4098-9601	1.27 - 3.6	2.5%	67037879
Penthouse inside south stairwell stair 2	1-10 19-2770	4098-9714	0.2 - 3.7	2.5%	57019699
Roof top of south stairwell stair 3	1-11 19-2769	4098-9714	0.2 - 3.7	2.5%	57019700
Device Total: 12					
Failed/Other					
Duct Detector					
Penthouse mechanical/fan room RF1 standing height	1-10-18 19-2762	2098-9131 (Housing			57019730
Penthouse mechanical/fan room SF1 Overhead, 12'	1-9-17 19-2763	2098-9131 (Housing			57019732
Penthouse mechanical/fan room SF2 standing height	1-19 19-2761	2098-9131 (Housing			57019731
Device Total: 3					
Building: Communication, Traffic, & Computer Centre			Control Panel: 2 - SimplexGrinnell 4100		
<i>The Sensitivity Testing section details the sensitivity test ranges and acceptable readings for each type of device. Items are grouped by Passed or Failed/Other. Normally, Devices that perform outside the acceptable range of sensitivity are listed in Failed/Other.</i>					
Location	Address	Model #	Range	Value	ScanID
Passed					
Smoke Detector					

Location	Address	Model #	Range	Value	ScanID
Basement ceiling Network Comm. room 34/35 by entrance	2-57 19-2975	4098-9714	0.2 - 3.7		57019971
Basement ceiling Network Comm. room 34/35 by entrance FM-200 system	2-62 19-3068	4098-9714	0.2 - 3.7		57019970
Basement ceiling Network Comm. room 34/35 middle FM-200 system	2-62 19-3069	4098-9714	0.2 - 3.7		57019972
Basement ceiling Network Comm. room 34/35 rear FM-200 system	2-62 19-3068	4098-9714	0.2 - 3.7		64248327
Basement ceiling Telephone room 33 by entrance west FM-200 system, Zone -1	2-63 19-3067	4098-9714	0.2 - 3.7		57019982
Basement ceiling Telephone room 33 east FM-200 system, Z-2	2-64 19-3066	4098-9714	0.2 - 3.7		57019983
2nd Elevator Lobby	2-19-2632	4098-9714	0.2 - 3.7	2.5%	67060235

**Device Total: 7**

**Building: Communication, Traffic, & Computer Centre**

**Control Panel: 3 - SimplexGrinnell 4100**

*The Sensitivity Testing section details the sensitivity test ranges and acceptable readings for each type of device. Items are grouped by Passed or Failed/Other. Normally, Devices that perform outside the acceptable range of sensitivity are listed in Failed/Other.*

Location	Address	Model #	Range	Value	ScanID
<b>Passed</b>					
<b>Smoke Detector</b>					
3rd Elevator Lobby	3-19-2625	4098-9714	0.2 - 3.7	2.5%	67060244
3rd Computer Room , Under Floor N/C Area Z-1	3-13 19-2954	2451A			62125489
3rd Computer Room , Under Floor N/C Area Z-1	3-13 19-2954	2451A			62125487
3rd Computer Room , Under Floor N/C Area Z-1 , by FM -200 Tanks	3-13 19-2954	2451A			62125491
3rd Computer Room , Under Floor N/C Area Z-2	3-14 19-2953	2451A			62125492
3rd Computer Room , Under Floor N/C Area Z-2	3-14 19-2953	2451A			62125490
3rd Computer Room , Under Floor N/C Area Z-2	3-14 19-2953	2451A			62125488
3rd Computer Room , Under Floor N/E Area Z-1	3-13 19-2954	2451A			62125505
3rd Computer Room , Under Floor N/E Area Z-1	3-13 19-2951	1451A			62125495
3rd Computer Room , Under Floor N/E Area Z-1 , by D3AS-C01	3-13 19-2954	2451A			62125501
3rd Computer Room , Under Floor N/E Area Z-1 by D3AP-C01	3-13 19-2955	2451A			62125497
3rd Computer Room , Under Floor N/E Area Z-1 by D3AU-C01	3-13 19-2954	2451A			62125493

Location	Address	Model #	Range	Value	ScanID
3rd Computer Room , Under Floor N/E Area Z-1 by D3AZ-CO6	3-13 19-2954	2451	2.3 - 3.3		62125499
3rd Computer Room , Under Floor N/E Area Z-2	3-14 19-2953	2151A			62125498
3rd Computer Room , Under Floor N/E Area Z-2	3-14 19-2953	2151A			62125496
3rd Computer Room , Under Floor N/E Area Z-2	3-14 19-2953	2451	2.3 - 3.3		62125494
3rd Computer Room , Under Floor N/E Area Z-2, By D3AM-C01	3-14 19-2953	2451A			62125500
3rd Computer Room , Under Floor N/W Area Z-1	3-13 19-2954	2451A			62125486
3rd Computer Room , Under Floor N/W Area Z-1	3-13 19-2954	2451A			62125484
3rd Computer Room , Under Floor N/W Area Z-2	3-14 19-2953	2451A			62125485
3rd Computer Room , Under Floor N/W Area Z-2	3-14 19-2953	2451A			62125482
3rd Computer Room , Under Floor N/W Area Z-2	3-14 19-2953	2451A			62125481
3rd Computer Room , Under Floor S/E Area Z-1	3-13 19-2954	2451A			62125503
3rd Computer Room , Under Floor S/E Area Z-2	3-14 19-2953	2451A			62125506
3rd Computer Room , Under Floor S/E Area Z-2	3-14 19-2953	2451A			62125504
3rd Computer Room , Under Floor S/E Area Z-2	3-14 19-2953	2451A			62125502
3rd Computer Room Ceiling Centre Above D3AX -CO5 Z-1	3-12 19-2625	4098-2955			62125530
3rd Computer Room Ceiling N/C Above D3AL-CO3 Z-1	3-19-2955	4098-9714	0.2 - 3.7		62125525
3rd Computer Room Ceiling N/E By D3AS-CO3 Z-1	3-19-2955	4098-9714	0.2 - 3.7		62125531
3rd Computer Room Ceiling N/W Above D3AD-CO3 Z-2	3-19-2940	4098-9714	0.2 - 3.7		62125511
3rd Computer Room Ceiling N/W Above D3AG-CO2 Z-2	3-19-2940	4098-9714	0.2 - 3.7		62125526
3rd Computer Room Ceiling N/W Above FM -200 Tanks Z-1	3-19-2955	2098-9130			62125521
3rd Computer Room Ceiling North Above D3AB-CO3 Z-1	3-19-2955	4098-9714	0.2 - 3.7		62125510
3rd Computer Room Ceiling S/E By D3AZ-CO3 Z-2	3-19-2940	4098-9714	0.2 - 3.7		62125532
3rd Computer Room Ceiling S/E By D3BA-CO4 Z-1	3-12 19-2625	4098-2955			62125535



Location	Address	Model #	Range	Value	ScanID
3rd Computer Room Ceiling S/E By D3BC-C05 Z-2	3-19-2940	4098-9714	0.2 - 3.7		62125537
3rd Computer Room Ceiling S/w Above D3BB-CO3 Z-1	3-12 19-2625	4098-2955			62125536
4th Elevator Lobby	3-19-2624	4098-9601	1.27 - 3.6	2.5%	67060247
5th Elevator Lobby	3-19-2623	4098-9601	1.27 - 3.6	2.5%	67060250

**Device Total: 39**

**Building: Communication, Traffic, & Computer Centre** **Control Panel: 4 - SimplexGrinnell 4100**

*The Sensitivity Testing section details the sensitivity test ranges and acceptable readings for each type of device. Items are grouped by Passed or Failed/Other. Normally, Devices that perform outside the acceptable range of sensitivity are listed in Failed/Other.*

Location	Address	Model #	Range	Value	ScanID
----------	---------	---------	-------	-------	--------

### ***Passed***

#### **Smoke Detector**

6th Elevator Lobby	4-19-2615	4098-9714	0.2 - 3.7	2.5%	67060240
7th Elevator Lobby	4-19-2614	4098-9714	0.2 - 3.7	2.5%	67060255
7th main computer room 724D ceiling, north row, centre Z-1	4-1 19-2889	1451A		1.26%	59582842
7th main computer room 724D ceiling, north row, centre Z-2	4-2 19-2867	4098-9601		1.21%	59582841
7th main computer room 724D ceiling, north row, east Z-1	4-1 19-2889	2098-9130		1.31%	59582840
7th main computer room 724D ceiling, north row, east Z-2	4-2 19-2867	2098-9130		1.38%	59582839
7th main computer room 724D ceiling, north row, west Z-1	4-1 19-2889	2098-9130			59582844
7th main computer room 724D ceiling, north row, west Z-2	4-2 19-2867	2098-9130		2.5%	59582843
7th main computer room 724D ceiling, south row, centre Z-1	4-1 19-2889	2098-9130		2.5%	59582836
7th main computer room 724D ceiling, south row, centre Z-2	4-2 19-2867	1451A		1.14%	59582835
7th main computer room 724D ceiling, south row, east Z-1	4-1 19-2889	1451A		1.11%	59582834
7th main computer room 724D ceiling, south row, east Z-2	4-2 19-2867	2098-9130		2.5%	59582833
7th main computer room 724D under, middle row, centre	4-3 19-2887	2151A			59582815
7th main computer room 724D under, middle row, centre	4-4 19-2888	1451A			59582814
7th main computer room 724D under, middle row, east	4-4 19-2888	1451A			59582818
7th main computer room 724D under, middle row, east	4-3 19-2887	2151A			59582817

Location	Address	Model #	Range	Value	ScanID
7th main computer room 724D under, middle row, east	4-4 19-2888	2098-9130			59582816
7th main computer room 724D under, middle row, west	4-3 19-2887	1451A			59582813
7th main computer room 724D under, middle row, west	4-4 19-2888	2151A			59582812
7th main computer room 724D under, middle row, west	4-3 19-2887	2098-9130			59582811
7th main computer room 724D under, north row, centre	4-3 19-2887	1451A			59582823
7th main computer room 724D under, north row, centre	4-4 19-2888	1451A			59582822
7th main computer room 724D under, north row, east	4-3 19-2887	2151A			59582821
7th main computer room 724D under, north row, east	4-4 19-2888	2151A			59582820
7th main computer room 724D under, north row, east	4-3 19-2887	1451A			59582819
7th main computer room 724D under, north row, west	4-4 19-2888	2151A			59582826
7th main computer room 724D under, north row, west	4-3 19-2887	1451A			59582825
7th main computer room 724D under, north row, west	4-4 19-2888	2098-9130			59582824
7th main computer room 724D under, south row, centre	4-3 19-2887	1451A			59582809
7th main computer room 724D under, south row, centre	4-4 19-2888	1451A			59582808
7th main computer room 724D under, south row, east	4-3 19-2887	1451A			59582807
7th main computer room 724D under, south row, east	4-4 19-2888	1451A			59582806
7th main computer room 724D under, south row, east	4-3 19-2887	1451A			59582805
7th main computer room 724D under, south row, west	4-4 19-2888	1451A			59582810
Device Total: 34					
Building: Communication, Traffic, & Computer Centre		Control Panel: 5 - SimplexGrinnell 4100			
The Sensitivity Testing section details the sensitivity test ranges and acceptable readings for each type of device. Items are grouped by Passed or Failed/Other. Normally, Devices that perform outside the acceptable range of sensitivity are listed in Failed/Other.					
Location	Address	Model #	Range	Value	ScanID
Passed					
Smoke Detector					

Location	Address	Model #	Range	Value	ScanID
9th ceiling computer room north/east FM-200 system	5-19-2668	4098-9714	0.2 - 3.7	2.5%	57019928
9th ceiling computer room north/west FM-200 system	5-19-2669	4098-9714C		1.3%	57019929
9th ceiling computer room south/east FM-200 system	5-19-2667	4098-9714	0.2 - 3.7	2.5%	57019927
9th ceiling computer room south/west FM-200 system	5-19-2666	4098-9714	0.2 - 3.7	2.5%	57019930
9th under tile computer room north/east FM-200 system	5-19-2674	4098-9714	0.2 - 3.7	2.5%	57019932
9th under tile computer room north/west FM-200 system	5-19-2675	4098-9714C		1.3%	57019933
9th under tile computer room south/east FM-200 system	5-19-2673	4098-9714C		1.3%	57019931
9th under tile computer room south/west FM-200 system	5-19-2672	4098-9714	0.2 - 3.7	2.5%	57019934

**Device Total: 8**

**Building: Communication, Traffic, & Computer Centre**

**Control Panel: 6**

*The Sensitivity Testing section details the sensitivity test ranges and acceptable readings for each type of device. Items are grouped by Passed or Failed/Other. Normally, Devices that perform outside the acceptable range of sensitivity are listed in Failed/Other.*

Location	Address	Model #	Range	Value	ScanID
<b><i>Passed</i></b>					
<b>Smoke Detector</b>					
4th comp. & comm. room ceiling, comm. room c/e Z-1	6-1 19-2960	4098-9601			58612459
4th comp. & comm. room ceiling, comm. room c/e Z-1	6-1 19-2960	4098-9601			58612461
4th comp. & comm. room ceiling, comm. room c/w Z-1	6-2 19-2960	1451A			58612458
4th comp. & comm. room ceiling, comm. room n/e Z-2	6-2 19-2939	1451A			58612460
4th comp. & comm. room ceiling, comm. room s/e Z-2	6-2 19-2939	1451A			58612462
4th comp. & comm. room ceiling, comm. room s/w Z-1	6-1 19-2960	4098-9601			58612463
4th comp. & comm. room ceiling, north area	6-7 19-2960	2098-9130			58612473
4th comp. & comm. room ceiling, north area	6-2 19-2939	4098-9601			58612477
4th comp. & comm. room ceiling, north area Z-1	6-1 19-2960	1451A			58612475
4th comp. & comm. room ceiling, north area Z-1	6-1 19-2960	1451A			58612476
4th comp. & comm. room ceiling, north area Z-2	6-28 19-2939	4098-9601			58612474

Location	Address	Model #	Range	Value	ScanID
4th comp. & comm. room ceiling, s/e area Z-1	6-1 19-2960	1451A			58612470
4th comp. & comm. room ceiling, s/e area Z-2	6-2 19-2939	1451A			58612469
4th comp. & comm. room ceiling, s/w area Z-2	6-1 19-2939	4098-9601			58612472
4th comp. & comm. room ceiling, s/w by maintenance lab Z-2	6-2 19-2939	1451A			58612467
4th comp. & comm. room ceiling, south area Z-1	6-1 19-2960	4098-9601			58612468
4th comp. & comm. room ceiling, south area Z-1	6-2 19-2960	1451A			58612471
4th comp. & comm. room under, comm. room c/e	6-19-2958	1451A			58612431
4th comp. & comm. room under, comm. room c/w	6-19-2959	1451A			58612434
4th comp. & comm. room under, comm. room n/e	6-19-2959	1451A			58612432
4th comp. & comm. room under, comm. room n/w	6-19-2958	1451A			58612433
4th comp. & comm. room under, comm. room s/e	6-19-2959	1451A			58612430
4th comp. & comm. room under, comm. room s/w	6-19-2958	1451A			58612435
4th comp. & comm. room under, north area c/c	6-19-2959	1451A			58612440
4th comp. & comm. room under, north area c/e	6-19-2958	1451A			58612441
4th comp. & comm. room under, north area c/w	6-19-2958	1451A			58612439
4th comp. & comm. room under, north area n/e	6-19-2959	1451A			58612442
4th comp. & comm. room under, north area s/c	6-19-2958	1451A			58612437
4th comp. & comm. room under, north area s/e	6-19-2959	1451A			58612436
4th comp. & comm. room under, north area s/w	6-19-2959	1451A			58612438
4th comp. & comm. room under, south area c/c	6-19-2958	1451A			58612425
4th comp. & comm. room under, south area c/e	6-19-2959	1451A			58612426
4th comp. & comm. room under, south area n/c	6-19-2959	1451A			58612428
4th comp. & comm. room under, south area n/e	6-19-2958	1451A			58612427
4th comp. & comm. room under, south area n/w	6-19-2958	1451A			58612429
4th comp. & comm. room under, south area s/c	6-19-2958	1451A			58612424
4th comp. & comm. room under, south area s/e	6-19-2959	1451A			58612423
4th maintenance lab E ceiling Z-2 barcode on doorframe	6-2 19-2939	4098-9601			58612465
4th maintenance lab W ceiling Z-1 barcode on doorframe	6-1 19-2960	1451A			58612464
4th maintenance/test lab under, n/c	6-19-2958	1451A			58612421
4th maintenance/test lab under, n/e	6-19-2959	1451A			58612420
4th maintenance/test lab under, n/w	6-19-2959	1451A			58612422
4th maintenance/test lab under, s/c	6-19-2959	1451A			58612498

Location	Address	Model #	Range	Value	ScanID
4th maintenance/test lab under, s/e	6-19-2958	1451A			58612499
4th maintenance/test lab under, s/w	6-19-2958	1451A			58612497
<b>Device Total: 45</b>					
<i>Failed/Other</i>					
<b>Smoke Detector</b>					
4th comp. & comm. room ceiling, s/w by tanks Z-1	6-1 19-2960	4098-9601			58612466
<b>Device Total: 1</b>					

# Battery & Power Supply Testing

Generated by: BuildingReports.com

Building: Communication, Traffic, & Computer Centre				Control Panel: 1 - SimplexGrinnell 4100			
The Battery & Power Supply Testing section details the readings and measurements of batteries and power supplies used to provide power to the fire alarm and life safety systems. Items are grouped by Passed or Failed/Other.							
Type	Location	Rated Ah	Rated Volts	Pre Test	Post Test	Min Ah	Tested Ah
Battery							
Passed							
Sealed Lead Acid	1st security deck at front entrance	42	2x 12V				

Building: Communication, Traffic, & Computer Centre				Control Panel: 2 - SimplexGrinnell 4100			
The Battery & Power Supply Testing section details the readings and measurements of batteries and power supplies used to provide power to the fire alarm and life safety systems. Items are grouped by Passed or Failed/Other.							
Type	Location	Rated Ah	Rated Volts	Pre Test	Post Test	Min Ah	Tested Ah
Battery							
Passed							
Sealed Lead Acid	1st electrical room amplifier door plaque 111	34	12V x2				
Failed/Other							
Sealed Lead Acid	1st electrical room door plaque 111	34	12V x2				

Building: Communication, Traffic, & Computer Centre				Control Panel: 3 - SimplexGrinnell 4100			
The Battery & Power Supply Testing section details the readings and measurements of batteries and power supplies used to provide power to the fire alarm and life safety systems. Items are grouped by Passed or Failed/Other.							
Type	Location	Rated Ah	Rated Volts	Pre Test	Post Test	Min Ah	Tested Ah
Battery							
Passed							
Sealed Lead Acid	4th electrical room Amplifier Cabinet	34	2x 12V				
Failed/Other							
Sealed Lead Acid	4th electrical room Node -3	34	2x 12V				

Building: Communication, Traffic, & Computer Centre				Control Panel: 4 - SimplexGrinnell 4100			
The Battery & Power Supply Testing section details the readings and measurements of batteries and power supplies used							

to provide power to the fire alarm and life safety systems. Items are grouped by Passed or Failed/Other.

Type	Location	Rated Ah	Rated Volts	Pre Test	Post Test	Min Ah	Tested Ah
Battery							
Failed/Other							
Sealed Lead Acid	7th Electrical/Fire Alarm Panel Room door plaque 704 Left tub	42	2x 12V				
Sealed Lead Acid	7th Electrical/Fire Alarm Panel Room door plaque 704 Main tub	42	2x 12V				
Building: Communication, Traffic, & Computer Centre				Control Panel: 5 - SimplexGrinnell 4100			
The Battery & Power Supply Testing section details the readings and measurements of batteries and power supplies used to provide power to the fire alarm and life safety systems. Items are grouped by Passed or Failed/Other.							
Type	Location	Rated Ah	Rated Volts	Pre Test	Post Test	Min Ah	Tested Ah
Battery							
Failed/Other							
Sealed Lead Acid	9th Electrical Room Fire Alarm Panel Room Left tub	35	2x 12V				
Sealed Lead Acid	9th Electrical Room Fire Alarm Panel Room Main tub	35	2x 12V				