

September 11, 2024

Sent via Email (2 pages)

ADDENDUM NO. 1
RFTWORK ASSIGNMENT NO. CREM-PMO-24-016
IN ACCORDANCE WITH
REQUEST FOR SUPPLIER QUALIFICATION (RFSQ) NO. Doc 3512316731
Closing September 27, 2024

Overhead Security Gate Replacement located at 4330 Dufferin Street detailed in the consultant's drawings and specifications documents and according to the City's Contract.

CLOSING DATE: September 27, 2024 AT 2:00 P.M. (LOCAL TORONTO TIME)

Please refer to the above Request for Tender (RFT) document in your possession and be advised of the following:

I. REFERENCE TO APPENDIX B – BASE BID – PRICING FORM

.1 Add Alternate Prices to Bid Form for the following scope:

The following alternate prices apply to work not included in the BASE BID amount, but which may be substituted by Owner for Work that is included. Alternate prices listed are to take into consideration and allow for changes and adjustments in other Work as required to form a complete and finished job. Alternate prices represent the amount to be added to or deducted from the Contract Price, should Owner accept the alternative. No price listed shall mean that there is no change in price. Owner reserves the right to accept or reject any or all alternative prices listed.

.1 "Delete trenching and site work on the north side of driveway and instead provide wall mounted conduit on the interior of the parking garage from the end of the planter to the electrical room."

.2 "Install PVC conduit from north junction box to south junction box surface mounted along the overhead door frame in lieu of underground routing, trenching and site work."

II. REFERENCE TO ELECTRICAL DRAWING E-4

.1 The following is to clarify Electrical Drawing E-4:

Conduit from south junction box to building face is to be routed underground.
Contractor to trench, core through exterior wall, and reinstate all finishes affected by the work.

The contractor is to include the revised Bid Form (attached) in their Bid Submission.

III. QUESTIONS/ CLARIFICATIONS:

RFI from the OH door contractors:

1. Could you please provide a written specification for the Overhead Gate door, which is on electrical drawing E-5.

A: Overhead door written specifications can be found on electrical drawings E-3.

2. I see on the drawings they refer to a specification. Are you able to send that to me so I can be sure I am quoting the right thing.

A: Overhead door written specifications can be found on electrical drawings E-3.

3. The pricing form has a section for DSS Abatement. There is asbestos in the building but there does not appear to be any abatement required to complete the project scope of work. What are we to include in this section on the pricing form?

A: DSS to be treated as allowance. Item 4 on Price Breakdown to be prefilled. Refer to updated form.

Should you have any questions regarding this addendum, please contact the Roster Captain named below.

Please attach this addendum to your call document and be governed accordingly. Suppliers must acknowledge receipt of all addenda in their submission in the space provided on the Bid Form as per Clause 1.10 in Part 2 – Form of Agreements **(RFSQ) NO. Doc 3512316731**. All other aspects of the call remain the same.

END OF ADDENDUM NO. 1

Roster Captain Name: Malake AbouHmaid,
Title: Sr. Project Manager, Project Management Office,
Division: CREM