



---

## **NOTICE OF ADDENDUM**

**Addendum No.:** 8

**Addendum Issue Date:** September 26, 2024

**Procurement No.:** PRC004630

**Procurement Name:** General Contracting services for Mavis South - Renovations, Roof and HVAC Replacement

**Closing Date:** Wednesday, October 2, 2024, 2:00 PM

---

The additions, deletions, revisions and/or clarifications as hereinafter specified shall form an integral part of the bid document and shall be read in conjunction with the requirements set forth in the bid request document.

---

### **MODIFICATIONS**

Refer to attached 22312 CofM Mavis S\_ARCH -Addendum 8

---

### **QUESTIONS & ANSWERS**

#### **Question 1:**

As per addendum #3 and drawing D1-A502, the existing parapet has to be removed and build a new parapet from roof level. Based on our investigation on roof, the existing parapet is brick about 14" higher than roof deck level and continue down to ground. Please advise if all this bricks from roof level have to be removed or not? If not need to be remove as per addendum #3, then drawing D1-A502 is not working. How you want us to build new parapet.

**Answer 1:**

It appears that the parapet in question is referring to the chimney walls. In this case, the chimney wall on the existing parapet side should remain up to the current parapet level. To address the construction of the new parapet, please refer to the updated Detail 1-A602 attached to this Addendum 8, which provides revised instructions and clarifies how to proceed with the construction while maintaining the necessary portions of the existing Brick wall.

**Question 2:**

Our suppliers have noted that light type A is supplied by SAYLITE, which is no longer in business. Can you supply a different specification for light type A?

**Answer 2:**

The General Contractor (GC) should provide an equivalent product for any discontinued items. The replacement for light Type A must match the original specifications and be submitted for approval by the Architect.

**Question 3:**

I just wanted to ask you that, All removal and replacement of HVAC units are on roof (B1, B2 or A2). If these units are not on that roof, could you please provide roof assembly for that roof.

**Answer 3:**

Please refer to updated architectural drawings attached to this Addendum 8.

This Addendum is issued by the City of Mississauga and is in effect as of the Addendum Issue Date.

Hyacinth Menezes Trivedi

Amrit Sidhu

Procurement Services, City of Mississauga

**End of Addendum**