



METRO TORONTO CONVENTION CENTRE

**REQUEST FOR PROPOSAL
RFP # 24-100P FIRE ALARM SYSTEM MODERNIZATION**

("RFP")

ADDENDUM #3

This RFP is issued by the Metropolitan Toronto Convention Centre Corporation (hereinafter called "MTCC") to select a qualified and experienced Service Provider for Fire Alarm System Modernization.

Questions and Responses

1. The following questions were received from Proponents via email:

Q#	Questions	Responses
1.	Can you confirm the new fire rated riser cable can be substituted with VitaLink 2 HR fire rated ULC listed AC90 or CIC cabling?	Yes
2.	Can you confirm the new fire rated cabling can be installed at the identified new chase and EMT conduit between DGP cabinets?	Response will be in addendum #4
3.	Can you confirm all work can be completed during normal business hours (Monday to Friday)?	Please refer to General Requirements 3.4.9.
4.	Can you advise and supply any hazardous material reports for basement, common floors, and mechanical rooms?	High- and low-pressure steam lines in Chiller Plant area only. Also, water treatment for chillers in the same plant.
5.	Can you confirm working hours in the building based on work areas IE: basement garage, access tunnel, mechanical rooms, common corridors, theatre and meeting rooms?	The back of the house will be available any time. We will provide a detailed schedule for the front of the house.



6.	Can you confirm coupling color coding for EMT conduits for this site if required?	Not required by code, red preferred
----	---	-------------------------------------

2. Effective September 9, 2024, the Addenda Deadline will be **extended to September 16, 2024 at 4 p.m.**
3. Effective September 9, 2024, the Proposal submission Deadline will be **extended to September 23, 2024 at 2:00 p.m.**

This is the end of Addendum #3 to RFP # 24-100P