



METRO TORONTO CONVENTION CENTRE

**REQUEST FOR PROPOSAL
RFP # 24-100P FIRE ALARM SYSTEM MODERNIZATION
("RFP")**

ADDENDUM #4

This RFP is issued by the Metropolitan Toronto Convention Centre Corporation (hereinafter called "MTCC") to select a qualified and experienced Service Provider for Fire Alarm System Modernization.

Questions and Responses

The following questions were received from Proponents via email:

Q#	Questions	Response
1.	<p>Can you confirm the new fire rated cabling can be installed at the identified new chase and EMT conduit between DGP cabinets?</p> <p>This would apply to the various locations for the new cabling between the FACP nodes. The Vitalink cable can be installed in conduit or there is a type that is armoured as well. The Chase locations that were shown during the walkthrough were in the rear area next to the elevators, mechanical room and near tunnel stairwells.</p> <p>The question relates to the aesthetics as conduit may not look great in some areas but as they are all back of house locations I'm assuming surface conduit is acceptable.</p>	<p>MTCC's priority revolves around complying with all applicable codes and is not concerned about aesthetics.</p>

This is the end of Addendum #4 to RFP # 24-100P