

September 18, 2024

Sent via Email (2 pages)

**ADDENDUM NO. 2
RFT WORK ASSIGNMENT NO. CREM-PMO-24-016
IN ACCORDANCE WITH
REQUEST FOR SUPPLIER QUALIFICATION (RFSQ) NO. Doc 3512316731
Closing September 27, 2024**

Overhead Security Gate Replacement located at 4330 Dufferin Street detailed in the consultant's drawings and specifications documents and according to the City's Contract.

CLOSING DATE: September 27, 2024 AT 2:00 P.M. (LOCAL TORONTO TIME)

Deadline for Questions September 11, 2024 AT 2:00 P.M. (LOCAL TORONTO TIME)

Please refer to the above Request for Tender (RFT) document in your possession and be advised of the following:

I. **QUESTIONS/ CLARIFICATIONS:**

RFI from the OH door contractors:

Q1: The spec requires an IP based Ai phone video intercom system, yet they also reference an AXIS camera to be built in and integrated. Which should it be?

A1: The Ai phone has a camera built in, no need for AXIS camera.

Should you have any questions regarding this addendum, please contact the Roster Captain named below.

Please attach this addendum to your call document and be governed accordingly. Suppliers must acknowledge receipt of all addenda in their submission in the space provided on the Bid Form as per Clause 1.10 in Part 2 – Form of Agreements (**RFSQ**) **NO. Doc 3512316731**. All other aspects of the call remain the same.

END OF ADDENDUM NO. 2

Roster Captain Name: Malake AbouHmaid,
Title: Sr. Project Manager, Project Management Office,
Division: CREM