

Geneviève Sharkey Chief Procurement Officer

Purchasing and Materials Management Division City Hall, 18th Floor, West Tower 100 Queen Street West Toronto, Ontario M5H 2N2 Francesco McGrillis, Acting Manager Purchasing Client Services

October 28, 2024

Via Ariba internet posting (2 Pages)

ADDENDUM No. 6 REQUEST FOR TENDER ARIBA Doc4744062042 CLOSING DATE (REVISED): 12:00 NOON (LOCAL TIME), October 30, 2024

For: Renovations to the Existing Occupied TSSS Family Residence, Located at 4222 Kingston Road, Toronto

Please refer to the above Tender Call document in your possession and be advised of the following information:

1. QUESTIONS

- **Q1** Please clarify if the specifications for the FRP panels are the Hygienic Wall Panels from Altro (Section 09 75 00)?
- **A1** For now, assume that you're accessing the site solely through the corridor.
- **Q2** What type of transition is to be used between porcelain floor tile and resilient sheet flooring?.
- **A2** Aluminum transition to be Schluter-SCHIENE, Schluter-VINPRO-S or similar.
- **Q3** Could you please clarify the following from the specifications calling out two different types of ceiling tile. They mention the LYYRA PB and then below they mention the Tectum. Just need confirmation of which will be used. Also, for the t-bar suspended grid, do they want aluminum or steel, both are mentioned in the specifications. Photo attached from specifications.
- A3 Basis-of-design should be Armstrong LYRA PB, disregard the Tectum...
- **Q4** HVAC Scope
- 4.1. Drawing M-1.4, please identify the 12x12 return air grille for drywall ceilings.
- 4.2. Drawing M-1.4, please indicate size for sanitary exhaust grille in washroom 106.
- 4.3. Drawing M-1.4, please indicate diffuser type for Common Area.
- 5. Plumbing Scope
- 5.1. Please provide fixture selection for L-1.

A4 - In order:

All return grilles are type 80 as indicated on Drawing M-0.1..

Sanitary exhaust grille is 12"x12"

Addendum No. 6 Page 1 of 2

Diffusers are EH Price type 620 as per the labels shown on the drawing.

A full specification for L-1 is shown on Drawing M-0.1.

Please continue to monitor this procurement as further extensions or possible cancellation may occur. Please see www.toronto.ca/covid19 for more information on the City's response. Should you have any questions regarding this addendum send via the event message board or contact Max Parker by email at Max.Parker@toronto.ca.

Bidders must acknowledge receipt of all addenda on the space provided on the submission form as per the Process Terms and Conditions, Part 1.7 - Addenda, of the RFT document. All other aspects of the RFT remain the same.

Sincerely,

Theodoros Maicantis, Supervisor Purchasing & Materials Management Division

Addendum No. 6 Page 2 of 2