



Date Issued: October 3, 2024

C13-20-24 - General Contractor required for Macassa Lodge Space and Domestic Hot Water (DHW) Heating Boilers Upgrade

ADDENDUM 3

1. BIDDER QUESTIONS AND CITY RESPONSES

Q4: To properly quote the demo of the venting stack, can you provide more details on the size & method of installation of the vertical portion for the three floors where the demo is required? Are you able to provide pictures? REF M10-DETAIL 1.

R4: The existing vent is approximately 1000mm in diameter. The installation details are not available.

Q5: Can we have an extension to close?

R5: Bidders are to refer to the Closing Date Extension within Addendum 2.

Q6: Is there a preferred location for craning?

R6: The Successful Bidder shall review the site conditions to come up with a craning plan with preferred location. For a suggested crane location as a generic guideline, please see "X" sign placed in a google snapshot below. The craning plan also needs to be coordinated during the construction phase with supply deliveries coming to Macassa Lodge through City's assigned Project Manager.



Q7: Formally requesting 1 week closing extension as venting has yet to be addressed via addendum.

R7: Bidders are to refer to the Closing Date Extension within Addendum 2.

Q8: Is there a base building water treatment contracts, if so please provide contact details.

R8: Bidders are to refer to R3 listed within Addendum 2.

END OF ADDENDUM