

ADDENDA 05 00 91 13

The information listed below is to form part of the Contract Documents. All associated costs are to be included in the Bid Price shown on the Bid Form. Acknowledgment of this Addendum, by number, is to be shown in the space provided on the Bid Form.

1 SPECIFICATIONS

1.1 Section 26 08 05 System Coordination, Verification and Testing (Re-issued herewith)

- .1 Div 26 to retain the independent testing organization as listed in specs section. Separate pricing item line deleted from specs.

1.2 Section 26 36 23 Transfer Switches (Re-issued herewith)

- .1 Revised spec to indicate 120/208V, 3 phase, 4 wire Automatic transfer switch, as per our design drawings.

1.3 Section 26 50 00 Lighting (Re-issued herewith)

- .1 Revised Exit sign spare quantities to three (3) as shown.
- .2 Added 'LW1' luminaire specification, as shown in specs section.

1.4 Section 27 05 33 - Conduits and Backboxes for Communications Systems

- .1 Added new spec section 27 05 33.

1.5 Section 27 05 53 - Identification for Communications Systems

- .1 Added new spec section 27 05 53.

1.6 Section 27 13 13.13 - Communications Copper Cable Splicing and Terminations

- .1 Added new spec section 27 13 13.13

1.7 Section 27 15 13 - Communications Copper Horizontal Cabling

- .1 Added new spec section 27 15 13.

1.8 Section 27 15 43 - Communications Faceplates and Connectors

- .1 Added new spec section 27 15 43.

1.9 Section 27 16 00 - Communications Connecting Cords, Devices, and Adapters

- .1 Added new spec section 27 16 00.

1.10 Section 28 10 00 - Access Control

- .1 Added new spec section 28 10 00.

2 DRAWINGS

2.1 DRAWING E-108 ELECTRICAL ROOM PLANS (Re-issued herewith)

- .1 Added tag 'LW1' for wall mounted luminaire, as shown on drawing.

End of Section