

December 3, 2024

Sent via Email (2 pages)

**ADDENDUM NO. 1  
RFTWORK ASSIGNMENT NO. CREM-PMO-24-021  
IN ACCORDANCE WITH  
REQUEST FOR SUPPLIER QUALIFICATION (RFSQ) NO. Doc 3512316731  
Closing December 30, 2024**

Toronto Paramedic Services District 6 renovation project to secure entry/access to the former bus terminal building located at 610 Bay Street, as detailed in the consultant's drawings and specifications document and according to the City's Contract.

**Revised CLOSING DATE:** From December 16 to **December 30, 2024**

**CLOSING TIME:** 14:00 PM local time

**Revised Deadline for Questions:** From November 29 to **December 13, 2024** at 12:00PM

Please sign the CONFIDENTIALITY AND NON-DISCLOSURE DECLARATION (NDA) form attached  
CITY OF TORONTO  
CONFIDENTIALITY AND NON-DISCLOSURE DECLARATION  
("Confidentiality Agreement")

so I can release the addenda 2.

**I. QUESTIONS/ CLARIFICATIONS:**

**1. Is there any new keying & cylinders?**

**Answer:** Yes. New keying and cylinders at all doors identified in hardware schedule. Refer to section 08 70 00.

**2. Are we removing any existing man doors & o/H Doors?**

**Answer:** No.

**3. Is temporary fencing not in contract?**

**Answer:** Perimeter temporary fencing in open bays is not in scope by other. Refer to Architectural A10. Hoarding only required at location of two new O/H doors during installation. Refer to Section 01 01 01 50.

**4. Is drywall part of work?**

**Answer:** Not anticipated.

**5. Appendix A notes Elevator to Mezzanine offices to have CR access, as does Appendix B item 2; however, this is not noted anywhere on the provided drawings. Please clarify this scope of work.**

**Answer:** Card reader access at elevator is not in scope of work.

6. **There was mention at the site walk of programming existing card readers at the top of the stair landings to be included in new security system; this is not noted anywhere on drawings or in contract documents. Please confirm.**

**Answer:** Card readers at top of stair landings are not included in scope of work.

7. **Appendix A of the tender point 2.2.2 says that construction is not to interfere with regular business hours of 8am to 5pm. Please confirm that this work is slated for regular business hours and not after-hours**

**Answer:** That is correct. Work is to be scheduled during regular business hours.

8. **Requesting extension to question period as many of our subtrades have yet to review this project due to workload**

**Answer:** Question period extended until December 13, 2024.  
Closing date is extended until December 30, 2024

Should you have any questions regarding this addendum, please contact the Roster Captain named below.

Please attach this addendum to your call document and be governed accordingly. Suppliers must acknowledge receipt of all addenda in their submission in the space provided on the Bid Form as per Clause 1.10 in Part 2 – Form of Agreements **(RFSQ) NO. Doc 3512316731**. All other aspects of the call remain the same.

**END OF ADDENDUM NO. 1**

**Roster Captain Name:** Malake AbouHmaid,  
**Title:** Sr. Project Manager, Project Management Office,  
**Division:** CREM