

- 1 General
- 1.1 **SECTION INCLUDES**
 - .1 Labour, Products, equipment and services necessary for resilient base work and accessories in accordance with the Contract Documents.
- 1.2 **REFERENCES**
 - .1 ASTM F1861, Specification for Resilient Wall Base.
- 1.3 **SUBMITTALS**
 - .1 Product data:
 - .1 Submit copies of manufacturer's Product data in accordance with Section 01 10 10 indicating:
 - .1 Performance criteria, compliance with appropriate reference standard, characteristics, limitations.
 - .2 Product transportation, storage, handling and installation requirements.
 - .2 Samples: Submit two 250 mm long samples of resilient base in accordance with Section 01 10 10.
 - .3 Closeout submittals: Submit maintenance and cleaning data for incorporation into Operations and Maintenance Manuals in accordance with Section 01 10 10.
- 1.4 **SITE CONDITIONS**
 - .1 Maintain air temperature and structural base temperature at installation area above 20°C for 48 hr before, during and 48 hr after installation.
 - .2 Store materials for 2 days prior to installation in area of work to achieve temperature stability.
 - .3 Do not install base in conditions of high humidity or where exposed to cold drafts. In hot weather, protect from direct sunlight.
 - .4 Provide adequate ventilation during installation.
- 1.5 **MAINTENANCE**
 - .1 Submit extra 2% or to nearest full roll of each colour, pattern and type of base required for maintenance use. Identify each carton. Store where directed.

2 Products

2.1 **MATERIALS**

- .1 All materials under work of this Section, including but not limited to, adhesives, are to have low VOC content limits.
- .2 Rubber base (RB-1): ASTM F1861, Type TV, Group 1, rubber wall base, approximately 100 mm high x 6 mm thick toeless, tapered wedge, in lengths as long as possible including premoulded end stops and inner and outer corners. Colour: 'Pewter (38)' . 'TightLock Carpet and Resilient Wall Base' by Tarkett or approved alternative.
- .3 Adhesives: Low VOC, waterproof, recommended by base manufacturer for specific material on applicable substrate, above, at or below grade.

3 Execution

3.1 **EXAMINATION**

- .1 Verify condition and dimensions of previously installed work upon which this Section depends. Report defects to Consultant. Commencement of work of this Section means acceptance of existing conditions.
- .2 Defective work resulting from application to unsatisfactory surfaces will be considered the responsibility of those performing the work of this Section.

3.2 **RESILIENT BASE APPLICATION**

- .1 Install resilient base in accordance with manufacturer's written instructions.
- .2 Lay out base to keep number of joints at minimum.
- .3 Prior to installing base, fill cracks and irregularities with a filler recommended by base manufacturer.
- .4 Set base in adhesive using a 3 kg hand roller, against wall and floor surfaces.
- .5 Install straight and level to variation of 1:1000.
- .6 Scribe and fit to door frames and other obstructions.
- .7 Cope internal corners.

3.3 CLEANING

- .1 Forty-eight hours after installation, clean resilient base surfaces with a mild soap solution approved by finish manufacturer.

END OF SECTION