



Geneviève Sharkey  
Chief Procurement Officer

Purchasing & Materials Management Division  
City Hall, 18th Floor, West Tower  
100 Queen Street West  
Toronto, Ontario M5H 2N2

Clarman Yang  
Manager  
Purchasing Client Services

February 24, 2025

Posted via Ariba  
(2 pages + 0 attachments)

**ADDENDUM No. 2  
REQUEST FOR TENDER No. Doc4924595340**

**SUBMISSION DEADLINE: 12:00 NOON (LOCAL TIME), February 28, 2025**

**FOR: Air Handling Units Replacement at Wesburn Manor**

Please refer to the above Request for Tender document in your possession and be advised of the following:

**I. REVISIONS**

**R1.**

The collection of structural and architectural drawings can be accessed at the following link:

<https://www.dropbox.com/scl/fo/ggw4vlkvvtcdb3dd2g0ri/AOrS1BFESQ3-k8jFNmaa1II?rlkey=5dx0jsh85sxmm4purokydv1pc&st=9t2k2aah&dl=0>

**R2.**

The following changes and clarifications shall be considered when submitting your bid.

**MECHANICAL SPECIFICATION**

23 21 16 HYDRONIC PIPING SPECIALTIES.pdf

- .1 Added Part 2.10 Buffer Tank.
- .2 Added Part 3.7 Installation of Buffer Tank.

**ELECTRICAL DRAWINGS**

E101 ROOF PLAN-E101.pdf

- .1 Revise the drawing backgrounds to show MCC-6AP, MCC-6BP, MCC-6CP as requested and several other MCCs, panels, starters, and receptacles:

**II. QUESTIONS AND ANSWERS**

**Q1. What type of conduit is needed for Mechanical equipment wiring, Rigid or PVC?**

**A1.** Refer to E301 Electrical Specifications Item 17 for conduit requirements.

Q2. Project will be performed in regular hours?

A2. Yes, 8:00am-4:40pm

Q3. Is there free parking available on site?

A3. No parking available

Q4. Will be phasing for this project? Can we collect the refrigeration in one visit?

A4. Please see addendum 1 – already responded to this question

Q5. Can you advise if the base building contractor list is mandatory or preferred

A5. Please see addendum 1 – already responded to this question

Q6. Is there a base building roofing contractor that we can contact to price the associated roofing work

A6. Yes, Cordeiro Roofing

Should you have any questions regarding this addendum send via the event message board or contact **Lynda Forbes** at **Lynda.forbes@toronto.ca**.

Suppliers must acknowledge receipt of all addenda in the space provided on Part 4 – Submission Form as per Part 1 Tender Process, Section 1 RFT Specific Process and Submission Instructions, Item 1.7 – Addenda, of the Tender document. All other aspects of the Tender remain the same.

Yours truly,

Clarman Yang  
Manager  
Purchasing Client Services  
Purchasing & Materials Management Division