

March 17, 2025

Sent via Email (1 page)

**ADDENDUM NO. 4
RFQ WORK ASSIGNMENT No. 25-PFR-CAP-GC-003.
IN ACCORDANCE WITH
REQUEST FOR SUPPLIER QUALIFICATION (RFSQ) NO. DOC4509693485
FOR: Etobicoke Olympium Bleachers**

CLOSING DATE: March 21, 2025 AT 2:00 P.M. (LOCAL TORONTO TIME)

Please refer to the above Request for Quotation (RFQ) document in your possession and be advised of the following:

I. QUESTIONS AND ANSWERS

- Q.1:** Will the telescopic bleachers for the pool deck need to be manufactured with a galvanized steel understructure along with stainless steel hardware for the high-humidity environment?
- A.1:** The under structure, frames, rails and steps to be galvanized. Electrical system to be waterproof. Decking to be aluminum, plastic seats. All hardware to be stainless steel.

Should you have any questions regarding this addendum, please contact the Roster Captain named below.

Please attach this addendum to your call document and be governed accordingly.

Suppliers must acknowledge receipt of all addenda in their submission in the space provided on the Bid Form as per Clause 1.10 in Part 2 – Form of Agreements. All other aspects of the call remain the same.

END OF ADDENDUM

Cristian Lukaszuk
Senior Project Manager
Capital Projects Design & Delivery
Parks, Forestry and Recreation