



Parks and Recreation Division  
Metro Hall, 24<sup>th</sup> Floor, 55 John Street  
M5V 3C6

Mario Pecchia, Manager (Acting)  
Capital Project Design & Delivery

March 13, 2025

Sent via Email (4 pages)

**ADDENDUM NO. 03  
RFQ WORK ASSIGNMENT No. 25-PFR-CAP-GC-003.  
IN ACCORDANCE WITH  
REQUEST FOR SUPPLIER QUALIFICATION (RFSQ) NO. DOC4509693485  
FOR: Etobicoke Olympium Bleachers**

**CLOSING DATE: March 21, 2025 AT 2:00 P.M. (LOCAL TORONTO TIME)**

Please refer to the above Request for Quotation (RFQ) document in your possession and be advised of the following:

**I. REVISIONS / ADDITIONS**

**1. SECTION 1 – SUBMISSION INSTRUCTIONS**

- 1.1 A second optional bidders meeting will be held on Tuesday March 18, 2025 at 11:00am at Etobicoke Olympium for anyone that requires additional inspection.

**II. QUESTIONS AND ANSWERS**

- Q.1:** Please clarify whether the new bleacher system is required to be manual or motorized.  
**A.1:** The bleacher system is to be motorized with manual over-ride.
- Q.2:** Can you confirm that “Sheridan Seating” is the only approved supplier for the bleachers system. Is “Sport Systems” accepted supplier for the bleachers system. Could “Creative Sports Solutions” be alternative approved supplier for the new telescopic bleachers.  
**A.2:** Other suppliers will be considered if they are able to supply telescopic high humidity bleacher systems.
- Q.3:** The floor plan of a Universal Change Room which has been issued in the Adden-02, doesn't show the detailed drawings 1/A110 as well as type of floor tile & Base Board tile along with the Color for the side Pattern on the floor, as well as BB? Please clarify the BB Dimensions.  
**A.3:** Please see attached drawing A110 as requested. Also included is drawing A104 to show the baseboard detail. These drawings are for reference and measurements only. Floor tile was sent in Add. #02.

**III. ATTACHMENTS**

**Attachment 1:** EtobicokeOlympium-UniversalChangeRoomA104

**Attachment 2:** EtobicokeOlympium-UniversalChangeRoomA110

Should you have any questions regarding this addendum, please contact the Roster Captain named below.

Please attach this addendum to your call document and be governed accordingly.

Suppliers must acknowledge receipt of all addenda in their submission in the space provided on the Bid Form as per Clause 1.10 in Part 2 – Form of Agreements. All other aspects of the call remain the same.

**END OF ADDENDUM**

Cristian Lukaszyk  
Senior Project Manager  
Capital Projects Design & Delivery  
Parks, Forestry and Recreation