



Hamilton

Date Issued: Wednesday, March 26, 2025

**C13-16-25: General Contractor for the Supply and Installation of new Energy Efficient LED Lighting at various City Yards and Municipal Service Centres**

### **ADDENDUM 3**

---

#### **1. CLOSING DATE EXTENSION**

The closing date has been extended from March 27, 2025, to Friday March 28, 2025, at 3:00 PM (Hamilton time).

#### **2. REVISIONS**

##### **1) Specifications, Section 26500 Lighting, 1.2 Linear Fluorescent Retrofit Measures, item .1 T8 Ballasts**

Delete item .10 in its entirety

Add:

“.10 120V Representative Products:

1-Lamp: ADVANCE (Signify): ICN-1P32-SC@120V

2-Lamp: LEDVANCE (SYLVANIA) LHE2X32T8UNVISNSCB;

4-Lamp: LEDVANCE (SYLVANIA) LHE4X32T8UNVISNSCB;

All T8 Ballasts shall be normal ballast factor type, with a 0.88 ballast factor. Lamps and ballast must be listed as compatible by the lamp manufacturer.”

#### **3. ADDITIONS**

##### **1) LUMP SUM BREAKDOWN OF BASE BID PRICE**

Add: Lump Sum Breakdown of Base Bid Price attached herein

## 2) Specifications, Section 26500, Item 1.5 Equivalents

Add: The following parts have been added to the list of approved equivalents. These products shall be considered equal to the representative products listed in section 26500:

1. LINEAR FLUORESCENT RETROFIT MEASURES: T8 LED LAMPS  
4ft T8LED : Current 34291  
T8-U6LED: Current 43129  
2ft T8LED: Current 35778
2. LINEAR FLUORESCENT RETROFIT MEASURES: T8 BALLASTS :  
Current GE GE232MAX-G-N, GE432MAX-G-N,  
GE232MAX-G-N-347, GE432MAX-G-N-347
3. LINEAR FLUORESCENT RETROFIT MEASURES: T5 LED LAMPS :  
Current 34355
4. LINEAR FLUORESCENT RETROFIT MEASURES Type: T5 BALLASTS  
:  
Current 68993
5. NEW FIXTURES: NLED-STR2-20 :  
1) LEDVANCE / 62351 STRIP1B/S020UNVD8SC7/24S/WH  
2) CURRENT / NSL-RA-2-23-40K
6. Type: NLED-STR4-30: CURRENT / NSL-RA-4-40-40K
7. Type: NLED-PO6: LEDVANCE / 62807 RT65AS900UNVD9SC8WHTAA
8. Type: NLED-PO10: LEDVANCE / 62809  
RT85AS2000UNVD9SC8WHTAA  
complete with 62789 RT8105ATRIMEXT
9. Type: NLED-PO8: LEDVANCE / 62809  
RT85AS2000UNVD9SC8WHTAA
10. Type: NLED-VAP30:  
1) LEDVANCE / 65700 VAPOR3A/S050UNHD8SC7/48/GR  
2) CURRENT - APG-4-V40W-V35K-PF-MV3
11. Type: NLED-AL300-347V: CURRENT EFP1320WLSCS:
12. Type: NLED-AL120, NLED AL120-347V: CURRENT / EFP1200WLSCS
13. Type: NLED-FL100: CURRENT: EFP1120WLSCS

- 14. Type: NLED-RND12: Eurofase 47520-011
- 15. Type: NLED-22PNL20-347V: Columbia CBT22-B-LSCS-EDD-34
- 16. Type: NLED-24PNL50-347V: Columbia CBT24-B-LSCS-EDD-34
- 17. Type: NLED-HB150, NLED-HB150-347V: Columbia CRN2-2-LSCS-EDMV
- 18. Type: NLED-SCO80: Fase1 Lighting MODEL F50 36121-014
- 19. Type: NLED-WP120: CURRENT/GE EXO WGH3-120-LSCS-UNVC

**4. BIDDER QUESTIONS AND CITY RESPONSES**

**Q5: Could you please clarify that what is the difference between the 14 and 18 codes under T8 LED LIGHTING RETROFIT TYPES (Section 26500 on Page#32). It looks to possibly be a TYPO where the 14 is 4ft and 18 is 8ft. But by the current description it is the same? Please advise.**

R5: The '18 Codes' describe an 8' long fixture with 4' long lamps in tandem or 'end-to-end' arrangement. There are no 8' long lamps on the project.

**Q6: Can I get a two week extension on this bid? My suppliers are having a difficult time pulling the lighting pricing together.**

R6: See Revision 1 in this Addendum.

**END OF ADDENDUM**

## LUMP SUM BREAKDOWN OF BASE BID PRICE

Revised: March 11, 2025

**Contract Number: C13-16-25**

<b>LOCATION:</b> Various City Yards and Municipal Service Centres		
<b>DESCRIPTION:</b> General Contractor for the Supply and Installation of new Energy Efficient LED Lighting at various City Yards and Municipal Service Centres		
After opening of the Bids, the two apparent low bidders are required to submit to the City, within two Business Days of the closing date of the Request for Tenders, the breakdown of their Base Bid Price. The breakdown shall be given according to the following Lump Sum Breakdown. The City may refuse to accept any breakdown, which contains prices considered to be unbalanced and request the bidder to adjust the breakdown to correct such unbalancing, and by submitting its Bid, the bidder agrees to do so upon such request by the City.		
ITEM NO.	DESCRIPTION	LUMP SUM PRICES
1.1	Dundas Yard	\$
1.2	Forestry Yard	\$
1.3	Glanbrook Municipal Service Centre	\$
1.4	Mountain Transit Centre	\$
1.5	Rymal Road Yard	\$
1.6	Stoney Creek Yard	\$
1.7	Winona Community Centre	\$
<b>BASE BID PRICE</b>		\$