



110 Drewry Avenue
Toronto (Ontario) M2M 1C8
Tel.: 416-397-6564 or 1-800-274-3764

Addendum #1

RFQ 2025-21

General Contractor Services for Exterior Doors Replacement at ÉSC Sainte-Trinité, Oakville

Closing Date: March 14, 2025 at 2:00 PM local time

This Addendum forms part of the Contract Documents and amends the original Bids Documents and Specifications as noted below.

Ensure all parties submitting bids are aware of all items included in this Addendum.

Acknowledge receipt of this Addendum by inserting its number on the Bid Form. Failure to do so may subject bidder to disqualification.

PART I – QUESTION AND ANSWER

Question 1: Please clarify the details for doors 11 and 12. The door schedule indicates that both doors are new, but the finish is listed as 'repaint'. Could you please confirm whether these doors are to be newly supplied or if we are repainting existing ones?

Answer 1: According to the Door Schedule:

- Door # 11 is an overhead door, is listed as new, prefinished, and the door frame is to be repainted.
- Door #12 is listed as a new door, listed as repaint when it should be painted, the frame is listed as new to be painted.
- Door # 13 is listed as existing, listed as paint when it should be repainted, and the frame is listed as existing to be repainted.

END OF ADDENDUM 1