

April 15, 2025

Sent via Email (1 page)

**ADDENDUM NO. 4
RFQ WORK ASSIGNMENT No. 25-PFR-CAP-GC-005.
IN ACCORDANCE WITH
REQUEST FOR SUPPLIER QUALIFICATION (RFSQ) NO. DOC4509693485
FOR: Wallace C. Swanek Park - Pathway Lighting**

CLOSING DATE: April 17, 2025 AT 2:00 P.M. (LOCAL TORONTO TIME)

Please refer to the above Request for Quotation (RFQ) document in your possession and be advised of the following:

I. Questions and Answers

- Q.1: Can we back fill around the poles with Limestone screening in lieu of concrete?
- A.1: No, the poles shall be backfilled with concrete as indicated on the Contract Drawings.

Please attach this addendum to your call document and be governed accordingly.

Suppliers must acknowledge receipt of all addenda in their submission in the space provided on the Bid Form as per Clause 1.10 in Part 2 – Form of Agreements. All other aspects of the call remain the same.

END OF ADDENDUM

Cristian Lukaszuk
Senior Project Manager
Capital Projects Design & Delivery
Parks, Forestry and Recreation