



Parks and Recreation Division
Metro Hall, 24th Floor, 55 John Street
M5V 3C6

Mario Pecchia, Manager (Acting)
Capital Project Design & Delivery

April 8, 2025

Sent via Email (1 page)

**ADDENDUM NO. 3
RFQ WORK ASSIGNMENT No. 25-PFR-CAP-GC-005.
IN ACCORDANCE WITH
REQUEST FOR SUPPLIER QUALIFICATION (RFSQ) NO. DOC4509693485
FOR: Wallace C. Swanek Park - Pathway Lighting**

CLOSING DATE: April 17, 2025 AT 2:00 P.M. (LOCAL TORONTO TIME)

Please refer to the above Request for Quotation (RFQ) document in your possession and be advised of the following:

I. Added to the scope of work

DESCRIPTION:

1. Refer to revised drawing 25-PFR-CAP-GC-005_Wallace C. Swanek Park - Pathway Lighting 6905-E2 Revised
 - Existing wood pole and overhead wiring to be removed and disposed of including overhead wiring. Coordinate with Toronto Hydro.

II. Questions and Answers

Q.1: Our Electrician is asking whether the entire project can be done with directional bore instead of trenching?

A.1: Yes, directional bore can be done for the entire project, in either cases trenching or directional boring, the site will have to be restored to the same or better than the original condition.

Please attach this addendum to your call document and be governed accordingly.

Suppliers must acknowledge receipt of all addenda in their submission in the space provided on the Bid Form as per Clause 1.10 in Part 2 – Form of Agreements. All other aspects of the call remain the same.

END OF ADDENDUM

Cristian Lukaszuk
Senior Project Manager
Capital Projects Design & Delivery
Parks, Forestry and Recreation

