

Addendum 2

Issued May 27, 2025

The following information changes the competitive process documents issued on May 7, 2025.

CLOSING DATE CHANGE

Change of closing date to Wednesday, June 4, 2025, on or before 2:00:00 PM local time.

GENERAL INFORMATION

Item 1: Refer to RFT Document, Instructions to Bidders
REMOVE and REPLACE Section 1.5 Project Schedule with below:

1.5 PROJECT SCHEDULE

- .1 The Successful Bidder will adhere to section GC 3.4 in regard to milestone dates set below.
- .2 The following are Project milestone dates:
 - a. Tender Issued Wednesday, May 7, 2025
 - b. Site Walkthrough at 12:30 PM Wednesday, May 14, 2025
 - c. Closing for Questions Tuesday, May 20, 2025
 - d. Tender Closing at 2:00:00 PM Wednesday, June 4, 2025**
 - e. Anticipated Construction Commencement Monday, June 30, 2025
 - f. Anticipated Delivery Period for Dust Collectors Week of July 14, 2025
 - g. Substantial Performance of the Work Friday, August 22, 2025
 - h. Ready-for-Takeover Tuesday, September 2, 2025
- .3 Any Work remaining after the Substantial Performance of the Work date will need to be completed after-hours and weekends and cannot be disruptive to the school and operations of the school in any way.

Item 2: See attached Addendum #2 by Barry Bryan Associates, issued May 27, 2025, (1 Page).

End of Addendum 2



**BARRY BRYAN
ASSOCIATES**

Architects
Engineers
Project Managers

Addendum No. 2

Page 1 of 1

Project No.: 24141.1 and 24141.2
Date: May 27, 2025
Tender No.: 2025-138-P01970-P01972 - RFT
Project: **ORCHARD PARK SECONDARY SCHOOL AND
WATERDOWN DISTRICT HIGH SCHOOL DUST COLLECTOR
REPLACEMENTS
Hamilton-Wentworth District School Board**

The following information supplements and/or supersedes the bid documents issued on May 7, 2025

This Addendum forms part of the contract documents and is to be read, interpreted, and coordinated with all other parts. The cost of all contained herein is to be included in the contract sum. The following revisions supersede the information contained in the original drawings and specifications issued for the above-named project to the extent referenced and shall become part thereof. Acknowledge receipt of this Addendum by inserting its number and date on the Tender Form. Failure to do so may subject bidder to disqualification.

QUESTIONS AND ANSWERS

2.1 Question: Please find the question from our subtrade.
Reference to addendum No.1, 1.5 answer. we would like to inform you that HSS 5x5x3/4 is not available in the market. This specific wall thickness is not produced for the HSS 5x5 size. Please advise

Answer: For 24141.1 Orchard Park School, the column size is HSS 4x4x1/4.

For 24141.2 Waterdown District School, the column size is HSS 5x5x1/4.

End of Addendum No. 2

Barry Bryan Associates
Architects, Engineers, Project Managers

Crystal Gardner, OAA



250 Water Street,
Suite 201
Whitby, Ontario
Canada
L1N 0G5

Tele: **905-666-5252**
Fax: **905-666-5256**
Email: bba@bba-archeng.com
www.bba-archeng.com