



Project No. & Name:	230467-274385 - RFT - Absorption Chiller Decommissioning	Addendum No.: 01
	No. of Pages: 2+6+2	
	Date: May 1, 2025	
	Doc. No.: P2704-143606558-73 (1.0)	

The following change(s) in the Tender Documents are effective immediately.
This Addendum forms part of the Contract Documents.

ITEM	DESCRIPTION	ACTION
------	-------------	--------

Please be advised of the following changes:

The following changes in the Tender Documents are effective immediately.

- | | | |
|-----|---|--------|
| 1.1 | Revised Tender Documents have been issued and form part of this Addendum. | Issued |
| 1.2 | The closing date for this Tender has been extended by one week. The new closing date is May 15, 2025 . | |
| 1.3 | All submitted questions have been addressed. | |

- Regarding the weight of the area with the underground tanks, it would be best to
- | | |
|-----|--|
| 1.4 | avoid putting any crane there. If the awarded contractor needs to know what the maximum weight is, the consultant can coordinate with a structural engineer to have the area reviewed. |
|-----|--|

Project Number & Name

Addendum No.:

1.5 The scope of this project involves the demolition of the absorption chiller, it's associated cooling towers (2), condensing water pumps (3), and all associated piping and accessories as outlined in the drawings and specifications. Contractor to demolish all piping connected to the absorption chiller and cooling towers, including all valves and accessories outlined in the drawings and specifications. Contractor to isolate and cap existing chilled water and heating water lines as outlined in the drawings and specifications. Contractor to patch any/all roof penetrations that are associated with the work being completed.

Note: All other terms and conditions of the original Tender Documents remain unchanged.

All other terms and conditions remain unchanged.

Distribution: All Bidders

File