

Date: May 23, 2025

(2 pages)

### **Addendum No. 3**

#### **Bid Call No. T2025-224**

#### **Flooring Replacement and Renovation at McMurphy Recreation Centre**

---

This Addendum forms part of the Bid Document.

1. **Pertaining to Bid Closing**

*The Closing Date has been extended from NOT LATER THAN 2:00:00 o'clock p.m. LOCAL TIME on Monday May 26, 2025, to:*

*NOT LATER THAN 2:00:00 o'clock p.m. LOCAL TIME on Wednesday May 28, 2025.*

*Bidders are encouraged to use their best judgement with all the materials provided to submit their bids. There will be no further date extensions or addenda for this tender.*

2. **PERTAINING TO APPENDIX A - IFP&T MCMURPHY RC DWGS – A2.2**

**ADD THE FOLLOWING NOTE:**

***CONTRACTOR TO PROVIDE AND INSTALL JOHNSONITE STAIR NOSING 'RCN-XX-A' ON ALL EXPOSED STAIR EDGES THROUGHOUT. INSTALLATION SHALL BE IN STRICT ACCORDANCE WITH THE MANUFACTURER'S WRITTEN SPECIFICATIONS AND INSTALLATION INSTRUCTIONS. COLOUR TO BE SELECTED BY THE CONSULTANT FROM THE FULL RANGE OF STANDARD COLOURS.***

3. **PERTAINING TO APPENDIX A - IFP&T MCMURPHY RC DWGS – A1.3 & M101**

**DRAWINGS RE-ISSUED:**

***Drawings A1.3 and M101 were revised – refer to new drawings dated 22 May 2025. These replace the previously issued versions (2 pages attached to this addendum)***

4. **QUESTION AND ANSWER**

**Question 1:**

Drawings show a number of new floor drains. Each floor drain requires a primer and vent. There's no indication where to connect these to the existing system.

No specifications on primers. This will require substantially more concrete re/re and excavation than the drawings show.

**Answer 1:**

***Drawing M101(Appendix A), updated to indicate length of fixture drain for floor drains. Floor drains are 100-mm and will have fixture drain exceeding 450-mm to main drain. Floor drains are not required to be protected by an individual vent. Drawing M101 updated to indicate trap seal primer location feed location and floor drains served by each trap seal primer.***

All other terms and conditions remain unchanged.

If you have any questions, please do not hesitate to contact the undersigned.

Bidders are required to acknowledge all Addenda.

Name: Soni Edem  
Title: Senior Buyer  
Ph: (905) 874-2180  
Email: soni.edem@brampton.ca