

May 14, 2025

Posted via Ariba  
(1 page)

## **ADDENDUM No. 12**

### **REQUEST FOR TENDER No. Doc4978764580**

**SUBMISSION DEADLINE: 12:00 NOON (LOCAL TIME), MAY 20, 2025 (REVISED)**

#### **For: Request for Tenders for Interior and Exterior Upgrades at Castleview Wychwood Towers Long-Term Care Home**

Please refer to the above Request of Tender (RFT) document in your possession and be advised of the following:

#### **I. QUESTIONS & ANSWERS:**

**Q1: In response to Addendum #10 – Q&A #6 – notes that there are no restorative works or duct banks required. Is there another contractor installing the new underground electrical services identified on drawing E-100 or its existing? Based on routing, we are running through asphalt drive ways, concrete curbs and sidewalks, as well as grassed areas.**

**Unless instructed otherwise, we will omit/exclude any restorative works as instructed via Addendum #10 – Q&A #6.**

**A1: In Addendum #10 – Q&A #6, it was clarified no NEW Duct Back, Paving and Sod are proposed and required. Note: The Conduits for the new parking gates are not existing, and must be provided by the electrical contractor. And any remedial site repairs to facilitate the electrical works should be part of the base contract – the General Contractor shall be responsible for making good any damages to the site to match existing due to demolition and construction.**

Should you have any questions regarding this addendum send via the event message board or contact Wanda Luo at [Wanda.Luo@toronto.ca](mailto:Wanda.Luo@toronto.ca).

Suppliers must acknowledge receipt of all addenda in the space provided on Part 4 – Submission Form as per Part 1 Tender Process, Section 1 RFT Specific Process and Submission Instructions, Item 1.7 – Addenda, of the Tender document. All other aspects of the Tender remain the same.

Yours truly,

Aimee Yang, Supervisor  
Community & Social Services and City Manager's Office  
Purchasing Client Services  
Purchasing and Materials Management