


FRONT VIEW OF PDP-0400E



FLOOR VIEW OF PDP-0400E

FHA-ELS-PDP-0400E ELEVATION LAYOUT

N.T.S.

NOTES:

- ALL CONDUCTORS, EQUIPMENT, AND FIELD CONNECTIONS SHALL BE TAGGED AND IDENTIFIED AS PER CITY REQUIREMENTS.
- THIS DRAWING IS INTENDED TO PROVIDE THE GENERAL SCHEMATIC, SIZE, AND LAYOUT OF PANELS. ACTUAL SIZE AND LAYOUT MAY VARY PER EQUIPMENT. CONTRACTOR SHALL SUBMIT ALL LAYOUTS FOR REVIEW.
- PROVIDE CONCRETE HOUSEKEEPING PAD. REFER TO STRUCTURAL DRAWINGS FOR DETAILS.
- DIMENSIONS ARE SHOWN IN MILLIMETERS UNLESS OTHERWISE NOTED.
- DIMENSIONS SHOWN ARE APPROXIMATE AND NOT TO BE EXCEEDED.
- REFER TO DWG E202 FOR LOCATION DETAILS.
- NEW ATS UNIT TO BE SEPARATE FROM NEW STANDBY PDP.

EXISTING
NEW

Drawing: J:\M16-0273 TOR_HARRISWTP-STANDBYGENERATOR\500_CAD\401-CAD\1-SS OR BU\SHEET\6 ELEC\2F-2017-08-44-E104.DWG
Layout: Tab: E104
Date: 06/10/2025 Time: 11:25:30 PM

								TORONTO WATER		ENGINEERING AND CONSTRUCTION SERVICES		R.C. HARRIS WATER TREATMENT PLANT INSTALLATION OF A STANDBY GENERATOR FOR CRITICAL LOADS FHA-ELS-PDP-0400E ELEVATION LAYOUT			
		COPYRIGHT: This drawing has been prepared solely for the intended use, thus any reproduction or distribution for any purpose other than authorized by ARCADIS is forbidden. Written dimensions shall have precedence over scaled dimensions. Contractors shall verify and be responsible for all dimensions and conditions on the job, and ARCADIS shall be informed of any variations from the dimensions and conditions shown on the drawing. Shop drawings shall be submitted to B1 Group for general conformance before proceeding with fabrication.		ARCADIS Professional Services (Canada) Inc.				WILLIAM FERNANDES, P.ENG DIRECTOR WATER TREATMENT AND SUPPLY		SIMON HOPTON, P. ENG. DIRECTOR DESIGN & CONSTRUCTION MAJOR INFRASTRUCTURE		ELECTRICAL			
DESIGN:		SC		DRAFTING:		SC		CHECK:		TS		CONTRACT No. 25ECS-MI-03HA			
SCALE:				N.T.S.				DRAWING NUMBER:		2F-2017-08-44		E104			
DATE:				2024-09-30											
NO.		DATE		REVISIONS		INITIAL		SIGNED							
B		2025-06-10		ISSUED FOR ADDENDUM #1		T.S.									
A		2025-03-18		ISSUED FOR TENDER		T.S.									