



NOTES:

- MCC CUBICLES TO BE SPARE.
- WHEN RELOCATING OR REMOVING EQUIPMENT, SHOULD ANY CIRCUITS BE ABANDONED, THE CONDUCTORS TO THESE CIRCUITS MUST BE REMOVED OR PROPERLY TERMINATED AS DETAILED IN RULE 2-130, RULE 12-114, RULE 12-3000 AND BULLETIN 12-25-7.
- REFEED FROM FHA-ELS-PDP-0401A. SEE DRAWING E105.
- REFEED FROM FHA-ELS-PDP-0401B. SEE DRAWING E105.
- UPS FEEDER CABLES TO BE RE-USED, UPS TO BE REPLACED.

FHA-ELS-PDP-0500A/B SINGLE LINE DIAGRAM - MODIFICATIONS

N.T.S.

—	EXISTING
—	NEW
▨	REMOVAL, TO BE REPLACED WITH NEW CABLES & INSTALLED COMPLETE

				TORONTO WATER ENGINEERING AND CONSTRUCTION SERVICES		R.C. HARRIS WATER TREATMENT PLANT INSTALLATION OF A STANDBY GENERATOR FOR CRITICAL LOADS FHA-ELS-PDP-0500A/B SINGLE LINE DIAGRAM - MODIFICATIONS			
				WILLIAM FERNANDES, P. ENG. DIRECTOR WATER TREATMENT AND SUPPLY		SIMON HOPTON, P. ENG. DIRECTOR DESIGN & CONSTRUCTION MAJOR INFRASTRUCTURE		ELECTRICAL	
COPYRIGHT: This drawing has been prepared solely for the intended use. Thus, any reproduction or distribution for any purpose other than authorized by ARCADIS is forbidden. Written dimensions shall have precedence over scaled dimensions. Contractors shall verify and be responsible for all dimensions and conditions on the job, and ARCADIS shall be informed of any variations from the dimensions and conditions shown on the drawing. Shop drawings shall be submitted to the Client for general conformance before proceeding with fabrication.		B 2025-06-10 ISSUED FOR ADDENDUM #1 T.S.		DESIGN: SC DRAFTING: SC CHECK: TS CONTRACT No. 25ECS-MI-03HA		SCALE: N.T.S. DRAWING NUMBER: 2F-2017-08-49		E111	
ARCADIS Professional Services (Canada) Inc.		A 2025-03-18 ISSUED FOR TENDER T.S.		DATE: 2024-09-30					
NO.	DATE	REVISIONS		INITIAL	SIGNED				