

The following information changes the competitive process documents issued on March 24, 2026.

QUESTIONS AND RESPONSES

- Q1 Electrical Question: All the drawings say to wire back to the nearest power panel. None of the drawings show where the panel is located in relation to the project areas. It also doesn't show any existing power panel schedules. I have no way of knowing if there is available space at the nearest panels or the distance between the panel and work area.
- R1 Not required - connect to existing closest circuits.**
- Q2 Please provide base building fire alarm vendor contact information, Do we need to carry an allowance for this vendor? If not I'll need to know the make and model of their existing fire alarm system.
- R2 See note 13 on E0.01 Fire Alarm Specifications and Notes.**
- Q3 Please confirm the location of the nearest electrical panel for each area of work.
- R3 Not required- connect to existing closest circuits.**
- Q4 Please confirm if the pre-cast covebase is epoxy terrazzo. if its cement terrazzo it has to be poured on site.
- R4 Yes, it is seam-less cement cove terrazzo base as specified and if you wish this can be poured and finished on site.**

End of Addendum #2