



110 Drewry Avenue
Toronto (Ontario) M2M 1C8
Tel. : 416-397-6564 or 1-800-274-3764

Addendum # 7

2026-16

GC Services for New-Build Elementary School in Cobourg

Closing Date:

April 28, 2026, at 2:00:00 pm local time

This Addendum forms part of the Contract Documents and amends the original Bids Documents and Specifications as noted below.

Ensure all parties submitting bids are aware of all items included in this Addendum.

Acknowledge receipt of this Addendum by inserting its number on the Bid Form. Failure to do so may subject bidder to disqualification.

Question 1:

Addendum 3: DWG E15: Note 1 indicates to provide a new cable tray. Cable tray shall be 12 inches wide x 6 inches high, black finish, stainless steel 316L. Manufacturer indicated that they cannot provide a stainless steel with black finish on top. It is either one or the other only. Can we please provide a black painted finish only with standard steel? Stainless steel cable tray is very expensive and very rare in a school.

Answer 1:

Steel power coated black is acceptable.

END OF ADDENDUM 1