



Addendum # 1

Bid Opportunity: 26-7861-RFT - Preston High School Family Studies and Science Classroom Renovation

Closing Date Revised to: Tuesday, May 5, 2026 2:00 PM

The following issued by the Board shall form part of the Bid / Proposal Solicitation document. The revisions and additions noted herein along with any attachments shall be read in conjunction with all other related documents. This Addendum shall, take precedence over the previously issued documents where differences occur. Receipt of this addendum must be acknowledged in the Bidding System, bids&tenders.

If you have already submitted a Bid / Proposal, it will be automatically withdrawn as a result of this addendum. You must resubmit the Bid / Proposal acknowledging all addenda and revising your Bid / Proposal to comply with all addenda.

Question 1:

Please advise which circuit is feeding power to lighting room 233

Answer 1:

Unknown, panel to be confirmed on site during construction. Circuit can remain to feed new fixtures.

Question 2:

Please provide location of existing power pack to feed new PK lighting control room 233

Answer 2:

All lighting and controls in 233 are to be replaced with new per drawing E3.1, lighting is to be fed using existing circuit.

**I. Revision to Section 00 21 13 Instructions to Bidders, item no. 1.7
Anticipated Project Schedule.**

DESCRIPTION	DATE
Deadline for Questions	Monday, April 29, 2026
Closing Date and Time	Tuesday, May 5, 2026 2:00:00 pm local time

END OF ADDENDUM