



**Addendum 3**

DATE: April 20, 2026

SUBJECT: Request for Proposals (RFP) for Interior Renovation of Room SY270 in the Science Research Building,  
(UTSC 2026-09).

This Addendum consists of two page(s).

---

**1. Questions and Answers**

**Question 1:**

Can you please provide us the work schedule – regular or after hrs.

**Answer 1:**

Work Schedule will include typical construction days and hours. Monday through Friday, 6:00 a.m. through 5:00 p.m.

**Question 2:**

Please confirm if wall base MO1 and painting PT01 are required only behind cabinet with sliding glass doors.

**Answer 2:**

Correct, wall base M01 and painting PT01 are only required behind the cabinet with sliding glass doors.

**Question 3:**

Please clarify for the paint DTM what exposed metal elements are.

**Answer 3:**

No DTM paint will be required in this project, please omit any reference to DTM on Drawings.

**Question 4:**

Can we have some clarification on the hoarding wall?  
The wall doesn't appear to enclose the work area.

**Answer 4:**

Hoarding wall information on architectural plans to be read in conjunction with Drawing Note 15 on architectural sheet A1.1. Soft screening (i.e. poly tarping to be used) where wall is interrupted by casework.

**Question 5:**

I have a quick question regarding the AV scope. Could you please confirm if there is any AV scope of work for this project? I noticed AV is mentioned in the specifications, but I'm not seeing it reflected on the drawings.

**Answer 5:**

There is no AV scope in this project.

**END OF ADDENDUM 3**